


Scoping Analysis of Source Term and Functional Containment Attenuation Factors

February 2012



DISCLAIMER

This information was prepared as an account of work sponsored by an agency of the U.S. Government. Neither the U.S. Government nor any agency thereof, nor any of their employees, makes any warranty, expressed or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness, of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. References herein to any specific commercial product, process, or service by trade name, trade mark, manufacturer, or otherwise, does not necessarily constitute or imply its endorsement, recommendation, or favoring by the U.S. Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the U.S. Government or any agency thereof.

Scoping Analysis of Source Term and Functional Containment Attenuation Factors

February 2012

**Idaho National Laboratory
Next Generation Nuclear Plant Project
Idaho Falls, Idaho 83415**

<http://www.inl.gov>


**Prepared for the
U.S. Department of Energy
Office of Nuclear Energy
Under DOE Idaho Operations Office
Contract DE-AC07-05ID14517**

Scoping Analysis of Source Term and Functional Containment Attenuation Factors


INL/EXT-11-24034
Revision 1

February 2012


Approved by:




Peter P. Lowry
NGNP Regulatory Affairs




Date




Jim C. Kinsey
NGNP Regulatory Affairs Director



Date



David A. Petti
VHTR R&D Director



Date

EXECUTIVE SUMMARY

This scoping analysis estimates postulated radiological releases and associated offsite doses from representative high temperature gas-cooled reactor (HTGR) module designs. The objectives of this analysis were to: (1) provide insight for next generation nuclear plant (NGNP) Technology Development Program activities, (2) provide a preliminary assessment of the performance of the HTGR relative to NGNP Project objectives regarding public health and safety; and (3) support ongoing NGNP Project discussions regarding possible HTGR deployment in advance of completion of detailed design and accident analyses.

It is important to note that the results of these analyses are not intended for, nor suitable for, submittal to regulatory authorities as part of the licensing basis of the HTGR. The analyses are intended solely to provide insights and internal guidance for the NGNP Project.

In the absence of complete technical information to support detailed mechanistic source term assessments, the NGNP Project utilized a simplified model to perform parametric scoping analyses of the release and retention parameters that define the source terms for a modular HTGR. To estimate the source terms, the model incorporates expert opinion regarding the performance of each of the radionuclide barriers that comprise the HTGR functional containment: (1) the fuel particle kernel, (2) the fuel particle coatings, (3) the fuel matrix and graphite, (4) the helium pressure boundary; and (5) the reactor building. These assessments reflect improved fuel performance characteristics being demonstrated by the Advanced Gas Reactor (AGR) Fuel Development and Qualification Program.

Accident scenarios were chosen for analysis based on the results of previous modular HTGR safety analyses. Analyses were limited to the scenarios that have been shown to present the highest risk to public health and safety. The results of the analyses were compared to the following project objectives regarding the protection of public health and safety:

- Protection of the health and safety of the public and the environment with the objective that under no postulated accident condition would public evacuation or sheltering be required. To achieve this objective, the NGNP must meet:
 - The Nuclear Regulatory Commission (NRC) siting criteria for both the plant exclusion area boundary (EAB) and low population zone (LPZ) (10CFR52.47/50.34) at a nominal distance of 400 m from the reactor centerline.
 - The early phase Environmental Protection Agency (EPA) plume exposure Protective Action Guides (PAGs) at the plant EAB.
- Protection of the food and water supplies from being unacceptably impacted by radionuclide contamination. This objective is satisfied by either meeting the intermediate phase EPA ingestion pathway PAGs at the plant EAB, or by assuring through the specific siting analyses and related administrative controls that no food or water supplies exist in the area immediately surrounding the EAB.
- The analyses were completed for a single reactor module. Additional analyses will be needed to confirm that project objectives are satisfied for multi-module HTGR facilities when responding to postulated events that may result in fission product release from more than one module.

In assessing the results against the NRC siting criteria, the model utilized conservative assumptions regarding the performance of the radionuclide release barriers and did not credit any fission product release attenuation by the reactor building. With these assumptions, the model shows that the siting criteria are met at the EAB with large margins for all single-module reactor configurations and accident scenarios assessed, as discussed in Section 5.1.

In assessing the results against the EPA plume exposure PAGs, the model utilized realistic (mean) assumptions on the performance of all of the radionuclide barriers, including the reactor building. The model results show that the PAGs are met at the EAB with large margins for all single-module reactor configurations and accident scenarios assessed, as discussed in Section 0.

In assessing the potential for contamination of food and water supplies, the model utilized realistic (mean) assumptions on the performance of all of the radionuclide barriers, including the reactor building, and modeling of the ingestion of foods consistent with regulatory guidance. The model results indicate that the ingestion limits for an infant receptor (the most limiting case) are generally exceeded at the 400 m EAB but are met at approximately 900 m for all single-module reactor configurations and accident scenarios assessed.

The results presented in this report indicate that I-131 is the dominant contributor to thyroid doses as has been observed in past modular HTGR safety analyses. However, the dominant contributors to total effective doses (includes all health effects such as thyroid and whole body weighted by their relative health contribution) for the offsite receptors for the accident scenarios assessed are Ag-111, Ag-110m, and Ce-144. This result is different from results of previous modular HTGR accident analyses in which Cs-137 was the dominant contributor for the offsite total effective dose. Because of the better fuel performance assumed in this study based on recent encouraging results of fuel R&D, defect levels and assumed incremental failure rates under normal and accident conditions are lower than used in past modular HTGR accident analyses. This better fuel performance translates into much lower release of Cs-137. Thus, these silver and cerium isotopes that were minor contributors in the past are more important now. This result may also be due in part to the simplified methodology used in this scoping study to establish the source term. Enhanced attention to the behavior of these isotopes will be given in the NGNP Technology Development Program going forward.

In summary, the results of this scoping analysis indicate that the NGNP Project objectives related to offsite dose for the inhalation pathway are expected to be met for a single reactor module with the functional containment performance levels that are currently envisioned and being validated, in part through the NGNP Technology Development Program. Additional technical assessment and design development work may be required to fully achieve project objectives related to the ingestion pathway PAG.

CONTENTS

EXECUTIVE SUMMARY	v
ACRONYMS.....	xi
1. BACKGROUND.....	1
2. SCOPE AND BRIEF DESCRIPTION.....	3
3. SOURCE TERM DEVELOPMENT.....	4
3.1 HTGR Configurations, Fission Product Classes and Associated Inventories.....	4
3.2 Tristructural-isotropic (TRISO) Fuel Fabrication Quality	6
3.3 Fission Product Release from Fuel/Graphite during Normal Operation.....	6
3.4 Attenuation Factors during Normal Operations.....	7
3.5 Accidents Selected for Evaluation	9
3.6 Releases and Attenuation Factors Under Accident Conditions	10
3.7 Source Terms	13
4. DOSE CONVERSION FACTORS.....	14
4.1 Meteorology	14
4.2 Dose Conversion	14
5. COMPARISON OF RESULTS TO PROJECT OBJECTIVES.....	15
5.1 Comparison with NRC Siting Criteria (Cases A and B).....	15
5.2 Comparison with PAG Emergency Planning Criteria (Cases C–F).....	16
5.3 Overall Conclusions.....	18
6. REFERENCE	19
Appendix A Expert Review Panel Meeting and Results	21
Appendix B Dose Conversion Factors.....	47
Appendix C Doses	57
Appendix D Key Limitations and Assumptions Used in the Scoping Analyses	89

FIGURES

Figure 1. Case E, infant, EDE (rem), single reactor module.	17
Figure 2. Case F, infant, thyroid (rem) single reactor module.....	18

TABLES

Table 1. Fission product classes.....	5
Table 2. Initial core fission product inventories, in curies.....	5
Table 3. Fuel defect fractions for all reactor configurations.....	6
Table 4. Prismatic 700°C ROT incremental fuel failure fractions under normal operations.....	7
Table 5. Prismatic 700°C ROT barrier attenuation factors during normal operations.....	8
Table 6. Mean values for I-131, Cs-137, and Sr-90 inventories (curies) released to the helium pressure boundary and retained in the fuel matrix and graphite.....	9
Table 7. Mechanistic source term events for model simulations.....	10
Table 8. Prismatic 700°C ROT short-term accident attenuation factors for a break in He pressure boundary.....	11
Table 9. Prismatic 700°C ROT long-term accident release and attenuation factors for a break in helium pressure boundary.....	12
Table 10. 600 MW(t) Prismatic 700°C ROT, source terms for a break in He pressure boundary.....	13
Table 11. Dose limits and associated protocols for calculating exposures.....	14
Table 12. Upper bound comparison with NRC siting criteria (DBA) – (TEDE rem).	15
Table 13. Realistic comparison with plume exposure PAG at EAB.....	16
Table A-1. 600 MW(t) prismatic 700°C ROT—normal operations—release fractions and attenuation factors.....	34
Table A-2. 600 MW(t) prismatic 700°C ROT— break in HPB—short term attenuation factors.....	35
Table A-3. 600 MW(t) prismatic 700°C ROT— break in HPB—long term release fractions and attenuation factors.....	36
Table A-4. 600 MW(t) prismatic 700°C ROT—water ingress—short term attenuation factors.	37
Table A-5. 600 MW(t) prismatic 700°C ROT—water ingress—long term release fractions and attenuation factors.....	38
Table A-6. 600 MW(t) prismatic 900°C ROT—normal operations—release fractions and attenuation factors.....	39
Table A-7. 600 MW(t) prismatic 900°C ROT— break in HPB—short term attenuation factors.....	40
Table A-8. 600 MW(t) prismatic 900°C ROT— break in HPB—long term release fractions and attenuation factors.....	41
Table A-9. 250 MW(t) pebble bed 700°C ROT—normal operations—release fractions and attenuation factors.....	42
Table A-10. 250 MW(t) pebble bed 700°C ROT—break in HPB—short term attenuation factors.	43
Table A-11. 250 MW(t) pebble bed 700°C ROT— break in HPB—long term release fractions and attenuation factors.....	44
Table A-12. 250 MW(t) pebble bed 700°C ROT—water ingress—short term attenuation factors.....	45
Table A-13. 250 MW(t) pebble bed 700°C ROT—water ingress—long term release fractions and attenuation factors.....	46

Table B-1. Dose conversion factors—Cases A/B 400 meters (rem/curie).	49
Table B-2. Dose conversion factors—Case C (rem/curie).....	50
Table B-3. Dose conversion factors—Case D (rem/curie).	50
Table B-4. Dose conversion factors—Case E, infant, whole body (rem/curie).....	51
Table B-5. Dose conversion factors—Case E, adult, whole body (rem/curie).....	52
Table B-6. Dose conversion factors—Case F, infant, thyroid (rem/curie).	53
Table B-7. Dose conversion factors—Case F, adult, thyroid (rem/curie).....	54
Table B-8. Deposition factors—Case G (curie/m ²).	55
Table C-1. 600 MW(t) prismatic 700°C ROT— break in HPB—source term (curies).....	59
Table C-2. 600 MW(t) prismatic 700°C ROT—break in HPB—Cases A and B—400 m from release (rem).	60
Table C-3. 600 MW(t) prismatic 700°C ROT—break in HPB—Cases C and D—400 m from release (rem).	61
Table C-4. 600 MW(t) prismatic 700°C ROT—break in HPB—Cases E and F, infant and adult— 400 m from release (rem).	62
Table C-5. 600 MW(t) prismatic 700°C ROT—break in HPB—Cases E and F, infant and adult— 800 m from release (rem).	63
Table C-6. 600 MW(t) prismatic 700°C ROT—break in HPB—Cases E and F, infant and adult— 1600 m from release (rem).	64
Table C-7. 600 MW(t) prismatic 700°C ROT—water ingress—source term (curies).	65
Table C-8. 600 MW(t) prismatic 700°C ROT—water ingress—Cases A and B—400 m from release (rem).	66
Table C-9. 600 MW(t) prismatic 700°C ROT—water ingress—Cases C and D—400 m from release (rem).	67
Table C-10. 600 MW(t) prismatic 700°C ROT—water ingress—Cases E and F, infant and adult—400 m from release (rem).	68
Table C-11. 600 MW(t) prismatic 700°C ROT—water ingress—Cases E and F, infant and adult—800 m from release (rem).	69
Table C-12. 600 MW(t) prismatic 700°C ROT—water ingress—Cases E and F, infant and adult—1600 m from release (rem).	70
Table C-13. 600 MW(t) prismatic 900°C ROT— break in HPB—source term (curies).....	71
Table C-14. 600 MW(t) prismatic 900°C ROT—break in HPB—Cases A and B—400 m from release (rem).	72
Table C-15. 600 MW(t) prismatic 900°C ROT—break in HPB—Cases C and D—400 m from release (rem).	73
Table C-16. 600 MW(t) prismatic 900°C ROT—break in HPB—Cases E and F, infant and adult—400 m from release (rem).	74
Table C-17. 600 MW(t) prismatic 900°C ROT—break in HPB—Cases E and F, infant and adult—800 m from release (rem).	75

Table C-18. 600 MW(t) prismatic 900°C ROT—break in HPB—Cases E and F, infant and adult—1600 m from release (rem).	76
Table C-19. 250 MW(t) pebble bed 700°C ROT—break in HPB—source term (curies).	77
Table C-20. 250 MW(t) pebble bed 700°C ROT—break in HPB—Cases A and B—400 m from release (rem).	78
Table C-21. 250 MW(t) pebble bed 700°C ROT—break in HPB—Cases C and D—400 m from release (rem).	79
Table C-22. 250 MW(t) pebble bed 700°C ROT—break in HPB—Cases E and F, infant and adult—400 m from release (rem).	80
Table C-23. 250 MW(t) pebble bed 700°C ROT—break in HPB—Cases E and F, infant and adult—800 m from release (rem).	81
Table C-24. 250 MW(t) pebble bed 700°C ROT—break in HPB—Cases E and F, infant and adult—1600 m from release (rem).	82
Table C-25. 250 MW(t) pebble bed 700°C ROT—water ingress—source term (curies).	83
Table C-26. 250 MW(t) pebble bed 700°C ROT—water ingress—Cases A and B—400 m from release (rem).	84
Table C-27. 250 MW(t) pebble bed 700°C ROT—water ingress—Cases C and D—400 m from release (rem).	85
Table C-28. 250 MW(t) Pebble Bed 700°C ROT—water ingress—Cases E and F, infant and adult—400 m from release (rem).	86
Table C-29. 250 MW(t) pebble bed 700°C ROT—water ingress—Cases E and F, infant and adult—800 m from release (rem).	87
Table C-30. 250 MW(t) pebble bed 700°C ROT—water ingress—Cases E and F, infant and adult—1600 m from release (rem).	88

ACRONYMS

AF	attenuation factors
AGR	Advanced Gas Reactor
D/Q	deposition
DBA	design basis accidents
EAB	exclusion area boundary
EPA	Environmental Protection Agency
HPB	helium pressure boundary
HTGR	high temperature gas-cooled reactor
LBE	licensing basis events
LPZ	low population zone
MACCS2	MELCOR Accident Consequence Code System
MHTGR	modular high temperature gas-cooled reactor
MST	Mechanistic Source Terms
NGNP	Next Generation Nuclear Plant
NRC	Nuclear Regulatory Commission
PAG	Protective Action Guides
R&D	research and development
PBMR	Pebble Bed Modular Reactor
RB	reactor building
RCCS	reactivity cavity cooling system
ROT	reactor outlet temperature
SSC	safety-related systems, structures, and components
TRISO	tristructural-isotropic
χ/Q	atmospheric dispersion

Scoping Analysis of Source Term and Functional Containment Attenuation Factors

1. BACKGROUND

This scoping analysis estimates postulated radiological releases and associated offsite doses from representative high temperature gas-cooled reactor (HTGR) module designs. The objectives of this analysis were to: (1) provide insight for next generation nuclear plant (NGNP) Technology Development Program activities, (2) provide a preliminary assessment of the performance of the HTGR relative to NGNP Project objectives regarding public health and safety; and (3) support ongoing NGNP Project discussions regarding possible HTGR deployment in advance of completion of detailed design and accident analyses.

Because the design of the NGNP demonstration plant has not progressed to the point where definitive source term analyses could be performed, the calculation of source terms used in these analysis is simplified and is not considered final. In the interim, however, to provide an approximate characterization of the source term, the NGNP Project developed a simplified parametric model to establish mechanistic source term estimates for a set of representative HTGR configurations based on prior detailed analyses of similar modular HTGRs.¹

This report summarizes the results of evaluating the specified radionuclide barrier performance characteristics (i.e., attenuation factors) of the functional containment, focusing on improved fuel performance, to determine the mechanistic source term and the offsite dose consequences for a set of HTGR configurations using a simplified model. To provide an approximate characterization of the source term, the NGNP Project model incorporates expert opinion related to the performance of each of the radionuclide barriers that comprise the HTGR functional containment: (1) the fuel particle kernel; (2) the fuel particle coatings, (3) the fuel matrix and graphite, (4) the helium pressure boundary; and (5) the reactor building, as discussed in *HTGR Mechanistic Source Terms White Paper* (MST white paper); INL/EXT-10-17997.² As more testing is completed under the NGNP Technology Development Program and further design development is completed, the assumed values for the barrier performance allocations can be revised, as necessary. In addition to establishing estimates of the source terms, the model was designed to interface with the MELCOR Accident Consequence Code System (MACCS2) code³ to derive dose estimates from the source term.

The resulting estimates were then compared to project objectives regarding the protection of public health and safety. The key principles of the NGNP Project public safety objectives include:

- Protection of the health and safety of the public and the environment with the objective that under no postulated accident condition would public evacuation or sheltering be required. To achieve this objective, the NGNP must meet:
 - The Nuclear Regulatory Commission (NRC) siting criteria for both the plant exclusion area boundary (EAB) and low population zone (LPZ) (10 CFR 52.47/50.34) at a nominal distance of 400 m from the reactor centerline
 - The early phase EPA plume exposure Protective Action Guides (PAGs) at the plant EAB.

- Protection of the food and water supplies from being unacceptably impacted by radionuclide contamination. This objective is satisfied by either meeting the intermediate phase EPA ingestion pathway PAGs at the plant EAB, or by assuring through the specific siting analyses and related administrative controls that no food or water supplies exist in the area immediately surrounding the EAB.

This report describes the model, documents key assumptions used, and presents the results of several simulations involving a set of proposed reactor configurations and accident scenarios involving a single HTGR module.

It is important to note that the results of these analyses are not intended for, nor suitable for, submittal to regulatory authorities as part of the licensing basis of the HTGR. The analyses are intended solely to provide insights for the NGNP Technology Development Program activities and internal guidance for the NGNP Project.

2. SCOPE AND BRIEF DESCRIPTION

The *HTGR Mechanistic Source Terms White Paper* provides a description of the approach the NGNP Project is taking in developing radiological source terms for licensing basis events (LBEs). Consistent with the HTGR safety design approach, this approach establishes the technical basis for taking appropriate credit for the radionuclide retention capabilities of each of the functional containment's multiple barriers to radionuclide transport to the environment. This mechanistic approach is expected to be used by future HTGR designers and licensing applicants for the following evaluations:

- Demonstration of compliance with 10 CFR 52.47/50.34 offsite dose requirements for design basis accidents (DBA), with only safety-related systems, structures, and components (SSCs) considered.
- Demonstration of compliance with PAGs for LBEs, with all SSCs (safety and non-safety) considered.

The mechanistic source terms will ultimately be determined using computer codes and models developed by the reactor vendor team to calculate the response of the reactor and associated barriers under normal and off-normal conditions as part of the safety assessment of the HTGR. In the absence of complete technical information to support detailed mechanistic source term assessments, the NGNP Project utilized a simplified model to perform parametric scoping analyses of the release and retention parameters that define the source terms for a modular HTGR.

The model requires the user to select a reactor configuration, reactor core size (thermal power rating), reactor outlet temperature, fuel degradation and failure fractions, and attenuation factors associated with each of the radionuclide barriers that make up the functional containment. The model uses Monte Carlo simulation to address uncertainties in fuel and barrier performance and provides range estimates of curies released for a user-specified accident scenario. The model combines the results of this probabilistic estimate with dose conversion coefficients calculated at specified distances from the reactor building⁴ to provide an estimate of the dose (rem) to a receptor.

The dose is evaluated for each design and accident as summarized below.

- The distribution of the source term, defined as the radionuclides released from the reactor building to the environment, is determined as a function of the initial core inventory and a release coefficient. The release coefficient is developed by combining the nuclide dependent distributions associated with the release of radionuclides and the attenuation factors associated with the barriers mitigating the release. The source term is calculated based upon fission products released from the fuel during both normal operations and accidents (see Section 3).
- Atmospheric dispersion (χ/Q) and deposition (D/Q) values are determined using the methodology and meteorological information identified in the report, "Engineering Evaluation of χ/Q Values Consistent with Regulatory Guide 1.145."⁵ For the purpose of the dose calculation, distances of 400 m, 800 m, 1600 m, 3200 m, and 8000 m are specified (see Section 4.1).
- The nuclide dependent distribution of the dose conversion factors is then adjusted by applicable χ/Q or D/Q values to derive a distance-weighted dose conversion factor, defined as the dose to an individual at a specified distance per curie of material released. The distance-weighted dose conversion factors are calculated externally to the model in MACCS (see Section 4.2).
- The results of the probabilistically derived source term and the distance-weighted dose conversion and deposition factors for each nuclide are then combined and summed as shown in the equation below. The results of this are then compared against the NGNP Project selected set of acceptance criteria (see Section 0).

$$Dose_i = Core\ Inventory_i\ (curies) \times Release\ Coefficient_i\ (fraction) \times Dose\ Conversion\ Factor_i\ (rem/curie)$$

3. SOURCE TERM DEVELOPMENT

An expert panel of personnel knowledgeable of NGNP fuel development activities, HTGR technology development activities, past HTGR accident analysis, representative design alternatives and the NGNP licensing approach for mechanistic source terms was convened during the week of September 5, 2011. Identification of the expert panel and summary of the meeting is contained in Appendix A to this report. This expert panel established the attributes and accident scenarios that were considered for determining the mechanistic source terms within the dose evaluation model.

Consistent with the approach discussed in the MST white paper, the radionuclide source terms were derived as a function of the performance of each of the barriers to radionuclide transport under event-specific conditions. Barrier performance was estimated based on expert opinion. Radionuclide retention of the barriers associated with fuel and graphite was estimated based on current capabilities of the technology as recently demonstrated in the Advanced Gas Reactor (AGR) fuel program. In assessing against the NRC siting criteria, the analyses utilized conservative estimates regarding the performance of the radionuclide release barriers, and did not credit any fission product release attenuation by the reactor building. In assessing against the EPA plume exposure PAGs, the analyses utilized realistic (mean) estimates of the performance of the radionuclide barriers including the reactor building.

The panel examined each design configuration, each event, and each radionuclide source by estimating a 50% and 95% upper bound value attenuation factor with an uncertainty distribution for each barrier. The radionuclide release distributions for each event for each source from each barrier were combined statistically to calculate the source terms released from the reactor building. These source terms were then evaluated in accordance with the accident rule sets appropriate to the NRC and EPA requirements as discussed in Section 4 and Table 11.

3.1 HTGR Configurations, Fission Product Classes and Associated Inventories

During this meeting, a number of HTGR configurations were considered to reflect the needs for various potential missions for a HTGR. Based on pre-conceptual and conceptual designs established during the NGNP Project, both prismatic and pebble fuel modular HTGRs with a range of reactor power ratings and reactor coolant outlet temperatures (ROT) were addressed. The configurations carried forth for further evaluation were judged representative of the above considerations and included:

- a. A single 600 MW(t) prismatic HTGR module with a 700°C ROT, providing high temperature steam via a steam generator.
- b. A single 600 MW(t) 900°C ROT prismatic HTGR module providing high temperature process heat via an intermediate heat exchanger.
- c. A single 250 MW(t) 700°C ROT pebble bed HTGR module providing high temperature steam via a steam generator.

To facilitate the development of radionuclide-specific source terms, the team developed a set of fission product classes, listed in Table 1. Radionuclides within a fission product class are assumed to have the same release and attenuation factors based on physical and chemical properties, with the exception of silver where the two representative isotopes have much different half-lives. The short-lived Ag-111 is distinguished from the much longer-lived Ag-110m in estimating the diffusive release from the fuel under normal operation. Each fission product class contains the key radionuclides, identified via past modular HTGR analyses that are expected to account for the majority of the offsite dose.

Table 1. Fission product classes.

Fission Product Class	Characteristic Nuclides
Noble Gases	Kr-85, Kr-88, Xe-133
I, Br, Te, Se	I-131, I-133, Te-132
Cs, Rb	Cs-134, Cs-137
Sr, Ba, Eu	Sr-90
Ag, Pd	Ag-110m, Ag-111
Sb	Sb-125
Mo, Ru, Rh, Tc	Ru-103
La, Ce	La-140, Ce-144
Pu, actinides	Pu-239

Individual radionuclide inventories used in the evaluation were based on the core for the 600 MW(t) prismatic configuration.⁶ Radionuclide inventories for the 250 MW(t) pebble bed configuration were scaled based on that inventory. Inventories for the 600 MW(t) prismatic and 250 MW(t) pebble bed are shown in Table 2. With regard to scaling of the 600 MW(t) prismatic HTGR radionuclide inventories to obtain the inventories for the 250 MW(t) pebble bed configuration, it is recognized that the scaling approach is an approximation that does not take into account the detailed differences between the pebble and prismatic fuel configurations and the detailed differences between the operating conditions of the two reactors. However, it is believed that the approximation is acceptable for the purposes of these analyses.

Table 2. Initial core fission product inventories, in curies.

Fission Product Class	Characteristic Nuclide	Inventory – 600 MW(t) Prismatic	Inventory – 250MW(t) Pebble Bed
Noble Gases	Xe-133	3.63E+07	1.51E+07
	Kr-85	1.90E+05	7.92E+04
	Kr-88	1.85E+07	7.71E+06
I, Br, Te, Se	I-131	2.00E+07	8.33E+06
	I-133	3.60E+07	1.50E+07
	Te-132	2.71E+07	1.13E+07
Cs, Rb	Cs-137	1.69E+06	7.04E+05
	Cs-134	1.90E+06	7.92E+05
Sr, Ba, Eu	Sr-90	1.69E+06	7.04E+05
Ag, Pd	Ag-110m	2.81E+04	1.17E+04
	Ag-111	2.96E+06	1.23E+06
Sb	Sb-125	2.35E+05	9.79E+04
Mo, Ru, Rh, Tc	Ru-103	3.61E+07	1.50E+07
La, Ce groups	Ce-144	2.33E+07	9.71E+06
	La-140	3.27E+07	1.36E+07
Pu, actinides	Pu-239	4.66E+03	1.94E+03

3.2 Tristructural-isotropic (TRISO) Fuel Fabrication Quality

The level of defects in tristructural isotropic (TRISO) fuel (or the fuel “quality”) resulting from the fuel fabrication process is important in establishing the overall source term for an HTGR. Specifications are placed on fuel fabrication to limit the levels of heavy metal contamination and SiC coating defects so that overall radionuclide control requirements are met. The values selected for heavy metal contamination (within the matrix that is not coated) and SiC defects (in the multiple coatings of each particle) reflect current fuel fabrication experience in the United States. The heavy metal contamination fractions are the same as those used historically by U.S. reactor designers in their design assessments. The SiC coating defect fractions are about 5 times lower than those historically required by the reactor designer.⁷ A lower SiC coating defect level results in a lower metallic fission product (e.g., cesium and strontium) release into the graphite and fuel matrix during normal operation. The fuel defect fraction estimates are presented in Table 3 and were assumed to be normally distributed.

Table 3. Fuel defect fractions for all reactor configurations.

Fission Product Class	Fabrication			
	Fraction Heavy Metal Contamination		Fraction SiC Coating Defects	
Confidence Limit	50%	95%	50%	95%
Noble Gases	1E-5	2E-5	NA	NA
I, Br, Se, Te	1E-5	2E-5	NA	NA
Cs, Rb	1E-5	2E-5	1E-5	3E-5
Sr, Ba, Eu	1E-5	2E-5	1E-5	3E-5
Ag, Pd	1E-5	2E-5	1E-5	3E-5
Sb,	1E-5	2E-5	1E-5	3E-5
Mo, Ru ,Rh, Tc	1E-5	2E-5	1E-5	3E-5
La, Ce	1E-5	2E-5	1E-5	3E-5
Pu, actinides	1E-5	2E-5	1E-5	3E-5

3.3 Fission Product Release from Fuel/Graphite during Normal Operation

As discussed in the MST white paper, the normal operations source terms for modular HTGRs are developed from four major sources: (1) heavy metal contamination in the fuel, (2) particles with SiC coating defects (which release fission metals but not fission gases and halogens), (3) incremental in-service fuel failures that occur under normal operation; and (4) diffusional release through intact coatings. Fuel failure is defined as a loss of the specified retention capability of all the coating layers. However, significant retention of radionuclides is maintained with the kernel, which is accounted for in the analysis. Reactor designers calculate fuel performance accounting for some incremental level of particle coating degradation and failures. The fuel qualification program will provide actual data on a large statistically significant population of TRISO fuel particles to better quantify this value.

Even for similar reactor sizes, HTGR source terms vary depending upon reactor type, thermal power rating, and outlet temperature. For this study, the evaluation assumed the pebble bed designs had a peak normal operating fuel temperature that is 100 to 150°C lower than that for a prismatic reactor at the same power rating. Additionally, the higher outlet temperature designs have higher fuel temperatures and higher average core temperatures, which results in a higher normal operational source term, a greater amount of potential incremental fuel failure during normal operation, and a larger inventory of fission

products captured in the graphite and circulating in the primary coolant. These effects were accounted for in the analysis.

To account for uncertainty in fuel and barrier performance, the review team estimated 50% and 95% confidence values for the incremental in-service failure fractions and attenuation factors upon which the mechanistic source terms are based. Incremental in-service failure fractions were assumed to be normally distributed. Attenuation factors were assumed to be lognormally distributed.

Because of the robust nature of the TRISO fuel, demonstrated through historical German and recent U.S. AGR Program experience,⁸ minimal particle failures are expected under anticipated normal NGNP design service conditions (temperature, burnup, fast fluence). Thus, the particle failure fractions under normal conditions represent statistical lower limits based on testing of fuel as part of the fuel development and qualification program. Because a large amount of fuel will be tested under prototypic conditions, the statistically based failure rate is 7–10 times less than the historical reactor design requirements, thus reducing the source term associated with incremental particle failures under normal conditions. Table 4 lists the 50 and 95% incremental fuel failure fraction under normal operation for the fission product classes in a prismatic reactor with a 700°C reactor outlet temperature. Appendix A contains a complete listing of normal operations fuel defect fractions for the reactor configurations identified in Table 7.

Table 4. Prismatic 700°C ROT incremental fuel failure fractions under normal operations.

Fission Product Class	Operations	
	In-Service Failure	
Confidence Limit	50%	95%
Noble Gases	7.0E-6	2.0E-5
I, Br, Se, Te	7.0E-6	2.0E-5
Cs, Rb	7.0E-6	2.0E-5
Sr, Ba, Eu	7.0E-6	2.0E-5
Ag, Pd	7.0E-6	2.0E-5
Sb,	7.0E-6	2.0E-5
Mo, Ru, Rh, Tc	7.0E-6	2.0E-5
La, Ce	7.0E-6	2.0E-5
Pu, actinides	7.0E-6	2.0E-5

3.4 Attenuation Factors during Normal Operations

Attenuation factors (AF) represent the retention capability of each barrier to fission product release. These AFs were estimated by the expert panel based on HTGR fuel testing results and radionuclide transport predictions developed for previous HTGR designs such as the modular high temperature gas-cooled reactor (MHTGR) and Pebble Bed Modular Reactor (PBMR). In developing the values, the experts accounted for (a) the plant configuration, (b) the design service conditions; and (c) the current fuel knowledge database (e.g., diffusion coefficients in the different layers and materials) and its associated uncertainties. For the noble gases, AFs associated with the matrix, graphite blocks (prismatic only), and the helium pressure boundary (HPB) were set to 1 (no retention). Of the fission products released to the coolant with the helium pressure boundary, noble gases were assumed to remain in circulation (AF = 1), while all others were assumed to plate out in the HPB during normal operation.

For the pebble bed HTGR cases, the lower normal operating fuel temperature results in higher attenuation factors associated with heavy metal contamination, the kernel, and diffusive releases. However, the pebble bed does not have fuel element graphite, so the total fuel element AFs are lower,

reflecting the lower fission product retentiveness of the fuel matrix of the pebble spheres compared to that of the combined prismatic fuel matrix of the compacts and the fuel element graphite.

In general, higher outlet temperatures tend to increase projected particle failure and decrease the in-core retention of the fission products. Thus, a larger inventory of fission products is released from the core and helium pressure boundary, and the reactor building plays a more important role in mitigating the release to the environment.

Table 5 lists the 50 and 95% confidence AFs for a prismatic reactor with a 700°C ROT under normal operations. Appendix A contains the complete listing of attenuation factors under normal operations for the reactor configurations identified in Table 7.

Table 5. Prismatic 700°C ROT barrier attenuation factors during normal operations.

Fission Product Class	Heavy Metal Contamination		Fuel Particle Kernel		Diffusive Release through Fuel Particle Coatings		Graphite (Compact Matrix and Fuel Element)		Helium Pressure Boundary	
	AF 50%	AF 95%	AF 50%	AF 95%	AF 50%	AF 95%	AF 50%	AF 95%	AF 50%	AF 95%
Noble Gases	10	3	50	17	1E8	1E7	1	1	1	1
I, Br, Se, Te	10	3	50	17	1E8	1E7	1	1	1E6	1E5
Cs, Rb	1	1	3	1	1E8	1E6	5	2	1E6	1E5
Sr, Ba, Eu	1	1	50	20	1E3	200	1E3	300	1E6	1E5
Ag, Pd	1	1	2	1	500 ^a	100 ^a	2	1	1E6	1E5
Sb	1	1	2	1	1E8	1E6	20	2	1E6	1E5
Mo, Ru, Rh, Tc	1	1	500	30	1E8	1E7	1E3	300	1E6	1E5
La, Ce	1	1	500	30	1E8	1E7	1E3	300	1E6	1E5
Pu, actinides	1	1	1E3	100	1E8	1E7	1E4	1E3	1E6	1E5

a. Values presented here for Ag-110m. For Ag-111, the values for the diffusive release through the coating are increased by a factor of 5 to account for the effect of the half-life on the release.

Table 6 compares the mean values for I-131, Cs-137, and Sr-90 inventories retained in the fuel matrix and graphite for an equilibrium core and circulating in the HPB (after a 60-year lifetime) under normal operations for the reactor configurations identified in Table 7. In the two prismatic configurations, the proportional effect of the higher outlet temperature on the inventory of fission products retained in the fuel matrix and graphite and released to the coolant system is evident. For the higher outlet temperature case, the attenuation factors are reduced, reflecting the fact that the core is hotter on average relative to the 700°C outlet temperature case. This results in greater release of fission products from the fuel, greater inventory in the fuel matrix and graphite for cesium and strontium, and a greater inventory in the coolant system. The pebble bed design, with a lower power rating and a lower outlet temperature, has correspondingly lower inventories, despite having a lower graphite attenuation factor than the prismatic reactor.

Table 6. Mean values for I-131, Cs-137, and Sr-90 inventories (curies) released to the helium pressure boundary and retained in the fuel matrix and graphite.

Reactor Design Configuration	I-131, Curies		Cs-137, Curies		Sr-90, Curies	
	In Fuel Matrix and Graphite	In Helium Pressure Boundary	In Fuel Matrix and Graphite	In Helium Pressure Boundary	In Fuel Matrix and Graphite	In Helium Pressure Boundary
600 MW(t) Prismatic 700°C ROT	-	30	24	5	2750	0.1
600 MW(t) Prismatic 900°C ROT	-	74	226	254	5680	31
250 MW(t) Pebble Bed 700°C ROT	-	9	34	3	1250	0.4

3.5 Accidents Selected for Evaluation

Based on safety analyses performed for prior gas-cooled reactor studies, breaks in the HPB and water ingress events pose the greatest challenges with respect to offsite dose consequences. As discussed further in Appendix A, previous analyses of these events were reviewed to aid in developing the scenarios to be considered in this model for evaluating the mechanistic source terms. The results from these past assessments also provided additional data for the expert panel to estimate barrier performance and against which the panel's intermediate results were benchmarked. The two scenarios developed and key conditions are summarized here:

- Break in HPB with loss of forced cooling
 - Leak or break in the HPB piping up to the largest connecting pipe
 - Reactor trip
 - Loss of heat transport to the energy conversion
 - Loss of shutdown cooling
 - Immediate depressurization of helium in the helium pressure boundary
 - Opening of the reactor building vent to relieve helium pressure

This event included an early release of the circulating activity with liftoff of plated out material from the HPB due to the depressurization followed by a subsequent long term release because of the core heatup from the fuel and graphite and then from the helium pressure boundary.
- Water ingress event (for design configurations with a steam generator)
 - Steam generator tube break
 - Reactor trip
 - Loss of heat transport to the energy conversion
 - Loss of shutdown cooling
 - Detection of water ingress
 - Isolation of the steam generator main steam and feedwater lines
 - Over-pressurization of the HPB through the vessel system relief valve

- Opening of the reactor building vent to relieve helium and water/steam pressure.

This event included an early release of the circulating activity with washoff of plated out material from the HPB due to the over-pressurization followed by a subsequent long term release due to the core heatup from the fuel and graphite and then from the HPB.

The barrier performance characteristics required as input in the model simulations for these scenarios were then established to be representative of the significant accidents based on knowledge of the requisite phenomenology and results from similar events previously analyzed in HTGR safety assessments.

A third key scenario that has been determined to be risk-significant in prior analyses of the MHTGR and the PBMR, and that was initially considered by the NNGP expert panel, was a small HPB leak followed by a depressurized conduction cooldown. In this event, the HPB depressurization extends for up to several hundred hours, which provides a transport mechanism for the delayed radionuclide release from the fuel as a result of the core heatup but this event does not include the release of plateout material within the helium pressure boundary. The working group bounded this event in the accidents analyzed by including the initial release of plateout material due to lift off and the release of radionuclides due to core heatup following the depressurization phase (even in the absence of a strong driving mechanism for the release). The analysis further assumed shorter release durations, which resulted in higher atmospheric dispersion (X/Q) values than would be expected for a release lasting many hours. Thus, the working group decided that for the very unlikely event of a small leak without mitigative actions taking place, such as restart of forced cooling and/or intentional helium depressurization through the helium purification system to helium storage, the event would be adequately addressed by the analyzed break scenario and was not selected for further study as part of this initial evaluation.

Based on the proposed HTGR configurations and the selected accident scenarios, five separate model simulations were evaluated. The configurations for each of the simulation are presented in Table 7.

Table 7. Mechanistic source term events for model simulations.

Reactor Configuration	Accident Scenario
600 MW(t) Prismatic, 700°C ROT	Break in Helium Pressure Boundary
600 MW(t) Prismatic, 700°C ROT	Water Ingress Event
600 MW(t) Prismatic, 900°C ROT	Break in Helium Pressure Boundary
250 MW(t) Pebble Bed, 700°C ROT	Break in Helium Pressure Boundary
250 MW(t) Pebble Bed, 700°C ROT	Water Ingress Event

The model inputs and simulation results presented in the body of this report are for a break in the HPB in a 600 MW(t) prismatic reactor with an outlet temperature of 700°C. The model inputs are presented in Appendices A and B and the results are presented in Appendices C and D for all the reactor configurations and selected accident scenarios identified in Table 7.

3.6 Releases and Attenuation Factors Under Accident Conditions

For modeling the accident conditions identified in Section 3, the mechanistic source term is assumed to comprise two distinct phases: a short-term (prompt) release during depressurization of the fission products from normal operations, and a long-term (delayed) release primarily due to heatup of the fuel.

For the prompt release, the entire inventory of circulating activity (noble gases) is assumed to be released, and a portion of the material plated out within the HPB is assumed to be lifted off (in the event of a dry break in the helium pressure boundary) or washed off (in a water ingress event). Table 8 lists the

short-term 50 and 95% confidence AFs estimated for the HPB and the reactor building for a 600 MW(t) prismatic reactor with a 700°C ROT under a break in the HPB accident scenario. Appendix A contains the complete listing of short-term attenuation factors estimated by the expert team for the reactor configurations and selected accident conditions identified in Table 7.

Table 8. Prismatic 700°C ROT short-term accident attenuation factors for a break in He pressure boundary.

Fission Product Class	Break in the Helium Pressure Boundary			
	Helium Pressure Boundary – liftoff		Reactor Building	
Confidence Limit	AF 50%	AF 95%	AF 50%	AF 95%
Noble Gases	1	1	1	1
I, Br, Se, Te	200	20	2	1
Cs, Rb	200	20	2	1
Sr, Ba, Eu	200	20	2	1
Ag, Pd	200	20	2	1
Sb	200	20	2	1
Mo, Ru, Rh, Tc	200	20	2	1
La, Ce	200	20	2	1
Pu, actinides	200	20	2	1

The AF estimated for the early depressurization phase in the break in the helium boundary scenario is based on the shear force ratio on surfaces of the HPB and is based on results from the COMEDIE in-pile loop tests.⁹ The COMEDIE tests indicated an AF of 1000 at a shear ratio of 1.7. Since this is a shear ratio higher than calculated for HPB breaks in modular HTGR designs, the 50% value of 200 used here is judged to be acceptable in light of the lack of detailed plant configuration and design.

For the long-term release, the core is assumed to heat up for 50 hours, after which time a release of nuclides is assumed for the next 40 hours. Table 9 lists the long term 50% and 95% AFs for a 600 MW(t) prismatic reactor with a 700°C ROT under a HPB break accident scenario.

Additionally, Table 9 also lists the 50% and 95% incremental fuel failure under accident conditions. The incremental particle failure fractions under accident conditions represent statistical lower limits based on anticipated testing of fuel as part of the fuel development and qualification program. Because a large amount of fuel will be tested under prototypic conditions, the statistically based failure rate is 7 to 10 times less than the historical reactor design requirements, thus reducing the source term associated with incremental particle failures under accident conditions. Under accident conditions, intact fuel particles do not release fission products except silver. Releases from the core under accidents are dominated by release from heavy metal contamination, in-service incremental failures, and release of fission products retained in the graphite under normal operation. Appendix A contains the long-term incremental release and attenuation factors as estimated by the expert team for the reactor configurations and selected accident conditions identified in Table 7.

Under the accident scenario of a break in the helium pressure boundary, the AF of the HPB for a long-term heat up was reduced relative to the AF under prompt release conditions. The long-term accident AFs take into account the very low flows expected at this phase of the event and the eventual

contraction of the helium in the reactor vessel as the core cools down and the flow reverses into the helium pressure boundary. Preliminary calculations performed by PBMR for a medium break scenario suggest that AFs greater than 750 are achievable due to the lack of pressure driving force for radionuclide transport from the core through the HPB into the reactor building. In the cases where there is a pressure driving force (such as a very small break) the AF was only 1.7.¹⁰ Thus, the AFs of 5–10 in Table 9 were also judged to be acceptable estimates given the limited knowledge associated with the accident phenomenology and design detail available.

Table 9. Prismatic 700°C ROT long-term accident release and attenuation factors for a break in helium pressure boundary.

Fission Product Class	Accident Release		Attenuation Factors											
	Incremental Failure-Accident		Heavy Metal Accident Release		Non-Intact Accident Release		Intact Accident Release		Graphite		Helium Pressure Boundary		Reactor Building	
Confidence Limit	50%	95%	AF 50%	AF 95%	AF 50%	AF 95%	AF 50%	AF 95%	AF 50%	AF 95%	AF 50%	AF 95%	AF 50%	AF 95%
Noble Gases	3E-5	8E-5	2	1	10	5	1E7	2E6	1	1	5	2	1	1
I, Br, Se, Te	3E-5	8E-5	2	1	10	5	1E7	2E6	1	1	5	2	10	2
Cs, Rb	3E-5	8E-5	1	1	1	1	1E7	2E6	10	3	10	3	10	2
Sr, Ba, Eu	3E-5	8E-5	1	1	1	1	1E6	2E5	100	30	10	3	10	2
Ag, Pd	3E-5	8E-5	1	1	1	1	500	100	1	1	10	3	10	2
Sb	3E-5	8E-5	1	1	1	1	1E6	2E5	100	30	10	3	10	2
Mo, Ru, Rh, Tc	3E-5	8E-5	1	1	100	50	1E7	2E6	10	3	10	3	10	2
La, Ce	3E-5	8E-5	1	1	100	50	1E7	2E6	100	30	10	3	10	2
Pu, actinides	3E-5	8E-5	1	1	1E3	500	1E7	2E6	1E4	300	10	3	10	2

In the break in the HPB scenarios, the reactor building AF of 10 was judged to be acceptable in light of the lack of building design and the desire to focus the reactor building requirements on structural protection of the reactor as opposed to radionuclide retention. The PBMR calculations indicate long term AFs in excess of 2000 for a medium size break and 20 for a very small break may be achieved. In these calculations, the reactor building was assumed to leak at 100% per day at 0.1 bar overpressure. As such, the AFs are not associated with any specific fission product retention mechanisms or leak tightness of the reactor building but rather with the lack of any strong flow to transport the gas through the reactor building to the environment.

In the case of the water ingress event, the uncertainties are larger because of the lack of data. However, because the water is expected to remove a large fraction of the plateout inventory, the AFs for the HPB were set much lower than in the HPB break case. Because condensation of the moisture in the reactor building during transport is expected to mitigate the escape of fission products from the building, a higher AF was estimated for the reactor building. As discussed above, in general, the AFs for the reactor building (RB) were selected to allow flexibility in the final design details to accomplish the primary function of the building to provide structural protection of the reactor to maintain core geometry for control of heat generation and core heat removal to the reactivity cavity cooling system (RCCS). Thus, the AFs are not overly aggressive for the RB's supportive function of radionuclide retention.

3.7 Source Terms

Using the attenuation factors and modeling assumptions discussed in the previous sections, mechanistic source terms (release from the reactor building) were estimated for the short term and long term releases for each reactor configuration identified in Section 3. Table 10 lists the 50%, mean, and 95% source term values for a 600 MW(t) prismatic reactor with a 700°C ROT under the HPB break accident scenario. Source term values are presented in curies. Appendix B contains the source terms for the other reactor configurations identified in Table 7.

Table 10. 600 MW(t) Prismatic 700°C ROT, source terms for a break in He pressure boundary.

Fission Product Class	Nuclide	Short Term Release (curies)			Long Term Release (curies)		
		50%	Mean	95%	50%	Mean	95%
Noble Gases	Xe-133	3.99E+01	3.99E+01	3.99E+01	4.92E+01	6.44E+01	1.68E+02
	Kr-85	2.10E-01	2.10E-01	2.10E-01	3.39E-01	4.50E-01	1.21E+00
	Kr-88	2.06E+01	2.06E+01	2.06E+01	1.38E-04	1.82E-04	4.91E-04
I, Br, Te, Se	I-131	5.51E-02	1.61E-01	6.10E-01	2.85E+00	6.11E+00	2.24E+01
	I-133	1.00E-01	2.90E-01	1.08E+00	1.17E+00	2.64E+00	9.72E+00
	Te-132	7.44E-02	2.17E-01	8.08E-01	3.12E+00	6.51E+00	2.41E+01
Cs, Rb	Cs-137	1.17E-01	3.43E-01	1.33E+00	1.15E-01	3.31E-01	1.28E+00
	Cs-134	1.93E-02	5.54E-02	2.10E-01	1.32E-01	3.82E-01	1.49E+00
Sr, Ba, Eu	Sr-90	1.57E-03	4.56E-03	1.72E-02	1.79E-01	4.71E-01	1.76E+00
Ag, Pd	Ag-110m	3.86E-02	1.13E-01	4.22E-01	8.61E-01	2.30E+00	8.51E+00
	Ag-111	7.96E-01	2.28E+00	8.93E+00	5.48E+01	1.72E+02	6.49E+02
Sb	Sb-125	7.27E-04	2.12E-03	8.15E-03	1.78E-03	5.23E-03	2.05E-02
Mo, Ru, Rh, Tc	Ru-103	8.05E-04	2.34E-03	8.68E-03	7.19E-01	1.96E+00	7.54E+00
La, Ce groups	Ce-144	9.74E-03	2.75E-02	1.05E-01	4.57E-02	1.30E-01	5.01E-01
	La-140	7.46E-04	2.16E-03	8.13E-03	2.88E-02	7.65E-02	2.92E-01
Pu, actinides	Pu-239	1.90E-07	5.74E-07	2.10E-06	8.97E-07	2.60E-06	1.01E-05

This source term assessment has produced release estimates that are lower than have historically been produced by HTGR reactor vendors. The lower estimates presented here are the result of incorporating better fuel performance expectations with lower coated particle fuel defects and lower estimated coated fuel particle failure rates based on current and anticipated data from the AGR program.

4. DOSE CONVERSION FACTORS

To support the parametric model, a series of calculations was performed with MACCS to generate a set of distance-weighted dose conversion factors (rem/curie) at distances of 400, 800, 1600, 3200, and 8000 meters [3] for the exposure protocols identified in Table 11.

4.1 Meteorology

The meteorology for this analysis was based on data from the report, “Engineering Evaluation of χ/Q Values Consistent with Regulatory Guide 1.145.”⁵ The atmospheric dispersion factors (χ/Q values) were determined at the specified downwind distances for a hypothetical ground-level release using meteorological data from a site with the worst case average annual dispersion coefficients. Building wake-effects were not included. For DBA analyses, 95% values for χ/Q were used consistent with NUREG 0800 *Standard Review Plan for the Review of Safety Analysis Reports for Nuclear Power Plants*,¹¹ Section 2.3.4, “Short-Term Atmospheric Dispersion Estimates for Accident Releases.” For the PAG analyses, average χ/Q values and deposition factors (D/Q values) were used consistent with NUREG 0800, Section 2.3.5, “Long-Term Atmospheric Dispersion Estimates for Routine Releases.”

4.2 Dose Conversion

Using the standard dose conversion factors listed in the EPA Federal Guidance Technical Reports 11 and 12, MACCS generated a set of distance-weighted dose conversion factors for each exposure scenario. The model used a normalized release of one curie for each key fission product. These distance-weighted dose conversion factors were then multiplied by the source term values presented in Section 3.7 to provide dose estimates in rem. A summary of the distance-weighted dose conversion factors is presented in Appendix C.

Table 11. Dose limits and associated protocols for calculating exposures.

Case	Limits	Nuclides	Organ	Exposure	Pathway	Reference
NRC Siting Criteria (95th percentile meteorological conditions)						
A	25 rem	List of nuclides	TEDE	Worst 2 hr	Cloud-shine, inhalation, ground-shine	10 CFR 52.47(a) Exclusion Area Boundary
B	25 rem	List of nuclides	TEDE	Cloud Passage	Cloud-shine, inhalation, ground-shine	10 CFR 52.47(a) Low Population Zone
EPA PAG - Plume Exposure Related Dose (mean meteorological conditions)						
C	1 rem	List of nuclides	TEDE	4 days	Cloud-shine, inhalation, ground-shine	EPA 400-R-92-001, Table 2-1
D	5 rem	Iodine (I-131, I-133, Te-132)	Thyroid	4 days	Inhalation	EPA 400-R-92-001, Table 2-1
EPA PAG—Ingestion Related Dose (mean meteorological conditions)						
E	0.5 rem	List of non-noble nuclides	Whole body (Effective)	1 year	Pasture, cow, milk, person (infant, adult)	EPA 400-R-92-001, Chapter 3 (FR Vol. 47, No. 205, paragraph [c])
F	1.5 rem	List of non-noble nuclides	Thyroid	1 year	Pasture, cow, milk, person (infant, adult)	EPA 400-R-92-001, Chapter 3 (FR Vol. 47, No. 205, paragraph [c])

5. COMPARISON OF RESULTS TO PROJECT OBJECTIVES

Dose estimates were produced by multiplying source terms by distance-weighted dose conversion factors. Estimates were produced for each combination of reactor configuration, accident scenario, and exposure case. In this section, summaries of the dose estimates are presented for the five scenarios modeled for a receptor located at 400 m for plume exposures (Cases A–D), and at all analyzed distances for the ingestion pathway (Cases E–F).

For the exposure scenarios A through C and E, the dominant contributors to total effective doses for the offsite receptors for the accident scenarios assessed are Ag-111, Ag-110m, and Ce-144. This result is different from results of previous modular HTGR accident analyses. Because of the better fuel performance assumed in this study based on recent encouraging results of fuel R&D, defect levels and assumed incremental failure rates under normal and accident conditions are lower than used in past modular HTGR accident analyses. This better fuel performance translates into much lower release of Cs-137, the isotope that has historically dominated total effective doses off site. Thus, these silver and cerium isotopes that were minor contributors in the past have shown up as more important now. This result may also be due in part to the simplified methodology used in this study to establish the source term. Enhanced attention to the behavior of these isotopes will be given in the NGNP Technology Development Program going forward.

Inhalation and ingestion doses directly to the thyroid Cases D and F were the primarily the result of I-131.

Appendix C contains a complete listing of dose estimates for each of the five reactor configurations and selected accident scenarios presented in Table 7.

5.1 Comparison with NRC Siting Criteria (Cases A and B)

For comparison with the NRC siting criteria (Cases A - Exclusion Area Boundary and B - Low Population Zone from Table 11) the 95% mechanistic source term and 95% distance-weighted dose conversion factors were used. In developing the mechanistic source term, it was conservatively assumed that the reactor building does not retain any fission products released from the helium pressure boundary. The short term and long term accident attenuation factors for the reactor building were set to 1. Even with this assumption, the siting criteria are met at the EAB with large margins for all single module reactor configurations and accident scenarios, as summarized in Table 12 for all scenarios evaluated. These results demonstrate the high degree of radionuclide retention afforded by the fuel matrix and graphite within the core of a modular HTGR.

Table 12. Upper bound comparison with NRC siting criteria (DBA) – (TEDE rem).

Design Configuration	Event Scenario	Case A, EAB (400 m)	Case B, LPZ (400 m)
600 MW(t) Prismatic, 700°C ROT	Break in Helium Pressure Boundary	0.02	1.32
600 MW(t) Prismatic, 700°C ROT	Water Ingress Event	0.46	6.43
600 MW(t) Prismatic, 900°C ROT	Break in Helium Pressure Boundary	0.43	2.06
250 MW(t) Pebble Bed, 700°C ROT	Break in Helium Pressure Boundary	0.04	0.57
250 MW(t) Pebble Bed, 700°C ROT	Water Ingress Event	0.86	3.33
Limits (rem)		25	25

5.2 Comparison with PAG Emergency Planning Criteria (Cases C–F)

For comparison with the EPA PAG Emergency Planning Criteria (Cases C–F from Table 11), the mean values for mechanistic source term and distance-weighted dose conversion factors were used. The plume exposure PAG criteria of 1 rem (total effective dose equivalent) and 5 rem (inhalation thyroid dose) are shown to be met at the EAB (400 m) for all single module reactor configurations under the evaluated accident scenarios. The results of the dose evaluation at the EAB compared against the plume exposure PAG limits are summarized in Table 13 for all scenarios evaluated.

Table 13. Realistic comparison with plume exposure PAG at EAB.

Design Configuration	Event Scenario	Case C, TEDE (rem)	Case D, Thyroid (rem)
600 MW(t) Prismatic, 700°C ROT	Break in Helium Pressure Boundary	0.04	0.18
600 MW(t) Prismatic, 700°C ROT	Water Ingress Event	0.05	0.25
600 MW(t) Prismatic, 900°C ROT	Break in Helium Pressure Boundary	0.07	0.21
250 MW(t) Pebble Bed, 700°C ROT	Break in Helium Pressure Boundary	0.02	0.07
250 MW(t) Pebble Bed, 700°C ROT	Water Ingress Event	0.04	0.10
Limits (rem)		1	5

For Cases E and F, the ingestion pathway PAG criteria are met for an adult receptor at 400m. However, for an infant receptor the ingestion pathway PAG criteria of 0.5 rem (whole body) is not met at 400 m, but is met at a distance of less than 800 m. For the infant receptor the ingestion pathway PAG criteria of 5 rem (thyroid) is the limiting case and is not met at 400 m, but is met at a distance of approximately 900 m. The results of the dose evaluation for the ingestion pathway PAG for the infant receptor as a function of distance are presented in Figure 1 and Figure 2 for the whole body and thyroid criteria, respectively.




Figure 1. Case E, infant, EDE (rem), single reactor module.




Figure 2. Case F, infant, thyroid (rem) single reactor module.

5.3 Overall Conclusions

In summary, the results of this scoping analysis indicate that all NGNP Project objectives related to offsite dose for the NRC Siting and EPA PAG plume exposures (Cases A–D) are met for a single reactor module with the functional containment performance levels that are currently envisioned, and are being validated, in part through the NGNP Technology Development Program. These offsite release results demonstrate the high degree of radionuclide retention afforded by the fuel and graphite within the core of a modular HTGR and support the assertion that no public evacuation or sheltering would be required. However, additional technical assessment and design development work are needed to fully demonstrate that project objectives related to meeting the ingestion pathway EPA PAG (Cases E and F) at or near the EAB are achieved.

Additional analyses will be needed to confirm that project objectives are satisfied for multi-module HTGR facilities when responding to postulated events that may result in fission product releases from more than one module. These additional analyses can be completed when the licensing basis events at multi-module facilities are established. These methods are being developed through ongoing NGNP licensing efforts regarding establishment of the risk informed performance based approach for identifying postulated events.

6. REFERENCE

1. Idaho National Laboratory, *Next Generation Nuclear Plant Mechanistic Source Terms White Paper*, INL/EXT-10-17997, July 2010.
2. Idaho National Laboratory, *Next Generation Nuclear Plant Mechanistic Source Terms White Paper*, INL/EXT-10-17997, July 2010.
3. D. Chanin, M. L. Young, J. Randall, and K. Jamali, "Code Manual for MACCS2: Volume 1, User's Guide," NUREG/CR-6613 (SAND97-0594), May 1998.
4. PNNL-21012, 2011, "MACCS2 Unit Dose Conversion Factors for Use with Next Generation Nuclear Plant Source Term Analysis," Pacific Northwest National Laboratory, Richland, WA, 2011.
5. PNNL 19217, "Engineering Evaluation of X/Q Values Consistent with Regulatory Guide 1.145," Pacific Northwest National Laboratory, Richland, WA, 2010.
6. GA 2008, Engineering Services For The Next Generation Nuclear Plant (NGNP) With Hydrogen Production: NGNP Contamination Control Study; GA Report 911117 April 2008, General Atomics, San Diego CA.
7. C. M. Barnes, and J. D. Hunn, "Fabrication and Comparison of Fuels for Advanced Gas Reactor Tests," *5th International Topical Meeting on High Temperature Reactor Technology (HTR-2010)* Prague Czech Republic, Oct 18–20, 2010.
8. S. B. Grover, et al., "Mission and Status of the First Two Next Generation Nuclear Plant Fuel Irradiation Experiments in the Advanced Test Reactor," *Proceedings of the 18th International Conference of Nuclear Engineering*, Xian China, May 17–20, 2010.
9. W. Medwid and A. Gillespie, *COMEDIE BD-1 Test Evaluation Report*, DOE, DOE-HTGR-88552, General Atomics, 1993.
10. NGNP-PLD-GEN-RPT-N-00007, "Next Generation Nuclear Plant: Plant Level Assessments Leading to Fission Product Retention Allocations," October 2009, Westinghouse Electric Company LLC, Pittsburgh, PA.
11. NUREG 0800, Standard Review Plan for the Review of Safety Analysis Reports for Nuclear Power Plant, Nuclear Regulatory Commission.

Appendix A

Expert Review Panel Meeting and Results

Appendix A

Expert Review Panel Meeting and Results

As a result of discussions on Next Generation Nuclear Plant (NGNP) Research and Development (R&D) needs, it was recommended that the NGNP Project develop a simplified parametric model as a surrogate to performing detailed accident analysis models in the absence of a selected NGNP Demonstration Plant design. This model establishes scoping source terms based on performance of the NGNP identified barriers in *HTGR Mechanistic Source Terms White Paper* (INL/EXT-10-17997) and evaluates the impact of these releases to public health.

An expert review process was used to establish defensible and target values for the radionuclide transport factors and necessary input assumptions to develop the mechanistic source term used in the simplified parametric dose analysis model. To facilitate this process, a meeting of the expert panel was convened during the week of September 5, 2011. The agenda and outputs of this meeting are contained as attachments to this appendix. The expert panel consisted of personnel knowledgeable of NGNP Fuel Development Activities, high temperature gas-cooled reactor (HTGR) R&D activities, past HTGR and light water reactor (LWR) accident analysis, and the proposed NGNP design alternatives and licensing approach for mechanistic source terms.

The team members and their relevant background for this panel topic were:

- David Alberstein: BS – Physics, MS – Nuclear Engineering. 40 years of experience in nuclear energy, including 27 years of experience in HTGR design, licensing, and program management. Former technical lead at General Atomics for analysis of metallic fission product transport in and release from the HTGR core.
- Hans Gougar: BS – Education, Ms and PhD – Nuclear Engineering. 14 years of experience at the INL working in core safety analysis and code development, including 12 years on methods development for HTGRs. Deputy Technical Director for VHTR research and development at the INL. Consultant to the PBMR Company on core analysis methods.
- David Hanson: BS, MS – Chemical Engineering. 40 years of experience in HTGR core performance analysis, TRISO fuel performance, and fission product transport at General Atomics. Prepared numerous umbrella technology development plans, test plans, and test specifications to characterize fuel performance and fission product transport in HTGRs.
- Tom Hicks: Over 30 years of management, licensing, safety, operations, ITAAC and engineering experience. U.S. nuclear submarine program; U.S. Nuclear Regulatory Commission (NRC) inspector; consulting firm director of commercial plant nuclear programs; team leader for nuclear plant inspection teams; COLA licensing support lead/advisory positions for new reactor plants. NGNP Regulatory Affairs – Licensing staff.
- Richard Hobbins: BS – Chemistry, PhD – Metallurgy. 42 years of experience in nuclear fuel development and source terms – 24 years at INL and 18 years as an independent consultant, including 13 years with gas-cooled reactor programs (NPR and NGNP).
- Peter Lowry: BS – Engineering. 20 years of experience in nuclear safety for nuclear reprocessing facilities and reactors. NGNP Engineering Lead for Safety Analysis and Probabilistic Risk Assessment. Member of the Working Group for ANS 53.1 *Nuclear Safety Design Process for Modular Helium-Cooled Reactor Plants*.

- Phil Mills: BS – Mechanical Engineering. 27 years of experience in the nuclear industry. Acting Director of NGNP Engineering at the Idaho National Laboratory.
- David Petti: PhD – Nuclear Engineering. 25 years experience in nuclear fuel development and source term analysis. Director of NGNP R&D at the INL, responsible for the AGR fuel development, testing, and qualification program.
- Fred Silady: BS, MS, PhD – Nuclear Engineering. 38 years of experience in HTGR safety, licensing, and systems engineering Former technical and management lead at General Atomics for deterministic and probabilistic safety analyses. Consultant on modular HTGR design and development to PBMR, AREVA, and General Atomics.

As an initial step, the team reviewed accidents scenarios and attributes (see attached September meeting agenda pages 3-5) to be considered for the initial development of mechanistic source term (release characteristics) within the dose evaluation model. The initial considerations supporting the selection of the accident conditions to be further evaluated are provided below:

Event Descriptor	Characteristics	PSID	AREVA Safety Assessment	Mission	Core Difference	Power Difference	Outlet Temperature
Large Break	Depressurization time < 1 minute. Initial: Circulating, Mechanical Entrainment (liftoff, dust) long term: air ingress (enhance matrix graphite release, impact on fuel failure)	NA	7.2.1	IHX with piping - yes SG TBD-ASME	PBR More Dust larger impact of air	Scalable. (More of % core/ inventory is impacted)	More initial inventory in matrix/graphite. Implies IHX (>800) impact on Iodine
Medium Break	Depressurization time < 5 minute. Less Mechanical Entrainment long term: air ingress (less - enhanced matrix graphite release, impact on fuel failure)	DBA-10		All	PBR More Dust larger impact of air	Scalable. (More of % core /inventory is impacted)	More initial inventory in matrix/graphite. Implies IHX (>800) impact on Iodine
Small Break	Depressurization time hours. 20-30 hrs. Initial circulating (look at time phases depressurization, expansion, and contraction)	DBA-11	7.2.2	All	Pebble peaks sooner - timing of heat up release may overlap with depressurization	Scalable. (More of % core /inventory is impacted)	More initial inventory in matrix/graphite. Implies IHX (>800) impact on Iodine
Pressurized Cooldown with subsequent HPB failure	Breach occurs at peak heat up. shifts release phase - timing			IHX Process Heat	Pebble peaks sooner - timing of heat up release may overlap with depressurization	Scalable. (More of % core /inventory is impacted)	More initial inventory in matrix/graphite. Implies IHX (>800) impact on Iodine
Water Ingress	large (PRV cycles, sticks open) hydrolysis, wash off, water induced matrix/graphite release, reactivity affects	DBA-6	7.2.4	SG only	none	Scalable	Limited to <750 C due to SG

Based on safety analyses performed for prior gas-cooled reactor studies, breaks in the HPB and water ingress events pose the greatest challenges with respect to offsite dose consequences. As discussed further in Appendix A, previous analyses of these events were reviewed to aid in developing the scenarios to be considered in this model for evaluating the mechanistic source terms. The results from these past assessments also provided additional data for the expert panel to estimate barrier performance and against which the panel's intermediate results were benchmarked. The two scenarios developed and key conditions are summarized here:

- Break in helium pressure boundary (HPB) with loss of forced cooling
 - a leak or break in the HPB piping up to the largest connecting pipe
 - reactor trip
 - loss of heat transport to the energy conversion
 - loss of shutdown cooling
 - immediate depressurization of helium in the helium pressure boundary
 - opening of the reactor building vent to relieve helium pressure.

This event included an early release of the circulating activity with liftoff of plated out material from the HPB due to the depressurization followed by a subsequent long term release due to the core heatup from the fuel and graphite and then from the helium pressure boundary.

- Water Ingress Event (for design configurations with a steam generator)
 - steam generator tube break
 - reactor trip
 - loss of heat transport to the energy conversion
 - loss of shutdown cooling
 - detection of water ingress
 - isolation of the steam generator main steam and feedwater lines
 - over-pressurization of the HPB through the vessel system relief valve
 - opening of the reactor building vent to relieve helium and water/steam pressure.

This event included an early release of the circulating activity with washoff of plated out material from the HPB due to the over-pressurization followed by a subsequent long term release due to the core heatup from the fuel and graphite and then from the HPB.

After selection of the reactor configurations and accident scenarios, the team developed estimates for the release fractions and attenuations factors for the specific configuration and accident scenario presented in Section A-4. These factors and the initial core inventory (Section 2.3) are used as inputs to the dose evaluation model following the formulas presented in A-2.

The development of the release and attenuation factors included consideration of past HTGR analyses and experiments including:

- Barnes, C.M. and J.D. Hunn, "Fabrication and Comparison of Fuels for Advanced Gas Reactor Tests," 5th International Topical Meeting on High Temperature Reactor Technology (HTR-2010) Prague Czech Republic, Oct 18-20, 2010.
- Bullock, R.E., "Fission Product Release during Postirradiation Annealing of Several Types of Coated Particle Fuels," J. Nuclear Mater. Vol 125, 304 (1984).
- DOE-HTGR-86024, Rev. 13, Preliminary Safety Information Document for the Standard MHTGR, September 1992.
- DOE-HTGR-86-011, Rev. 3, Vol. 1 &2, Probabilistic Risk Assessment for the Standard Modular High Temperature Gas-Cooled Reactor .
- DOE-HTGR-88552, *COMEDIE BD-1 Test Evaluation Report*, W. Medwid and A. Gillespie, General Atomics, 1993.
- DOE-HTGR-90229, Rev. 0, 450 MWt MHTGR Safety Consequence Assessment, September 1991.
- DOE- GT-MHR-100230, GT-MHR Preliminary Safety Assessment Report, September 1994.

- Grover, S.B. et al., “Mission and Status of the First Two Next Generation Nuclear Plant Fuel Irradiation Experiments in the Advanced Test Reactor,” Proceedings of the 18th International Conference of Nuclear Engineering, Xian China, May 17-20, 2010.
- Hanson, D.L., “NGNP Contamination Control Study,” GA Document 911117, Rev. 0, General Atomics, April 2008.
- Hanson, D.L., “Reconciliation of NGNP DDNs with NRC PIRTs,” GA Document PC-000570, Rev. 0, General Atomics, September 2008.
- Hanson, D.L., “Logic for Deriving Fuel Quality Specifications,” GA Document PC-00049810, Rev. 0, General Atomics, March 2001.
- Hanson, D. L., “Technical Basis for NGNP Fuel Performance and Quality Requirements,” GA Document 911168, Rev. 0, General Atomics, September 2009.
- NGNP-IN-RPT-001, NGNP and Hydrogen Production Preconceptual Design Report, May 2007.
- NGNP-NHS 50-CC, NGNP and Hydrogen Production Preconceptual Design Study, May 2008.
- NGNP-PLD-GEN-RPT-N-0007, NGNP: Plant Level Assessments Leading to Fission Product Retention Allocations, October 2009.
- Minato K., et al., “Fission Product Release Behavior of Individual Coated Fuel Particles for High Temperature Gas Cooled Reactors,” Nuclear Technology, Vol 131, 36 (2000).
- Petti, D.A., et al., “Key differences in the Fabrication, Irradiation, and Safety Testing of U.S. and German TRISO-coated Particle Fuel and their Implications on Fuel Performance,” INL/EXT-02-00300, April 2002.
- TECDOC-978, Fuel Performance and Fission Product Behavior in Gas Cooled Reactors, International Atomic Energy Agency, November 1997.

A-1. Agenda



Expert Panel Scoping Analysis - Offsite Dose Analysis

September 7-8, 2011

AmeriTel Inn, 645 Lindsay Boulevard, Idaho Falls, Idaho

Attire: Business Casual

Wednesday, September 7

- | | | |
|-------|--|--------------------------|
| 8:00 | Meeting Kickoff | David Petti
Tom Hicks |
| 8:15 | Confirm list of accidents to be evaluated – list previously distributed to panel for comment | Pete Lowry |
| 10:00 | <i>Break</i> | |
| 10:15 | Establish the initial set of key parameters (including assumed design and environmental conditions) for selected accidents to include core size, radionuclides to be modeled, initial inventory assumptions (core, circulating, plateout and dust) | Pete Lowry |
| 11:30 | <i>Lunch</i> | <i>No host</i> |
| 1:00 | Continue discussion of initial set of key parameters and algorithm to be used | Pete Lowry |
| 2:00 | Develop input assumptions for the performance of each of the barriers presented in the MST paper | David Petti |
| 3:00 | <i>Break</i> | |
| 3:15 | Continue discussion of input assumptions for barrier performance | David Petti |
| 5:00 | Wrap up and adjourn | David Petti
Tom Hicks |

Meeting Chair: Pete Lowry

Thursday, September 8

- | | | |
|-------|---|--------------------------|
| 8:00 | Assess the impacts of applicable parameters for each event, e.g., release duration (break size), release point-elevation, and impacts of dust, air and water (chemical attack) on the barrier performance | David Petti |
| 10:00 | <i>Break</i> | |
| 10:15 | Continue discussion of impacts of applicable parameters | David Petti |
| 11:30 | <i>Lunch</i> | <i>No host</i> |
| 1:00 | Development of uncertainty ranges for each of the key parameters | David Petti |
| 3:00 | <i>Break</i> | |
| 3:15 | Continue discussion of uncertainty ranges | David Petti |
| 4:00 | Wrap up and adjourn | David Petti
Tom Hicks |

Summary of Proposed “DBA” Events to be Considered

Event Category	Summary of Event (Reference)
Loss of forced circulation with depressurization	<p>Large Break (AREVA 7.2.1) Primary System is voided within minutes at a maximum depressurization rate of 0.8 bar/s [11 psi/s]. SCRAM occurs after ~10 sec, pressure drops from 60 BAR [870 psi,] to 55 BAR [800 psi]. Response of internal pressure equalization system 70 sec, pressure drops to ~25 BAR [362 psi].</p> <p>Assumed break occurs in the outlet line to the helium purification system at the steam generator pressure vessel.</p> <p>Desorption leads to the release from the primary system of approximately 3 times the steady-state coolant activity until pressure equalization is reached.</p> <p>Primary system surface activity, design values for 32 equivalent-power years. 1 kg of dust taken up by the primary coolant from dead flow zones during blowdown and is subsequently released from the primary system. For long-lived radionuclides, the specific activity of this dust is equivalent to the specific activity of the graphite on the surfaces of the fuel elements.</p>
Loss of forced circulation with depressurization	<p>Pressure Relief with Subsequent Core Heat-up (AREVA 7.2.2) Reactor is depressurized while in long-term steady-state operation with a cold gas temperature of 280°C and at 105% of nominal power. Peak core temperature of ~1522°C is reached after 30 hrs. The max heat flux at the cavity cooler is ~720 kW.</p>
Rupture with air ingress	<p>Primary Coolant Leak without HTS and SCS Cooling (PSID 15.12) Leak, 0.32 sq cm area, near the top of the reactor vessel. Primary coolant pressure decreases below about 2.93 Mpa [425 psi] at 5300 seconds. At the time of HTS and SCS failure pressure conditions of 0.155 Mpa [22 psi] exist.</p> <p>Maximum fuel temperature reaches a peak of 1533°C approximately 120 hours after the initiating event.</p> <p>During hydrostatic displacement 172 kg of air enters and 0.005 percent of graphite mass in the core is oxidized. Complete consumption of the oxygen in the air is assumed. During thermal contraction 95 kg of additional air is ingressed, oxidizing another 0.003 percent of graphite mass in the core.</p> <p>Fission products are released from two sources: the primary coolant circulating activity and the fuel body activity.</p>

Event Category	Summary of Event (Reference)
Water Ingress Events	<p>Steam Generator Tube Ruptures (AREVA 7.2.4, PSID 15.7-15.10) Leak rates range from: 0.05 kg/s to 5.7 kg/s (can be up to 27.2 kg/s within the first few seconds). Total inleakage ranges from: 18.1 kg to 841 kg.</p> <p>Burnoff for bottom reflector blocks range from: 8E-05 to 8E-04 weight fraction. Burnoff for hot channel ranges from: 3E-04 to 6.1E-03.</p> <p>Steam reaction with fuel and hot graphite structure forms a water gas fraction around 9%, which is not flammable in any mixture with air.</p> <p>Mechanisms for release: hydrolysis of UCO particles having failed coatings, liberation of sorbed fission products in the bulk moderator graphite which is oxidized, diffusion (due to elevated temperatures) of fission products out of fuel particles that have failed, or steam-induced vaporization and recirculation of fission products plated out on metallic surfaces.</p>
Reactivity events	<p>Control Rod Withdrawal without HTS and SCS cooling (PSID 15.5) Peak fuel temperature 1394°C. Max core temperature peaks at approximately 1307°C. System pressure peaks at 1016 psia. The gaseous fission products, including halogens, are released directly to the reactor vessel without significant attenuation by the fuel rod matrix graphite and fuel element graphite. Metallic fission products released from the fuel particles are delayed by adsorption and slow diffusion through the fuel rod matrix and the fuel element graphite. This accident will result in the release of some fission products to the primary coolant from failed fuel.</p> <p>The primary coolant remains pressurized and the primary coolant boundary integrity remains intact, there is no release from the vessel, no release from the Reactor Building, and no offsite dose.</p>
Loss of forced circulation - Pressurized	<p>Control Rod Withdrawal without HTS and SCS cooling (PSID 15.5) Peak fuel temperature 1394°C. Max core temperature peaks at approximately 1307°C. System pressure peaks at 1016 psia. The gaseous fission products, including halogens, are released directly to the reactor vessel without significant attenuation by the fuel rod matrix graphite and fuel element graphite. Metallic fission products released from the fuel particles are delayed by adsorption and slow diffusion through the fuel rod matrix and the fuel element graphite. This accident will result in the release of some fission products to the primary coolant from failed fuel.</p> <p>The primary coolant remains pressurized and the primary coolant boundary integrity remains intact, there is no release from the vessel, no release from the Reactor Building, and no offsite dose.</p>

Initial radionuclide inventory and other conditions to be established for all events.

Core Inventory (Fuel):
Inventory sorbed in Graphite (Core)

Circulating Inventory (HPB)
Plateout (assumed on HPB piping)
Inventory in Dust (HPB)

Review of Radionuclides to be modeled. (Does Ingestion and Contamination drive consideration of additional nuclides?)

Overview of project scope and purpose:

As an output of recent discussions on NGNP R&D needs, including the need for in-pile loop testing, it was concluded that an expert review process be used to establish defensible and target values for the radionuclide transfer factors for the input assumptions to develop the mechanistic source term used in the simplified parametric dose analysis model. The results of this modeling will assist in determining where the NGNP Project is in establishing parameters that will meet Project objectives related to protection of public health and safety. Key principals of these objectives believed to significantly impact the need for R&D information include:

- Development of a HTGR safety basis that protects the health and safety of the public and the environment with the objective that under no projected accident condition are evacuation or sheltering required nor will the food and water supplies be adversely impacted by radionuclide contamination.
- Meeting EPA PAGs at the Plant EAB. This includes a goal of meeting the Ingestion Pathway PAG (if reasonably achievable).
- Quantification of the risk of contamination and demonstration of the ability to reduce this risk via measures (including prevention and mitigation) acceptable to both the end user and reactor owner/operator. (A concern of potential end users is that an accident in the HTGR plant would contaminate the co-located facility rendering it indefinitely un-usable.)

As more analysis and testing are completed under the NGNP R&D Program these values will be revised as necessary.

As a separate subgroup to this panel, a review of the approach for modeling radionuclide transport outside of RB will be included.

As a follow-on activity, the expert panel will review the results of the calculations supporting the assessment the dose and contamination levels associated with above.

A-2. Formulas Used in Dose Evaluation Model

Using these inputs and the 50% and 95% upper bound barrier performance characteristics developed in this appendix, the mechanistic source terms (releases) are calculated consistent with the simplified equations presented herein:

where:

DF: decontamination factor; (attenuation factor)

DR: diffusive release through coating;

G: graphite;

HMC: heavy metal contamination;

i: radionuclide index;

IF: incremental failure under accident;

Inv: Inventory;

FP: Fission Product

ISF: in-service failure;

K: fuel kernel;

LO: Lift Off –HPB;

LT: long term;

HPB: helium pressure boundary;

RB: reactor building;

ST: short term.

Normal Operations Release

$$= \text{Normal Ops HMC} + \text{Normal Ops SiC Defect} + \text{Normal Ops In-Service Failure}$$

Normal Operations HMC

$$= \text{Inv}_i \cdot \frac{FP_{i,HMC}}{DF_{i,HMC} \cdot DF_{i,G}}$$

Normal Operations SiC

$$= \text{Inv}_i \cdot \frac{FP_{i,ISF}}{DF_{i,K} \cdot DF_{i,G}}$$

Normal Operations In-Service Failure

$$= \text{Inv}_i \cdot \frac{1}{DF_{i,K} \cdot DF_{i,DR} \cdot DF_{i,G}}$$

Release to Environment Short Term

$$= \frac{\left(\text{Normal Ops}_{\text{Circulating NGs}} + \frac{\text{Normal Ops}_{\text{Plateout}}}{\text{Liftoff}_{\text{HPB}}} \right)}{\text{Decontamination Factor}_{\text{RB}}}$$

Release to Environment Long Term

$$= \frac{\text{Accident Release from Fuel to HPB} + \text{Accident Release from Graphite}}{\text{Decontamination Factor}_{\text{HPB}} \times \text{Decontamination Factor}_{\text{RB}}}$$

$$= \frac{\left(\text{Inv}_i \cdot \left(\frac{FP_{i,LT,HMC}}{DF_{i,LT,HMC}} + \frac{FP_{i,LT,ISF}}{DF_{i,LT,NINT}} + \frac{FP_{i,LT,IF}}{DF_{i,LT,NINT}} + \frac{1}{DF_{i,LT,INT}} \right) \cdot DF_{i,LT,G}^{-1} + \frac{\text{Normal Ops Graphite}}{DF_{i,LT,G}} \right)}{(DF_{LT,HPB} \times DF_{LT,RB})}$$

A-3. Inventory Assumptions

The following inventory assumptions and inputs were used to develop the source term.

Fission Product Class	Characteristic Nuclide	Half-Life Days	Decay Constant ^a	Inventory-600MW ^{b,c}
Noble Gases	Xe-133	5.29	1.52E-06	3.63E+07
	Kr-85	3916.45	2.05E-09	1.90E+05
	Kr-88	0.116667	6.88E-05	1.85E+07
I, Br, Te, Se	I-131	8.04	9.98E-07	2.00E+07
	I-133	0.866667	9.26E-06	3.60E+07
	Te-132	3.25	2.47E-06	2.71E+07
Cs, Rb	Cs-137	10986.5	7.30E-10	1.69E+06
	Cs-134	751.9	1.07E-08	1.90E+06
Sr, Ba, Eu	Sr-90	10585	7.58E-10	1.69E+06
Ag, Pd	Ag-110m	252	3.18E-08	2.81E+04
	Ag-111	7.47	1.07E-06	2.96E+06
Sb	Sb-125	996.45	8.05E-09	2.35E+05
Mo, Ru, Rh, Tc	Ru-103	39.6	2.03E-07	3.61E+07
La, Ce groups	Ce-144	103660	7.74E-11	2.33E+07
	La-140	1.675	4.79E-06	3.27E+07
Pu, actinides	Pu-239	8800150	9.12E-13	4.66E+03

a. Decay constant (λ) from http://users.ictp.it/~pub_off/lectures/Ins020/Nichols/Nichols.pdf

b. Inventory based on 91117 Rev 0 *NGNP Contamination Control Study*, General Atomics, 2008

c. Plutonium inventory from General Atomics (350 MW).

A-4. Release Fractions And Attenuation Factors

A-4.1 600 MW(t) Prismatic 700°C

A-4.1.1 Normal Operations

Table A-1. 600 MW(t) prismatic 700°C ROT—normal operations—release fractions and attenuation factors.

Nuclide	Sources of Fission Product Release						Barriers to Fission Product Release (Attenuation Factors)							
	Fract. HM Contamination		Fraction SiC Defects		In-Service Failure		Heavy Metal Contamination		Kernel		Diffusive Release thru coating		Graphite	
	50%	95%	50%	95%	50%	95%	50%	95%	50%	95%	50%	95%	50%	95%
Xe-133	1E-05	2E-05	NA	NA	7E-06	2E-05	10	3	50	17	1E+08	1E+07	1	1
Kr-85	1E-05	2E-05	NA	NA	7E-06	2E-05	10	3	50	17	1E+08	1E+07	1	1
Kr-88	1E-05	2E-05	NA	NA	7E-06	2E-05	10	3	50	17	1E+08	1E+07	1	1
I-131	1E-05	2E-05	NA	NA	7E-06	2E-05	10	3	50	17	1E+08	1E+07	1	1
I-133	1E-05	2E-05	NA	NA	7E-06	2E-05	10	3	50	17	1E+08	1E+07	1	1
Te-132	1E-05	2E-05	NA	NA	7E-06	2E-05	10	3	50	17	1E+08	1E+07	1	1
Cs-137	1E-05	2E-05	1E-05	3E-05	7E-06	2E-05	1	1	3	1	1E+08	1E+06	5	2
Cs-134	1E-05	2E-05	1E-05	3E-05	7E-06	2E-05	1	1	3	1	1E+08	1E+06	5	2
Sr-90	1E-05	2E-05	1E-05	3E-05	7E-06	2E-05	1	1	50	20	1000	200	1000	300
Ag-110m	1E-05	2E-05	1E-05	3E-05	7E-06	2E-05	1	1	2	1	500	100	2	1
Ag-111	1E-05	2E-05	1E-05	3E-05	7E-06	2E-05	1	1	2	1	500	100	2	1
Sb-125	1E-05	2E-05	1E-05	3E-05	7E-06	2E-05	1	1	2	1	1E+08	1E+06	20	2
Ru-103	1E-05	2E-05	1E-05	3E-05	7E-06	2E-05	1	1	500	30	1E+08	1E+07	1000	300
Ce-144	1E-05	2E-05	1E-05	3E-05	7E-06	2E-05	1	1	500	30	1E+08	1E+07	1000	300
La-140	1E-05	2E-05	1E-05	3E-05	7E-06	2E-05	1	1	500	30	1E+08	1E+07	1000	300
Pu-239	1E-05	2E-05	1E-05	3E-05	7E-06	2E-05	1	1	1000	100	1E+08	1E+07	1E+04	1000

A-4.1.2 Accident Scenario: Break in Helium Pressure Boundary

Table A-2. 600 MW(t) prismatic 700°C ROT— break in HPB—short term attenuation factors.

Nuclide	Short Term Barriers to Fission Product Release (Attenuation Factors)			
	Accident – HPB		Accident – Reactor Building	
	DF 50%	DF 95%	DF 50%	DF 95%
Xe-133	1	1	1	1
Kr-85	1	1	1	1
Kr-88	1	1	1	1
I-131	200	20	2	1
I-133	200	20	2	1
Te-132	200	20	2	1
Cs-137	200	20	2	1
Cs-134	200	20	2	1
Sr-90	200	20	2	1
Ag-110m	200	20	2	1
Ag-111	200	20	2	1
Sb-125	200	20	2	1
Ru-103	200	20	2	1
Ce-144	200	20	2	1
La-140	200	20	2	1
Pu-239	200	20	2	1

Table A-3. 600 MW(t) prismatic 700°C ROT— break in HPB—long term release fractions and attenuation factors.

Nuclide	Sources of Fission Product Release						Barriers to Fission Product Release (Attenuation Factors)											
	Fract. HM Contamination		Non-Intact (In-service failure)		Incremental Failure – Accidents		HM Accident Release		Non-intact Accident Release		Intact Accident Release		Accident – Graphite		Accident – HPB		Accident – Reactor Building	
	50%	95%	50%	95%	50%	95%	DF 50%	DF 95%	DF 50%	DF 95%	DF 50%	DF 95%	DF 50%	DF 95%	DF 50%	DF 95%	DF 50%	DF 95%
Xe-133	1E-05	2E-05	7E-06	2E-05	3E-05	8E-05	2	1	10	5	1E+07	2E+06	1	1	5	2	1	1
Kr-85	1E-05	2E-05	7E-06	2E-05	3E-05	8E-05	2	1	10	5	1E+07	2E+06	1	1	5	2	1	1
Kr-88	1E-05	2E-05	7E-06	2E-05	3E-05	8E-05	2	1	10	5	1E+07	2E+06	1	1	5	2	1	1
I-131	1E-05	2E-05	7E-06	2E-05	3E-05	8E-05	2	1	10	5	1E+07	2E+06	1	1	5	2	10	2
I-133	1E-05	2E-05	7E-06	2E-05	3E-05	8E-05	2	1	10	5	1E+07	2E+06	1	1	5	2	10	2
Te-132	1E-05	2E-05	7E-06	2E-05	3E-05	8E-05	2	1	10	5	1E+07	2E+06	1	1	5	2	10	2
Cs-137	1E-05	2E-05	1.7E-05	5E-05	3E-05	8E-05	1	1	1	1	1E+07	2E+06	10	3	10	3	10	2
Cs-134	1E-05	2E-05	1.7E-05	5E-05	3E-05	8E-05	1	1	1	1	1E+07	2E+06	10	3	10	3	10	2
Sr-90	1E-05	2E-05	1.7E-05	5E-05	3E-05	8E-05	1	1	1	1	1E+06	2E+05	100	30	10	3	10	2
Ag-110m	1E-05	2E-05	1.7E-05	5E-05	3E-05	8E-05	1	1	1	1	5E+02	1E+02	1	1	10	3	10	2
Ag-111	1E-05	2E-05	1.7E-05	5E-05	3E-05	8E-05	1	1	1	1	5E+02	1E+02	1	1	10	3	10	2
Sb-125	1E-05	2E-05	1.7E-05	5E-05	3E-05	8E-05	1	1	1	1	1E+06	2E+05	100	30	10	3	10	2
Ru-103	1E-05	2E-05	1.7E-05	5E-05	3E-05	8E-05	1	1	100	50	1E+07	2E+06	10	3	10	3	10	2
Ce-144	1E-05	2E-05	1.7E-05	5E-05	3E-05	8E-05	1	1	100	50	1E+07	2E+06	100	30	10	3	10	2
La-140	1E-05	2E-05	1.7E-05	5E-05	3E-05	8E-05	1	1	100	50	1E+07	2E+06	100	30	10	3	10	2
Pu-239	1E-05	2E-05	1.7E-05	5E-05	3E-05	8E-05	1	1	1000	500	1E+07	2E+06	1000	300	10	3	10	2

A-4.1.3 Accident Scenario: Water Ingress

Table A-4. 600 MW(t) prismatic 700°C ROT—water ingress—short term attenuation factors.

Nuclide	Short Term Barriers to Fission Product Release (Attenuation Factors)			
	Accident – HPB		Accident – Reactor Building	
	DF 50%	DF 95%	DF 50%	DF 95%
Xe-133	1	1	1	1
Kr-85	1	1	1	1
Kr-88	1	1	1	1
I-131	2	1	10	2
I-133	2	1	10	2
Te-132	2	1	10	2
Cs-137	2	1	10	2
Cs-134	2	1	10	2
Sr-90	2	1	10	2
Ag-110m	2	1	10	2
Ag-111	2	1	10	2
Sb-125	2	1	10	2
Ru-103	2	1	10	2
Ce-144	2	1	10	2
La-140	2	1	10	2
Pu-239	2	1	10	2

Table A-5. 600 MW(t) prismatic 700°C ROT—water ingress—long term release fractions and attenuation factors.

Nuclide	Sources of Fission Product Release						Barriers to Fission Product Release (Attenuation Factors)											
	Fract. HM Contamination		Non-Intact (In-service failure)		Incremental Failure – Accidents		HM Accident Release		Non-intact Accident Release		Intact Accident Release		Accident – Graphite		Accident – HPB		Accident – Reactor Building	
	50%	95%	50%	95%	50%	95%	DF 50%	DF 95%	DF 50%	DF 95%	DF 50%	DF 95%	DF 50%	DF 95%	DF 50%	DF 95%	DF 50%	DF 95%
Xe-133	1E-05	2E-05	7E-06	2E-05	3E-05	2E-04	1	1	5	3.33	1E+07	2E+06	1	1	5	2	1	1
Kr-85	1E-05	2E-05	7E-06	2E-05	3E-05	2E-04	1	1	5	3.33	1E+07	2E+06	1	1	5	2	1	1
Kr-88	1E-05	2E-05	7E-06	2E-05	3E-05	2E-04	1	1	5	3.33	1E+07	2E+06	1	1	5	2	1	1
I-131	1E-05	2E-05	7E-06	2E-05	3E-05	2E-04	1	1	5	3.33	1E+07	2E+06	1	1	2	1	50	10
I-133	1E-05	2E-05	7E-06	2E-05	3E-05	2E-04	1	1	5	3.33	1E+07	2E+06	1	1	2	1	50	10
Te-132	1E-05	2E-05	7E-06	2E-05	3E-05	2E-04	1	1	5	3.33	1E+07	2E+06	1	1	2	1	50	10
Cs-137	1E-05	2E-05	1.7E-05	5E-05	3E-05	2E-04	1	1	1	1	1E+07	2E+06	5	2	2	1	50	10
Cs-134	1E-05	2E-05	1.7E-05	5E-05	3E-05	2E-04	1	1	1	1	1E+07	2E+06	5	2	2	1	50	10
Sr-90	1E-05	2E-05	1.7E-05	5E-05	3E-05	2E-04	1	1	1	1	1E+06	2E+05	50	10	2	1	50	10
Ag-110m	1E-05	2E-05	1.7E-05	5E-05	3E-05	2E-04	1	1	1	1	5E+02	1E+02	1	1	2	1	50	10
Ag-111	1E-05	2E-05	1.7E-05	5E-05	3E-05	2E-04	1	1	1	1	5E+02	1E+02	1	1	2	1	50	10
Sb-125	1E-05	2E-05	1.7E-05	5E-05	3E-05	2E-04	1	1	1	1	1E+06	2E+05	100	30	2	1	50	10
Ru-103	1E-05	2E-05	1.7E-05	5E-05	3E-05	2E-04	1	1	100	50	1E+07	2E+06	10	3	2	1	50	10
Ce-144	1E-05	2E-05	1.7E-05	5E-05	3E-05	2E-04	1	1	100	50	1E+07	2E+06	100	30	2	1	50	10
La-140	1E-05	2E-05	1.7E-05	5E-05	3E-05	2E-04	1	1	100	50	1E+07	2E+06	100	30	2	1	50	10
Pu-239	1E-05	2E-05	1.7E-05	5E-05	3E-05	2E-04	1	1	1000	500	1E+07	2E+06	1000	300	2	1	50	10

A-4.2 600 MW(t) Prismatic 900°C

A-4.2.1 Normal Operations

Table A-6. 600 MW(t) prismatic 900°C ROT—normal operations—release fractions and attenuation factors.

Nuclide	Sources of Fission Product Release						Barriers to Fission Product Release (Attenuation Factors)							
	Fract. HM Contamination		Fraction SiC Defects		In-Service Failure		Heavy Metal Contamination		Kernel		Diffusive Release thru coating		Graphite	
	50%	95%	50%	95%	50%	95%	50%	95%	50%	95%	50%	95%	50%	95%
Xe-133	1E-05	2E-05	NA	NA	1.4E-05	7E-05	5	1.5	25	8.33	5E+07	5E+06	1	1
Kr-85	1E-05	2E-05	NA	NA	1.4E-05	7E-05	5	1.5	25	8.33	5E+07	5E+06	1	1
Kr-88	1E-05	2E-05	NA	NA	1.4E-05	7E-05	5	1.5	25	8.33	5E+07	5E+06	1	1
I-131	1E-05	2E-05	NA	NA	1.4E-05	7E-05	5	1.5	25	8.33	5E+07	5E+06	1	1
I-133	1E-05	2E-05	NA	NA	1.4E-05	7E-05	5	1.5	25	8.33	5E+07	5E+06	1	1
Te-132	1E-05	2E-05	NA	NA	1.4E-05	7E-05	5	1.5	25	8.33	5E+07	5E+06	1	1
Cs-137	1E-05	2E-05	1E-05	3E-05	2.1E-04	1.05E-03	1	1	1.2	1	1E+07	1E+05	2	1
Cs-134	1E-05	2E-05	1E-05	3E-05	2.1E-04	1.05E-03	1	1	1.2	1	1E+07	1E+05	2	1
Sr-90	1E-05	2E-05	1E-05	3E-05	2.1E-04	1.05E-03	1	1	3	1	500	100	100	30
Ag-110m	1E-05	2E-05	1E-05	3E-05	2.1E-04	1.05E-03	1	1	1	1	200	40	1	1
Ag-111	1E-05	2E-05	1E-05	3E-05	2.1E-04	1.05E-03	1	1	1	1	200	40	1	1
Sb-125	1E-05	2E-05	1E-05	3E-05	2.1E-04	1.05E-03	1	1	1	1	5E+07	5E+05	5	1
Ru-103	1E-05	2E-05	1E-05	3E-05	2.1E-04	1.05E-03	1	1	250	15	1E+07	1E+06	200	60
Ce-144	1E-05	2E-05	1E-05	3E-05	2.1E-04	1.05E-03	1	1	250	15	1E+07	1E+06	200	60
La-140	1E-05	2E-05	1E-05	3E-05	2.1E-04	1.05E-03	1	1	250	15	1E+07	1E+06	200	60
Pu-239	1E-05	2E-05	1E-05	3E-05	2.1E-04	1.05E-03	1	1	500	50	1E+07	1E+06	5E+03	500

A-4.2.2 Accident Scenario: Break in Helium Pressure Boundary

Table A-7. 600 MW(t) prismatic 900°C ROT— break in HPB—short term attenuation factors.

Nuclide	Short Term Barriers to Fission Product Release (Attenuation Factors)			
	Accident – HPB		Accident – Reactor Building	
	DF 50%	DF 95%	DF 50%	DF 95%
Xe-133	1	1	1	1
Kr-85	1	1	1	1
Kr-88	1	1	1	1
I-131	200	20	2	1
I-133	200	20	2	1
Te-132	200	20	2	1
Cs-137	200	20	2	1
Cs-134	200	20	2	1
Sr-90	200	20	2	1
Ag-110m	200	20	2	1
Ag-111	200	20	2	1
Sb-125	200	20	2	1
Ru-103	200	20	2	1
Ce-144	200	20	2	1
La-140	200	20	2	1
Pu-239	200	20	2	1

Table A-8. 600 MW(t) prismatic 900°C ROT— break in HPB—long term release fractions and attenuation factors.

Nuclide	Sources of Fission Product Release						Barriers to Fission Product Release (Attenuation Factors)											
	Fract. HM Contamination		Non-Intact (In-service failure)		Incremental Failure – Accidents		HM Accident Release		Non-intact Accident Release		Intact Accident Release		Accident – Graphite		Accident – HPB		Accident – Reactor Building	
	50%	95%	50%	95%	50%	95%	DF 50%	DF 95%	DF 50%	DF 95%	DF 50%	DF 95%	DF 50%	DF 95%	DF 50%	DF 95%	DF 50%	DF 95%
Xe-133	1E-05	2E-05	1.4E-05	7E-05	3E-05	8E-05	2	1	10	5	1E+07	2E+06	1	1	5	2	1	1
Kr-85	1E-05	2E-05	1.4E-05	7E-05	3E-05	8E-05	2	1	10	5	1E+07	2E+06	1	1	5	2	1	1
Kr-88	1E-05	2E-05	1.4E-05	7E-05	3E-05	8E-05	2	1	10	5	1E+07	2E+06	1	1	5	2	1	1
I-131	1E-05	2E-05	1.4E-05	7E-05	3E-05	8E-05	2	1	10	5	1E+07	2E+06	1	1	5	2	10	2
I-133	1E-05	2E-05	1.4E-05	7E-05	3E-05	8E-05	2	1	10	5	1E+07	2E+06	1	1	5	2	10	2
Te-132	1E-05	2E-05	1.4E-05	7E-05	3E-05	8E-05	2	1	10	5	1E+07	2E+06	1	1	5	2	10	2
Cs-137	1E-05	2E-05	2.2E-04	1.08E-03	3E-05	8E-05	1	1	1	1	1E+07	2E+06	10	3	10	3	10	2
Cs-134	1E-05	2E-05	2.2E-04	1.08E-03	3E-05	8E-05	1	1	1	1	1E+07	2E+06	10	3	10	3	10	2
Sr-90	1E-05	2E-05	2.2E-04	1.08E-03	3E-05	8E-05	1	1	1	1	1E+06	2E+05	100	30	10	3	10	2
Ag-110m	1E-05	2E-05	2.2E-04	1.08E-03	3E-05	8E-05	1	1	1	1	5E+02	1E+02	1	1	10	3	10	2
Ag-111	1E-05	2E-05	2.2E-04	1.08E-03	3E-05	8E-05	1	1	1	1	5E+02	1E+02	1	1	10	3	10	2
Sb-125	1E-05	2E-05	2.2E-04	1.08E-03	3E-05	8E-05	1	1	1	1	1E+06	2E+05	100	30	10	3	10	2
Ru-103	1E-05	2E-05	2.2E-04	1.08E-03	3E-05	8E-05	1	1	100	50	1E+07	2E+06	10	3	10	3	10	2
Ce-144	1E-05	2E-05	2.2E-04	1.08E-03	3E-05	8E-05	1	1	100	50	1E+07	2E+06	100	30	10	3	10	2
La-140	1E-05	2E-05	2.2E-04	1.08E-03	3E-05	8E-05	1	1	100	50	1E+07	2E+06	100	30	10	3	10	2
Pu-239	1E-05	2E-05	2.2E-04	1.08E-03	3E-05	8E-05	1	1	1000	500	1E+07	2E+06	1000	300	10	3	10	2

A-4.3 250 MW(t) Pebble Bed 700°C

A-4.3.1 Normal Operations

Table A-9. 250 MW(t) pebble bed 700°C ROT—normal operations—release fractions and attenuation factors.

Nuclide	Sources of Fission Product Release						Barriers to Fission Product Release (Attenuation Factors)							
	Fract. HM Contamination		Fraction SiC Defects		In-Service Failure		Heavy Metal Contamination		Kernel		Diffusive Release thru coating		Graphite	
	50%	95%	50%	95%	50%	95%	50%	95%	50%	95%	50%	95%	50%	95%
Xe-133	1E-05	2E-05	NA	NA	7E-06	2E-05	15	4.5	75	25.5	1E+06	1E+05	1	1
Kr-85	1E-05	2E-05	NA	NA	7E-06	2E-05	15	4.5	75	25.5	1E+06	1E+05	1	1
Kr-88	1E-05	2E-05	NA	NA	7E-06	2E-05	15	4.5	75	25.5	1E+06	1E+05	1	1
I-131	1E-05	2E-05	NA	NA	7E-06	2E-05	15	4.5	75	25.5	1E+06	1E+05	1	1
I-133	1E-05	2E-05	NA	NA	7E-06	2E-05	15	4.5	75	25.5	1E+06	1E+05	1	1
Te-132	1E-05	2E-05	NA	NA	7E-06	2E-05	15	4.5	75	25.5	1E+06	1E+05	1	1
Cs-137	1E-05	2E-05	1E-05	3E-05	7E-06	2E-05	1	1	20	8	1E+06	1E+04	5	1
Cs-134	1E-05	2E-05	1E-05	3E-05	7E-06	2E-05	1	1	20	8	1E+06	1E+04	5	1
Sr-90	1E-05	2E-05	1E-05	3E-05	7E-06	2E-05	1	1	200	80	800	200	50	15
Ag-110m	1E-05	2E-05	1E-05	3E-05	7E-06	2E-05	1	1	8	4	40	4	1	1
Ag-111	1E-05	2E-05	1E-05	3E-05	7E-06	2E-05	1	1	8	4	40	4	1	1
Sb-125	1E-05	2E-05	1E-05	3E-05	7E-06	2E-05	1	1	8	4	1E+06	1E+04	10	1
Ru-103	1E-05	2E-05	1E-05	3E-05	7E-06	2E-05	1	1	2000	120	1E+06	1E+05	100	30
Ce-144	1E-05	2E-05	1E-05	3E-05	7E-06	2E-05	1	1	2000	120	1E+06	1E+05	100	30
La-140	1E-05	2E-05	1E-05	3E-05	7E-06	2E-05	1	1	2000	120	1E+06	1E+05	100	30
Pu-239	1E-05	2E-05	1E-05	3E-05	7E-06	2E-05	1	1	4000	400	1E+06	1E+05	1000	100

A-4.3.2 Accident Scenario: Break in Helium Pressure Boundary

Table A-10. 250 MW(t) pebble bed 700°C ROT—break in HPB—short term attenuation factors.

Nuclide	Short Term Barriers to Fission Product Release (Attenuation Factors)			
	Accident – HPB		Accident – Reactor Building	
	DF 50%	DF 95%	DF 50%	DF 95%
Xe-133	1	1	1	1
Kr-85	1	1	1	1
Kr-88	1	1	1	1
I-131	200	20	2	1
I-133	200	20	2	1
Te-132	200	20	2	1
Cs-137	200	20	2	1
Cs-134	200	20	2	1
Sr-90	200	20	2	1
Ag-110m	200	20	2	1
Ag-111	200	20	2	1
Sb-125	200	20	2	1
Ru-103	200	20	2	1
Ce-144	200	20	2	1
La-140	200	20	2	1
Pu-239	200	20	2	1

Table A-11. 250 MW(t) pebble bed 700°C ROT— break in HPB—long term release fractions and attenuation factors.

Nuclide	Sources of Fission Product Release						Barriers to Fission Product Release (Attenuation Factors)												
	Fract. HM Contamination		Non-Intact (In-service failure)		Incremental Failure – Accidents		HM Accident Release		Non-intact Accident Release		Intact Accident Release		Accident – Graphite		Accident – HPB		Accident – Reactor Building		
	50%	95%	50%	95%	50%	95%	DF 50 %	DF 95 %	DF 50%	DF 95%	DF 50%	DF 95%	DF 50%	DF 95%	DF 50%	DF 95 %	DF 50%	DF 95 %	
Xe-133	1E-05	2E-05	7E-06	2E-05	3E-05	8E-05	2	1	10	5	1E+07	2E+06	1	1	5	2	1	1	
Kr-85	1E-05	2E-05	7E-06	2E-05	3E-05	8E-05	2	1	10	5	1E+07	2E+06	1	1	5	2	1	1	
Kr-88	1E-05	2E-05	7E-06	2E-05	3E-05	8E-05	2	1	10	5	1E+07	2E+06	1	1	5	2	1	1	
I-131	1E-05	2E-05	7E-06	2E-05	3E-05	8E-05	2	1	10	5	1E+07	2E+06	1	1	5	2	10	2	
I-133	1E-05	2E-05	7E-06	2E-05	3E-05	8E-05	2	1	10	5	1E+07	2E+06	1	1	5	2	10	2	
Te-132	1E-05	2E-05	7E-06	2E-05	3E-05	8E-05	2	1	10	5	1E+07	2E+06	1	1	5	2	10	2	
Cs-137	1E-05	2E-05	1.7E-05	5E-05	3E-05	8E-05	1	1	1	1	1E+07	2E+06	10	3	10	3	10	2	
Cs-134	1E-05	2E-05	1.7E-05	5E-05	3E-05	8E-05	1	1	1	1	1E+07	2E+06	10	3	10	3	10	2	
Sr-90	1E-05	2E-05	1.7E-05	5E-05	3E-05	8E-05	1	1	1	1	1E+06	2E+05	100	30	10	3	10	2	
Ag-110m	1E-05	2E-05	1.7E-05	5E-05	3E-05	8E-05	1	1	1	1	5E+02	1E+02	1	1	10	3	10	2	
Ag-111	1E-05	2E-05	1.7E-05	5E-05	3E-05	8E-05	1	1	1	1	5E+02	1E+02	1	1	10	3	10	2	
Sb-125	1E-05	2E-05	1.7E-05	5E-05	3E-05	8E-05	1	1	1	1	1E+06	2E+05	100	30	10	3	10	2	
Ru-103	1E-05	2E-05	1.7E-05	5E-05	3E-05	8E-05	1	1	100	50	1E+07	2E+06	10	3	10	3	10	2	
Ce-144	1E-05	2E-05	1.7E-05	5E-05	3E-05	8E-05	1	1	100	50	1E+07	2E+06	100	30	10	3	10	2	
La-140	1E-05	2E-05	1.7E-05	5E-05	3E-05	8E-05	1	1	100	50	1E+07	2E+06	100	30	10	3	10	2	
Pu-239	1E-05	2E-05	1.7E-05	5E-05	3E-05	8E-05	1	1	1000	500	1E+07	2E+06	1000	300	10	3	10	2	

A-4.3.3 Accident Scenario: Water Ingress

Table A-12. 250 MW(t) pebble bed 700°C ROT—water ingress—short term attenuation factors.

Nuclide	Barriers to Fission Product Release (Attenuation Factors)			
	Accident – HPB		Accident – Reactor Building	
	DF 50%	DF 95%	DF 50%	DF 95%
Xe-133	1	1	1	1
Kr-85	1	1	1	1
Kr-88	1	1	1	1
I-131	2	1	10	2
I-133	2	1	10	2
Te-132	2	1	10	2
Cs-137	2	1	10	2
Cs-134	2	1	10	2
Sr-90	2	1	10	2
Ag-110m	2	1	10	2
Ag-111	2	1	10	2
Sb-125	2	1	10	2
Ru-103	2	1	10	2
Ce-144	2	1	10	2
La-140	2	1	10	2
Pu-239	2	1	10	2

Table A-13. 250 MW(t) pebble bed 700°C ROT—water ingress—long term release fractions and attenuation factors.

Nuclide	Sources of Fission Product Release						Barriers to Fission Product Release (Attenuation Factors)											
	Fract. HM Contamination		Non-Intact (In-service failure)		Incremental Failure – Accidents		HM Accident Release		Non-intact Accident Release		Intact Accident Release		Accident – Graphite		Accident – HPB		Accident – Reactor Building	
	50%	95%	50%	95%	50%	95%	DF 50%	DF 95%	DF 50%	DF 95%	DF 50%	DF 95%	DF 50%	DF 95%	DF 50%	DF 95%	DF 50%	DF 95%
Xe-133	1E-05	2E-05	7E-06	2E-05	3E-05	2E-04	1	1	5	3.33	1E+07	2E+06	1	1	5	2	1	1
Kr-85	1E-05	2E-05	7E-06	2E-05	3E-05	2E-04	1	1	5	3.33	1E+07	2E+06	1	1	5	2	1	1
Kr-88	1E-05	2E-05	7E-06	2E-05	3E-05	2E-04	1	1	5	3.33	1E+07	2E+06	1	1	5	2	1	1
I-131	1E-05	2E-05	7E-06	2E-05	3E-05	2E-04	1	1	5	3.33	1E+07	2E+06	1	1	2	1	50	10
I-133	1E-05	2E-05	7E-06	2E-05	3E-05	2E-04	1	1	5	3.33	1E+07	2E+06	1	1	2	1	50	10
Te-132	1E-05	2E-05	7E-06	2E-05	3E-05	2E-04	1	1	5	3.33	1E+07	2E+06	1	1	2	1	50	10
Cs-137	1E-05	2E-05	1.7E-05	5E-05	3E-05	2E-04	1	1	1	1	1E+07	2E+06	5	2	2	1	50	10
Cs-134	1E-05	2E-05	1.7E-05	5E-05	3E-05	2E-04	1	1	1	1	1E+07	2E+06	5	2	2	1	50	10
Sr-90	1E-05	2E-05	1.7E-05	5E-05	3E-05	2E-04	1	1	1	1	1E+06	2E+05	50	10	2	1	50	10
Ag-110m	1E-05	2E-05	1.7E-05	5E-05	3E-05	2E-04	1	1	1	1	5E+02	1E+02	1	1	2	1	50	10
Ag-111	1E-05	2E-05	1.7E-05	5E-05	3E-05	2E-04	1	1	1	1	5E+02	1E+02	1	1	2	1	50	10
Sb-125	1E-05	2E-05	1.7E-05	5E-05	3E-05	2E-04	1	1	1	1	1E+06	2E+05	100	30	2	1	50	10
Ru-103	1E-05	2E-05	1.7E-05	5E-05	3E-05	2E-04	1	1	100	50	1E+07	2E+06	10	3	2	1	50	10
Ce-144	1E-05	2E-05	1.7E-05	5E-05	3E-05	2E-04	1	1	100	50	1E+07	2E+06	100	30	2	1	50	10
La-140	1E-05	2E-05	1.7E-05	5E-05	3E-05	2E-04	1	1	100	50	1E+07	2E+06	100	30	2	1	50	10
Pu-239	1E-05	2E-05	1.7E-05	5E-05	3E-05	2E-04	1	1	1000	500	1E+07	2E+06	1000	300	2	1	50	10

Appendix B

Dose Conversion Factors

Appendix B

Dose Conversion Factors

B-1. Dose Conversion Factors

Table B-1. Dose conversion factors—Cases A/B 400 meters (rem/curie).

Nuclide	Short Term DCF 95% Meteorology	Long Term DCF 95% Meteorology
Xe-133	4.67E-07	3.17E-07
Kr-85	3.91E-08	2.62E-08
Kr-88	3.05E-05	1.01E-05
I-131	2.00E-03	1.14E-03
I-133	3.07E-04	1.54E-04
Te-132	7.46E-04	5.17E-04
Cs-134	3.02E-03	1.94E-03
Cs-137	2.02E-03	1.20E-03
Sr-90	1.02E-02	8.97E-03
Ag-110m	5.04E-03	3.21E-03
Ag-111	3.03E-04	2.18E-04
Sb-125	2.08E-04	1.23E-04
Ru-103	5.16E-04	3.65E-04
Ce-144	2.00E-02	1.29E-02
La-140	5.16E-04	2.72E-04
Pu-239	1.15E+01	1.10E+01

Table B-2. Dose conversion factors—Case C (rem/curie).

Nuclide	Short Term DCF Mean Meteorology					Long Term DCF Mean Meteorology				
	400m	800m	1600m	3200m	8000m	400m	800m	1600m	3200m	8000m
Xe-133	1.87E-07	9.38E-08	4.37E-08	1.76E-08	4.50E-09	1.90E-07	9.71E-08	4.63E-08	1.88E-08	4.89E-09
Kr-85	1.43E-08	7.17E-09	3.35E-09	1.35E-09	3.49E-10	1.57E-08	8.05E-09	3.85E-09	1.57E-09	4.11E-10
Kr-88	1.36E-05	7.00E-06	3.23E-06	1.19E-06	2.21E-07	4.43E-06	2.29E-06	1.07E-06	3.97E-07	7.56E-08
I-131	6.18E-04	2.14E-04	7.39E-05	2.38E-05	5.08E-06	6.92E-04	2.40E-04	8.27E-05	2.67E-05	5.70E-06
I-133	1.19E-04	4.16E-05	1.45E-05	4.65E-06	9.63E-07	9.23E-05	3.23E-05	1.12E-05	3.63E-06	7.55E-07
Te-132	2.68E-04	9.50E-05	3.39E-05	1.15E-05	2.64E-06	2.82E-04	1.01E-04	3.63E-05	1.23E-05	2.81E-06
Cs-134	9.42E-04	3.28E-04	1.14E-04	3.73E-05	8.09E-06	1.09E-03	3.81E-04	1.33E-04	4.33E-05	9.42E-06
Cs-137	6.54E-04	2.28E-04	7.95E-05	2.59E-05	5.64E-06	7.59E-04	2.64E-04	9.22E-05	3.01E-05	6.55E-06
Sr-90	4.36E-03	1.51E-03	5.19E-04	1.67E-04	3.57E-05	5.20E-03	1.80E-03	6.18E-04	1.99E-04	4.25E-05
Ag-110m	1.64E-03	5.70E-04	1.99E-04	6.48E-05	1.41E-05	1.90E-03	6.61E-04	2.30E-04	7.51E-05	1.63E-05
Ag-111	1.13E-04	3.90E-05	1.34E-05	4.32E-06	9.18E-07	1.26E-04	4.37E-05	1.50E-05	4.84E-06	1.03E-06
Sb-125	6.65E-05	2.38E-05	8.54E-06	2.89E-06	6.54E-07	7.27E-05	2.60E-05	9.35E-06	3.17E-06	7.26E-07
Ru-103	1.93E-04	6.74E-05	2.36E-05	7.73E-06	1.69E-06	2.19E-04	7.67E-05	2.68E-05	8.81E-06	1.93E-06
Ce-144	6.81E-03	2.35E-03	8.10E-04	2.61E-04	5.57E-05	8.06E-03	2.79E-03	9.60E-04	3.09E-04	6.59E-05
La-140	1.64E-04	5.98E-05	2.17E-05	7.39E-06	1.65E-06	1.49E-04	5.43E-05	1.99E-05	6.80E-06	1.54E-06
Pu-239	5.61E+00	1.94E+00	6.68E-01	2.15E-01	4.59E-02	6.65E+00	2.30E+00	7.92E-01	2.55E-01	5.44E-02

Table B-3. Dose conversion factors—Case D (rem/curie).

Nuclide	Short Term DCF Mean Meteorology					Long Term DCF Mean Meteorology				
	400m	800m	1600m	3200m	8000m	400m	800m	1600m	3200m	8000m
I-131	1.96E-02	6.78E-03	2.33E-03	7.49E-04	1.59E-04	2.21E-02	7.63E-03	2.62E-03	8.43E-04	1.79E-04
I-133	3.23E-03	1.11E-03	3.78E-04	1.19E-04	2.41E-05	2.50E-03	8.58E-04	2.92E-04	9.23E-05	1.87E-05
Te-132	4.31E-03	1.49E-03	5.13E-04	1.65E-04	3.52E-05	4.58E-03	1.58E-03	5.46E-04	1.76E-04	3.72E-05

Table B-4. Dose conversion factors—Case E, infant, whole body (rem/curie).

Nuclide	Short Term DCF Mean Meteorology					Long Term DCF Mean Meteorology				
	400m	800m	1600m	3200m	8000m	400m	800m	1600m	3200m	8000m
Xe-133	—	—	—	—	—	—	—	—	—	—
Kr-85	—	—	—	—	—	—	—	—	—	—
Kr-88	—	—	—	—	—	—	—	—	—	—
I-131	2.32E-02	8.54E-03	3.11E-03	1.06E-03	2.54E-04	2.51E-02	9.35E-03	3.53E-03	1.27E-03	3.11E-04
I-133	9.97E-04	3.65E-04	1.32E-04	4.42E-05	1.02E-05	7.36E-04	2.73E-04	1.02E-04	3.63E-05	8.58E-06
Te-132	6.26E-05	2.30E-05	8.38E-06	2.84E-06	6.78E-07	6.27E-05	2.33E-05	8.82E-06	3.16E-06	7.70E-07
Cs-134	9.96E-03	3.66E-03	1.33E-03	4.55E-04	1.10E-04	1.13E-02	4.21E-03	1.59E-03	5.72E-04	1.41E-04
Cs-137	8.68E-03	3.19E-03	1.16E-03	3.97E-04	9.59E-05	9.87E-03	3.67E-03	1.39E-03	4.99E-04	1.23E-04
Sr-90	1.65E-02	6.06E-03	2.21E-03	7.52E-04	1.81E-04	1.88E-02	6.98E-03	2.63E-03	9.43E-04	2.32E-04
Ag-110m	1.90E-02	6.95E-03	2.53E-03	8.63E-04	2.08E-04	2.15E-02	8.00E-03	3.01E-03	1.08E-03	2.66E-04
Ag-111	3.34E-03	1.23E-03	4.48E-04	1.52E-04	3.66E-05	3.59E-03	1.34E-03	5.06E-04	1.82E-04	4.46E-05
Sb-125	8.97E-05	3.28E-05	1.19E-05	4.06E-06	9.78E-07	1.02E-04	3.77E-05	1.42E-05	5.07E-06	1.25E-06
Ru-103	1.11E-07	4.08E-08	1.49E-08	5.07E-09	1.22E-09	1.25E-07	4.66E-08	1.76E-08	6.33E-09	1.56E-09
Ce-144	5.34E-05	1.96E-05	7.14E-06	2.43E-06	5.86E-07	6.07E-05	2.25E-05	8.49E-06	3.05E-06	7.50E-07
La-140	1.44E-06	5.28E-07	1.92E-07	6.48E-08	1.53E-08	1.29E-06	4.79E-07	1.80E-07	6.45E-08	1.55E-08
Pu-239	1.91E-05	7.00E-06	2.55E-06	8.68E-07	2.09E-07	2.17E-05	8.07E-06	3.03E-06	1.09E-06	2.68E-07

Table B-5. Dose conversion factors—Case E, adult, whole body (rem/curie).

Nuclide	Short Term DCF Mean Meteorology					Long Term DCF Mean Meteorology				
	400m	800m	1600m	3200m	8000m	400m	800m	1600m	3200m	8000m
Xe-133	—	—	—	—	—	—	—	—	—	—
Kr-85	—	—	—	—	—	—	—	—	—	—
Kr-88	—	—	—	—	—	—	—	—	—	—
I-131	1.44E-03	5.30E-04	1.93E-04	6.57E-05	1.58E-05	1.56E-03	5.81E-04	2.20E-04	7.89E-05	1.93E-05
I-133	4.49E-05	1.64E-05	5.95E-06	1.99E-06	4.60E-07	3.32E-05	1.23E-05	4.62E-06	1.64E-06	3.87E-07
Te-132	2.61E-06	9.58E-07	3.49E-07	1.18E-07	2.82E-08	2.61E-06	9.73E-07	3.67E-07	1.32E-07	3.21E-08
Cs-134	6.06E-03	2.23E-03	8.13E-04	2.77E-04	6.70E-05	6.89E-03	2.56E-03	9.68E-04	3.49E-04	8.60E-05
Cs-137	4.41E-03	1.62E-03	5.91E-04	2.01E-04	4.87E-05	5.01E-03	1.86E-03	7.04E-04	2.53E-04	6.25E-05
Sr-90	2.23E-03	8.16E-04	2.97E-04	1.01E-04	2.44E-05	2.53E-03	9.39E-04	3.54E-04	1.27E-04	3.13E-05
Ag-110m	1.82E-03	6.69E-04	2.44E-04	8.30E-05	2.00E-05	2.07E-03	7.69E-04	2.90E-04	1.04E-04	2.56E-05
Ag-111	2.54E-04	9.34E-05	3.41E-05	1.16E-05	2.78E-06	2.73E-04	1.02E-04	3.85E-05	1.38E-05	3.39E-06
Sb-125	5.26E-06	1.92E-06	6.99E-07	2.38E-07	5.72E-08	5.97E-06	2.21E-06	8.29E-07	2.97E-07	7.31E-08
Ru-103	1.02E-08	3.75E-09	1.37E-09	4.66E-10	1.12E-10	1.15E-08	4.28E-09	1.62E-09	5.83E-10	1.43E-10
Ce-144	3.62E-06	1.33E-06	4.84E-07	1.65E-07	3.97E-08	4.11E-06	1.53E-06	5.76E-07	2.07E-07	5.09E-08
La-140	1.33E-07	4.90E-08	1.78E-08	6.01E-09	1.42E-09	1.19E-07	4.45E-08	1.67E-08	5.98E-09	1.44E-09
Pu-239	5.07E-08	1.86E-08	6.76E-09	2.30E-09	5.55E-10	5.77E-08	2.14E-08	8.05E-09	2.89E-09	7.11E-10

Table B-6. Dose conversion factors—Case F, infant, thyroid (rem/curie).

Nuclide	Short Term DCF Mean Meteorology					Long Term DCF Mean Meteorology				
	400m	800m	1600m	3200m	8000m	400m	800m	1600m	3200m	8000m
Xe-133	—	—	—	—	—	—	—	—	—	—
Kr-85	—	—	—	—	—	—	—	—	—	—
Kr-88	—	—	—	—	—	—	—	—	—	—
I-131	4.62E-01	1.70E-01	6.19E-02	2.10E-02	5.06E-03	1.84E+00	6.06E-01	2.38E-01	8.23E-02	1.85E-02
I-133	1.94E-02	7.10E-03	2.57E-03	8.61E-04	1.99E-04	7.59E-02	2.64E-02	9.31E-03	3.10E-03	7.05E-04
Te-132	8.49E-04	3.12E-04	1.14E-04	3.85E-05	2.64E-06	3.31E-03	1.21E-03	4.06E-04	1.47E-04	3.40E-05
Cs-134	9.84E-03	3.61E-03	1.32E-03	4.50E-04	1.09E-04	3.43E-02	1.26E-02	4.41E-03	1.59E-03	3.98E-04
Cs-137	7.77E-03	2.85E-03	1.04E-03	3.55E-04	8.59E-05	2.92E-02	1.05E-02	3.77E-03	1.34E-03	2.96E-04
Sr-90	8.60E-04	3.15E-04	1.15E-04	3.91E-05	9.42E-06	3.17E-03	1.15E-03	3.92E-04	1.42E-04	3.24E-05
Ag-110m	5.11E-03	1.87E-03	6.82E-04	2.32E-04	5.60E-05	2.05E-02	6.90E-03	2.40E-03	8.40E-04	1.95E-04
Ag-111	9.05E-05	3.32E-05	1.21E-05	4.12E-06	9.90E-07	3.35E-04	1.23E-04	4.30E-05	1.57E-05	3.82E-06
Sb-125	9.40E-05	3.43E-05	1.25E-05	4.24E-06	1.02E-06	3.55E-04	1.32E-04	4.38E-05	1.64E-05	3.89E-06
Ru-103	1.73E-08	6.35E-09	2.32E-09	7.89E-10	1.90E-10	7.15E-08	2.30E-08	8.33E-09	2.65E-09	6.59E-10
Ce-144	6.78E-07	2.48E-07	9.06E-08	3.08E-08	7.43E-09	2.43E-06	8.37E-07	3.27E-07	1.11E-07	2.64E-08
La-140	9.22E-09	3.38E-09	1.23E-09	4.15E-10	9.80E-11	3.39E-08	1.25E-08	4.46E-09	1.63E-09	3.74E-10
Pu-239	2.51E-06	9.19E-07	3.35E-07	1.14E-07	2.74E-08	9.03E-06	3.35E-06	1.25E-06	4.09E-07	9.61E-08

Table B-7. Dose conversion factors—Case F, adult, thyroid (rem/curie).

Nuclide	Short Term DCF Mean Meteorology					Long Term DCF Mean Meteorology				
	400m	800m	1600m	3200m	8000m	400m	800m	1600m	3200m	8000m
Xe-133	—	—	—	—	—	—	—	—	—	—
Kr-85	—	—	—	—	—	—	—	—	—	—
Kr-88	—	—	—	—	—	—	—	—	—	—
I-131	4.77E-02	1.75E-02	6.39E-03	2.17E-03	5.22E-04	5.15E-02	1.92E-02	7.26E-03	2.61E-03	6.39E-04
I-133	1.46E-03	5.34E-04	1.93E-04	6.48E-05	1.50E-05	1.08E-03	4.00E-04	1.50E-04	5.32E-05	1.26E-05
Te-132	6.11E-05	2.24E-05	8.17E-06	2.77E-06	6.61E-07	6.11E-05	2.28E-05	8.60E-06	3.09E-06	7.52E-07
Cs-134	5.39E-03	1.98E-03	7.23E-04	2.46E-04	5.96E-05	6.13E-03	2.28E-03	8.61E-04	3.10E-04	7.65E-05
Cs-137	4.11E-03	1.51E-03	5.51E-04	1.88E-04	4.54E-05	4.68E-03	1.74E-03	6.57E-04	2.36E-04	5.83E-05
Sr-90	8.73E-05	3.20E-05	1.17E-05	3.97E-06	9.57E-07	9.93E-05	3.68E-05	1.39E-05	4.98E-06	1.23E-06
Ag-110m	1.13E-04	4.14E-05	1.51E-05	5.14E-06	1.24E-06	1.28E-04	4.77E-05	1.80E-05	6.45E-06	1.59E-06
Ag-111	1.39E-06	5.10E-07	1.86E-07	6.32E-08	1.52E-08	1.49E-06	5.56E-07	2.10E-07	7.56E-08	1.85E-08
Sb-125	2.64E-07	9.66E-08	3.52E-08	1.20E-08	2.88E-09	3.00E-07	1.11E-07	4.17E-08	1.50E-08	3.68E-09
Ru-103	7.72E-10	2.84E-10	1.04E-10	3.52E-11	8.50E-12	8.69E-10	3.24E-10	1.22E-10	4.40E-11	1.08E-11
Ce-144	3.27E-09	1.20E-09	4.37E-10	1.49E-10	3.59E-11	3.71E-09	1.38E-09	5.20E-10	1.87E-10	4.59E-11
La-140	3.75E-10	1.37E-10	5.00E-11	1.69E-11	3.98E-12	3.35E-10	1.25E-10	4.70E-11	1.68E-11	4.05E-12
Pu-239	2.72E-13	9.95E-14	3.62E-14	1.23E-14	2.97E-15	3.09E-13	1.15E-13	4.31E-14	1.55E-14	3.81E-15

B-2. Deposition Factors

Table B-8. Deposition factors—Case G (curie/m²).

Nuclide	Short Term Deposition Mean Meteorology					Long Term Deposition Mean Meteorology				
	400m	800m	1600m	3200m	8000m	400m	800m	1600m	3200m	8000m
Xe-133	—	—	—	—	—	—	—	—	—	—
Kr-85	—	—	—	—	—	—	—	—	—	—
Kr-88	—	—	—	—	—	—	—	—	—	—
I-131	1.45E-07	5.38E-08	1.99E-08	6.95E-09	1.71E-09	1.70E-07	1.17E-07	7.51E-08	4.79E-08	9.71E-09
I-133	1.44E-07	5.32E-08	1.96E-08	6.70E-09	1.59E-09	1.68E-07	9.95E-08	5.00E-08	2.38E-08	4.79E-09
Te-132	1.45E-07	5.38E-08	2.00E-08	6.97E-09	1.73E-09	1.69E-07	1.13E-07	6.98E-08	4.19E-08	8.49E-09
Cs-134	1.45E-07	5.38E-08	2.00E-08	6.97E-09	1.73E-09	1.70E-07	1.19E-07	7.93E-08	5.25E-08	1.07E-08
Cs-137	1.45E-07	5.38E-08	2.00E-08	6.97E-09	1.73E-09	1.70E-07	1.19E-07	7.96E-08	5.28E-08	1.07E-08
Sr-90	1.45E-07	5.38E-08	2.00E-08	6.97E-09	1.73E-09	1.70E-07	1.19E-07	7.96E-08	5.28E-08	1.07E-08
Ag-110m	1.45E-07	5.38E-08	2.00E-08	6.97E-09	1.73E-09	1.70E-07	1.19E-07	7.93E-08	5.25E-08	1.06E-08
Ag-111	1.45E-07	5.38E-08	1.99E-08	6.95E-09	1.71E-09	1.70E-07	1.16E-07	7.50E-08	4.76E-08	9.65E-09
Sb-125	1.45E-07	5.38E-08	2.00E-08	6.97E-09	1.72E-09	1.70E-07	1.19E-07	7.93E-08	5.25E-08	1.07E-08
Ru-103	1.45E-07	5.38E-08	2.00E-08	6.97E-09	1.73E-09	1.70E-07	1.18E-07	7.85E-08	5.16E-08	1.05E-08
Ce-144	1.45E-07	5.38E-08	2.00E-08	6.97E-09	1.73E-09	1.70E-07	1.19E-07	7.93E-08	5.25E-08	1.06E-08
La-140	1.45E-07	5.35E-08	1.98E-08	6.84E-09	1.65E-09	1.69E-07	1.08E-07	6.18E-08	3.43E-08	6.91E-09
Pu-239	1.45E-07	5.38E-08	2.00E-08	6.97E-09	1.73E-09	1.70E-07	1.19E-07	7.96E-08	5.28E-08	1.07E-08

Appendix C

Doses

Appendix C Doses

C-1. 600 MW(t) Prismatic 700°C

C-1.1 Accident Scenario: Break in Helium Pressure Boundary

C-1.1.1 Source Term

Table C-1. 600 MW(t) prismatic 700°C ROT—break in HPB—source term (curies).

Nuclide	Release to Environment Short Term				Release to Environment Long Term			
	DBA	50%	Mean	95%	DBA	50%	Mean	95%
Xe-133	3.99E+01	3.99E+01	3.99E+01	3.99E+01	4.92E+01	4.92E+01	6.44E+01	1.68E+02
Kr-85	2.10E-01	2.10E-01	2.10E-01	2.10E-01	3.39E-01	3.39E-01	4.50E-01	1.21E+00
Kr-88	2.06E+01	2.06E+01	2.06E+01	2.06E+01	1.38E-04	1.38E-04	1.82E-04	4.91E-04
I-131	1.10E+00	5.51E-02	1.61E-01	6.10E-01	1.02E+02	2.85E+00	6.11E+00	2.24E+01
I-133	1.89E+00	1.00E-01	2.90E-01	1.08E+00	4.32E+01	1.17E+00	2.64E+00	9.72E+00
Te-132	1.50E+00	7.44E-02	2.17E-01	8.08E-01	1.11E+02	3.12E+00	6.51E+00	2.41E+01
Cs-137	2.59E+00	1.17E-01	3.43E-01	1.33E+00	7.58E+00	1.15E-01	3.31E-01	1.28E+00
Cs-134	3.58E-01	1.93E-02	5.54E-02	2.10E-01	8.47E+00	1.32E-01	3.82E-01	1.49E+00
Sr-90	3.08E-02	1.57E-03	4.56E-03	1.72E-02	9.65E+00	1.79E-01	4.71E-01	1.76E+00
Ag-110m	7.93E-01	3.86E-02	1.13E-01	4.22E-01	4.65E+01	8.61E-01	2.30E+00	8.51E+00
Ag-111	1.67E+01	7.96E-01	2.28E+00	8.93E+00	3.50E+03	5.48E+01	1.72E+02	6.49E+02
Sb-125	1.40E-02	7.27E-04	2.12E-03	8.15E-03	1.06E-01	1.78E-03	5.23E-03	2.05E-02
Ru-103	1.58E-02	8.05E-04	2.34E-03	8.68E-03	4.25E+01	7.19E-01	1.96E+00	7.54E+00
Ce-144	1.97E-01	9.74E-03	2.75E-02	1.05E-01	2.64E+00	4.57E-02	1.30E-01	5.01E-01
La-140	1.46E-02	7.46E-04	2.16E-03	8.13E-03	1.66E+00	2.88E-02	7.65E-02	2.92E-01
Pu-239	3.73E-06	1.90E-07	5.74E-07	2.10E-06	5.29E-05	8.97E-07	2.60E-06	1.01E-05

C-1.1.2 Doses

Table C-2. 600 MW(t) prismatic 700°C ROT—break in HPB—Cases A and B—400 m from release (rem).

Nuclide	Case A/EAB (400 m)/ TEDE		Case B/LPZ (400 m)/ TEDE	
	Short	Long	Short	Long
Xe-133	1.80E-05		1.80E-05	5.26E-05
Kr-85	8.30E-09		8.30E-09	3.01E-08
Kr-88	6.18E-04		6.18E-04	4.95E-09
I-131	2.15E-03		2.15E-03	1.19E-01
I-133	5.95E-04		5.95E-04	6.48E-03
Te-132	1.15E-03		1.15E-03	5.53E-02
Cs-137	4.90E-03		4.90E-03	8.71E-03
Cs-134	1.07E-03		1.07E-03	1.59E-02
Sr-90	3.37E-04		3.37E-04	8.70E-02
Ag-110m	3.69E-03		3.69E-03	1.53E-01
Ag-111	2.31E-02		2.31E-02	9.24E-01
Sb-125	3.00E-06		3.00E-06	1.35E-05
Ru-103	8.35E-06		8.35E-06	1.54E-02
Ce-144	4.00E-03		4.00E-03	3.66E-02
La-140	7.63E-06		7.63E-06	4.38E-04
Pu-239	4.40E-05		4.40E-05	5.84E-04
Sum	2.39E-02	0.00E+00	2.39E-02	1.30E+00
TOTAL	2.39E-02		1.32E+00	
Limits (rem)	25			

Table C-3. 600 MW(t) prismatic 700°C ROT—break in HPB—Cases C and D—400 m from release (rem).

Nuclide	CASE C/Inh, grndshine, cldshine/TEDE		CASE D/Inh, grndshine, cldshine/Thyroid	
	Short	Long	Short	Long
Xe-133	7.46E-06	1.22E-05		
Kr-85	3.01E-09	7.06E-09		
Kr-88	2.80E-04	8.08E-10		
I-131	9.98E-05	4.23E-03	3.16E-03	1.35E-01
I-133	3.46E-05	2.43E-04	9.38E-04	6.59E-03
Te-132	5.82E-05	1.83E-03	9.36E-04	2.98E-02
Cs-137	2.24E-04	2.51E-04		
Cs-134	5.21E-05	4.16E-04		
Sr-90	1.99E-05	2.45E-03		
Ag-110m	1.85E-04	4.36E-03		
Ag-111	2.58E-04	2.17E-02		
Sb-125	1.41E-07	3.80E-07		
Ru-103	4.52E-07	4.30E-04		
Ce-144	1.87E-04	1.05E-03		
La-140	3.54E-07	1.14E-05		
Pu-239	3.22E-06	1.73E-05		
Sum	1.41E-03	3.70E-02	5.04E-03	1.71E-01
TOTAL	3.84E-02		1.76E-01	
Limits (rem)	1		5	

Table C-4. 600 MW(t) prismatic 700°C ROT—break in HPB—Cases E and F, infant and adult—400 m from release (rem).

Nuclide	CASE E/Ingestion – milk/ EDE (infant)		CASE F/Ingestion – milk/ Thyroid (infant)		CASE E/Ingestion – milk/ EDE (adult)		CASE F/Ingestion – milk/ Thyroid (adult)	
	Short	Long	Short	Long	Short	Long	Short	Long
Xe-133	–	–	–	–	–	–	–	–
Kr-85	–	–	–	–	–	–	–	–
Kr-88	–	–	–	–	–	–	–	–
I-131	3.74E-03	1.53E-01	7.46E-02	3.05E+00	2.32E-04	9.53E-03	7.70E-03	3.15E-01
I-133	2.90E-04	1.94E-03	5.63E-03	3.77E-02	1.30E-05	8.75E-05	4.24E-04	2.85E-03
Te-132	1.36E-05	4.08E-04	1.84E-04	5.52E-03	5.67E-07	1.70E-05	1.33E-05	3.98E-04
Cs-137	2.97E-03	3.27E-03	2.66E-03	2.93E-03	1.51E-03	1.66E-03	1.41E-03	1.55E-03
Cs-134	5.51E-04	4.32E-03	5.45E-04	4.28E-03	3.35E-04	2.63E-03	2.98E-04	2.34E-03
Sr-90	7.53E-05	8.86E-03	3.92E-06	4.61E-04	1.02E-05	1.19E-03	3.98E-07	4.68E-05
Ag-110m	2.14E-03	4.93E-02	5.76E-04	1.33E-02	2.05E-04	4.75E-03	1.27E-05	2.94E-04
Ag-111	7.63E-03	6.17E-01	2.07E-04	1.67E-02	5.80E-04	4.69E-02	3.17E-06	2.56E-04
Sb-125	1.90E-07	5.34E-07	1.99E-07	5.60E-07	1.12E-08	3.12E-08	5.60E-10	1.57E-09
Ru-103	2.60E-10	2.45E-07	4.05E-11	3.81E-08	2.39E-11	2.26E-08	1.81E-12	1.70E-09
Ce-144	1.47E-06	7.87E-06	1.87E-08	9.98E-08	9.96E-08	5.33E-07	9.00E-11	4.81E-10
La-140	3.11E-09	9.87E-08	1.99E-11	6.31E-10	2.87E-10	9.11E-09	8.09E-13	2.56E-11
Pu-239	1.10E-11	5.65E-11	1.44E-12	7.42E-12	2.91E-14	1.50E-13	1.56E-19	8.05E-19
Sum	1.74E-02	8.39E-01	8.44E-02	3.13E+00	2.89E-03	6.68E-02	9.86E-03	3.22E-01
TOTAL	8.56E-01		3.21E+00		6.97E-02		3.32E-01	
Limits (rem)	0.5		1.5		0.5		1.5	

Table C-5. 600 MW(t) prismatic 700°C ROT—break in HPB—Cases E and F, infant and adult—800 m from release (rem).

Nuclide	CASE E/Ingestion – milk/ EDE (infant)		CASE F/Ingestion – milk/ Thyroid (infant)		CASE E/Ingestion – milk/ EDE (adult)		CASE F/Ingestion – milk/ Thyroid (adult)	
	Short	Long	Short	Long	Short	Long	Short	Long
Xe-133	–	–	–	–	–	–	–	–
Kr-85	–	–	–	–	–	–	–	–
Kr-88	–	–	–	–	–	–	–	–
I-131	1.38E-03	5.71E-02	2.74E-02	1.14E+00	8.56E-05	3.55E-03	2.82E-03	1.17E-01
I-133	1.06E-04	7.20E-04	2.06E-03	1.40E-02	4.76E-06	3.24E-05	1.55E-04	1.05E-03
Te-132	5.00E-06	1.52E-04	6.78E-05	2.06E-03	2.08E-07	6.33E-06	4.87E-06	1.48E-04
Cs-137	1.09E-03	1.22E-03	9.76E-04	1.09E-03	5.55E-04	6.16E-04	5.17E-04	5.76E-04
Cs-134	2.03E-04	1.61E-03	2.00E-04	1.59E-03	1.23E-04	9.78E-04	1.10E-04	8.71E-04
Sr-90	2.77E-05	3.29E-03	1.44E-06	1.71E-04	3.72E-06	4.42E-04	1.46E-07	1.73E-05
Ag-110m	7.84E-04	1.84E-02	2.11E-04	4.93E-03	7.55E-05	1.76E-03	4.67E-06	1.09E-04
Ag-111	2.81E-03	2.30E-01	7.58E-05	6.23E-03	2.13E-04	1.75E-02	1.16E-06	9.56E-05
Sb-125	6.96E-08	1.97E-07	7.28E-08	2.06E-07	4.07E-09	1.16E-08	2.05E-10	5.81E-10
Ru-103	9.55E-11	9.14E-08	1.49E-11	1.42E-08	8.77E-12	8.39E-09	6.64E-13	6.35E-10
Ce-144	5.39E-07	2.92E-06	6.82E-09	3.71E-08	3.66E-08	1.98E-07	3.30E-11	1.79E-10
La-140	1.14E-09	3.67E-08	7.29E-12	2.35E-10	1.06E-10	3.41E-09	2.96E-13	9.57E-12
Pu-239	4.02E-12	2.10E-11	5.27E-13	2.76E-12	1.07E-14	5.57E-14	5.71E-20	3.00E-19
Sum	6.41E-03	3.13E-01	3.10E-02	1.17E+00	1.06E-03	2.49E-02	3.62E-03	1.20E-01
TOTAL	3.19E-01		1.20E+00		2.60E-02		1.24E-01	
Limits (rem)	0.5		1.5		0.5		1.5	

Table C-6. 600 MW(t) prismatic 700°C ROT—break in HPB—Cases E and F, infant and adult—1600 m from release (rem).

Nuclide	CASE E/Ingestion – milk/ EDE (infant)		CASE F/Ingestion – milk/ Thyroid (infant)		CASE E/Ingestion – milk/ EDE (adult)		CASE F/Ingestion – milk/ Thyroid (adult)	
	Short	Long	Short	Long	Short	Long	Short	Long
Xe-133	–	–	–	–	–	–	–	–
Kr-85	–	–	–	–	–	–	–	–
Kr-88	–	–	–	–	–	–	–	–
I-131	5.02E-04	2.16E-02	9.99E-03	4.30E-01	3.12E-05	1.34E-03	1.03E-03	4.44E-02
I-133	3.83E-05	2.69E-04	7.46E-04	5.27E-03	1.73E-06	1.22E-05	5.60E-05	3.95E-04
Te-132	1.82E-06	5.74E-05	2.48E-05	7.74E-04	7.58E-08	2.39E-06	1.77E-06	5.60E-05
Cs-137	3.97E-04	4.60E-04	3.56E-04	4.11E-04	2.02E-04	2.33E-04	1.89E-04	2.18E-04
Cs-134	7.36E-05	6.07E-04	7.31E-05	6.00E-04	4.50E-05	3.70E-04	4.00E-05	3.29E-04
Sr-90	1.01E-05	1.24E-03	5.25E-07	6.45E-05	1.36E-06	1.67E-04	5.34E-08	6.55E-06
Ag-110m	2.85E-04	6.91E-03	7.69E-05	1.86E-03	2.75E-05	6.66E-04	1.70E-06	4.13E-05
Ag-111	1.02E-03	8.70E-02	2.76E-05	2.36E-03	7.79E-05	6.62E-03	4.25E-07	3.61E-05
Sb-125	2.52E-08	7.43E-08	2.65E-08	7.69E-08	1.48E-09	4.34E-09	7.47E-11	2.18E-10
Ru-103	3.49E-11	3.45E-08	5.43E-12	5.37E-09	3.21E-12	3.18E-09	2.43E-13	2.39E-10
Ce-144	1.96E-07	1.10E-06	2.49E-09	1.40E-08	1.33E-08	7.47E-08	1.20E-11	6.74E-11
La-140	4.14E-10	1.38E-08	2.65E-12	8.88E-11	3.84E-11	1.28E-09	1.08E-13	3.60E-12
Pu-239	1.46E-12	7.89E-12	1.92E-13	1.04E-12	3.88E-15	2.10E-14	2.08E-20	1.12E-19
Sum	2.33E-03	1.18E-01	1.13E-02	4.41E-01	3.87E-04	9.42E-03	1.32E-03	4.54E-02
TOTAL	1.20E-01		4.52E-01		9.80E-03		4.68E-02	
Limits (rem)	0.5		1.5		0.5		1.5	

C-1.2 Accident Scenario: Water Ingress Event

C-1.2.1 Source Term

Table C-7. 600 MW(t) prismatic 700°C ROT—water ingress—source term (curies).

Nuclide	Release to Environment Short Term				Release to Environment Long Term			
	DBA	50%	Mean	95%	DBA	50%	Mean	95%
Xe-133	3.99E+01	3.99E+01	3.99E+01	3.99E+01	4.42E+02	1.08E+02	1.54E+02	4.42E+02
Kr-85	2.10E-01	2.10E-01	2.10E-01	2.10E-01	3.08E+00	7.31E-01	1.06E+00	3.08E+00
Kr-88	2.03E+01	2.03E+01	2.03E+01	2.03E+01	1.25E-03	3.05E-04	4.32E-04	1.25E-03
I-131	2.21E+01	1.10E+00	1.90E+00	6.56E+00	5.62E+02	3.16E+00	6.90E+00	2.48E+01
I-133	4.00E+01	2.01E+00	3.36E+00	1.12E+01	2.32E+02	1.31E+00	2.85E+00	1.02E+01
Te-132	2.99E+01	1.48E+00	2.54E+00	8.52E+00	5.94E+02	3.29E+00	7.00E+00	2.54E+01
Cs-137	4.84E+01	2.37E+00	4.06E+00	1.35E+01	6.53E+01	2.59E-01	7.06E-01	2.67E+00
Cs-134	7.55E+00	3.77E-01	6.36E-01	2.16E+00	7.41E+01	2.92E-01	7.81E-01	3.09E+00
Sr-90	6.26E-01	3.12E-02	5.28E-02	1.72E-01	1.04E+02	3.62E-01	9.59E-01	3.58E+00
Ag-110m	1.52E+01	7.60E-01	1.30E+00	4.31E+00	1.71E+02	8.89E-01	2.01E+00	7.33E+00
Ag-111	3.17E+02	1.57E+01	2.65E+01	8.81E+01	1.42E+04	5.59E+01	1.53E+02	5.60E+02
Sb-125	2.98E-01	1.51E-02	2.52E-02	8.35E-02	5.69E-01	1.95E-03	5.52E-03	2.17E-02
Ru-103	3.20E-01	1.57E-02	2.66E-02	8.79E-02	1.48E+02	6.91E-01	1.69E+00	6.42E+00
Ce-144	3.96E+00	1.98E-01	3.33E-01	1.08E+00	1.01E+01	4.82E-02	1.13E-01	4.08E-01
La-140	2.95E-01	1.45E-02	2.46E-02	8.36E-02	6.10E+00	2.81E-02	6.66E-02	2.44E-01
Pu-239	7.53E-05	3.70E-06	6.23E-06	2.09E-05	1.89E-04	9.07E-07	2.13E-06	7.80E-06

C-1.2.2 Doses

Table C-8. 600 MW(t) prismatic 700°C ROT—water ingress—Cases A and B—400 m from release (rem).

Nuclide	Case A/EAB (400 m)/TEDE		Case B/LPZ (400 m)/TEDE	
	Short	Long	Short	Long
Xe-133	1.86E-05		1.86E-05	1.40E-04
Kr-85	8.22E-09		8.22E-09	8.06E-08
Kr-88	6.20E-04		6.20E-04	1.27E-08
I-131	4.42E-02		4.42E-02	6.41E-01
I-133	1.23E-02		1.23E-02	3.57E-02
Te-132	2.23E-02		2.23E-02	3.07E-01
Cs-137	9.78E-02		9.78E-02	7.84E-02
Cs-134	2.28E-02		2.28E-02	1.44E-01
Sr-90	6.39E-03		6.39E-03	9.29E-01
Ag-110m	7.66E-02		7.66E-02	5.48E-01
Ag-111	9.60E-02		9.60E-02	3.10E+00
Sb-125	6.21E-05		6.21E-05	7.00E-05
Ru-103	1.65E-04		1.65E-04	5.39E-02
Ce-144	7.93E-02		7.93E-02	1.31E-01
La-140	1.52E-04		1.52E-04	1.66E-03
Pu-239	8.66E-04		8.66E-04	2.08E-03
Sum	4.60E-01	0.00E+00	4.60E-01	5.97E+00
TOTAL	4.60E-01		6.43E+00	
Limits (rem)	25			

Table C-9. 600 MW(t) prismatic 700°C ROT—water ingress—Cases C and D—400 m from release (rem).

Nuclide	CASE C/Inh, grndshine, cldshine/TEDE		CASE D/Inh, grndshine, cldshine/Thyroid	
	Short	Long	Short	Long
Xe-133	7.46E-06	2.93E-05		
Kr-85	3.01E-09	1.66E-08		
Kr-88	2.76E-04	1.91E-09		
I-131	1.18E-03	4.78E-03	3.73E-02	1.53E-01
I-133	4.00E-04	2.63E-04	1.09E-02	7.12E-03
Te-132	6.79E-04	1.97E-03	1.09E-02	3.21E-02
Cs-137	2.66E-03	5.36E-04		
Cs-134	5.99E-04	8.51E-04		
Sr-90	2.30E-04	4.99E-03		
Ag-110m	2.13E-03	3.81E-03		
Ag-111	3.00E-03	1.93E-02		
Sb-125	1.68E-06	4.01E-07		
Ru-103	5.14E-06	3.70E-04		
Ce-144	2.27E-03	9.08E-04		
La-140	4.03E-06	9.93E-06		
Pu-239	3.49E-05	1.42E-05		
Sum	1.35E-02	3.78E-02	5.91E-02	1.92E-01
TOTAL	5.13E-02		2.51E-01	
Limits (rem)	1		5	

Table C-10. 600 MW(t) prismatic 700°C ROT—water ingress—Cases E and F, infant and adult—400 m from release (rem).

Nuclide	CASE E/Ingestion – milk/ EDE (infant)		CASE F/Ingestion – milk/ Thyroid (infant)		CASE E/Ingestion – milk/ EDE (adult)		CASE F/Ingestion – milk/ Thyroid (adult)	
	Short	Long	Short	Long	Short	Long	Short	Long
Xe-133	–	–	–	–	–	–	–	–
Kr-85	–	–	–	–	–	–	–	–
Kr-88	–	–	–	–	–	–	–	–
I-131	4.42E-02	1.73E-01	8.79E-01	3.44E+00	2.74E-03	1.08E-02	9.08E-02	3.55E-01
I-133	3.35E-03	2.10E-03	6.53E-02	4.07E-02	1.51E-04	9.45E-05	4.91E-03	3.07E-03
Te-132	1.59E-04	4.39E-04	2.15E-03	5.95E-03	6.62E-06	1.83E-05	1.55E-04	4.28E-04
Cs-137	3.53E-02	6.97E-03	3.16E-02	6.24E-03	1.79E-02	3.54E-03	1.67E-02	3.30E-03
Cs-134	6.33E-03	8.83E-03	6.26E-03	8.75E-03	3.85E-03	5.38E-03	3.43E-03	4.79E-03
Sr-90	8.71E-04	1.80E-02	4.54E-05	9.38E-04	1.18E-04	2.43E-03	4.61E-06	9.52E-05
Ag-110m	2.46E-02	4.31E-02	6.63E-03	1.16E-02	2.36E-03	4.15E-03	1.47E-04	2.57E-04
Ag-111	8.85E-02	5.50E-01	2.40E-03	1.49E-02	6.73E-03	4.18E-02	3.68E-05	2.28E-04
Sb-125	2.26E-06	5.63E-07	2.37E-06	5.90E-07	1.33E-07	3.29E-08	6.65E-09	1.65E-09
Ru-103	2.96E-09	2.11E-07	4.61E-10	3.28E-08	2.72E-10	1.95E-08	2.06E-11	1.47E-09
Ce-144	1.78E-05	6.84E-06	2.26E-07	8.67E-08	1.21E-06	4.63E-07	1.09E-09	4.18E-10
La-140	3.54E-08	8.59E-08	2.26E-10	5.50E-10	3.27E-09	7.93E-09	9.21E-12	2.23E-11
Pu-239	1.19E-10	4.63E-11	1.56E-11	6.08E-12	3.16E-13	1.23E-13	1.69E-18	6.59E-19
Sum	2.03E-01	8.02E-01	9.94E-01	3.53E+00	3.39E-02	6.82E-02	1.16E-01	3.68E-01
TOTAL	1.01E+00		4.53E+00		1.02E-01		4.84E-01	
Limits (rem)	0.5		1.5		0.5		1.5	

Table C-11. 600 MW(t) prismatic 700°C ROT—water ingress—Cases E and F, infant and adult—800 m from release (rem).

Nuclide	CASE E/Ingestion – milk/ EDE (infant)		CASE F/Ingestion – milk/ Thyroid (infant)		CASE E/Ingestion – milk/ EDE (adult)		CASE F/Ingestion – milk/ Thyroid (adult)	
	Short	Long	Short	Long	Short	Long	Short	Long
Xe-133	–	–	–	–	–	–	–	–
Kr-85	–	–	–	–	–	–	–	–
Kr-88	–	–	–	–	–	–	–	–
I-131	1.63E-02	6.45E-02	3.24E-01	1.28E+00	1.01E-03	4.01E-03	3.33E-02	1.33E-01
I-133	1.23E-03	7.77E-04	2.39E-02	1.51E-02	5.52E-05	3.50E-05	1.80E-03	1.14E-03
Te-132	5.83E-05	1.63E-04	7.91E-04	2.21E-03	2.43E-06	6.81E-06	5.68E-05	1.60E-04
Cs-137	1.30E-02	2.59E-03	1.16E-02	2.32E-03	6.58E-03	1.31E-03	6.14E-03	1.23E-03
Cs-134	2.33E-03	3.29E-03	2.30E-03	3.25E-03	1.42E-03	2.00E-03	1.26E-03	1.78E-03
Sr-90	3.20E-04	6.69E-03	1.66E-05	3.48E-04	4.31E-05	9.01E-04	1.69E-06	3.53E-05
Ag-110m	9.02E-03	1.61E-02	2.43E-03	4.31E-03	8.68E-04	1.54E-03	5.37E-05	9.57E-05
Ag-111	3.26E-02	2.05E-01	8.80E-04	5.54E-03	2.48E-03	1.56E-02	1.35E-05	8.51E-05
Sb-125	8.26E-07	2.08E-07	8.64E-07	2.17E-07	4.84E-08	1.22E-08	2.43E-09	6.12E-10
Ru-103	1.09E-09	7.88E-08	1.69E-10	1.22E-08	9.99E-11	7.24E-09	7.56E-12	5.48E-10
Ce-144	6.53E-06	2.53E-06	8.26E-08	3.22E-08	4.43E-07	1.72E-07	4.00E-10	1.55E-10
La-140	1.30E-08	3.19E-08	8.30E-11	2.05E-10	1.20E-09	2.96E-09	3.37E-12	8.33E-12
Pu-239	4.36E-11	1.72E-11	5.72E-12	2.26E-12	1.16E-13	4.57E-14	6.19E-19	2.45E-19
Sum	7.48E-02	2.99E-01	3.65E-01	1.32E+00	1.25E-02	2.54E-02	4.26E-02	1.37E-01
TOTAL	3.74E-01		1.68E+00		3.79E-02		1.80E-01	
Limits (rem)	0.5		1.5		0.5		1.5	

Table C-12. 600 MW(t) prismatic 700°C ROT—water ingress—Cases E and F, infant and adult—1600 m from release (rem).

Nuclide	CASE E/Ingestion – milk/ EDE (infant)		CASE F/Ingestion – milk/ Thyroid (infant)		CASE E/Ingestion – milk/ EDE (adult)		CASE F/Ingestion – milk/ Thyroid (adult)	
	Short	Long	Short	Long	Short	Long	Short	Long
Xe-133	—	—	—	—	—	—	—	—
Kr-85	—	—	—	—	—	—	—	—
Kr-88	—	—	—	—	—	—	—	—
I-131	5.92E-03	2.44E-02	1.18E-01	4.85E-01	3.67E-04	1.52E-03	1.22E-02	5.01E-02
I-133	4.44E-04	2.90E-04	8.64E-03	5.69E-03	2.00E-05	1.32E-05	6.49E-04	4.27E-04
Te-132	2.12E-05	6.18E-05	2.89E-04	8.33E-04	8.85E-07	2.57E-06	2.07E-05	6.02E-05
Cs-137	4.71E-03	9.81E-04	4.23E-03	8.75E-04	2.40E-03	4.97E-04	2.24E-03	4.64E-04
Cs-134	8.46E-04	1.24E-03	8.39E-04	1.23E-03	5.17E-04	7.56E-04	4.60E-04	6.73E-04
Sr-90	1.17E-04	2.52E-03	6.07E-06	1.31E-04	1.57E-05	3.40E-04	6.18E-07	1.33E-05
Ag-110m	3.28E-03	6.04E-03	8.85E-04	1.63E-03	3.17E-04	5.82E-04	1.96E-05	3.61E-05
Ag-111	1.19E-02	7.75E-02	3.21E-04	2.10E-03	9.04E-04	5.89E-03	4.93E-06	3.21E-05
Sb-125	3.00E-07	7.83E-08	3.15E-07	8.11E-08	1.76E-08	4.57E-09	8.87E-10	2.30E-10
Ru-103	3.97E-10	2.98E-08	6.18E-11	4.64E-09	3.65E-11	2.74E-09	2.77E-12	2.06E-10
Ce-144	2.38E-06	9.56E-07	3.02E-08	1.22E-08	1.61E-07	6.49E-08	1.46E-10	5.86E-11
La-140	4.72E-09	1.20E-08	3.02E-11	7.73E-11	4.37E-10	1.11E-09	1.23E-12	3.13E-12
Pu-239	1.59E-11	6.47E-12	2.09E-12	8.49E-13	4.21E-14	1.72E-14	2.25E-19	9.20E-20
Sum	2.72E-02	1.13E-01	1.33E-01	4.98E-01	4.54E-03	9.60E-03	1.56E-02	5.18E-02
TOTAL	1.40E-01		6.31E-01		1.41E-02		6.74E-02	
Limits (rem)	0.5		1.5		0.5		1.5	

C-2. 600 MW(t) Prismatic 900°C

C-2.1 Accident Scenario: Break in Helium Pressure Boundary

C-2.1.1 Source Term

Table C-13. 600 MW(t) prismatic 900°C ROT— break in HPB—source term (curies).

Nuclide	Release to Environment Short Term				Release to Environment Long Term			
	DBA	50%	Mean	95%	DBA	50%	Mean	95%
Xe-133	1.04E+02	1.04E+02	1.04E+02	1.04E+02	1.94E+02	5.64E+01	7.42E+01	1.94E+02
Kr-85	5.34E-01	5.34E-01	5.34E-01	5.34E-01	1.40E+00	3.90E-01	5.19E-01	1.40E+00
Kr-88	5.32E+01	5.32E+01	5.32E+01	5.32E+01	5.51E-04	1.58E-04	2.10E-04	5.51E-04
I-131	2.86E+00	1.40E-01	4.03E-01	1.57E+00	1.17E+02	3.35E+00	6.95E+00	2.46E+01
I-133	4.96E+00	2.53E-01	7.12E-01	2.61E+00	4.86E+01	1.33E+00	2.90E+00	1.08E+01
Te-132	3.77E+00	1.83E-01	5.31E-01	2.05E+00	1.22E+02	3.37E+00	7.19E+00	2.66E+01
Cs-137	8.45E+01	4.23E+00	1.18E+01	4.57E+01	4.61E+01	4.96E-01	1.93E+00	7.93E+00
Cs-134	1.43E+01	7.17E-01	2.03E+00	8.04E+00	5.71E+01	5.86E-01	2.34E+00	9.34E+00
Sr-90	7.60E+00	3.83E-01	1.10E+00	4.09E+00	2.43E+01	4.16E-01	1.13E+00	4.33E+00
Ag-110m	8.07E+00	4.03E-01	1.22E+00	4.61E+00	4.44E+01	6.89E-01	2.03E+00	7.75E+00
Ag-111	2.13E+02	1.04E+01	2.95E+01	1.14E+02	3.81E+03	6.04E+01	1.75E+02	6.33E+02
Sb-125	7.01E-01	3.47E-02	1.03E-01	3.94E-01	7.43E-01	8.98E-03	3.13E-02	1.25E-01
Ru-103	1.02E-01	5.04E-03	1.42E-02	5.50E-02	5.13E+01	8.77E-01	2.40E+00	8.78E+00
Ce-144	1.20E+00	6.03E-02	1.74E-01	6.56E-01	3.54E+00	5.99E-02	1.68E-01	6.39E-01
La-140	9.38E-02	4.63E-03	1.34E-02	5.03E-02	2.08E+00	3.53E-02	9.80E-02	3.81E-01
Pu-239	8.94E-06	4.46E-07	1.30E-06	4.90E-06	5.72E-05	1.01E-06	2.77E-06	1.06E-05

Table C-14. 600 MW(t) prismatic 900°C ROT—break in HPB—Cases A and B—400 m from release (rem).

Nuclide	Case A/EAB (400 m)/TEDE		Case B/LPZ (400 m)/TEDE	
	Short	Long	Short	Long
Xe-133	4.87E-05		4.87E-05	6.15E-05
Kr-85	2.09E-08		2.09E-08	3.66E-08
Kr-88	1.62E-03		1.62E-03	5.56E-09
I-131	5.71E-03		5.71E-03	1.33E-01
I-133	1.52E-03		1.52E-03	7.49E-03
Te-132	2.81E-03		2.81E-03	6.29E-02
Cs-137	1.71E-01		1.71E-01	5.54E-02
Cs-134	4.31E-02		4.31E-02	1.11E-01
Sr-90	7.75E-02		7.75E-02	2.18E-01
Ag-110m	4.07E-02		4.07E-02	1.42E-01
Ag-111	6.46E-02		6.46E-02	8.31E-01
Sb-125	1.46E-04		1.46E-04	9.14E-05
Ru-103	5.27E-05		5.27E-05	1.87E-02
Ce-144	2.40E-02		2.40E-02	4.57E-02
La-140	4.84E-05		4.84E-05	5.66E-04
Pu-239	1.03E-04		1.03E-04	6.29E-04
Sum	4.33E-01	0.00E+00	4.33E-01	1.63E+00
TOTAL	4.33E-01		2.06E+00	
Limits (rem)	25			

Table C-15. 600 MW(t) prismatic 900°C ROT—break in HPB—Cases C and D—400 m from release (rem).

Nuclide	CASE C/Inh, grndshine, cldshine/TEDE		CASE D/Inh, grndshine, cldshine/Thyroid	
	Short	Long	Short	Long
Xe-133	1.95E-05	1.41E-05		
Kr-85	7.64E-09	8.15E-09		
Kr-88	7.23E-04	9.31E-10		
I-131	2.49E-04	4.81E-03	7.89E-03	1.54E-01
I-133	8.48E-05	2.68E-04	2.30E-03	7.25E-03
Te-132	1.42E-04	2.03E-03	2.29E-03	3.29E-02
Cs-137	7.72E-03	1.47E-03		
Cs-134	1.91E-03	2.55E-03		
Sr-90	4.79E-03	5.89E-03		
Ag-110m	2.01E-03	3.85E-03		
Ag-111	3.33E-03	2.20E-02		
Sb-125	6.86E-06	2.28E-06		
Ru-103	2.75E-06	5.26E-04		
Ce-144	1.19E-03	1.36E-03		
La-140	2.20E-06	1.46E-05		
Pu-239	7.30E-06	1.84E-05		
Sum	2.22E-02	4.48E-02	1.25E-02	1.94E-01
TOTAL	6.70E-02		2.06E-01	
Limits (rem)	1		5	

Table C-16. 600 MW(t) prismatic 900°C ROT—break in HPB—Cases E and F, infant and adult—400 m from release (rem).

Nuclide	CASE E/Ingestion – milk/ EDE (infant)		CASE F/Ingestion – milk/ Thyroid (infant)		CASE E/Ingestion – milk/ EDE (adult)		CASE F/Ingestion – milk/ Thyroid (adult)	
	Short	Long	Short	Long	Short	Long	Short	Long
Xe-133	—	—	—	—	—	—	—	—
Kr-85	—	—	—	—	—	—	—	—
Kr-88	—	—	—	—	—	—	—	—
I-131	9.34E-03	1.75E-01	1.86E-01	3.47E+00	5.80E-04	1.08E-02	1.92E-02	3.58E-01
I-133	7.10E-04	2.13E-03	1.38E-02	4.15E-02	3.20E-05	9.62E-05	1.04E-03	3.13E-03
Te-132	3.32E-05	4.51E-04	4.51E-04	6.10E-03	1.39E-06	1.88E-05	3.25E-05	4.39E-04
Cs-137	1.02E-01	1.91E-02	9.17E-02	1.71E-02	5.20E-02	9.68E-03	4.85E-02	9.04E-03
Cs-134	2.02E-02	2.64E-02	2.00E-02	2.62E-02	1.23E-02	1.61E-02	1.10E-02	1.43E-02
Sr-90	1.81E-02	2.13E-02	9.44E-04	1.11E-03	2.45E-03	2.87E-03	9.59E-05	1.13E-04
Ag-110m	2.32E-02	4.36E-02	6.25E-03	1.18E-02	2.23E-03	4.19E-03	1.38E-04	2.59E-04
Ag-111	9.85E-02	6.28E-01	2.67E-03	1.70E-02	7.49E-03	4.78E-02	4.10E-05	2.61E-04
Sb-125	9.25E-06	3.19E-06	9.69E-06	3.35E-06	5.42E-07	1.87E-07	2.72E-08	9.39E-09
Ru-103	1.58E-09	3.00E-07	2.46E-10	4.66E-08	1.45E-10	2.76E-08	1.10E-11	2.09E-09
Ce-144	9.31E-06	1.02E-05	1.18E-07	1.30E-07	6.31E-07	6.92E-07	5.70E-10	6.24E-10
La-140	1.93E-08	1.26E-07	1.24E-10	8.08E-10	1.78E-09	1.17E-08	5.03E-12	3.28E-11
Pu-239	2.49E-11	6.01E-11	3.27E-12	7.89E-12	6.60E-14	1.60E-13	3.54E-19	8.56E-19
Sum	2.73E-01	9.16E-01	3.22E-01	3.59E+00	7.71E-02	9.16E-02	8.00E-02	3.86E-01
TOTAL	1.19E+00		3.91E+00		1.69E-01		4.66E-01	
Limits (rem)	0.5		1.5		0.5		1.5	

Table C-17. 600 MW(t) prismatic 900°C ROT—break in HPB—Cases E and F, infant and adult—800 m from release (rem).

Nuclide	CASE E/Ingestion – milk/ EDE (infant)		CASE F/Ingestion – milk/ Thyroid (infant)		CASE E/Ingestion – milk/ EDE (adult)		CASE F/Ingestion – milk/ Thyroid (adult)	
	Short	Long	Short	Long	Short	Long	Short	Long
Xe-133	–	–	–	–	–	–	–	–
Kr-85	–	–	–	–	–	–	–	–
Kr-88	–	–	–	–	–	–	–	–
I-131	3.44E-03	6.50E-02	6.84E-02	1.29E+00	2.13E-04	4.04E-03	7.05E-03	1.34E-01
I-133	2.60E-04	7.91E-04	5.06E-03	1.54E-02	1.17E-05	3.57E-05	3.80E-04	1.16E-03
Te-132	1.22E-05	1.68E-04	1.66E-04	2.27E-03	5.09E-07	6.99E-06	1.19E-05	1.64E-04
Cs-137	3.76E-02	7.09E-03	3.36E-02	6.36E-03	1.91E-02	3.59E-03	1.78E-02	3.36E-03
Cs-134	7.44E-03	9.84E-03	7.33E-03	9.72E-03	4.53E-03	5.98E-03	4.02E-03	5.33E-03
Sr-90	6.65E-03	7.91E-03	3.46E-04	4.11E-04	8.96E-04	1.06E-03	3.51E-05	4.17E-05
Ag-110m	8.50E-03	1.62E-02	2.29E-03	4.36E-03	8.19E-04	1.56E-03	5.07E-05	9.67E-05
Ag-111	3.63E-02	2.34E-01	9.79E-04	6.33E-03	2.75E-03	1.78E-02	1.50E-05	9.73E-05
Sb-125	3.38E-06	1.18E-06	3.54E-06	1.23E-06	1.98E-07	6.92E-08	9.96E-09	3.47E-09
Ru-103	5.81E-10	1.12E-07	9.04E-11	1.74E-08	5.34E-11	1.03E-08	4.04E-12	7.78E-10
Ce-144	3.42E-06	3.79E-06	4.32E-08	4.81E-08	2.32E-07	2.58E-07	2.09E-10	2.32E-10
La-140	7.08E-09	4.69E-08	4.53E-11	3.01E-10	6.57E-10	4.36E-09	1.84E-12	1.22E-11
Pu-239	9.11E-12	2.23E-11	1.20E-12	2.94E-12	2.42E-14	5.93E-14	1.30E-19	3.18E-19
Sum	1.00E-01	3.41E-01	1.18E-01	1.34E+00	2.83E-02	3.41E-02	2.94E-02	1.44E-01
TOTAL	4.42E-01		1.46E+00		6.25E-02		1.73E-01	
Limits (rem)	0.5		1.5		0.5		1.5	

Table C-18. 600 MW(t) prismatic 900°C ROT— break in HPB—Cases E and F, infant and adult—1600 m from release (rem).

Nuclide	CASE E/Ingestion – milk/ EDE (infant)		CASE F/Ingestion – milk/ Thyroid (infant)		CASE E/Ingestion – milk/ EDE (adult)		CASE F/Ingestion – milk/ Thyroid (adult)	
	Short	Long	Short	Long	Short	Long	Short	Long
Xe-133	–	–	–	–	–	–	–	–
Kr-85	–	–	–	–	–	–	–	–
Kr-88	–	–	–	–	–	–	–	–
I-131	1.25E-03	2.45E-02	2.49E-02	4.89E-01	7.77E-05	1.53E-03	2.57E-03	5.05E-02
I-133	9.40E-05	2.96E-04	1.83E-03	5.80E-03	4.24E-06	1.34E-05	1.37E-04	4.35E-04
Te-132	4.45E-06	6.34E-05	6.06E-05	8.55E-04	1.85E-07	2.64E-06	4.34E-06	6.18E-05
Cs-137	1.37E-02	2.69E-03	1.23E-02	2.40E-03	6.97E-03	1.36E-03	6.50E-03	1.27E-03
Cs-134	2.70E-03	3.72E-03	2.68E-03	3.67E-03	1.65E-03	2.26E-03	1.47E-03	2.01E-03
Sr-90	2.43E-03	2.98E-03	1.26E-04	1.55E-04	3.26E-04	4.01E-04	1.28E-05	1.57E-05
Ag-110m	3.10E-03	6.10E-03	8.34E-04	1.64E-03	2.99E-04	5.88E-04	1.85E-05	3.65E-05
Ag-111	1.32E-02	8.85E-02	3.57E-04	2.40E-03	1.01E-03	6.74E-03	5.48E-06	3.67E-05
Sb-125	1.23E-06	4.44E-07	1.29E-06	4.60E-07	7.21E-08	2.59E-08	3.63E-09	1.30E-09
Ru-103	2.12E-10	4.23E-08	3.30E-11	6.58E-09	1.95E-11	3.89E-09	1.48E-12	2.93E-10
Ce-144	1.25E-06	1.43E-06	1.58E-08	1.82E-08	8.44E-08	9.70E-08	7.62E-11	8.75E-11
La-140	2.57E-09	1.76E-08	1.65E-11	1.14E-10	2.39E-10	1.64E-09	6.70E-13	4.61E-12
Pu-239	3.32E-12	8.39E-12	4.36E-13	1.10E-12	8.80E-15	2.23E-14	4.71E-20	1.19E-19
Sum	3.65E-02	1.29E-01	4.31E-02	5.06E-01	1.03E-02	1.29E-02	1.07E-02	5.44E-02
TOTAL	1.65E-01		5.49E-01		2.32E-02		6.51E-02	
Limits (rem)	0.5		1.5		0.5		1.5	

C-3. 250 MW(t) Pebble Bed 700°C

C-3.1 Accident Scenario: Break in Helium Pressure Boundary

C-3.1.1 Source Term

Table C-19. 250 MW(t) pebble bed 700°C ROT—break in HPB—source term (curies).

Nuclide	Release to Environment Short Term				Release to Environment Long Term			
	DBA	50%	Mean	95%	DBA	50%	Mean	95%
Xe-133	1.17E+01	1.17E+01	1.17E+01	1.17E+01	7.07E+01	2.06E+01	2.70E+01	7.07E+01
Kr-85	6.07E-02	6.07E-02	6.07E-02	6.07E-02	4.80E-01	1.40E-01	1.84E-01	4.80E-01
Kr-88	6.10E+00	6.10E+00	6.10E+00	6.10E+00	1.98E-04	5.74E-05	7.53E-05	1.98E-04
I-131	3.51E-01	1.68E-02	4.95E-02	1.88E-01	4.37E+01	1.22E+00	2.59E+00	9.28E+00
I-133	5.59E-01	2.80E-02	8.21E-02	3.12E-01	1.78E+01	4.99E-01	1.04E+00	3.69E+00
Te-132	4.61E-01	2.15E-02	6.54E-02	2.47E-01	4.44E+01	1.27E+00	2.65E+00	9.48E+00
Cs-137	7.97E-01	4.15E-02	1.18E-01	4.40E-01	2.98E+00	4.59E-02	1.36E-01	5.26E-01
Cs-134	1.22E-01	6.39E-03	1.79E-02	6.63E-02	3.28E+00	5.04E-02	1.53E-01	5.73E-01
Sr-90	1.36E-01	7.07E-03	1.98E-02	7.46E-02	4.96E+00	9.19E-02	2.45E-01	9.32E-01
Ag-110m	1.99E+00	9.91E-02	2.80E-01	1.09E+00	1.76E+01	2.42E-01	7.93E-01	3.09E+00
Ag-111	3.75E+01	1.90E+00	5.32E+00	2.08E+01	1.45E+03	2.17E+01	6.82E+01	2.59E+02
Sb-125	1.09E-02	5.31E-04	1.52E-03	5.78E-03	4.36E-02	6.65E-04	1.90E-03	7.47E-03
Ru-103	6.59E-02	3.34E-03	9.76E-03	3.73E-02	1.86E+01	3.19E-01	8.85E-01	3.28E+00
Ce-144	7.90E-01	3.94E-02	1.14E-01	4.13E-01	1.27E+00	2.14E-02	6.13E-02	2.26E-01
La-140	6.07E-02	2.88E-03	8.54E-03	3.24E-02	7.30E-01	1.29E-02	3.54E-02	1.32E-01
Pu-239	1.58E-05	7.83E-07	2.22E-06	8.75E-06	2.41E-05	4.22E-07	1.16E-06	4.47E-06

C-3.1.2 Doses

Table C-20. 250 MW(t) pebble bed 700°C ROT—break in HPB—Cases A and B—400 m from release (rem).

Nuclide	Case A/EAB (400 m) /TEDE		Case B/LPZ (400 m)/ TEDE	
	Short	Long	Short	Long
Xe-133	5.48E-06		5.48E-06	2.24E-05
Kr-85	2.37E-09		2.37E-09	1.26E-08
Kr-88	1.86E-04		1.86E-04	2.00E-09
I-131	7.01E-04		7.01E-04	4.98E-02
I-133	1.72E-04		1.72E-04	2.74E-03
Te-132	3.44E-04		3.44E-04	2.30E-02
Cs-137	1.61E-03		1.61E-03	3.58E-03
Cs-134	3.70E-04		3.70E-04	6.37E-03
Sr-90	1.38E-03		1.38E-03	4.45E-02
Ag-110m	1.00E-02		1.00E-02	5.65E-02
Ag-111	1.14E-02		1.14E-02	3.15E-01
Sb-125	2.27E-06		2.27E-06	5.36E-06
Ru-103	3.40E-05		3.40E-05	6.78E-03
Ce-144	1.58E-02		1.58E-02	1.64E-02
La-140	3.13E-05		3.13E-05	1.99E-04
Pu-239	1.82E-04		1.82E-04	2.65E-04
Sum	4.22E-02	0.00E+00	4.22E-02	5.25E-01
TOTAL	4.22E-02		5.67E-01	
Limits (rem)	25			

Table C-21. 250 MW(t) pebble bed 700°C ROT—break in HPB—Cases C and D—400 m from release (rem).

Nuclide	CASE C/Inh, grndshine, cldshine/TEDE		CASE D/Inh, grndshine, cldshine/Thyroid	
	Short	Long	Short	Long
Xe-133	2.19E-06	5.13E-06		
Kr-85	8.68E-10	2.89E-09		
Kr-88	8.30E-05	3.34E-10		
I-131	3.06E-05	1.79E-03	9.70E-04	5.72E-02
I-133	9.77E-06	9.61E-05	2.65E-04	2.60E-03
Te-132	1.75E-05	7.48E-04	2.82E-04	1.21E-02
Cs-137	7.73E-05	1.04E-04		
Cs-134	1.68E-05	1.66E-04		
Sr-90	8.65E-05	1.27E-03		
Ag-110m	4.59E-04	1.51E-03		
Ag-111	6.01E-04	8.60E-03		
Sb-125	1.01E-07	1.38E-07		
Ru-103	1.88E-06	1.94E-04		
Ce-144	7.75E-04	4.94E-04		
La-140	1.40E-06	5.27E-06		
Pu-239	1.25E-05	7.72E-06		
Sum	2.17E-03	1.50E-02	1.52E-03	7.19E-02
TOTAL	1.72E-02		7.34E-02	
Limits (rem)	1		5	

Table C-22. 250 MW(t) pebble bed 700°C ROT—break in HPB—Cases E and F, infant and adult—400 m from release (rem).

Nuclide	CASE E/Ingestion – milk/ EDE (infant)		CASE F/Ingestion – milk/ Thyroid (infant)		CASE E/Ingestion – milk/ EDE (adult)		CASE F/Ingestion – milk/ Thyroid (adult)	
	Short	Long	Short	Long	Short	Long	Short	Long
Xe-133	–	–	–	–	–	–	–	–
Kr-85	–	–	–	–	–	–	–	–
Kr-88	–	–	–	–	–	–	–	–
I-131	1.15E-03	6.49E-02	2.29E-02	1.29E+00	7.13E-05	4.04E-03	2.36E-03	1.33E-01
I-133	8.19E-05	7.66E-04	1.59E-03	1.49E-02	3.69E-06	3.46E-05	1.20E-04	1.12E-03
Te-132	4.09E-06	1.66E-04	5.55E-05	2.25E-03	1.71E-07	6.92E-06	4.00E-06	1.62E-04
Cs-137	1.03E-03	1.35E-03	9.18E-04	1.21E-03	5.21E-04	6.83E-04	4.86E-04	6.38E-04
Cs-134	1.78E-04	1.72E-03	1.76E-04	1.71E-03	1.08E-04	1.05E-03	9.63E-05	9.36E-04
Sr-90	3.27E-04	4.60E-03	1.71E-05	2.39E-04	4.43E-05	6.19E-04	1.73E-06	2.43E-05
Ag-110m	5.31E-03	1.70E-02	1.43E-03	4.60E-03	5.09E-04	1.64E-03	3.16E-05	1.01E-04
Ag-111	1.78E-02	2.45E-01	4.81E-04	6.63E-03	1.35E-03	1.86E-02	7.39E-06	1.02E-04
Sb-125	1.36E-07	1.94E-07	1.43E-07	2.04E-07	7.99E-09	1.14E-08	4.01E-10	5.71E-10
Ru-103	1.08E-09	1.11E-07	1.69E-10	1.72E-08	9.96E-11	1.02E-08	7.54E-12	7.69E-10
Ce-144	6.08E-06	3.72E-06	7.72E-08	4.72E-08	4.12E-07	2.52E-07	3.72E-10	2.28E-10
La-140	1.23E-08	4.56E-08	7.88E-11	2.92E-10	1.14E-09	4.21E-09	3.20E-12	1.19E-11
Pu-239	4.24E-11	2.52E-11	5.58E-12	3.31E-12	1.13E-13	6.70E-14	6.04E-19	3.59E-19
Sum	2.58E-02	3.35E-01	2.75E-02	1.32E+00	2.61E-03	2.67E-02	3.11E-03	1.36E-01
TOTAL	3.61E-01		1.35E+00		2.93E-02		1.39E-01	
Limits (rem)	0.5		1.5		0.5		1.5	

Table C-23. 250 MW(t) pebble bed 700°C ROT—break in HPB—Cases E and F, infant and adult—800 m from release (rem).

Nuclide	CASE E/Ingestion – milk/ EDE (infant)		CASE F/Ingestion – milk/ Thyroid (infant)		CASE E/Ingestion – milk/ EDE (adult)		CASE F/Ingestion – milk/ Thyroid (adult)	
	Short	Long	Short	Long	Short	Long	Short	Long
Xe-133	–	–	–	–	–	–	–	–
Kr-85	–	–	–	–	–	–	–	–
Kr-88	–	–	–	–	–	–	–	–
I-131	4.23E-04	2.42E-02	8.41E-03	4.81E-01	2.62E-05	1.50E-03	8.66E-04	4.97E-02
I-133	3.00E-05	2.84E-04	5.83E-04	5.54E-03	1.35E-06	1.28E-05	4.38E-05	4.16E-04
Te-132	1.50E-06	6.18E-05	2.04E-05	8.38E-04	6.26E-08	2.58E-06	1.46E-06	6.04E-05
Cs-137	3.77E-04	5.01E-04	3.37E-04	4.49E-04	1.91E-04	2.54E-04	1.78E-04	2.37E-04
Cs-134	6.54E-05	6.43E-04	6.45E-05	6.35E-04	3.98E-05	3.91E-04	3.54E-05	3.48E-04
Sr-90	1.20E-04	1.71E-03	6.25E-06	8.88E-05	1.62E-05	2.30E-04	6.35E-07	9.00E-06
Ag-110m	1.94E-03	6.34E-03	5.23E-04	1.70E-03	1.87E-04	6.10E-04	1.16E-05	3.78E-05
Ag-111	6.54E-03	9.14E-02	1.77E-04	2.47E-03	4.97E-04	6.96E-03	2.71E-06	3.79E-05
Sb-125	4.98E-08	7.18E-08	5.21E-08	7.50E-08	2.92E-09	4.21E-09	1.47E-10	2.11E-10
Ru-103	3.98E-10	4.12E-08	6.20E-11	6.41E-09	3.66E-11	3.79E-09	2.77E-12	2.87E-10
Ce-144	2.23E-06	1.38E-06	2.82E-08	1.75E-08	1.51E-07	9.38E-08	1.37E-10	8.46E-11
La-140	4.51E-09	1.69E-08	2.89E-11	1.09E-10	4.19E-10	1.57E-09	1.17E-12	4.42E-12
Pu-239	1.55E-11	9.37E-12	2.04E-12	1.23E-12	4.13E-14	2.48E-14	2.21E-19	1.33E-19
Sum	9.50E-03	1.25E-01	1.01E-02	4.93E-01	9.59E-04	9.96E-03	1.14E-03	5.08E-02
TOTAL	1.35E-01		5.03E-01		1.09E-02		5.20E-02	
Limits (rem)	0.5		1.5		0.5		1.5	

Table C-24. 250 MW(t) pebble bed 700°C ROT—break in HPB—Cases E and F, infant and adult—1600 m from release (rem).

Nuclide	CASE E/Ingestion – milk/ EDE (infant)		CASE F/Ingestion – milk/ Thyroid (infant)		CASE E/Ingestion – milk/ EDE (adult)		CASE F/Ingestion – milk/ Thyroid (adult)	
	Short	Long	Short	Long	Short	Long	Short	Long
Xe-133	–	–	–	–	–	–	–	–
Kr-85	–	–	–	–	–	–	–	–
Kr-88	–	–	–	–	–	–	–	–
I-131	1.54E-04	9.13E-03	3.06E-03	1.82E-01	9.55E-06	5.69E-04	3.16E-04	1.88E-02
I-133	1.08E-05	1.06E-04	2.11E-04	2.08E-03	4.89E-07	4.81E-06	1.58E-05	1.56E-04
Te-132	5.48E-07	2.34E-05	7.45E-06	3.15E-04	2.28E-08	9.73E-07	5.34E-07	2.28E-05
Cs-137	1.37E-04	1.90E-04	1.23E-04	1.69E-04	6.98E-05	9.60E-05	6.51E-05	8.96E-05
Cs-134	2.38E-05	2.43E-04	2.36E-05	2.40E-04	1.45E-05	1.48E-04	1.29E-05	1.31E-04
Sr-90	4.39E-05	6.43E-04	2.28E-06	3.35E-05	5.89E-06	8.66E-05	2.32E-07	3.40E-06
Ag-110m	7.08E-04	2.39E-03	1.91E-04	6.43E-04	6.82E-05	2.30E-04	4.22E-06	1.43E-05
Ag-111	2.38E-03	3.45E-02	6.44E-05	9.35E-04	1.81E-04	2.63E-03	9.89E-07	1.43E-05
Sb-125	1.81E-08	2.70E-08	1.90E-08	2.80E-08	1.06E-09	1.58E-09	5.35E-11	7.94E-11
Ru-103	1.45E-10	1.56E-08	2.27E-11	2.43E-09	1.34E-11	1.43E-09	1.02E-12	1.08E-10
Ce-144	8.13E-07	5.21E-07	1.03E-08	6.62E-09	5.51E-08	3.53E-08	4.97E-11	3.19E-11
La-140	1.64E-09	6.37E-09	1.05E-11	4.10E-11	1.52E-10	5.91E-10	4.27E-13	1.66E-12
Pu-239	5.66E-12	3.52E-12	7.44E-13	4.62E-13	1.50E-14	9.34E-15	8.04E-20	5.00E-20
Sum	3.46E-03	4.72E-02	3.69E-03	1.86E-01	3.50E-04	3.76E-03	4.16E-04	1.92E-02
TOTAL	5.07E-02		1.90E-01		4.11E-03		1.96E-02	
Limits (rem)	0.5		1.5		0.5		1.5	

C-3.2 Accident Scenario: Water Ingress Event

B-1.1.1 Source Term

Table C-25. 250 MW(t) pebble bed 700°C ROT—water ingress—source term (curies).

Nuclide	Release to Environment Short Term				Release to Environment Long Term			
	DBA	50%	Mean	95%	DBA	50%	Mean	95%
Xe-133	1.16E+01	1.16E+01	1.16E+01	1.16E+01	1.85E+02	4.58E+01	6.43E+01	1.85E+02
Kr-85	6.26E-02	6.26E-02	6.26E-02	6.26E-02	1.31E+00	3.08E-01	4.42E-01	1.31E+00
Kr-88	6.00E+00	6.00E+00	6.00E+00	6.00E+00	5.33E-04	1.26E-04	1.82E-04	5.33E-04
I-131	6.41E+00	3.21E-01	5.42E-01	1.80E+00	2.40E+02	1.33E+00	2.80E+00	1.02E+01
I-133	1.15E+01	5.76E-01	9.78E-01	3.27E+00	9.70E+01	5.32E-01	1.20E+00	4.41E+00
Te-132	8.80E+00	4.29E-01	7.51E-01	2.49E+00	2.39E+02	1.37E+00	2.95E+00	1.10E+01
Cs-137	1.63E+01	8.22E-01	1.40E+00	4.64E+00	2.84E+01	1.03E-01	2.89E-01	1.10E+00
Cs-134	2.62E+00	1.30E-01	2.26E-01	7.49E-01	3.12E+01	1.17E-01	3.15E-01	1.23E+00
Sr-90	2.78E+00	1.37E-01	2.31E-01	7.50E-01	5.30E+01	1.83E-01	5.38E-01	2.00E+00
Ag-110m	3.94E+01	1.95E+00	3.30E+00	1.11E+01	6.43E+01	2.45E-01	6.59E-01	2.53E+00
Ag-111	7.93E+02	3.95E+01	6.81E+01	2.29E+02	5.50E+03	2.11E+01	5.67E+01	2.12E+02
Sb-125	2.11E-01	1.06E-02	1.82E-02	5.99E-02	2.48E-01	8.10E-04	2.41E-03	9.48E-03
Ru-103	1.35E+00	6.72E-02	1.14E-01	3.77E-01	6.65E+01	3.17E-01	7.55E-01	2.79E+00
Ce-144	1.61E+01	8.16E-01	1.37E+00	4.56E+00	4.53E+00	2.14E-02	5.23E-02	1.95E-01
La-140	1.23E+00	6.09E-02	1.02E-01	3.44E-01	2.70E+00	1.24E-02	3.15E-02	1.16E-01
Pu-239	3.20E-04	1.58E-05	2.70E-05	8.93E-05	8.78E-05	4.12E-07	1.01E-06	3.77E-06

C-3.2.1 Doses

Table C-26. 250 MW(t) pebble bed 700°C ROT—water ingress—Cases A and B—400 m from release (rem).

Nuclide	Case A/EAB (400 m)/TEDE		Case B/LPZ (400 m)/TEDE	
	Short	Long	Short	Long
Xe-133	5.42E-06		5.42E-06	5.86E-05
Kr-85	2.45E-09		2.45E-09	3.42E-08
Kr-88	1.83E-04		1.83E-04	5.38E-09
I-131	1.28E-02		1.28E-02	2.74E-01
I-133	3.54E-03		3.54E-03	1.49E-02
Te-132	6.56E-03		6.56E-03	1.24E-01
Cs-137	3.29E-02		3.29E-02	3.41E-02
Cs-134	7.92E-03		7.92E-03	6.05E-02
Sr-90	2.83E-02		2.83E-02	4.76E-01
Ag-110m	1.98E-01		1.98E-01	2.06E-01
Ag-111	2.40E-01		2.40E-01	1.20E+00
Sb-125	4.40E-05		4.40E-05	3.05E-05
Ru-103	6.98E-04		6.98E-04	2.43E-02
Ce-144	3.22E-01		3.22E-01	5.84E-02
La-140	6.36E-04		6.36E-04	7.33E-04
Pu-239	3.68E-03		3.68E-03	9.66E-04
Sum	8.58E-01	0.00E+00	8.58E-01	2.47E+00
TOTAL	8.58E-01		3.33E+00	
Limits (rem)	25			

Table C-27. 250 MW(t) pebble bed 700°C ROT—water ingress—Cases C and D—400 m from release (rem).

Nuclide	CASE C/Inh, grndshine, cldshine/TEDE		CASE D/Inh, grndshine, cldshine/Thyroid	
	Short	Long	Short	Long
Xe-133	2.17E-06	1.22E-05		
Kr-85	8.96E-10	6.94E-09		
Kr-88	8.16E-05	8.07E-10		
I-131	3.35E-04	1.94E-03	1.06E-02	6.19E-02
I-133	1.16E-04	1.11E-04	3.16E-03	3.00E-03
Te-132	2.01E-04	8.32E-04	3.24E-03	1.35E-02
Cs-137	9.13E-04	2.19E-04		
Cs-134	2.13E-04	3.44E-04		
Sr-90	1.01E-03	2.80E-03		
Ag-110m	5.42E-03	1.25E-03		
Ag-111	7.69E-03	7.15E-03		
Sb-125	1.21E-06	1.75E-07		
Ru-103	2.20E-05	1.65E-04		
Ce-144	9.34E-03	4.22E-04		
La-140	1.68E-05	4.69E-06		
Pu-239	1.51E-04	6.72E-06		
Sum	2.55E-02	1.53E-02	1.70E-02	7.84E-02
TOTAL	4.08E-02		9.54E-02	
Limits (rem)	1		5	

Table C-28. 250 MW(t) Pebble Bed 700°C ROT—water ingress—Cases E and F, infant and adult—400 m from release (rem).

Nuclide	CASE E/Ingestion – milk/ EDE (infant)		CASE F/Ingestion – milk/ Thyroid (infant)		CASE E/Ingestion – milk/ EDE (adult)		CASE F/Ingestion – milk/ Thyroid (adult)	
	Short	Long	Short	Long	Short	Long	Short	Long
Xe-133	–	–	–	–	–	–	–	–
Kr-85	–	–	–	–	–	–	–	–
Kr-88	–	–	–	–	–	–	–	–
I-131	1.26E-02	7.03E-02	2.50E-01	1.40E+00	7.80E-04	4.37E-03	2.58E-02	1.44E-01
I-133	9.75E-04	8.82E-04	1.90E-02	1.71E-02	4.39E-05	3.98E-05	1.43E-03	1.29E-03
Te-132	4.70E-05	1.85E-04	6.38E-04	2.51E-03	1.96E-06	7.70E-06	4.59E-05	1.80E-04
Cs-137	1.21E-02	2.85E-03	1.08E-02	2.56E-03	6.15E-03	1.45E-03	5.74E-03	1.35E-03
Cs-134	2.25E-03	3.56E-03	2.22E-03	3.53E-03	1.37E-03	2.17E-03	1.22E-03	1.93E-03
Sr-90	3.81E-03	1.01E-02	1.99E-04	5.26E-04	5.15E-04	1.36E-03	2.02E-05	5.34E-05
Ag-110m	6.28E-02	1.42E-02	1.69E-02	3.82E-03	6.01E-03	1.36E-03	3.73E-04	8.44E-05
Ag-111	2.27E-01	2.04E-01	6.16E-03	5.51E-03	1.73E-02	1.55E-02	9.46E-05	8.45E-05
Sb-125	1.63E-06	2.45E-07	1.71E-06	2.57E-07	9.57E-08	1.44E-08	4.80E-09	7.22E-10
Ru-103	1.27E-08	9.44E-08	1.97E-09	1.47E-08	1.16E-09	8.69E-09	8.80E-11	6.56E-10
Ce-144	7.33E-05	3.18E-06	9.30E-07	4.03E-08	4.97E-06	2.15E-07	4.49E-09	1.94E-10
La-140	1.47E-07	4.06E-08	9.44E-10	2.60E-10	1.36E-08	3.75E-09	3.84E-11	1.05E-11
Pu-239	5.16E-10	2.19E-11	6.78E-11	2.88E-12	1.37E-12	5.83E-14	7.35E-18	3.12E-19
Sum	3.22E-01	3.06E-01	3.06E-01	1.43E+00	3.22E-02	2.63E-02	3.48E-02	1.49E-01
TOTAL	6.28E-01		1.74E+00		5.84E-02		1.84E-01	
Limits (rem)	0.5		1.5		0.5		1.5	

Table C-29. 250 MW(t) pebble bed 700°C ROT—water ingress—Cases E and F, infant and adult—800 m from release (rem).

Nuclide	CASE E/Ingestion – milk/ EDE (infant)		CASE F/Ingestion – milk/ Thyroid (infant)		CASE E/Ingestion – milk/ EDE (adult)		CASE F/Ingestion – milk/ Thyroid (adult)	
	Short	Long	Short	Long	Short	Long	Short	Long
Xe-133	–	–	–	–	–	–	–	–
Kr-85	–	–	–	–	–	–	–	–
Kr-88	–	–	–	–	–	–	–	–
I-131	4.63E-03	2.62E-02	9.21E-02	5.21E-01	2.87E-04	1.63E-03	9.48E-03	5.38E-02
I-133	3.57E-04	3.27E-04	6.95E-03	6.37E-03	1.60E-05	1.47E-05	5.22E-04	4.79E-04
Te-132	1.73E-05	6.88E-05	2.34E-04	9.33E-04	7.20E-07	2.87E-06	1.68E-05	6.73E-05
Cs-137	4.45E-03	1.06E-03	3.98E-03	9.51E-04	2.26E-03	5.38E-04	2.11E-03	5.03E-04
Cs-134	8.26E-04	1.33E-03	8.15E-04	1.31E-03	5.03E-04	8.07E-04	4.47E-04	7.19E-04
Sr-90	1.40E-03	3.75E-03	7.28E-05	1.95E-04	1.89E-04	5.05E-04	7.40E-06	1.98E-05
Ag-110m	2.30E-02	5.27E-03	6.18E-03	1.42E-03	2.21E-03	5.07E-04	1.37E-04	3.15E-05
Ag-111	8.37E-02	7.60E-02	2.26E-03	2.05E-03	6.36E-03	5.79E-03	3.47E-05	3.15E-05
Sb-125	5.97E-07	9.07E-08	6.24E-07	9.48E-08	3.49E-08	5.32E-09	1.76E-09	2.67E-10
Ru-103	4.65E-09	3.52E-08	7.24E-10	5.47E-09	4.28E-10	3.23E-09	3.24E-11	2.45E-10
Ce-144	2.69E-05	1.18E-06	3.40E-07	1.50E-08	1.82E-06	8.01E-08	1.65E-09	7.22E-11
La-140	5.41E-08	1.51E-08	3.46E-10	9.67E-11	5.02E-09	1.40E-09	1.40E-11	3.94E-12
Pu-239	1.89E-10	8.16E-12	2.48E-11	1.07E-12	5.02E-13	2.16E-14	2.69E-18	1.16E-19
Sum	1.18E-01	1.14E-01	1.13E-01	5.34E-01	1.18E-02	9.79E-03	1.28E-02	5.56E-02
TOTAL	2.32E-01		6.47E-01		2.16E-02		6.84E-02	
Limits (rem)	0.5		1.5		0.5		1.5	

Table C-30. 250 MW(t) pebble bed 700°C ROT—water ingress—Cases E and F, infant and adult—1600 m from release (rem).

Nuclide	CASE E/Ingestion – milk/ EDE (infant)		CASE F/Ingestion – milk/ Thyroid (infant)		CASE E/Ingestion – milk/ EDE (adult)		CASE F/Ingestion – milk/ Thyroid (adult)	
	Short	Long	Short	Long	Short	Long	Short	Long
Xe-133	–	–	–	–	–	–	–	–
Kr-85	–	–	–	–	–	–	–	–
Kr-88	–	–	–	–	–	–	–	–
I-131	1.69E-03	9.88E-03	3.35E-02	1.97E-01	1.05E-04	6.16E-04	3.46E-03	2.03E-02
I-133	1.29E-04	1.22E-04	2.51E-03	2.40E-03	5.82E-06	5.54E-06	1.89E-04	1.80E-04
Te-132	6.29E-06	2.60E-05	8.56E-05	3.51E-04	2.62E-07	1.08E-06	6.14E-06	2.54E-05
Cs-137	1.62E-03	4.02E-04	1.45E-03	3.59E-04	8.25E-04	2.04E-04	7.69E-04	1.90E-04
Cs-134	3.00E-04	5.01E-04	2.98E-04	4.95E-04	1.83E-04	3.05E-04	1.63E-04	2.72E-04
Sr-90	5.11E-04	1.41E-03	2.66E-05	7.37E-05	6.87E-05	1.90E-04	2.70E-06	7.47E-06
Ag-110m	8.36E-03	1.98E-03	2.25E-03	5.35E-04	8.06E-04	1.91E-04	4.99E-05	1.19E-05
Ag-111	3.05E-02	2.87E-02	8.24E-04	7.77E-04	2.32E-03	2.18E-03	1.27E-05	1.19E-05
Sb-125	2.17E-07	3.42E-08	2.27E-07	3.54E-08	1.27E-08	1.99E-09	6.40E-10	1.00E-10
Ru-103	1.70E-09	1.33E-08	2.65E-10	2.07E-09	1.56E-10	1.22E-09	1.19E-11	9.21E-11
Ce-144	9.80E-06	4.44E-07	1.24E-07	5.65E-09	6.64E-07	3.02E-08	6.00E-10	2.72E-11
La-140	1.97E-08	5.67E-09	1.26E-10	3.65E-11	1.82E-09	5.26E-10	5.12E-12	1.48E-12
Pu-239	6.89E-11	3.06E-12	9.05E-12	4.02E-13	1.83E-13	8.14E-15	9.78E-19	4.36E-20
Sum	4.31E-02	4.30E-02	4.10E-02	2.02E-01	4.32E-03	3.70E-03	4.66E-03	2.10E-02
TOTAL	8.62E-02		2.43E-01		8.01E-03		2.57E-02	
Limits (rem)	0.5		1.5		0.5		1.5	

Appendix D

Key Limitations and Assumptions Used in the Scoping Analyses

Appendix D

Key Limitations and Assumptions Used in the Scoping Analyses

1. The results of these analyses are not intended for, nor are they suitable for, submittal to regulatory authorities as part of the licensing basis for the high temperature gas-cooled reactor (HTGR). The analyses are intended solely to provide insights and internal guidance for the Next Generation Nuclear Plant (NGNP) Project.
2. In the absence of certain technical information to support a detailed mechanistic assessment, the NGNP Project utilized a simplified model to perform parametric scoping analyses of the release and retention parameters that define the source terms for a modular HTGR.
3. The results are based on accident scenarios for a single HTGR module. Additional analyses will be needed to confirm that project objectives are satisfied for multi-module HTGR facilities for postulated events that may result in fission product releases from more than one module.
4. Based on safety analyses performed for prior gas-cooled reactor studies, breaks in the helium pressure boundary (HPB) and water ingress events were assumed to pose the greatest challenges with respect to offsite dose consequences.
5. Barrier performance
 - Barrier performance was estimated based on expert opinion. As more testing is completed under the NGNP Technology Development Program and further design development is completed, the assumed values for the barrier performance allocations can be revised, as necessary, and detailed accident analyses can be performed.
 - Radionuclide retention of the barriers associated with fuel and graphite was estimated based on current capabilities of the technology as recently demonstrated in the Advanced Gas Reactor fuel program.
 - Radionuclide retention of the HPB and reactor building under accident conditions were intentionally estimated on a conservative basis to account for uncertainty in the underlying phenomenology and so as not to constrain the development of design.
 - In assessing against the NRC siting criteria, the analyses utilized conservative estimates regarding the performance of the radionuclide release barriers, and did not credit any fission product release attenuation by the reactor building.
 - In assessing against the Environmental Protection Agency plume exposure Protective Action Guides (PAGs), the analyses utilized realistic (mean) estimates on the performance of the radionuclide barriers including the reactor building.
6. All radionuclides within a fission product class in the source term are assumed to have the same release and attenuation factors based on physical and chemical properties.
7. Each fission product group in the source term contains the key radionuclides identified via past modular HTGR analyses that are expected to account for the majority of the offsite dose.
8. To account for uncertainty in fuel and barrier performance, the review team assigned 50% and 95% confidence values to the defect fractions and attenuation factors upon which the mechanistic source terms are based. Fuel defect fraction uncertainties were assumed to be normally distributed. Attenuation factor uncertainties were assumed to be lognormally distributed.

9. Individual radionuclide inventories used in the evaluation were based on the 600 MW(t) prismatic configuration. Radionuclide inventories for the 250 MW(t) pebble bed configuration were scaled based on that inventory. It is recognized that the scaling approach is an approximation that does not take into account the detailed differences between the pebble and prismatic fuel configurations and the detailed differences between the operating conditions of the two reactors.
10. Time dependent radionuclide releases were grouped into two steps: an early and delayed release.
11. Atmospheric conditions (X/Q) assumed for the PAG analyses were based on mean conditions, consistent with regulatory guidance. Less probable, more stable (i.e., higher X/Q) atmospheric conditions would cause all of the dose results to increase.