


Technical Evaluation Study

Project No. 23843

Nuclear-Integrated Ammonia Production Analysis



The INL is a
U.S. Department of Energy
National Laboratory
operated by
Battelle Energy Alliance






The INL is a U.S. Department of Energy National Laboratory
operated by Battelle Energy Alliance.

Idaho National Laboratory

NUCLEAR-INTEGRATED AMMONIA PRODUCTION ANALYSIS		Identifier:	TEV-666
		Revision:	2
		Effective Date:	05/25/2010
		Page: 1 of 69	
NGNP Project	Technical Evaluation Study (TEV)		eCR Number: <u>581221</u>

Signatures

Signature and Typed or Printed Name	Signature Code	Date (mm/dd/yyyy)	Organization/Discipline
 R. A. Wood	P	05/25/2010	NGNP Engineering Support
 R. D. Boardman	A	25 MAY 2010	NGNP Engineering Support
 M. W. Patterson	C	5/25/2010	NGNP Engineering Technical Manager

P For Preparer of the document.

A For Approval: This is for non-owner approvals that may be required as directed by a given program or project. This signature may not be applicable for all uses of this form.

C For documented review and concurrence.

Note: Applicable QLD: REC-000101

REVISION LOG

[illegible]

NUCLEAR-INTEGRATED AMMONIA PRODUCTION ANALYSIS	Identifier:	TEV-666
	Revision:	2
	Effective Date:	05/25/2010

EXECUTIVE SUMMARY

This technical evaluation (TEV) has been prepared as part of a study for the Next Generation Nuclear Plant (NGNP) Project to evaluate integration of high-temperature gas-cooled reactor (HTGR) technology with conventional chemical processes. This TEV addresses the integration of an HTGR with the production of ammonia and derivatives such as urea, nitric acid, and ammonium nitrate.

The HTGR can produce steam, high-temperature helium that can be used for process heat, and/or electricity. In conventional chemical processes these products are generated by the combustion of fossil fuels such as coal and natural gas, resulting in significant emissions of greenhouse gases (GHGs) such as carbon dioxide. Heat or electricity produced in an HTGR could be used to supply process heat or electricity to conventional chemical processes without generating any GHGs. This report describes how nuclear-generated heat or electricity could be integrated into conventional coal-to-ammonia and gas-to-ammonia processes and provides a preliminary economic analysis of the conventional and nuclear-integrated options.

For the gas-to-ammonia cases, results indicate that a single 450 MW_t HTGR is required to support production of 3,360 tons per day of ammonia. Substituting nuclear heat for natural gas combustion decreases natural gas consumption by 18%. As a result, CO₂ emissions are decreased by 70% from the conventional gas-to-ammonia case.

For the coal-to-ammonia case, a compelling need for HTGR heat integration was not identified. However, the coal-to-ammonia process is a net consumer of electricity; hence, production of electricity using an HTGR could be considered to supplement this process.

HTGR-integrated high-temperature steam electrolysis (HTSE) was also considered to supply hydrogen to the ammonia process. In this scenario, coal usage for hydrogen production can be completely eliminated; hence, the process configuration is radically altered and no longer resembles the conventional coal-to-ammonia case. Two such configurations were considered in this study, and results indicate that approximately four 600 MW_t HTGRs are required to support production of 3,360 tons per day of ammonia. Substituting hydrogen from water via nuclear-integrated HTSE instead of natural gas reforming or coal gasification (followed by shift conversion) eliminates fossil fuel consumption and the CO₂ emissions associated with these processes.

The following table outlines the urea prices necessary for a 12% internal rate of return (IRR) for the cases analyzed with and without a carbon tax as well as assessing the impact of reducing the HTGR capital cost by 30%. Average and historical high urea prices are also presented.

NUCLEAR-INTEGRATED AMMONIA PRODUCTION ANALYSIS	Identifier:	TEV-666
	Revision:	2
	Effective Date:	05/25/2010
Page: 4 of 69		

Table ES 1. Ammonia production economic results summary for a 12% IRR.

Technology	Urea Price (\$/ton)*				
	No CO ₂ Tax			\$50/ton CO ₂ Tax	\$100/ton CO ₂ Tax
	Low Nat. Gas	Avg. Nat. Gas	High Nat. Gas	Avg. Nat. Gas	Avg. Nat. Gas
Conventional Gas-to-Ammonia	244.36	272.23	348.85	302.09	331.96
HTGR Integrated Gas-to-Ammonia	263.32	286.12	348.81	306.73	327.34
HTGR Integrated Gas-to-Ammonia, -30% HTGR Cost	249.88	272.68	335.37	293.29	313.90
HTSE Integrated Gas-to-Ammonia, N ₂ from Combustion	525.86	537.26	568.61	537.36	537.47
HTSE Integrated Gas-to-Ammonia, N ₂ from ASU	482.14	493.54	524.89	493.64	493.75
US Urea Price, Average	396.42				
US Urea Price, High (Apr. 2008)	565.80				
*No carbon sequestration assumed for this analysis					

Based on these results, integration of nuclear heat into a gas-to-ammonia process appears promising for the following reasons:

1. Urea selling price is comparable to the average U.S. selling price and the calculated production price for a conventional gas-to-ammonia process
2. Natural gas consumption can be reduced, thereby prolonging the availability of fossil resources in the U.S.
3. Carbon emissions can be significantly reduced.

Although the HTSE-integrated flowsheets offer even greater benefits in terms of reduced natural gas consumption and carbon emissions, at present these flowsheets do not appear to be economically viable.

NUCLEAR-INTEGRATED AMMONIA PRODUCTION ANALYSIS	Identifier: TEV-666 Revision: 2 Effective Date: 05/25/2010 Page: 5 of 69
---	--

CONTENTS

EXECUTIVE SUMMARY	3
ACRONYMS AND NOMENCLATURE	7
1. INTRODUCTION	9
2. PROCESS MODELING OVERVIEW.....	10
2.1 Conventional Coal-to-Ammonia Case	12
2.2 Conventional Natural Gas-to-Ammonia Case	18
2.3 Nuclear-Integrated Coal-to-Ammonia Case	21
2.4 Nuclear-Integrated Natural Gas-to-Ammonia Case.....	23
2.5 HTSE Hydrogen-to-Ammonia Case (Option 1: H ₂ /Air Combustion as the N ₂ Source).....	25
2.6 HTSE Hydrogen-to-Ammonia Case (Option 2: Cryogenic ASU as the N ₂ Source)	28
3. PROCESS MODELING RESULTS.....	31
4. ECONOMIC MODELING OVERVIEW.....	36
4.1 Capital Cost Estimation	36
4.2 Estimation of Revenue.....	45
4.3 Estimation of Manufacturing Costs	46
4.4 Economic Comparison.....	52
4.4.1 Cash Flow.....	54
4.4.2 Internal Rate of Return.....	55
5. ECONOMIC MODELING RESULTS.....	55
5.1 Coal-to-Ammonia Economic Results	55
5.2 Gas-to-Ammonia and HTSE-to-Ammonia Economic Results	57
6. COAL-TO-AMMONIA CONCLUSIONS.....	65
7. GAS-TO-AMMONIA CONCLUSIONS.....	66

NUCLEAR-INTEGRATED AMMONIA PRODUCTION ANALYSIS	Identifier:	TEV-666	
	Revision:	2	
	Effective Date:	05/25/2010	Page: 6 of 69

8. FUTURE WORK AND RECOMMENDATIONS67

9. REFERENCES67

10. APPENDIXES69

NUCLEAR-INTEGRATED AMMONIA PRODUCTION ANALYSIS	Identifier: TEV-666 Revision: 2 Effective Date: 05/25/2010
---	--

Page: 7 of 69

ACRONYMS AND NOMENCLATURE

AACE	Association for the Advancement of Cost Engineering
ASU	air separation unit
ATCF	after tax cash flow
BTCF	before tax cash flow
CEPCI	chemical engineering plant cost index
CMD	coal milling and drying
COPE	Claus oxygen-based process expansion
CTL	coal to liquids
DOE	Department of Energy
GT-MHR	gas turbine-modular helium reactor
HRSG	heat recovery steam generator
HTSE	high temperature steam electrolysis
HTGR	high temperature gas reactor
IHX	intermediate heat exchanger
INL	Idaho National Laboratory
IRR	internal rate of return
MACRS	modified accelerated cost recovery system
MARR	minimum annual rate of return
MMSCF	1,000,000 standard cubic feet
MSCF	1,000 standard cubic feet
NETL	National Energy Technology Laboratory
NGNP	Next Generation Nuclear Plant
NIBT	net income before taxes
O&M	operations and maintenance
PSA	pressure swing absorption
PW	present worth
SCOT	Shell Claus offgas treatment
SCR	Selective catalytic reduction
SGCP	Shell coal gasification process
SMR	steam methane reformer
TCI	total capital investment
TEV	Technical Evaluation

NUCLEAR-INTEGRATED AMMONIA PRODUCTION ANALYSIS	Identifier:	TEV-666
	Revision:	2
	Effective Date:	05/25/2010
Page: 8 of 69		

UAN	Urea/ammonium nitrate
USDA	United States Department of Agriculture
C_1	cost of equipment with capacity q_1
C_2	cost of equipment with capacity q_2
C_k	capital expenditures
d_k	depreciation
E_k	cash outflows
i'	IRR
k	year
n	exponential factor
q_1	equipment capacity
q_2	equipment capacity
R_k	revenues
t	tax rate
T_k	income taxes

NUCLEAR-INTEGRATED AMMONIA PRODUCTION ANALYSIS	Identifier:	TEV-666	Page: 9 of 69
	Revision:	2	
	Effective Date:	05/25/2010	

1. INTRODUCTION

This technical evaluation (TEV) has been prepared as part of a study for the Next Generation Nuclear Plant (NGNP) Project to evaluate integration of high-temperature gas-cooled reactor (HTGR) technology with conventional chemical processes. The NGNP Project is being conducted under U.S. Department of Energy (DOE) direction to meet a national strategic need identified in the *Energy Policy Act* to promote reliance on safe, clean, economic nuclear energy and to establish a greenhouse-gas-free technology for the production of hydrogen. The NGNP represents an integration of high-temperature reactor technology with advanced hydrogen, electricity, and process heat production capabilities, thereby meeting the mission need identified by DOE. The strategic goal of the NGNP Project is to broaden the environmental and economic benefits of nuclear energy in the U.S. economy by demonstrating its applicability to market sectors not being served by light water reactors.

The HTGR produces steam, high-temperature helium that can be used for process heat, and/or electricity. A summary of these products and a brief description is shown in Table 1. For this study the HTGR outlet temperature is assumed to be 750°C; this reflects the initial HTGR design and assumes a more conservative outlet temperature. Eventually, temperatures of 950°C are anticipated. Additionally, a 50°C temperature approach is assumed between the primary and secondary helium loops, if helium is the delivered working fluid. As a result, the helium stream available for heat exchange is assumed to be at 700°C. In conventional chemical processes, these products are generated by the combustion of fossil fuels such as coal and natural gas, resulting in significant emissions of greenhouse gases (GHGs) such as carbon dioxide. Heat or electricity produced in an HTGR could be used to supply process heat or electricity to conventional chemical processes while generating minimal GHGs. The use of an HTGR to supply process heat or electricity to conventional processes is referred to as a nuclear-integrated process. This report describes how nuclear-generated heat or electricity could be integrated into conventional processes and provides a preliminary economic analysis to show which nuclear-integrated processes compare favorably with conventional processes.

Table 1. Projected outputs of the NGNP.

HTGR Product	Product Description
Steam	540°C and 17 MPa
High-Temperature Helium	Delivered at 700°C and 9.1 MPa
Electricity	Generated by Rankine cycle with 40% thermal efficiency

This TEV addresses potential integration opportunities for production of ammonia and derivatives such as urea, nitric acid, and ammonium nitrate. The HTGR would produce electricity, heat, and/or hydrogen and be located near the ammonia production facility. Details of the specific cases considered are described in Section 2 of this report. A separate study should be conducted to assess the optimal siting of the HTGR with respect

NUCLEAR-INTEGRATED AMMONIA PRODUCTION ANALYSIS	Identifier:	TEV-666	
	Revision:	2	
	Effective Date:	05/25/2010	Page: 10 of 69

to the ammonia facilities, balancing safety concerns associated with separation distance and heat losses associated with transporting high-temperature heat long distances.

The Advanced Process and Decision Systems Department at Idaho National Laboratory (INL) has spent several years developing detailed process simulations of chemical processes, typically utilizing fossil fuels such as coal, biomass, or natural gas as the feedstock. These simulations have been developed using Aspen Plus, a state-of-the-art, steady-state chemical process simulator (Aspen 2006). This study makes extensive use of these models and the modeling capability at INL to evaluate the integration of HTGR technology with commercial ammonia production methods. The outputs from the material and energy balances generated in Aspen Plus were utilized as inputs into the Excel economic models (Excel 2007).

This TEV assumes familiarity with Aspen Plus; hence, a detailed explanation of the software capabilities, thermodynamic packages, unit operation models, and solver routines is beyond the scope of this TEV. Similarly, a familiarity with gasification, steam methane reforming (SMR), ammonia synthesis, urea synthesis, nitric acid synthesis, and common gas purification technologies is assumed. Hence, a thorough explanation of these technologies is also considered to be beyond the scope of this TEV.

This TEV first presents an overview of the process modeling performed for each case. Afterwards, the results of the process modeling are discussed with emphasis placed on the impact of the HTGR integration. Next, an overview of the economic modeling is presented, followed by results of this modeling. Again, emphasis is placed on the impact of the HTGR integration. Finally, overall conclusions for the coal- and natural gas-based cases are discussed separately. These conclusions also focus on the impact of the HTGR integration.

2. PROCESS MODELING OVERVIEW

Plant models for the coal-to-ammonia, natural-gas-to-ammonia, and high-temperature steam electrolysis (HTSE) hydrogen-to-ammonia process were developed using Aspen Plus (Aspen 2006). Because of the size and complexity of the process modeled, the simulation was constructed using “hierarchy” blocks. A hierarchy block is a method for nesting one simulation within another simulation. In this manner, submodels for each major plant section were constructed separately and then combined to represent the entire process.

Significant emphasis in the models has been placed on heat integration between different parts of the plant. To facilitate energy tracking, Aspen’s “utility” blocks were used extensively. Utility blocks tracked electricity, steam, and cooling water usage. Aspen Plus Version 2006 (Build 20.0.3.4127), run under Windows XP SP3 on computer ID 410530 was used for all modeling calculations.

The original models for the fossil portion of the plant were developed using English units, which is common industrial practice in the United States. Nuclear plants typically

NUCLEAR-INTEGRATED AMMONIA PRODUCTION ANALYSIS	Identifier: TEV-666	Page: 11 of 69
	Revision: 2	
	Effective Date: 05/25/2010	

use metric units; hence, this report contains both English and metric units depending on the context of the information presented.

Six cases were originally identified for modeling:

- Conventional coal-to-ammonia process
- Conventional natural gas-to-ammonia process
- Nuclear-integrated coal-to-ammonia process
- Nuclear-integrated natural-gas-to-ammonia process
- HTSE hydrogen-to-ammonia process using H₂/air combustion as the nitrogen source
- HTSE hydrogen-to-ammonia process using cryogenic air separation as the nitrogen source.

Producing ammonia from natural gas and coal are fundamentally different. Natural gas is hydrogen rich with a carbon-to-hydrogen ratio of 1:4. Coal is hydrogen limited with a carbon-to-hydrogen ratio of ~ 1:0.8. Coal requires significant capital to gasify and to clean up the resulting syngas of CO and H₂. CO is then used to produce additional H₂ via the water-gas shift reaction:



Excess heat is generated in the coal-based case due to carbon rejection (as CO₂).

For the natural-gas-to-ammonia process, nuclear heat was utilized, whereas for the coal-to-ammonia process, both nuclear heat and HTSE hydrogen were utilized. It is also possible to produce ammonia using HTSE as the hydrogen source rather than a fossil fuel. For this scenario, two distinct options were investigated for supplying nitrogen to the ammonia synthesis unit.

For the coal cases, a generic Illinois #6 coal was used as the feedstock due to its high availability and use within the United States. A dry-fed, entrained-flow, slagging gasifier (similar to a Shell, Uhde, or Siemens design) was selected as the gasification technology for this evaluation. For the natural gas cases, gas composition was taken from data published by Northwest Gas Association. Capacities for the coal cases were set based on a nominal gasifier throughput of 3,600 tonne/day, representing a commercial Shell gasifier. This resulted in an intermediate ammonia production rate of 3,360 ton/day. The capacity of a typical ammonia plant is between 1,500 and 2,000 ton/day; hence, this production rate is roughly equivalent to a 2-train ammonia plant configuration. For easy comparison of the cases, the natural gas cases were scaled to produce an equivalent amount of ammonia, with slight adjustments to compensate for differences in ammonia purity.

NUCLEAR-INTEGRATED AMMONIA PRODUCTION ANALYSIS	Identifier:	TEV-666
	Revision:	2
	Effective Date:	05/25/2010
		Page: 12 of 69

Because there are numerous derivative products that can be produced from ammonia, the models were constructed to include the most common derivative products: nitric acid, ammonium nitrate, and urea. By varying ammonia flow to each of these downstream processes, numerous end-product mixes could be simulated. For this study, the split of derivative products was adjusted to produce ammonium nitrate and urea in the right ratio for urea/ammonium nitrate (UAN) 32 synthesis (urea ammonium nitrate solution containing 32 wt% nitrogen—made by combining ammonium nitrate, urea, and water in a 45/35/20 blend). Hence, all modeled cases produced 2,939 ton/day of urea and 3,779 ton/day of ammonium nitrate.

Urea production requires CO_2 as a feed to the process. For the four fossil-based cases, CO_2 is readily available. For the two cases utilizing HTSE for the hydrogen supply, a CO_2 supply is not readily available and must be produced to support urea manufacture. For these cases, natural gas is burned to produce the required CO_2 . While coal could have been selected for this purpose, natural gas is preferred for its much simpler gas cleanup requirements.

For the Aspen models described in this analysis, rigorous submodels of the nuclear power cycle and high-temperature electrolysis have not yet been integrated. Results for the nuclear power cycle and HTSE were calculated separately using the UNISIM modeling package. Cooling water requirements for HTSE were then estimated and added to the overall Aspen model results. Water consumption for the HTGR and associated power cycle has not been included, as a detailed water balance for the HTGR has not been completed at this time.

The general model descriptions for all cases are presented below. Although the method of producing syngas varies from case to case, production of ammonia, nitric acid, ammonium nitrate, and urea are essentially unchanged between cases.

2.1 Conventional Coal-to-Ammonia Case

Figure 1 shows the block flow diagram for the conventional coal-to-ammonia case. The proposed process includes unit operations for air separation, coal milling and drying, coal gasification, syngas cleaning and conditioning, sulfur recovery, CO_2 purification/compression, ammonia synthesis, nitric acid synthesis, ammonium nitrate synthesis, urea synthesis, power production, cooling towers, and water treatment. Each plant area is briefly described below. For each description, the name capitalized and enclosed in parentheses corresponds to the name of the hierarchy block within the Aspen process model.

NUCLEAR-INTEGRATED AMMONIA PRODUCTION ANALYSIS

Identifier: TEV-666
 Revision: 2
 Effective Date: 05/25/2010

Page: 13 of 69




Figure 1. Block flow diagram for the conventional coal-to-ammonia process.

- Air Separation (ASU)** – Oxygen is produced via a standard cryogenic Linde-type air separation unit (ASU) that utilizes two distillation columns and extensive heat exchange in a cold box (Linde 2008). The oxygen product is used for gasification. An O_2 purity of 99.5% is specified, although a 95% O_2 purity plant would also be suitable for this application. Oxygen demand for gasification drives the size of the ASU; hence, in addition to the primary nitrogen demand for ammonia synthesis, excess nitrogen is also available for other plant uses such as coal drying and transport.
- Coal Milling and Drying (CMD)** – Coal is pulverized to below 90 μm using a roller mill to ensure efficient gasification. Currently, coal milling power consumption is modeled based on the power calculated by Aspen assuming a Hardgrove grindability index of 60. Drying is accomplished simultaneously using a heated inert gas stream. The gas stream removes evaporated water as it sweeps the pulverized coal through an internal classifier for collection in a baghouse. Inert nitrogen from the ASU is heated by firing clean syngas in a burner. This nitrogen is mixed with this

NUCLEAR-INTEGRATED AMMONIA PRODUCTION ANALYSIS	Identifier:	TEV-666
	Revision:	2
	Effective Date:	05/25/2010 Page: 14 of 69

hot gas to create a hot inert gas stream, which dries the Illinois coal down to 6% moisture (Shell 2005). Nitrogen is also used as transport gas for the coal from the baghouse to the lock hoppers. Pressurized nitrogen is used to transport the dry, sized coal into the gasifier. The transport gas is assumed to be 0.15 pounds of gas per pound of solids. The amount of N₂ vented during depressurization of the feed hopper is estimated using the ideal gas law.

- Gasification (GASIFIER)** – The dry coal is gasified at 2,800°F using an entrained-flow, dry-fed, slagging, oxygen-blown gasifier. Oxygen is fed to the gasifier to achieve the outlet temperature of 2,800°F, while steam (700 psi) is fed such that the mass ratio of dry coal to steam is 7:1. This ratio was selected in order to inhibit methane formation in the gasifier. Although some heat is recovered in the membrane wall of the gasifier, the majority of the heat recovery is accomplished downstream of the gasifier in the syngas coolers, which cool the gas down to 464°F, generating high-pressure steam (Shell 2004). The syngas is further cooled by a water quench. A portion of the quenched syngas is returned to gasifier effluent to cool the particle-laden gas to below the ash-softening point. Makeup water is provided to the quench loop to achieve a blowdown rate of approximately 5% around the quench loop. This blowdown is then used in the slag quench loop. Of the water from the slag quench loop, 2.5% is assumed to be sent to water treatment to avoid any buildup of contaminants.
- Syngas Conditioning (GAS-CLN)** – After gasification, the syngas is passed through sour shift reactors to maximize H₂ production via the water gas shift reaction as previously given in Equation 1. Steam (700 psi) is added to the syngas stream to maintain the water concentration necessary for the water gas shift reaction (steam-to-dry gas molar ratio of 1.2 is currently specified). To minimize the steam requirement, heat recuperation around the shift converters is employed in conjunction with a saturation/desaturation water recycle loop. Water recycle is limited in order to achieve a minimum inlet temperature to the second reactor of 450°F. Remaining condensed water is sent to water treatment to avoid high concentrations of ammonia and chloride compounds in the shift loop. Elemental mercury is then captured in a mercury guard bed. The syngas is further treated in an absorber with a solvent (a mixture of homologues of the dimethylether of polyethylene glycol) that acts as a chemical solvent for the removal of CO₂, H₂S, and COS (Selexol process). Absorption is carefully controlled to remove nearly all of the sulfur compounds while selectively removing only enough CO₂ to meet the downstream requirement for urea production. Additional removal of CO₂ is possible but would increase power consumption of the absorption process. The H₂S-rich stream is assumed to contain approximately 55% H₂S, with the

NUCLEAR-INTEGRATED AMMONIA PRODUCTION ANALYSIS	Identifier:	TEV-666
	Revision:	2
	Effective Date:	05/25/2010
Page: 15 of 69		

remainder being CO₂ (Breckenridge 2000). H₂S containing gas from the sulfur reduction unit is also sent to the Selexol process for sulfur removal. Utility usage is calculated based on values presented in literature for the Selexol process (Burr 2008).

The sulfur-free gas is further purified using pressure swing adsorption (PSA) to produce a purified H₂ stream for ammonia synthesis. Nitrogen from the air separation unit is then mixed with the purified hydrogen to make a syngas suitable for ammonia synthesis (H₂-to-N₂ molar ratio of 3.0).

- Sulfur Plant (CLAUS and S-REDUCT)** – Sulfur recovery is based on the Claus process. The Illinois coal has a sufficiently high sulfur content, which can create an acid gas stream with up to 60% H₂S. As a result, a straight-through Claus process can be used. In order to achieve optimal sulfur recovery, air flow to the Claus furnace is adjusted to achieve a molar ratio of 0.55:1 O₂ to H₂S. For this particular flow sheet, a Claus Oxygen-based Process Expansion (COPE) process was selected that uses pure oxygen as the oxidant rather than air. The advantage of this process over a conventional Claus process is that it minimizes inert gas recycle (N₂) to the Selexol unit, thus ensuring that a relatively pure stream of CO₂ can be produced for urea synthesis (Kohl 1997). Gas recycle is employed in the COPE process to limit the maximum temperature in the Claus furnace. Tail gas from the Claus unit is hydrogenated over a catalyst to convert the remaining sulfur species to H₂S, and this stream is recycled to the Selexol unit to maximize sulfur recovery. A small stream of clean syngas is used to fire and preheat the feed gas to the sulfur reduction unit.
- CO₂ Purification/Compression (CO2-PUR)^a** – Carbon dioxide is removed from the syngas in the Selexol process. By properly designing the solvent regeneration scheme, a relatively pure stream of CO₂ is produced. Final purification is accomplished using a zinc oxide sorbent bed to remove any remaining traces of sulfur, followed by a small catalytic oxidation unit to convert CO, H₂, and CH₄ to CO₂ and H₂O. Water is removed from the CO₂ using condensation, followed by compression to 2005 psi for urea synthesis. Eight stages are assumed for the CO₂ compression scheme, resulting in an overall efficiency of 84.4%. A small excess of CO₂ (above what is required for urea synthesis) is vented to the atmosphere.
- Ammonia Synthesis (AMMONIA)** – Syngas feeding the ammonia synthesis unit has been previously adjusted to achieve the H₂/N₂ molar ratio 3.0. Incoming feed gas is compressed to 3,000 psi. Unreacted recycle gas is mixed with the fresh feed gas and preheated by cross exchanging

a. This block was modeled separately, but is included within the block labeled “Syngas Conditioning” in Figure 1.

NUCLEAR-INTEGRATED AMMONIA PRODUCTION ANALYSIS	Identifier: TEV-666	Page: 16 of 69
	Revision: 2	
	Effective Date: 05/25/2010	

with hot reactor effluent gases. Equilibrium conversion is assumed in the ammonia converters for the following reaction (Eggerman 2010):



Effluent from the first ammonia converter is cooled by cross exchange with the reactor influent, followed by cooling in a steam generator. Additional steam is generated from the hot syngas downstream of the second and third ammonia conversion stages. Final cooling of the third stage effluent gas is accomplished using cooling water and recuperation with the cool recycle gas stream. Ammonia product is recovered in an ammonia separator. Effluent gas from this separator is further cooled using refrigeration. Additional ammonia is recovered in a second separator downstream of the refrigeration unit. Effluent gas from the second separator is recycled to the ammonia converters. Before entering the ammonia converters, the recycle gas is recompressed using a boost compressor and mixed with fresh syngas. Due to the very low concentrations of methane and argon entering the synthesis loop, inerts are removed from the synthesis loop with the ammonia product due to solubility alone.

Recovered ammonia is flashed to atmospheric pressure for storage. Ammonia in the flash gas is recovered in a wash column and subsequently distilled to remove water from the recovered product.


- Nitric Acid Synthesis (HNO₃)** – A monopressure process was selected for nitric acid synthesis due to capital cost advantages over a dual-pressure process. Cold ammonia is first preheated prior to mixing with compressed air. The ammonia-air mixture is reacted in an ammonia converter to produce N₂, NO, and H₂O. Due to the exothermic nature of the reactions, an exit temperature of 1,700°F is achieved (Clarke, 2005). Heat recuperation and steam generation are implemented downstream of the converter. As the gas cools, additional reaction with oxygen takes place to produce NO₂, N₂O₄, and finally HNO₃. Aqueous nitric is separated from the product stream while gaseous products are routed to an absorber to increase the yield of acid. A bleacher is included to further enhance reaction of NO with oxygen to improve acid yield. Unreacted gas exiting the absorber is routed to a selective catalytic reduction (SCR) unit for NO_x abatement prior to release to the atmosphere. This tailgas is also run through an expander, which significantly reduces the net electrical load required for air compression.
- Ammonium Nitrate Synthesis (NH₄NO₃)** – Ammonia and nitric acid are preheated and then fed to a neutralizer where the following reaction occurs (Speight 2002):

NUCLEAR-INTEGRATED AMMONIA PRODUCTION ANALYSIS	Identifier:	TEV-666	
	Revision:	2	
	Effective Date:	05/25/2010	Page: 17 of 69



The neutralizer products are then separated under slight negative pressure to remove excess water from the ammonium nitrate solution. Ninety-five percent of the solution is recycled back to the neutralizer, while 5% is withdrawn and further concentrated in a two-stage evaporator. Following evaporation, the concentrated ammonium nitrate solution is solidified using a prill tower. An Uhde-I. G. Farbenindustrie process was simulated. This particular process makes extensive use of process recycle and recuperation to minimize energy input requirements. Feeds to the process are controlled to maintain a pH of 1.5 in the neutralizer.

- **Urea Synthesis (UREA)** – The high-pressure Stamicarbon process was selected for urea synthesis. Principal feeds to this process are ammonia and CO₂. Reaction takes place at 2,005 psi; hence, compression of the feeds is required. The temperature is maintained around 360°F and NH₃/CO₂ molar ratio is maintained at 2.95:1. Ammonia and CO₂ react to form ammonium carbamate, which simultaneously dehydrates to form urea as (Mavrovic 2000):



Liquid product is separated downstream of the reactor and fed to the CO₂ stripper. In the CO₂ stripper and downstream decomposer, unreacted carbamate is decomposed to ammonia and CO₂ to allow easy separation from the urea product. Recovered ammonia and CO₂ are cooled and condensed to reform ammonium carbamate. After stripping inert gases from the ammonium carbamate, this solution is recycled and mixed with fresh feed gases to the high-pressure carbamate condenser prior to introduction to the reactor.

Liquid urea product is concentrated using evaporation under vacuum conditions. The concentrated urea solution is then solidified using a fluidized bed granulator.

- **Power Production (HRSG-ST)** – The high- (700 psi) and low-pressure (60 psi) steams generated throughout the plant are sent to the power production block where they are passed through three steam turbines to generate power. The efficiencies of the turbines for the various steam pressures were calculated using Steam Pro, steam turbine modeling software from Thermoflow (Thermoflow 2009). It was found that even given low-quality steam at 60 psi, efficiencies for the steam turbines remain constant at approximately 81% combined thermodynamic and mechanical efficiency. It is recognized that the piping size for the 60 psia

NUCLEAR-INTEGRATED AMMONIA PRODUCTION ANALYSIS	Identifier: TEV-666	Page: 18 of 69
	Revision: 2	
	Effective Date: 05/25/2010	

steam may be impractical and other methods for recovering the duty contained in this stream may be required. The condensed steams from the turbine outlets are mixed with condensate return from the plant, and makeup water is added to provide the necessary flow to the boiler feedwater pumps. Low-pressure steam is added to the deaerator. Purge gas produced in the plant is fired in the heat recovery steam generator (HRSG) to: (1) superheat and reheat steam feeds to the turbines, (2) raise additional steam to bolster power production, and (3) preheat boiler feed water prior to deaeration. Aspen Utility blocks are used to track all steam generation and use in the plant. This information is used as input to the power production section of the model, allowing reconciliation of the entire plant steam balance.

- **Cooling Towers (COOL-TWR)** – Conventional cooling towers are modeled in Aspen Plus using literature data. Air cooling could potentially be used in certain areas of the plant to decrease water consumption; however, for simplicity, cooling water only was assumed. The evaporation rate, drift, and blowdown are based on a rule-of-thumb guide for the design and simulation of wet cooling towers (Leeper 1981). Aspen Utility blocks are used to track all cooling water used in the plant. This information is used as input to the cooling tower section of the model, allowing reconciliation of the entire plant cooling water balance.
- **Water Treatment (H2O-TRTM)** – Water treatment is simplistically modeled in Aspen Plus using a variety of separation blocks. INL is currently collaborating with a major water treatment vendor to develop the water treatment portion of the model. The existing water treatment scenario is a place holder and will be revised as information is received from the water treatment vendor. Hence, it is anticipated that energy consumption for the water treatment portion of the plant could change considerably based on water treatment vendor feedback. Aspen Transfer blocks are used to reconcile water in and out flows from various parts of the plant, allowing reconciliation of the entire plant water balance.

2.2 Conventional Natural Gas-to-Ammonia Case

Figure 2 shows the block flow diagram for the conventional natural gas-to-ammonia case. The proposed process includes unit operations for natural gas reforming, syngas cleaning and conditioning, CO₂ compression, ammonia synthesis, nitric acid synthesis, ammonium nitrate synthesis, urea synthesis, power production, cooling towers, and water treatment. Each plant area is briefly described below. For each description, the name capitalized and enclosed in parentheses corresponds to the name of the hierarchy block within the Aspen process model. Because many of the unit operations downstream of syngas production remain unchanged from the conventional coal-to-ammonia flow sheet,

NUCLEAR-INTEGRATED AMMONIA PRODUCTION ANALYSIS

Identifier: TEV-666

Revision: 2

Effective Date: 05/25/2010

Page: 19 of 69

emphasis for these operations is placed on differences in configuration between the cases.




Figure 2. Block flow diagram for the conventional natural gas-to-ammonia process.

- Natural Gas Purification and Reforming (REFORMER)^b** – Two-step reforming consisting of primary steam reforming followed by secondary autothermal reforming was selected for syngas generation. Air is used as the oxidant in the autothermal reforming step, as this provides nitrogen to the process for downstream ammonia synthesis (Eggerman 2010). By carefully controlling process parameters, such as the steam-to-carbon inlet molar ratio, primary reformer temperature, amount of preheat to the secondary reformer, and secondary reformer temperature, a syngas containing the appropriate H_2/N_2 ratio for ammonia synthesis can be produced. Additionally, if the steam-to-carbon ratio is set high enough, additional water will not be required prior to downstream shift conversion. For this case, key parameters were set as follows:

b. The blocks labeled “Sulfur Removal,” “Primary Reformer,” and “Secondary Reformer” shown in Figure 2 are all included within this Aspen hierarchy block.

NUCLEAR-INTEGRATED AMMONIA PRODUCTION ANALYSIS	Identifier:	TEV-666
	Revision:	2
	Effective Date:	05/25/2010
Page: 20 of 69		

Preformer steam-to-carbon ratio	3.30
Primary reformer exit temperature	1,454°F (790°C)
Autothermal reformer outlet temperature	1,750°F (954°C)

Natural gas is split into two streams. Of the total natural gas flow, 22.7% is burned to provide heat for the primary reformer. The remaining 77.3% of the natural gas flow is compressed to 615 psi and then preheated to 329°F and saturated with hot water. After saturation, the gas is further heated to 662°F and mixed with a small amount of hydrogen. Sulfur is removed from the gas and then mixed with steam to achieve the desired steam-to-carbon molar ratio of 3.3. Because the resulting natural gas/steam mixture is preheated to only 1000°F, a preformer is not included in this flowsheet.

The natural gas/steam mixture is fed to the primary reformer, where methane is converted over a catalyst to CO, H₂, and CO₂. Methane conversion in this reactor is approximately 53%. A separate feed of the natural gas is mixed with fuel gas and burned to provide heat for the endothermic reforming reactions. The hot offgas from the reformer is exchanged with inlet syngas, water, air, and steam to provide preheat for these streams.

The effluent from the primary reformer and a preheated air stream are fed to the autothermal reformer where conversion of the remaining methane to syngas is accomplished. The oxygen-to-carbon molar ratio is set at 0.28, resulting in an exit temperature of 1,750°F. The hot syngas is cooled rapidly by exchange with boiler feed water to create high-pressure steam. The resulting syngas has a H₂/CO ratio of 4.4 and contains 5 mol% CO₂ and 0.5 mol% unreacted CH₄.

- **Syngas Conditioning (GAS-CLN)** – Syngas cleaning and conditioning for the natural gas-fed case is similar to the coal-fed case. However, the following changes are made for the natural gas-fed case:
 1. Water saturation is not necessary prior to shift conversion. By introducing sufficient steam to the reforming section of the plant, the syngas entering the high-temperature shift converter contains sufficient moisture for shift conversion. The steam-to-dry gas ratio of the syngas is 0.54, which is above the minimum requirement for the catalyst (0.40).
 2. The mercury sorbent bed is not required.
 3. Because sulfur has been removed prior to reforming, Selexol is used for CO₂ removal only. The Selexol unit is operated to remove the majority of the CO₂; hence, a PSA unit is not required.

NUCLEAR-INTEGRATED AMMONIA PRODUCTION ANALYSIS	Identifier:	TEV-666
	Revision:	2
	Effective Date:	05/25/2010
		Page: 21 of 69

The resulting syngas contains H_2 and N_2 in a molar ratio of 3:1. Small amounts of argon (0.3 mol%) and methane (1.1%) are also present in the cleaned syngas.

- **CO₂ Compression (CO₂-COMP)^c** – CO₂ compression in the natural gas-fed case is identical to the coal-fed case. However, because sulfur has been removed from the natural gas prior to reforming, sulfur removal from the CO₂ is not required.
- **Ammonia Synthesis (AMMONIA)** – Ammonia synthesis in the natural gas-fed case is identical to the coal-fed case. However, due the higher concentration of inerts in the feed gas (argon and methane), a purge is required. For this case, the purge rate is set at 0.54% of the recycle gas flow, resulting in an inert content in the recycle gas of about 15 mol%. Because the purge flow is significant, 90% of the H_2 and 30% of the N_2 are recovered using membrane separation. Recovered H_2 and N_2 are recompressed and remixed into the synthesis loop. The waste stream from the membrane is burned as fuel gas in the primary reformer.
- **Nitric Acid Synthesis (HNO₃)** – Nitric acid synthesis in the natural gas-fed case is identical to the coal-fed case.
- **Ammonium Nitrate Synthesis (NH₄NO₃)** – Ammonium nitrate synthesis in the natural gas-fed case is identical to the coal-fed case.
- **Urea Synthesis (UREA)** – Urea synthesis in the natural gas-fed case is identical to the coal-fed case.
- **Power Production (HRSG-ST)** – The steam system in the natural gas-fed case is identical to the coal-fed case. However, power production is accomplished solely from steam generated throughout the plant. Purge gas from the ammonia synthesis loop is burned in the primary reformer; hence, it is not available for firing a HRSG.
- **Cooling Towers (COOL-TWR)** – The cooling water system in the natural gas-fed case is identical to the coal-fed case.
- **Water Treatment (H₂O-TRTM)** – Water treatment for the natural gas-fed case is similar to the coal-fed case. Additional detail for the water treatment system will be added when vendor feedback has been received.

2.3 Nuclear-Integrated Coal-to-Ammonia Case

c. This block was modeled separately but is included within the block labeled “Syngas Conditioning” in Figure 2.

NUCLEAR-INTEGRATED AMMONIA PRODUCTION ANALYSIS

Identifier: TEV-666

Revision: 2

Effective Date: 05/25/2010

Page: 22 of 69

Figure 3 shows the block flow diagram for the nuclear-integrated coal-to-ammonia case. As this diagram shows, a need for high-temperature heat ($>300^{\circ}\text{C}$) integration was not identified. Additionally, modeling results for the conventional coal-to-ammonia case indicate that heat for coal drying, water treatment, and urea synthesis can be supplied by existing unit operations in the conventional configuration. Hence, electricity is the best integration need for this flow sheet. Because light water reactors could supply this need, there is no driving reason to integrate this flow sheet with nuclear HTGRs. Hence, process modeling was not performed for this case.




Figure 3. Block flow diagram for the nuclear-integrated coal-to-ammonia process.

NUCLEAR-INTEGRATED AMMONIA PRODUCTION ANALYSIS

Identifier: TEV-666

Revision: 2

Effective Date: 05/25/2010

Page: 23 of 69

2.4 Nuclear-Integrated Natural Gas-to-Ammonia Case

Figure 4 shows the block flow diagram for the nuclear-integrated natural gas-to-ammonia case. The proposed process includes the same unit operations as the conventional natural gas process except nuclear heat is used in the primary reformer rather than burning natural gas. Nuclear heat is also used to preheat all streams entering the primary reformer. Although nuclear heat was also considered for use in the urea synthesis and water treatment plants, sufficient low-temperature heat was produced elsewhere in the plant to meet these requirements. Because higher temperature heat is desired for steam reforming of natural gas, this configuration assumes the use of an intermediate heat exchanger (IHX) to provide 700°C helium gas as the heat transfer fluid to the reformer.




Figure 4. Block flow diagram for the nuclear-integrated natural gas-to-ammonia process.

The proposed process includes unit operations for natural gas reforming, syngas cleaning and conditioning, CO_2 compression, ammonia synthesis, nitric acid synthesis, ammonium nitrate synthesis, urea synthesis, power production, cooling towers, and water treatment. Each unit operation is briefly described below. For each description, the name capitalized and enclosed in parentheses corresponds to

NUCLEAR-INTEGRATED AMMONIA PRODUCTION ANALYSIS	Identifier:	TEV-666	
	Revision:	2	
	Effective Date:	05/25/2010	Page: 24 of 69

the name of the hierarchy block within the Aspen process model. Because the majority of unit operations remain unchanged from the conventional natural gas-to-ammonia flowsheet, emphasis is placed on differences in configuration between cases.

- **Natural Gas Purification and Reforming (REFORMER)^d** – Conditions in the reforming section of the plant had to be modified slightly because of the upper temperature limit of helium that can be delivered from the nuclear plant (700°C). Because of this constraint, primary reforming was split into two stages. In the first stage, nuclear heat is provided by hot helium exchange. The temperature of this reforming stage was set at 1,274°F (690°C). In the second stage of the primary reformer, purge gas is burned as the heat source. The temperature of this reforming stage was set at 1,400°F (760°C). Key reforming parameters for this case are summarized below:

Preformer steam-to-carbon ratio	3.30
Primary reformer stage 1 exit temperature	1,274°F (690°C)
Primary reformer stage 2 exit temperature	1,400°F (760°C)
Autothermal reformer outlet temperature	1,650°F (899°C)

With these changes, methane conversion in the primary reformer decreased from 53% to 46%. Feed O₂/C and effluent syngas H₂/CO ratios for the autothermal reformer were 0.27 and 4.81, respectively.

- **Syngas Cleaning and Conditioning (GAS-CLN)** – Syngas cleaning and conditioning for the nuclear-integrated natural gas-fed case is identical to the conventional natural gas-fed case.
- **CO₂ Compression (CO2-COMP)^e** – CO₂ compression for the nuclear-integrated natural gas-fed case is identical to the conventional natural gas-fed case.
- **Ammonia Synthesis (AMMONIA)** – Ammonia synthesis for the nuclear-integrated natural gas-fed case is identical to the conventional natural gas-fed case. Due to slightly higher inerts in the synthesis feed gas, a slightly higher purge rate is required.

d. The blocks labeled “Sulfur Removal,” “Primary Reformer,” and “Secondary Reformer” shown in Figure 4 are all included within this Aspen hierarchy block.

e. This block was modeled separately but is included within the block labeled “Syngas Conditioning” in Figure 4.

NUCLEAR-INTEGRATED AMMONIA PRODUCTION ANALYSIS	Identifier: TEV-666	Page: 25 of 69
	Revision: 2	
	Effective Date: 05/25/2010	

- **Nitric Acid Synthesis (HNO₃)** – Nitric acid synthesis for the nuclear-integrated natural gas-fed case is identical to the conventional natural gas-fed case.
- **Ammonium Nitrate Synthesis (NH₄NO₃)** – Ammonium nitrate synthesis for the nuclear-integrated natural gas-fed case is identical to the conventional natural gas-fed case.
- **Urea Synthesis (UREA)** – Urea synthesis for the nuclear-integrated natural gas-fed case is identical to the conventional natural gas-fed case.
- **Power Production (HRSG-ST)** – The steam system for the nuclear-integrated natural gas-fed case is identical to the conventional natural gas-fed case.
- **Cooling Towers (COOL-TWR)** – The cooling water system for the nuclear-integrated natural gas-fed case is identical to the conventional natural gas-fed case.
- **Water Treatment (H₂O-TRTM)** – Water treatment for the nuclear-integrated natural gas-fed case is identical to the conventional natural gas-fed case.

2.5 HTSE Hydrogen-to-Ammonia Case (Option 1: H₂/Air Combustion as the N₂ Source)

Figure 5 shows the block flow diagram for the HTSE hydrogen-to-ammonia case, which uses H₂/air combustion as the nitrogen source. The proposed process includes the same downstream unit operations as the nuclear-integrated and conventional ammonia processes. Syngas generation, however, is considerably modified. Hydrogen for ammonia synthesis is produced by HTSE. Nuclear HTGRs supply heat and power for the electrolysis units. Burning a fraction of the electrolysis H₂ with air generates a nitrogen-rich combustion gas. Water is subsequently condensed out of the combustion gas to yield nitrogen for ammonia synthesis.

Urea production requires CO₂ as a feed to the process. For this case, a CO₂ supply is not readily available and must be produced to support urea manufacture; hence, natural gas is burned with oxygen to produce the required CO₂. While coal could have been selected for this purpose, natural gas is preferred because of its much simpler gas cleanup requirements.

An opportunity was identified to use heat from the natural gas burner as topping heat for the electrolysis unit. As HTGR technology matures and reactor outlet temperatures increase, the nuclear reactors may be able to supply electrolysis topping heat. However, because of the upper limit of 700°C deliverable heat

NUCLEAR-INTEGRATED AMMONIA PRODUCTION ANALYSIS

Identifier: TEV-666

Revision: 2

Effective Date: 05/25/2010

Page: 26 of 69

assumed in this study, supplying topping heat from the burner to the electrolyzers is an attractive means of increasing electrolyzer efficiency.

The proposed process includes unit operations for H_2 generation via high-temperature electrolysis, N_2 generation via H_2 /air combustion, syngas purification, CO_2 generation via oxy-combustion of natural gas, CO_2 compression, ammonia synthesis, nitric acid synthesis, ammonium nitrate synthesis, urea synthesis, power production, cooling towers, and water treatment. Each unit operation is briefly described below. For each description, the name capitalized and enclosed in parentheses corresponds to the name of the hierarchy block within the Aspen process model. Because the majority of unit operations remain unchanged from the previously described ammonia flow sheets, emphasis is placed on differences in configuration between cases.




Figure 5. Block flow diagram for the HTSE hydrogen-to-ammonia process (N_2 from H_2 /air combustion).

- **HT Steam Electrolysis (HTE)** – Hydrogen is generated from water via electrolysis. INL's detailed model for high-temperature electrolysis has

NUCLEAR-INTEGRATED AMMONIA PRODUCTION ANALYSIS	Identifier: TEV-666	
	Revision: 2	
	Effective Date: 05/25/2010	Page: 27 of 69

not yet been converted to Aspen Plus. Hence, a very simplistic model is included and has been tuned using INL's detailed electrolysis model. Efficiency of the electrolysis process is improved by operating at elevated temperatures; 800°C was selected as the operating temperature in this study. Because of the presently assumed 700°C limit for heat delivery from the HTGRs, topping heat is supplied to the electrolysis process from the combustor in the CO₂ generation plant. Products from the electrolyzer include purified H₂ and O₂. The excess O₂ produced can be sold as an end product from this process.

- Hydrogen Burner (N2-GEN)** – Nitrogen is generated by burning a fraction of the hydrogen product from electrolysis with air. For this case, 15.4% of the total electrolysis H₂ production is burned to produce N₂. Air is pressurized to 720 psi prior to being fed to the burner. Steam injection is used to moderate temperature within the burner; outlet temperature from the burner is controlled to 1,800°F. The hot exhaust gas from the burner is used to raise steam. Water is then condensed from the gas to produce a nitrogen stream for ammonia synthesis.
- CO₂ Purification (CO2-GEN)** – Carbon dioxide for urea synthesis is generated by combustion of natural gas. The gas is preheated against hot combustion gas and sulfur is removed using a bed of zinc oxide. Oxygen from the electrolyzers is used as the oxidant in order to produce a nitrogen-free stream of CO₂. The hot combustion gas is used first to supply topping heat to the electrolyzer, followed by raising high-pressure steam in a heat-recovery boiler. The hot combustion gas is then used for recuperation with the natural gas feed stream and finally to raise low-pressure steam. A large fraction of the combustion gas is recycled to the combustor to moderate temperature within the burner. Water is then condensed from the gas stream prior to compression to 2,005 psi in preparation for urea synthesis.
- Syngas Conditioning (GAS-CLN)^f** – Syngas cleaning is similar to the conventional natural gas-fed case, but significantly simpler—only methanation and water removal are required.
- Ammonia Synthesis (AMMONIA)** – Ammonia synthesis for this case is identical to the conventional natural gas-fed case.
- Nitric Acid Synthesis (HNO₃)** – Nitric acid synthesis for this case is identical to the conventional natural gas-fed case.
- Ammonium Nitrate Synthesis (NH₄NO₃)** – Ammonium nitrate synthesis for this case is identical to the conventional natural gas-fed case.

f. This block was modeled separately but is included within the block labeled “Ammonia Synthesis” in Figure 5.

NUCLEAR-INTEGRATED AMMONIA PRODUCTION ANALYSIS	Identifier: TEV-666	
	Revision: 2	
	Effective Date: 05/25/2010	Page: 28 of 69

- **Urea Synthesis (UREA)** – Urea synthesis for this case is identical to the conventional natural gas-fed case.
- **Power Production (HRSG-ST)** – The steam system for this case is identical to the conventional natural gas-fed case.
- **Cooling Towers (COOL-TWR)** – The cooling water system for the nuclear-integrated natural gas-fed case is identical to the conventional natural gas-fed case.
- **Water Treatment (H2O-TRTM)** – Water treatment for this case is identical to the conventional natural gas-fed case.

2.6 HTSE Hydrogen-to-Ammonia Case (Option 2: Cryogenic ASU as the N₂ Source)

Figure 6 shows the block flow diagram for the HTSE hydrogen-to-ammonia case that uses cryogenic air separation as the nitrogen source. The proposed process includes similar unit operations as in the HTSE case with H₂/air combustion for N₂ generation. Hydrogen for ammonia synthesis is produced by HTSE. Nuclear HTGRs supply heat and power for the electrolysis units. However, a cryogenic air separation unit is used for N₂ generation instead of H₂ combustion.

NUCLEAR-INTEGRATED AMMONIA PRODUCTION ANALYSIS

Identifier: TEV-666

Revision: 2

Effective Date: 05/25/2010

Page: 29 of 69




Figure 6. Block flow diagram for the HTSE hydrogen-to-ammonia process (N₂ from cryogenic ASU).

Urea production requires CO₂ as a feed to the process. For this case, a CO₂ supply is not readily available and must be produced to support urea manufacture; hence, natural gas is burned with oxygen to produce the required CO₂. While coal could have been selected for this purpose, natural gas is preferred because of the much simpler gas cleanup requirements.

An opportunity was identified to use heat from the natural gas burner as topping heat for the electrolysis unit. As HTGR technology matures and reactor outlet temperatures increase, the nuclear reactors may be able to supply electrolysis topping heat. However, because of the upper limit of 700°C deliverable heat assumed in this study, supplying topping heat from the burner to the electrolyzers is an attractive means of increasing electrolyzer efficiency.

The proposed process includes unit operations for H₂ generation via high-temperature electrolysis, N₂ generation via cryogenic air separation, syngas purification, CO₂ generation via oxy-combustion of natural gas, CO₂

NUCLEAR-INTEGRATED AMMONIA PRODUCTION ANALYSIS	Identifier: TEV-666	Page: 30 of 69
	Revision: 2	
	Effective Date: 05/25/2010	

compression, ammonia synthesis, nitric acid synthesis, ammonium nitrate synthesis, urea synthesis, power production, cooling towers, and water treatment. Each unit operation is briefly described below. For each description, the name capitalized and enclosed in parentheses corresponds to the name of the hierarchy block within the Aspen process model. Because the majority of unit operations remain unchanged from the previously described ammonia flow sheets, emphasis is placed on differences in configuration between cases.

- **HT Steam Electrolysis (HTE)** – Hydrogen generation for this case is identical to the HTSE hydrogen-to-ammonia case using H₂/air combustion for the N₂ source.
- **Air Separation (ASU)** – Nitrogen generation for this case is identical to the conventional coal-fed case. However, in that scenario, the throughput of the ASU was driven by oxygen requirements for gasification. In this case, a much smaller unit can be utilized because throughput is driven by N₂ demand for ammonia synthesis. The excess O₂ produced could potentially be sold as an end product from this process.
- **CO₂ Purification (CO₂-GEN)** – Carbon dioxide generation for this case is identical to the HTSE hydrogen-to-ammonia case using H₂/air combustion for the N₂ source.
- **Syngas Conditioning (GAS-CLN)^g** – Syngas cleaning for this case is identical to the HTSE hydrogen-to-ammonia case using H₂/air combustion for the N₂ source.
- **Ammonia Synthesis (Ammonia)** – Ammonia synthesis for this case is identical to the HTSE hydrogen-to-ammonia case using H₂/air combustion for the N₂ source.
- **Nitric Acid Synthesis (HNO₃)** – Nitric acid synthesis for this case is identical to the HTSE hydrogen-to-ammonia case using H₂/air combustion for the N₂ source.
- **Ammonium Nitrate Synthesis (NH₄NO₃)** – Ammonium nitrate synthesis for this case is identical to the HTSE hydrogen-to-ammonia case using H₂/air combustion for the N₂ source.
- **Urea Synthesis (UREA)** – Urea synthesis for this case is identical to the HTSE hydrogen-to-ammonia case using H₂/air combustion for the N₂ source.

g. This block was modeled separately but is included within the block labeled “Ammonia Synthesis” in Figure 6.

NUCLEAR-INTEGRATED AMMONIA PRODUCTION ANALYSIS	Identifier: TEV-666	Page: 31 of 69
	Revision: 2	
	Effective Date: 05/25/2010	

- **Power Production (STEAM)** – The steam system for this case is similar to the HTSE hydrogen-to-ammonia case using H₂/air combustion for the N₂ source.
- **Cooling Towers (COOL-TWR)** – The cooling water system for this case is identical to the HTSE hydrogen-to-ammonia case using H₂/air combustion for the N₂ source.
- **Water Treatment (H₂O-TRTM)** – Water treatment for this case is identical to the HTSE hydrogen-to-ammonia case using H₂/air combustion for the N₂ source.

3. PROCESS MODELING RESULTS

Based on the results for the conventional coal-to-ammonia case, a need for high-temperature (>300°C) heat integration was not identified for the coal-fed case. In addition, because light water reactors can supply power in this scenario, a strong need for integration with HTGRs is not apparent. Hence, modeling of a nuclear-integrated coal-to-ammonia case was not pursued. Note, however, that other gasification technologies (hydrogasification) could be considered, and these technologies may be more complementary for HTGR integration.

Analysis of the conventional natural-gas-to-ammonia case indicates a strong potential heat integration opportunity for a HTGR. In the conventional case, 22.7% of the natural gas feed to the process is burned to provide heat in the primary reformer. The operating temperature in the primary reformer is 790°C, which is somewhat higher than the assumed 700°C temperature that can be supplied by an HTGR in this analysis. Analysis seems to indicate, however, that primary reforming can be accomplished in two stages—the first using nuclear heat at 690°C, followed by a second stage reformer fueled entirely by purge gas that operates at a somewhat higher temperature.

A summary of the modeling results for all cases is presented in Table 2. The conventional coal and natural gas cases serve as a basis for comparison with the nuclear-integrated cases. Figure 7 graphically presents a high-level material and energy balance summary for each case. For the complete Aspen stream results for all cases, see Appendixes C, D, E, F, and G.

Results for the nuclear-integrated natural gas-to-ammonia case look promising. One 450 MW_t HTGR would be required to support this configuration. The split of heat to power required from the nuclear plant is 42%/58%. By substituting nuclear heat for natural gas combustion in the primary reformer, natural gas consumption can be reduced by 18%. In addition, CO₂ emissions can be reduced by 70%.

Results for the HTSE hydrogen cases also look promising. CO₂ emissions are cut to very low levels, and the need to sequester carbon is eliminated. In addition, natural gas consumption is reduced to only the amount required to supply carbon for urea production.

Idaho National Laboratory**NUCLEAR-INTEGRATED AMMONIA
PRODUCTION ANALYSIS**

Identifier: TEV-666

Revision: 2

Effective Date: 05/25/2010

Page: 32 of 69

These configurations would require roughly four 600 MW_t HTGRs to support plant operation. It is apparent that, of the two HTSE hydrogen cases considered, the option utilizing cryogenic air separation for nitrogen production is more attractive from the perspectives of capital equipment cost.

Idaho National Laboratory

**NUCLEAR-INTEGRATED AMMONIA
PRODUCTION ANALYSIS**

Identifier: TEV-666
Revision: 2
Effective Date: 05/25/2010 Page: 33 of 69

Table 2. Ammonia modeling case study results.

	Conventional Coal- To-Ammonia Derivatives Process	Conventional Gas- To-Ammonia Derivatives Process	Nuclear-Integrated Gas-to-Ammonia Derivatives Process	HTSE-to-Ammonia Derivatives Process – N ₂ from Combustion	HTSE-to-Ammonia Derivatives Process – N ₂ from ASU
Inputs					
Coal Feed Rate (ton/day)	4,591	0	0	0	0
Natural Gas Feed Rate (MMSCFD)	N/A	88	72	36	36
# 600 MW _t HTGRs Required	N/A	N/A	0.75	4.10	3.58
Intermediate Products					
Ammonia (ton/day)	3,358	3,361	3,360	3,360	3,360
Nitric Acid (ton/day)	5,186	5,192	5,192	5,192	5,192
Outputs					
Urea (ton/day)	2,939	2,939	2,939	2,939	2,939
Ammonium Nitrate (ton/day)	3,779	3,779	3,779	3,779	3,779
Oxygen (ton/day)	0	0	0	2,508	2,435
Utility Summary					
Total Power (MW _e)	-141.8	-108.8	-106.2	-879.0	-769.5
Electrolyzers	N/A	N/A	N/A	-918.1	-778.1
Air Separation	-73.5	N/A	N/A	N/A	-23.2
Nitrogen Generation (non-ASU)	N/A	N/A	N/A	-18.8	N/A
Coal Milling and Drying	-2.5	N/A	N/A	N/A	N/A
Gasification Island	-2.5	N/A	N/A	N/A	N/A
Natural Gas Reforming	N/A	-21.6	-19.9	N/A	N/A
Syngas Purification	-5.4	-4.4	-4.5	N/A	N/A
Claus Plant	0.0	N/A	N/A	N/A	N/A
Sulfur Reduction (SCOT)	-0.7	N/A	N/A	N/A	N/A
Non-Nuclear Power Island	44.7	26.7	29.5	156.0	128.0
CO ₂ Production/Purification/Compression	-7.4	-13.0	-13.1	-5.6	-5.6

Idaho National Laboratory

**NUCLEAR-INTEGRATED AMMONIA
PRODUCTION ANALYSIS**

Identifier: TEV-666
Revision: 2
Effective Date: 05/25/2010 Page: 34 of 69

Table 2. Ammonia modeling case study results.

	Conventional Coal- To-Ammonia Derivatives Process	Conventional Gas- To-Ammonia Derivatives Process	Nuclear-Integrated Gas-to-Ammonia Derivatives Process	HTSE-to-Ammonia Derivatives Process – N ₂ from Combustion	HTSE-to-Ammonia Derivatives Process – N ₂ from ASU
Ammonia Synthesis	-43.2	-45.2	-46.8	-39.0	-38.5
Nitric Acid Synthesis	-15.1	-15.1	-15.1	-15.1	-15.1
Ammonium Nitrate Synthesis	-24.9	-24.9	-24.9	-24.9	-24.9
Urea Synthesis	-4.4	-4.4	-4.4	-4.4	-4.4
Cooling Towers	-2.1	-1.5	-1.5	-2.5	-2.3
Water Treatment	-4.8	-5.4	-5.6	-6.6	-5.6
Fossil Plant Water Balance (gpm)*	-4,466	-3,928	-3,984	-6,334	-5,555
Evaporation Rate (gpm)	-4,891	-3,601	-3,657	-5,979	-5,386
CO ₂ Emissions					
Captured (ton/day CO ₂)	0	1,762	1,786	0	0
Emitted (ton/day CO ₂)	7,987	1,449	430	11	11
Nuclear Integration Summary					
Electricity Demand (MW _e)	N/A	N/A	106.2	879.0	769.5
HTSE	N/A	N/A	N/A	918.1	778.1
Balance of Plant	N/A	N/A	106.2	-39.1	-8.6
Nuclear Heat Demand (MMBTU/hr)	N/A	N/A	649.2	894.6	758.2
Electrolyzers	N/A	N/A	N/A	894.6	758.2
Natural Gas Reforming	N/A	N/A	649.2	N/A	N/A
Fossil Topping Heat Supplied (MMBTU/hr)	N/A	N/A	N/A	50.4	42.7
Electrolysis Products					
Total Hydrogen (ton/day)	N/A	N/A	N/A	715	606
Total Oxygen (ton/day)	N/A	N/A	N/A	5,637	4,778

*Detailed water balance can be found in Appendix A.

Idaho National Laboratory


NUCLEAR-INTEGRATED AMMONIA PRODUCTION ANALYSIS

Identifier: TEV-666

Revision: 2

Effective Date: 05/25/2010

Page: 35 of 69

Figure 7. Ammonia modeling case material balance summary.^h^h Water balance breakdown can be found in Appendix A.

NUCLEAR-INTEGRATED AMMONIA PRODUCTION ANALYSIS	Identifier: TEV-666 Revision: 2 Effective Date: 05/25/2010	Page: 36 of 69
---	--	----------------

4. ECONOMIC MODELING OVERVIEW

The economic viability of the ammonia processes was assessed using standard economic evaluation methods. The economics were evaluated for the conventional and nuclear-integrated options described in the previous sections. The total capital investment (TCI), based on the total equipment costs, annual revenues, and annual manufacturing costs were first calculated for the cases. The present worth (PW) of the annual cash flows (after taxes) was then calculated for the TCI, as well as the TCI at + 50% and – 30% of the HTGR cost, with the debt to equity ratios equal to 80%/20% and 55%/45%. The following sections describe the methods used to calculate the capital costs, annual revenues, annual manufacturing costs, and the resulting economic results.

4.1 Capital Cost Estimation

Equipment items for this study were not individually priced. Rather, cost estimates were based on scaled costs for major plant processes from published literature.

For the coal-to-ammonia scenarios, cost estimates were generated for:

- Coal preparation
- The ASU
- Gasification
- Gas cleanup
- Ammonia synthesis
- Nitric acid synthesis
- Urea synthesis
- Ammonium nitrate synthesis
- Steam turbines
- The HRSG
- Cooling towers.

For the gas-to-ammonia scenarios, cost estimates were generated for:

- SMR
- Gas cleanup
- Ammonia synthesis
- Nitric acid synthesis
- Urea synthesis
- Ammonium nitrate synthesis
- Steam turbines

- The HRSG
- Cooling towers
- The HTGR.

For the HTSE-to-ammonia scenarios, cost estimates were generated for:

- HTSE
- Gas cleanup
- Ammonia synthesis
- Nitric acid synthesis
- Urea synthesis
- Ammonium nitrate synthesis
- Steam turbines
- The HRSG
- Cooling towers
- The HTGR.

NUCLEAR-INTEGRATED AMMONIA PRODUCTION ANALYSIS

Identifier: TEV-666

Revision: 2

Effective Date: 05/25/2010

Page: 37 of 69

In some instances, several costs were averaged. Gas cleanup includes costs for water gas shift reactors, the Selexol process, sulfur recovery, pressure swing absorption, methanation, and CO₂ compression/liquefaction as appropriate for the various process configurations. Appendix B presents the detailed breakdown for the equipment item costs. It is assumed that there is no impact on the capital cost of the ammonia facility when sequestration is not assumed, as the Selexol process is required for gas cleanup, and though the last stage of the CO₂ compressor would not be required, this cost is negligible when compared to the TCI required for the ammonia process. The estimate presented is a Class 5 estimate and has a probable error of +50% and –30% (AACE 2005).

The capital costs presented are for inside the battery limits and exclude costs for administrative offices, storage areas, utilities, and other essential and nonessential auxiliary facilities. Fixed capital costs were estimated from literature estimates and scaled estimates (capacity, year, and material) from previous quotes. Capacity adjustments were based on the six-tenths factor rule:

$$C_2 = C_1 \left(\frac{q_2}{q_1} \right)^n \quad (5)$$

where C_1 is the cost of the equipment item at capacity q_1 , C_2 is the cost of the equipment at capacity q_2 , and n is the exponential factor, which typically has a value of 0.6 (Peters 2002). It was assumed that the number of trains did not have an impact on cost scaling. Cost indices were used to adjust equipment prices from previous years to values in July of 2009 using the Chemical Engineering Plant Cost Index (CEPCI). Costs for HTGRs and HTSE were scaled directly based on capacity—the six-tenths factor rule was not used.

Table 3. CEPCI data.

Year	CEPCI	Year	CEPCI
1990	357.6	2000	394.1
1991	361.3	2001	394.3
1992	358.2	2002	395.6
1993	359.2	2003	402
1994	368.1	2004	444.2
1995	381.1	2005	468.2
1996	381.7	2006	499.6
1997	386.5	2007	525.4
1998	389.5	2008	575.4
1999	390.6	July 2009	512

For the nuclear-integrated cases, the estimates of capital costs and operating and maintenance costs assumed the nuclear plant was an “nth of a kind.” In other words, the estimates were based on the costs expected after the HTGR technology

NUCLEAR-INTEGRATED AMMONIA PRODUCTION ANALYSIS

Identifier: TEV-666

Revision: 2

Effective Date: 05/25/2010

Page: 38 of 69

is integrated into an industrial application more than 10 times. The economic modeling calculations were based on two capital cost scenarios: a current best estimate of \$2,000/kW_t (INL 2007) and a target of \$1,400/kW_t (Demick 2009) where kW_t is the thermal rating of the plant. In comparison, light water nuclear reactor costs are approximately \$1,333/kW_t (NEI 2008). Based on the two capital cost scenarios for HTGR technology, the nominal capital cost for a 600 MW_t HTGR would be \$1.2 billion; the target capital cost would be \$840 million.

After cost estimates were obtained for each of the process areas, the costs for water systems, piping, instrumentation and control, electrical systems, and buildings and structures were added based on scaling factors for the total installed equipment costs (NETL 2000). These factors were not added to the cost of the HTGR, as the cost basis for the HGTR was assumed to represent a complete and operable system. Table 4 presents the factors utilized in this study:

Table 4. Capital cost adjustment factors.

Year	Factor
Water Systems	7.1%
Piping	7.1%
Instrumentation and Control	2.6%
Electrical Systems	8.0%
Buildings and Structures	9.2%

Finally, an engineering fee of 10% and a project contingency of 18% were assumed to determine the TCI. The capital cost provided for the HTGR represents a complete and operable system; the total value represents all inside battery limits (ISBL) and outside battery limits (OSBL) elements as well as contingency and owner's costs; therefore, engineering fees and contingencies were not applied to this cost.

The Association for the Advancement of Cost Engineering (AACE) International recognizes five classes of estimates. The level of project definition for this study was determined to be an AACE International Class 5 estimate. Though the baseline case is actually more in line with the AACE International Class 4 estimate, which is associated with equipment factoring, parametric modeling, historical relationship factors, and broad unit cost data, the HTGR project definition falls under an AACE International Class 5 estimate, associated with less than 2 percent project definition, and based on preliminary design methodology (AACE 2005). Since the HTGR is a larger portion of the total capital investment, an overall Class 5 estimate was assumed.

Based on the AACE International contingency guidelines as presented in DOE/FETC-99/1100 it would appear that the overall project contingency for the non-nuclear portion of the capital should be in the range of 30 to 50 percent, 30 to 40 percent for Class 4, and 50% for Class 5 (Parsons 1999). However, because the

NUCLEAR-INTEGRATED AMMONIA PRODUCTION ANALYSIS	Identifier: TEV-666 Revision: 2 Effective Date: 05/25/2010 Page: 39 of 69
---	---

cost estimates were scaled based on estimated, quoted, and actual project costs, the overall non-nuclear project contingency should be more in the range of 15 to 20 percent. Eighteen percent was selected based on similar studies conducted by NETL (2007). Again, contingency was not applied to the HTGR as project contingency was accounted for in the basis for the capital cost estimate.

Table 5 and Figure 8 present the capital cost estimate breakdown for the conventional coal-to-ammonia case, Table 6 and Figure 9 for the conventional gas-to-ammonia case, Table 7 and Figure 10 for the nuclear-integrated gas-to-ammonia case, Table 8 and Figure 11 for the HTSE-to-ammonia (N₂ from combustion) case, and Table 9 and Figure 12 for the HTSE-to-ammonia (N₂ from ASU) case. Varying only the cost of the nuclear facility was an adequate assumption, as the HTGR accounts for a large percentage of the overall cost for the nuclear-integrated cases. In addition, there is a greater level of uncertainty in the nuclear plant price given the nascency of HTGR development.

Idaho National Laboratory

NUCLEAR-INTEGRATED AMMONIA PRODUCTION ANALYSIS

Identifier: TEV-666
Revision: 2
Effective Date: 05/25/2010

Page: 40 of 69

Table 5. Total capital investment, conventional coal-to-ammonia case.

	Installed Cost	Engineering Fee	Contingency	Total Capital Cost
Coal Preparation	\$43,520,480	\$4,352,048	\$8,617,055	\$56,489,583
ASU	\$86,335,052	\$8,633,505	\$17,094,340	\$112,062,898
Gasification	\$139,987,967	\$13,998,797	\$27,717,617	\$181,704,381
Gas Cleaning	\$162,917,578	\$16,291,758	\$32,257,680	\$211,467,016
Ammonia Synthesis	\$221,682,591	\$22,168,259	\$43,893,153	\$287,744,004
Nitric Acid Synthesis	\$202,970,888	\$20,297,089	\$40,188,236	\$263,456,213
Ammonium Nitrate Synthesis	\$129,812,295	\$12,981,230	\$25,702,834	\$168,496,359
Urea Synthesis	\$215,184,342	\$21,518,434	\$42,606,500	\$279,309,276
ST, HRSG & CT	\$31,249,924	\$3,124,992	\$6,187,485	\$40,562,401
Water Systems	\$87,589,939	\$8,758,994	\$17,342,808	\$113,691,741
Piping	\$87,589,939	\$8,758,994	\$17,342,808	\$113,691,741
I&C	\$32,075,189	\$3,207,519	\$6,350,887	\$41,633,595
Electrical Systems	\$98,692,889	\$9,869,289	\$19,541,192	\$128,103,370
Buildings and Structures	\$113,496,823	\$11,349,682	\$22,472,371	\$147,318,876
Total Capital Investment				\$2,145,731,455




Figure 8. Total capital investment, conventional coal-to-ammonia case.

Idaho National Laboratory

NUCLEAR-INTEGRATED AMMONIA PRODUCTION ANALYSIS

Identifier: TEV-666
Revision: 2
Effective Date: 05/25/2010

Page: 41 of 69

Table 6. Total capital investment, conventional gas-to-ammonia case.

	Installed Cost	Engineering Fee	Contingency	Total Capital Cost
Natural Gas Reforming	\$88,732,286	\$8,873,229	\$17,568,993	\$115,174,507
Shift Conversion	\$29,319,270	\$2,931,927	\$5,805,215	\$38,056,412
Selexol	\$34,653,118	\$3,465,312	\$6,861,317	\$44,979,748
Methanation	\$7,104,506	\$710,451	\$1,406,692	\$9,221,648
CO ₂ Compression	\$9,312,091	\$931,209	\$1,843,794	\$12,087,094
Ammonia Synthesis	\$221,801,399	\$22,180,140	\$43,916,677	\$287,898,216
Nitric Acid Synthesis	\$203,111,753	\$20,311,175	\$40,216,127	\$263,639,056
Ammonium Nitrate Synthesis	\$129,812,295	\$12,981,230	\$25,702,834	\$168,496,359
Urea Synthesis	\$215,184,342	\$21,518,434	\$42,606,500	\$279,309,276
ST, HRSG and CT	\$15,579,691	\$1,557,969	\$3,084,779	\$20,222,440
Water Systems	\$67,777,363	\$6,777,736	\$13,419,918	\$87,975,018
Piping	\$67,777,363	\$6,777,736	\$13,419,918	\$87,975,018
I&C	\$24,819,880	\$2,481,988	\$4,914,336	\$32,216,204
Electrical Systems	\$76,368,860	\$7,636,886	\$15,121,034	\$99,126,780
Buildings and Structures	\$87,824,189	\$8,782,419	\$17,389,189	\$113,995,798
Total Capital Investment				\$1,660,373,573




Figure 9. Total capital investment, conventional gas-to-ammonia case.

Idaho National Laboratory

NUCLEAR-INTEGRATED AMMONIA PRODUCTION ANALYSIS

Identifier: TEV-666

Revision: 2

Effective Date: 05/25/2010

Page: 42 of 69

Table 7. Total capital investment, nuclear-integrated gas-to-ammonia case.

	Installed Cost	Engineering Fee	Contingency	Total Capital Cost
Nuclear (Includes all costs)				768,613,333
Natural Gas Reforming	\$78,666,814	\$7,866,681	\$15,576,029	\$102,109,525
Shift Conversion	\$29,941,964	\$2,994,196	\$5,928,509	\$38,864,669
Selexol	\$34,950,194	\$3,495,019	\$6,920,138	\$45,365,351
Methanation	\$7,103,237	\$710,324	\$1,406,441	\$9,220,002
CO ₂ Compression	\$9,348,529	\$934,853	\$1,851,009	\$12,134,390
Ammonia Synthesis	\$221,761,801	\$22,176,180	\$43,908,837	\$287,846,818
Nitric Acid Synthesis	\$203,111,753	\$20,311,175	\$40,216,127	\$263,639,056
Ammonium Nitrate Synthesis	\$129,812,295	\$12,981,230	\$25,702,834	\$168,496,359
Urea Synthesis	\$215,184,342	\$21,518,434	\$42,606,500	\$279,309,276
ST, HRSG and CT	\$16,614,823	\$1,661,482	\$3,289,735	\$21,566,040
Nuclear Power Cycle	\$90,964,386	\$9,096,439	\$18,010,948	\$118,071,773
Water Systems	\$67,201,198	\$6,720,120	\$13,305,837	\$87,227,156
Piping	\$67,201,198	\$6,720,120	\$13,305,837	\$87,227,156
I&C	\$24,608,890	\$2,460,889	\$4,872,560	\$31,942,339
Electrical Systems	\$75,719,660	\$7,571,966	\$14,992,493	\$98,284,119
Buildings and Structures	\$87,077,609	\$8,707,761	\$17,241,367	\$113,026,737
Total Capital Investment				\$2,532,944,099
Total Capital Investment (+50% HTGR)				\$2,917,250,765
Total Capital Investment (-30% HTGR)				\$2,302,360,099




Figure 10. Total capital investment, nuclear-integrated gas-to-ammonia case.

Idaho National Laboratory

NUCLEAR-INTEGRATED AMMONIA PRODUCTION ANALYSIS

Identifier: TEV-666


Revision: 2

Effective Date: 05/25/2010

Page: 43 of 69

Table 8. Total capital investment, HTSE-to-ammonia (N₂ from combustion) case.

	Installed Cost	Engineering Fee	Contingency	Total Capital Cost
Nuclear (Includes all costs)				4,201,101,416
HTSE	\$271,216,232	\$27,121,623	\$53,700,814	\$352,038,669
N ₂ Generation (Combustion)	\$12,900,791	\$1,290,079	\$2,554,357	\$16,745,226
Methanation	\$7,103,237	\$710,324	\$1,406,441	\$9,220,002
CO ₂ Gen. & Compression	\$11,210,720	\$1,121,072	\$2,219,722	\$14,551,514
Ammonia Synthesis	\$221,761,801	\$22,176,180	\$43,908,837	\$287,846,818
Nitric Acid Synthesis	\$203,111,753	\$20,311,175	\$40,216,127	\$263,639,056
Ammonium Nitrate Synthesis	\$129,812,295	\$12,981,230	\$25,702,834	\$168,496,359
Urea Synthesis	\$215,184,342	\$21,518,434	\$42,606,500	\$279,309,276
ST, HRSG and CT	\$40,856,623	\$4,085,662	\$8,089,611	\$53,031,897
Nuclear Power Cycle	\$615,345,050	\$61,534,505	\$121,838,320	\$798,717,875
Water Systems	\$79,034,203	\$7,903,420	\$15,648,772	\$102,586,396
Piping	\$79,034,203	\$7,903,420	\$15,648,772	\$102,586,396
I&C	\$28,942,103	\$2,894,210	\$5,730,536	\$37,566,849
Electrical Systems	\$89,052,624	\$8,905,262	\$17,632,419	\$115,590,305
Buildings and Structures	\$102,410,517	\$10,241,052	\$20,277,282	\$132,928,851
Total Capital Investment				\$6,935,956,906
Total Capital Investment (+50% HTGR)				\$9,036,507,614
Total Capital Investment (-30% HTGR)				\$5,675,626,481

Figure 11. Total capital investment, HTSE-to-ammonia (N₂ from combustion) case.

Idaho National Laboratory

NUCLEAR-INTEGRATED AMMONIA PRODUCTION ANALYSIS

Identifier: TEV-666


Revision: 2

Effective Date: 05/25/2010

Page: 44 of 69

Table 9. Total capital investment, HTSE-to-ammonia (N₂ from ASU) case.

	Installed Cost	Engineering Fee	Contingency	Total Capital Cost
Nuclear (Includes all costs)				3,666,008,905
HTSE	\$229,865,245	\$22,986,525	\$45,513,319	\$298,365,088
N ₂ Generation (Cryo. ASU)	\$36,589,053	\$3,658,905	\$7,244,633	\$47,492,591
Methanation	\$7,103,237	\$710,324	\$1,406,441	\$9,220,002
CO ₂ Gen. & Compression	\$11,210,617	\$1,121,062	\$2,219,702	\$14,551,380
Ammonia Synthesis	\$221,761,801	\$22,176,180	\$43,908,837	\$287,846,818
Nitric Acid Synthesis	\$203,111,753	\$20,311,175	\$40,216,127	\$263,639,056
Ammonium Nitrate Synthesis	\$129,812,295	\$12,981,230	\$25,702,834	\$168,496,359
Urea Synthesis	\$215,184,342	\$21,518,434	\$42,606,500	\$279,309,276
ST and CT	\$36,974,182	\$3,697,418	\$7,320,888	\$47,992,488
Nuclear Power Cycle	\$568,211,288	\$56,821,129	\$112,505,835	\$737,538,251
Water Systems	\$77,504,489	\$7,750,449	\$15,345,889	\$100,600,827
Piping	\$77,504,489	\$7,750,449	\$15,345,889	\$100,600,827
I&C	\$28,381,926	\$2,838,193	\$5,619,621	\$36,839,740
Electrical Systems	\$87,329,002	\$8,732,900	\$17,291,142	\$113,353,045
Buildings and Structures	\$100,428,352	\$10,042,835	\$19,884,814	\$130,356,001
Total Capital Investment				\$6,302,210,656
Total Capital Investment (+50% HTGR)				\$8,135,215,109
Total Capital Investment (-30% HTGR)				\$5,202,407,985

Figure 12. Total capital investment, HTSE-to-ammonia (N₂ from ASU) case.

NUCLEAR-INTEGRATED AMMONIA PRODUCTION ANALYSIS	Identifier:	TEV-666	
	Revision:	2	
	Effective Date:	05/25/2010	Page: 45 of 69

4.2 Estimation of Revenue

Yearly revenues were estimated for all cases based on recent price data for the various products generated. Revenues were estimated for low, average, and high prices for urea and ammonium nitrate. High prices correspond to prices from April 2008, low prices are from April 2002, and average prices were the average of the high and low values. Product prices were gathered from the U. S. Department of Agriculture (USDA) and represent actual purchase prices for farm use (USDA 2010). For the coal-based case, selling prices for slag and sulfur were not varied in the study. A stream factor of 92% is assumed for both the fossil and nuclear plants. Table 10 presents the revenues for the conventional coal-to-ammonia case. Table 11 presents the revenues for the conventional gas-to-ammonia case, the nuclear-integrated gas-to-ammonia case, and both HTSE-to-ammonia cases (i.e., revenues are the same for all of these cases).

Table 10. Annual revenues, conventional coal-to-ammonia case.

	Price		Generated		Annual Revenue
Slag	25.63	\$/ton	328	ton/day	\$2,821,332
Sulfur	38.13	\$/ton	153	ton/day	\$1,960,719
Urea – Low	227.04	\$/ton	2,939	ton/day	\$224,068,446
Urea – Avg.	396.42	\$/ton	2,939	ton/day	\$391,232,816
Urea – High	565.80	\$/ton	2,939	ton/day	\$558,397,186
AN – Low	231.79	\$/ton	3,779	ton/day	\$294,143,498
AN – Avg.	376.76	\$/ton	3,779	ton/day	\$478,103,183
AN – High	521.73	\$/ton	3,779	ton/day	\$662,062,869
Annual Revenue, low					\$522,993,995
Annual Revenue, average					\$874,118,051
Annual Revenue, high					\$1,225,242,106

NUCLEAR-INTEGRATED AMMONIA PRODUCTION ANALYSIS	Identifier:	TEV-666	
	Revision:	2	
	Effective Date:	05/25/2010	Page: 46 of 69

Table 11. Annual revenues, conventional and nuclear-integrated gas-to-ammonia cases.

	Price		Generated		Annual Revenue
Urea – Low	227.04	\$/ton	2,939	ton/day	\$224,068,446
Urea – Avg.	396.42	\$/ton	2,939	ton/day	\$391,232,816
Urea – High	565.80	\$/ton	2,939	ton/day	\$558,397,186
AN – Low	231.79	\$/ton	3,779	ton/day	\$294,143,498
AN – Avg.	376.76	\$/ton	3,779	ton/day	\$478,103,183
AN – High	521.73	\$/ton	3,779	ton/day	\$662,062,869
Annual Revenue, low					\$518,211,944
Annual Revenue, average					\$869,335,999
Annual Revenue, high					\$1,220,460,055

Table 12. Annual revenues, HTSE-to-ammonia (N₂ from combustion) case.

	Price		Generated		Annual Revenue
Oxygen	41.60	\$/ton	2,506	ton/day	\$35,006,192
Urea – Low	227.04	\$/ton	2,939	ton/day	\$224,068,446
Urea – Avg.	396.42	\$/ton	2,939	ton/day	\$391,232,816
Urea – High	565.80	\$/ton	2,939	ton/day	\$558,397,186
AN – Low	231.79	\$/ton	3,779	ton/day	\$294,143,498
AN – Avg.	376.76	\$/ton	3,779	ton/day	\$478,103,183
AN – High	521.73	\$/ton	3,779	ton/day	\$662,062,869
Annual Revenue, low					\$553,218,136
Annual Revenue, average					\$904,342,191
Annual Revenue, high					\$1,255,466,246

Table 13. Annual revenues, HTSE-to-ammonia (N₂ from ASU) case.

	Price		Generated		Annual Revenue
Oxygen	41.60	\$/ton	2,435	ton/day	\$34,018,469
Urea – Low	227.04	\$/ton	2,939	ton/day	\$224,068,446
Urea – Avg.	396.42	\$/ton	2,939	ton/day	\$391,232,816
Urea – High	565.80	\$/ton	2,939	ton/day	\$558,397,186
AN – Low	231.79	\$/ton	3,779	ton/day	\$294,143,498
AN – Avg.	376.76	\$/ton	3,779	ton/day	\$478,103,183
AN – High	521.73	\$/ton	3,779	ton/day	\$662,062,869
Annual Revenue, low					\$552,230,413
Annual Revenue, average					\$903,354,468
Annual Revenue, high					\$1,254,478,523

4.3 Estimation of Manufacturing Costs

Manufacturing cost is the sum of direct and indirect manufacturing costs. Direct manufacturing costs for this project include the cost of raw materials, utilities, and

NUCLEAR-INTEGRATED AMMONIA PRODUCTION ANALYSIS	Identifier: TEV-666 Revision: 2 Effective Date: 05/25/2010 Page: 47 of 69
---	---

operating labor and maintenance. Indirect manufacturing costs include estimates for the cost of overhead and insurance and taxes (Perry 2008).

Labor costs are assumed to be 1.15% of the total capital investment for the fossil portion of each case (for a discussion of how this value was determined, see TEV-672). Maintenance costs were assumed to be 3% of the total capital investment per the *Handbook of Petroleum Processing*. The power cycles and HTSE were not included in the TCI for operation and maintenance costs, as they were calculated separately. Taxes and insurance were assumed to be 1.5% of the TCI, excluding the HTGR, an overhead of 65% of the labor and maintenance costs was assumed, and royalties were assumed to be 1% of the coal or natural gas cost based on information presented in the *Handbook of Petroleum Processing* (Jones 2006). Table 14 provides the manufacturing costs for the conventional coal-to-ammonia case. Availability of both the fossil and nuclear plants was assumed to be 92%.

For the gas-to-ammonia and nuclear-integrated gas-to-ammonia cases, manufacturing costs were calculated for two scenarios: with sequestration and without sequestration. For these cases, only the sequestration results are presented below.

For the gas-to-ammonia and HTSE-to-ammonia cases, natural gas prices were varied to account for the large fluctuations seen in the market. Costs were calculated for low (\$4.50/MSCFD), average (\$6.50/MSCFD), and high (\$12.00/MSCFD) industrial natural gas prices. High prices correspond to prices from June 2008, low prices are from September 2009, and the average price was chosen to reflect current natural gas price (EIA 2010). Only average natural gas prices are presented in the gas-to-ammonia tables below.

Operating and maintenance costs for the nuclear plant were based on data from General Atomics for the GT-MHR HTGR published in 2002; these costs were inflated to 2009 dollars (GA 2002). HTSE cell-replacement costs were calculated assuming cell replacement every eight years based on vendor input; see TEV-693, "Nuclear-Integrated Hydrogen Production Analysis," for detailed information regarding calculation of cell replacements costs (McKellar 2010).

Idaho National Laboratory

NUCLEAR-INTEGRATED AMMONIA PRODUCTION ANALYSIS	Identifier:	TEV-666	
	Revision:	2	
	Effective Date:	05/25/2010	Page: 48 of 69

Table 14. Annual manufacturing costs, conventional coal-to-ammonia case.

	Price		Consumed		Annual Cost
Direct Costs					
Materials					
Coal	36.16	\$/ton	4,591	ton/day	\$55,747,791
Fly Ash Disposal	33.20	\$/ton	138	ton/day	\$1,533,551
Selexol Solvent	2.57	\$/gal	8.13	gal/day	\$7,031
Makeup H ₂ O Treatment	0.02	\$/k-gal	6,431	k-gal/day	\$52,819
Wastewater Treatment	1.32	\$/k-gal	2,379	k-gal/day	\$1,050,381
Claus Catalyst	21.00	\$/ft ³	0.545	ft ³ /day	\$3,841
SCOT Catalyst	275.00	\$/ft ³	0.083	ft ³ /day	\$7,663
Carbon, Hg Guard Bed	5.57	\$/lb	6.000	lb/day	\$11,193
Zinc Oxide	300.00	\$/ft ³	0.035	ft ³ /day	\$3,515
WGS Catalyst	825.00	\$/ft ³	0.674	ft ³ /day	\$186,648
Methanation Catalyst	700.00	\$/ft ³	0.025	ft ³ /day	\$5,865
Ammonia Synthesis Catalyst	775.00	\$/ft ³	0.029	ft ³ /day	\$7,547
Platinum (HNO ₃ Catalyst)	23,118	\$/lb	0.622	lb/day	\$4,831,085
SCR Catalyst	424.93	\$/ft ³	0.135	ft ³ /day	\$19,298
Utilities					
Electricity	1.67	\$/kW-d	141,800	kW	\$79,538,501
Water	0.05	\$/k-gal	6,431	k-gal/day	\$99,337
Royalties					\$557,478
Labor and Maintenance					\$89,047,855
Indirect Costs					
Overhead					\$57,881,106
Insurance and Taxes					\$32,185,972
Manufacturing Costs					\$322,778,478

Idaho National Laboratory

NUCLEAR-INTEGRATED AMMONIA PRODUCTION ANALYSIS	Identifier:	TEV-666	
	Revision:	2	
	Effective Date:	05/25/2010	Page: 49 of 69

Table 15. Annual manufacturing costs, conventional gas-to-ammonia case.

	Price		Consumed		Annual Cost
Direct Costs					
Materials					
Average Natural Gas	6.50	\$/MSCF	88	MSCFD	\$192,077,600
Makeup H ₂ O Treatment	0.02	\$/k-gal	5,656	k-gal/day	\$46,452
Wastewater Treatment	1.32	\$/k-gal	2,474	k-gal/day	\$1,092,218
HDS Catalyst	700.00	\$/ft ³	0.04	ft ³ /day	\$8,613
Zinc Oxide	300.00	\$/ft ³	0.344	ft ³ /day	\$34,681
Preforming Catalyst	2,350	\$/ft ³	0.00	ft ³ /day	\$0
Primary SMR Catalyst	750.00	\$/ft ³	0.16	ft ³ /day	\$39,585
Secondary SMR Catalyst	650.00	\$/ft ³	0.04	ft ³ /day	\$9,372
HTS Catalyst	380.00	\$/ft ³	0.19	ft ³ /day	\$23,927
LTS Catalyst	600.00	\$/ft ³	0.15	ft ³ /day	\$30,611
Selexol Solvent	2.57	\$/gal	8.14	gal/day	\$7,037
Methanation Catalyst	700.00	\$/ft ³	0.042	ft ³ /day	\$9,906
Ammonia Synthesis Catalyst	775.00	\$/ft ³	0.029	ft ³ /day	\$7,498
Platinum (HNO ₃ Catalyst)	23,118	\$/lb	0.62	lb/day	\$4,836,674
SCR Catalyst	424.93	\$/ft ³	0.135	ft ³ /day	\$19,321
CO ₂ Sequestration	14.54	\$/ton	1,762	ton/day	\$8,601,852
Utilities					
Electricity	1.67	\$/kW-day	108,800	kW	\$61,028,131
Water	0.05	\$/k-gal	5,656	k-gal/day	\$87,363
Royalties					\$1,920,776
Labor and Maintenance					\$68,905,503
Indirect Costs					
Overhead					\$44,788,577
Insurance and Taxes					\$24,905,604
Manufacturing Costs, Average Natural Gas					\$408,481,302

Idaho National Laboratory

NUCLEAR-INTEGRATED AMMONIA PRODUCTION ANALYSIS	Identifier:	TEV-666
	Revision:	2
	Effective Date:	05/25/2010

Page: 50 of 69

Table 16. Annual manufacturing costs, nuclear-integrated gas-to-ammonia case.

	Price		Consumed		Annual Cost
Direct Costs					
Materials					
Average Natural Gas	6.50	\$/MSCF	72	MSCFD	\$157,154,400
Makeup H ₂ O Treatment	0.02	\$/k-gal	5,737	k-gal/day	\$47,122
Wastewater Treatment	1.32	\$/k-gal	2,560	k-gal/day	\$1,130,241
HDS Catalyst	700.00	\$/ft ³	0.04	ft ³ /day	\$9,077
Zinc Oxide	300.00	\$/ft ³	0.363	ft ³ /day	\$36,592
Preforming Catalyst	2,350	\$/ft ³	0.00	ft ³ /day	\$0
Primary SMR Catalyst	750.00	\$/ft ³	0.40	ft ³ /day	\$101,298
Secondary SMR Catalyst	650.00	\$/ft ³	0.04	ft ³ /day	\$8,638
HTS Catalyst	380.00	\$/ft ³	0.20	ft ³ /day	\$24,891
LTS Catalyst	600.00	\$/ft ³	0.16	ft ³ /day	\$31,810
Selexol Solvent	2.57	\$/gal	8.14	gal/day	\$7,035
Methanation Catalyst	700.00	\$/ft ³	0.043	ft ³ /day	\$10,122
Ammonia Synthesis Catalyst	775.00	\$/ft ³	0.030	ft ³ /day	\$7,770
Platinum (HNO ₃ Catalyst)	23,118	\$/lb	0.62	lb/day	\$4,836,674
SCR Catalyst	424.93	\$/ft ³	0.135	ft ³ /day	\$19,319
Nuclear Fuel	8.80	\$/MW-h	180	MW _e	\$12,758,100
CO ₂ Sequestration	14.54	\$/ton	1,786	ton/day	\$8,719,017
Utilities					
Electricity	1.67	\$/kW-day	0	kW	\$0
Water	0.05	\$/k-gal	5,737	k-gal/day	\$88,622
Royalties					\$1,571,544
O&M, Nuclear	3.57	\$/MW-h	180	MW _e	\$5,172,203
Labor and Maintenance, Fossil					\$68,319,748
Indirect Costs					
Overhead					\$44,407,836
Insurance and Taxes					\$26,464,961
Manufacturing Costs, Average Natural Gas					\$330,927,021

Idaho National Laboratory

NUCLEAR-INTEGRATED AMMONIA PRODUCTION ANALYSIS	Identifier:	TEV-666
	Revision:	2
	Effective Date:	05/25/2010
Page: 51 of 69		

Table 17. Annual manufacturing costs, HTGR-to-ammonia (N₂ from combustion).

	Price		Consumed		Annual Cost
Direct Costs					
Materials					
Average Natural Gas	6.50	\$/MSCF	36	MSCFD	\$78,577,200
Makeup H ₂ O Treatment	0.02	\$/k-gal	9,121	k-gal/day	\$74,913
Wastewater Treatment	1.32	\$/k-gal	3,038	k-gal/day	\$1,341,588
HDS Catalyst	700.00	\$/ft ³	0.02	ft ³ /day	\$5,693
Zinc Oxide	300.00	\$/ft ³	0.181	ft ³ /day	\$18,254
Methanation Catalyst	700.00	\$/ft ³	0.031	ft ³ /day	\$7,331
Ammonia Synthesis Catalyst	775.00	\$/ft ³	0.030	ft ³ /day	\$7,697
Platinum (HNO ₃ Catalyst)	23,118	\$/lb	0.62	lb/day	\$4,836,674
SCR Catalyst	424.93	\$/ft ³	0.135	ft ³ /day	\$19,318
HTSE Cell Replacements	0.02	\$/lb H ₂	1,430	k-lb H ₂ /day	\$11,646,491
Nuclear Fuel	8.80	\$/MW-h	984	MW _e	\$69,733,466
CO ₂ Sequestration	14.54	\$/ton	0	ton/day	\$0
Utilities					
Electricity	1.67	\$/kW-day	0	kW	\$0
Water	0.05	\$/k-gal	9,121	k-gal/day	\$140,890
Royalties					\$785,772
O&M, Nuclear	3.57	\$/MW-h	984	MW _e	\$28,270,324
Labor and Maintenance, Fossil					\$74,118,627
Indirect Costs					
Overhead					\$48,177,107
Insurance and Taxes					\$41,022,832
Manufacturing Costs, Average Natural Gas					\$358,784,178

NUCLEAR-INTEGRATED AMMONIA PRODUCTION ANALYSIS	Identifier:	TEV-666	
	Revision:	2	
	Effective Date:	05/25/2010	Page: 52 of 69

Table 18. Annual manufacturing costs, HTGR-to-ammonia (N₂ from ASU).

	Price		Consumed		Annual Cost
Direct Costs					
Materials					
Average Natural Gas	6.50	\$/MSCF	36	MSCFD	\$78,577,200
Makeup H ₂ O Treatment	0.02	\$/k-gal	7,999	k-gal/day	\$65,696
Wastewater Treatment	1.32	\$/k-gal	2,648	k-gal/day	\$1,169,280
HDS Catalyst	700.00	\$/ft ³	0.02	ft ³ /day	\$5,693
Zinc Oxide	300.00	\$/ft ³	0.181	ft ³ /day	\$18,254
Methanation Catalyst	700.00	\$/ft ³	0.031	ft ³ /day	\$7,181
Ammonia Synthesis Catalyst	775.00	\$/ft ³	0.029	ft ³ /day	\$7,514
Platinum (HNO ₃ Catalyst)	23,118	\$/lb	0.62	lb/day	\$4,836,674
SCR Catalyst	424.93	\$/ft ³	0.135	ft ³ /day	\$19,318
HTSE Cell Replacements	0.02	\$/lb H ₂	1,212	k-lb H ₂ /day	\$9,870,809
Nuclear Fuel	8.80	\$/MW-h	858	MW _e	\$60,851,544
CO ₂ Sequestration	14.54	\$/ton	0	ton/day	\$0
Utilities					
Electricity	1.67	\$/kW-day	0	kW	\$0
Water	0.05	\$/k-gal	7,999	k-gal/day	\$123,555
Royalties					\$785,772
O&M, Nuclear	3.57	\$/MW-h	858	MW _e	\$24,669,545
Labor and Maintenance, Fossil					\$73,513,473
Indirect Costs					
Overhead					\$47,783,758
Insurance and Taxes					\$39,543,026
Manufacturing Costs, Average Natural Gas					\$341,848,293

4.4 Economic Comparison

To assess the economic desirability of the coal-to-ammonia and gas-to-ammonia cases, several economic indicators were calculated for each case. For all cases the internal rate of return (IRR) for low, average, and high product selling price was calculated, as well as low, average, and high natural gas prices for the gas-to-ammonia cases. In addition, the product price necessary for a return of 12% was calculated for all cases for the baseline coal cost as well as low, average, and high natural gas prices. The following assumptions were made for the economic analyses:

- The plant startup year is 2014.
- A construction period of three years for the fossil plant and five years for the nuclear plant. In order to easily perform the analysis in 2009 dollars, the following simplifying assumptions were made:
 - Fossil plant construction begins in 2011

NUCLEAR-INTEGRATED AMMONIA PRODUCTION ANALYSIS	Identifier: TEV-666 Revision: 2 Effective Date: 05/25/2010 Page: 53 of 69
---	---

- Nuclear plant construction begins in 2009
- It is assumed that all reactors come online at the same time. A study was conducted for CTL to determine the impact of six-month and three-month reactor staging versus all reactors coming online at one time. It was determined that the simplification of assuming all reactors online at once does not impact the economic results significantly enough to warrant the complexity of creating multiple staging trains for each scenario. These results were assumed to be equally valid for all nuclear-integrated ammonia cases.
- Percent capital invested for the fossil plant is 33% per year
- Percent capital invested for the HTGR is 20% per year
- Plant startup time is one year.
 - Operating costs are 85% of the total value during startup
 - Revenues are 60% of the total value during startup
- The analysis period for the economic evaluation assumes an economic life of 30 years, excluding construction time (the model is built to accommodate up to 40 years).
- An availability of 92% was assumed for both the fossil and nuclear plants; the plants are assumed to operate 365 days a year, 24 hours per day.
- An inflation rate of 2.5% is assumed.
- Debt to equity ratios of 80%/20% and 55%/45% are calculated; however, results are only presented for 80%/20%.
 - The interest rate on debt is assumed to be 8%
 - The repayment term on the loan is assumed to be 15 years
- The effective income tax rate is 38.9%.
 - State tax is 6%
 - Federal tax is 35%
- MACRS depreciation is assumed.
- A CO₂ tax of \$0/ton to \$100/ton for coal-to-ammonia and \$0/ton to \$200/ton for the gas-to-ammonia cases is investigated.

NUCLEAR-INTEGRATED AMMONIA PRODUCTION ANALYSIS

Identifier: TEV-666

Revision: 2

Effective Date: 05/25/2010

Page: 54 of 69

4.4.1 Cash Flow

To assess the IRR and PW of each scenario, it is necessary to calculate the after tax cash flow (ATCF). To calculate the ATCF it is necessary to first calculate the revenues (R_k); cash outflows (E_k); sum of all noncash, or book, costs such as depreciation (d_k); net income before taxes (NIBT); the effective income tax rate (t); and the income taxes (T_k), for each year (k). The taxable income is revenue minus the sum of all cash outflow and noncash costs. Therefore the income taxes per year are defined as follows (Sullivan 2003):

$$T_k = t(R_k - E_k - d_k) \quad (6)$$

Depreciation for the economic calculations was calculated using a standard MACRS depreciation method with a property class of 15 years. Depreciation was assumed for the total capital investment over the 5-year construction schedule, including inflation. Table 19 presents the recovery rates for a 15-year property class (Perry 2008):

Table 19. MACRS depreciation.

Year	Recovery Rate	Year	Recovery Rate
1	0.05	9	0.0591
2	0.095	10	0.059
3	0.0855	11	0.0591
4	0.077	12	0.059
5	0.0693	13	0.0591
6	0.0623	14	0.059
7	0.059	15	0.0591
8	0.059	16	0.0295

The ATCF is then the sum of the before tax cash flow (BTCF) minus the income taxes owed. Note that the expenditures for capital are not taxed but are included in the BTCF each year there is a capital expenditure (C_k); this includes the equity capital and the debt principle. The BTCF is defined as follows (Sullivan 2003):

$$BTCF_k = R_k - E_k - C_k \quad (7)$$

The ATCF can then be defined as:

$$ATCF_k = BTCF_k - T_k \quad (8)$$

It should be noted that when a CO₂ tax credit is included in the economic analysis, the tax would be treated essentially as a manufacturing cost, decreasing the yearly revenue.

NUCLEAR-INTEGRATED AMMONIA PRODUCTION ANALYSIS	Identifier:	TEV-666	
	Revision:	2	
	Effective Date:	05/25/2010	Page: 55 of 69

4.4.2 Internal Rate of Return

The IRR method is the most widely used rate of return method for performing engineering economic analyses. This method solves for the interest rate that equates the equivalent worth of an alternative's cash inflows to the equivalent worth of cash outflows (after tax cash flow), i.e., the interest rate at which the PW is zero. The resulting interest is the IRR (i'). For the project to be economically viable, the calculated IRR must be greater than the desired minimum annual rate of return (MARR) (Sullivan 2003).

$$PW(i'\%) = \sum_{k=0}^N ATCF_k (1+i')^{-k} = 0 \quad (9)$$

IRR calculations were performed for a 80%/20% debt to equity ratio for the calculated fossil TCI and at +50% TCI and -30% TCI for the HTGR for all cases at low, average, and high product prices for coal-to-ammonia and gas-to-ammonia as well as low, average, and high natural gas purchase prices for gas-to-ammonia. In addition, the price of urea and ammonium nitrate necessary for an IRR of 12% and a PW of zero was calculated for each case at each debt to equity ratio. The IRR and product price required (for an IRR of 12%) was solved for using the Goal Seek function in Excel (Excel 2007).

Finally, a CO₂ tax was included into the calculations to determine the price of urea and ammonium nitrate necessary in all cases for a 12% IRR and a CO₂ tax of \$0/ton to \$100/ton for coal-to-ammonia and \$0/ton to \$200/ton for gas-to-ammonia. These cases were calculated for 80%/20% and 55%/45% debt to equity ratios for the TCI and +50% TCI and -30% TCI of the HTGR. Additionally, the gas-to-ammonia cases were calculated for either sequestering or not sequestering the CO₂. The tax calculated was added to the existing tax liability for each year.

5. ECONOMIC MODELING RESULTS

5.1 Coal-to-Ammonia Economic Results

Table 20 presents the results for an 80%/20% debt to equity ratio for the conventional coal-to-ammonia case, listing the IRR for low, average, and high urea selling prices, and the urea selling price required for a 12% IRR. Figure 13 depicts the associated IRR results for the conventional coal-to-ammonia case. Figure 14 shows the impact of a carbon tax on the selling price of urea and ammonium nitrate. Because a suitable nuclear-integrated coal-to-ammonia case was not identified, these results are presented for information only. Results indicate that a return of 12% can be achieved for a urea production price of \$259.07/ton. Note that carbon sequestration is not considered in this

NUCLEAR-INTEGRATED AMMONIA PRODUCTION ANALYSIS

Identifier: TEV-666

Revision: 2

Effective Date: 05/25/2010

Page: 56 of 69

analysis. Without sequestration, the urea production price increases sharply as a function of the carbon tax imposed; a urea selling price of \$407.64/ton is required to achieve a 12% return when a \$100/ton carbon tax is imposed.

Table 20. Conventional coal-to ammonia IRR results.

	TCI	
	IRR	\$/ton urea
Conventional Coal-to- Ammonia	\$2,087,531,131	
	9.04	\$227.04
	27.61	\$396.42
	42.55	\$565.80
	12.00	\$259.07




Figure 13. Conventional coal-to-ammonia IRR economic results.

NUCLEAR-INTEGRATED AMMONIA PRODUCTION ANALYSIS

Identifier: TEV-666
Revision: 2
Effective Date: 05/25/2010

Page: 57 of 69




Figure 14. Conventional coal-to-ammonia carbon tax results (12% IRR).

5.2 Gas-to-Ammonia and HTSE-to-Ammonia Economic Results

Table 21 presents the results for an 80%/20% debt to equity ratio for the conventional gas-to-ammonia, nuclear-integrated gas-to-ammonia, and HTSE-to-ammonia cases, listing the IRR for low, average, and high urea selling prices, and the urea selling price required for a 12% IRR. These results do not assume carbon sequestration. Figure 15 depicts the associated IRR results for these cases at the average natural gas price of \$6.50/MSCF. These results indicate that a favorable 12% IRR is achievable for the HTGR-integrated case when urea price rises above \$286/ton; hence, such an option appears to be economically viable given current fertilizer prices. The HTSE-to-ammonia cases do not look as favorable, as urea prices would need to be around \$500/ton to achieve a 12% return.

Idaho National Laboratory

NUCLEAR-INTEGRATED AMMONIA PRODUCTION ANALYSIS	Identifier:	TEV-666
	Revision:	2
	Effective Date:	05/25/2010
Page: 58 of 69		

Table 21. Gas-to-ammonia and HTSE-to-ammonia IRR results (no sequestration).

	TCI -30% HTGR		TCI		TCI +50% HTGR	
	IRR	\$/ton urea	IRR	\$/ton urea	IRR	\$/ton urea
Conventional Gas-to-Ammonia Low NG: \$4.50/MSCF			\$1,660,373,573			
			10.69 \$227.04			
			33.29 \$396.42			
			50.69 \$565.80			
			12.00 \$244.36			
HTGR-Integrated Gas-to-Ammonia Low NG: \$4.50/MSCF	\$2,302,360,099		\$2,532,944,099		\$2,917,250,765	
	10.47	\$227.04	9.24	\$227.04	7.59	\$227.04
	26.19	\$396.42	23.68	\$396.42	20.44	\$396.42
	38.46	\$565.80	35.00	\$565.80	30.56	\$565.80
	12.00	\$249.88	12.00	\$263.32	12.00	\$285.71
HTSE-to- Ammonia N ₂ from Comb. Low NG: \$4.50/MSCF	\$5,675,626,481		\$6,935,956,906		\$9,036,507,614	
	0.72	\$227.04	-0.69	\$227.04	-\$2.41	\$227.04
	9.57	\$396.42	7.30	\$396.42	4.74	\$396.42
	16.14	\$565.80	13.02	\$565.80	9.59	\$565.80
	12.00	\$452.42	12.00	\$525.86	12.00	\$648.27
HTSE-to- Ammonia N ₂ from ASU Low NG: \$4.50/MSCF	\$5,202,407,985		\$6,302,210,656		\$8,135,215,109	
	1.92	\$227.04	0.48	\$227.04	-\$1.27	\$227.04
	10.99	\$396.42	8.64	\$396.42	5.97	\$396.42
	17.93	\$565.80	14.67	\$565.80	11.07	\$565.80
	12.00	\$418.05	12.00	\$482.14	12.00	\$588.96
Conventional Gas-to-Ammonia Average NG: \$6.50/MSCF			\$1,660,373,573			
			5.84 \$227.04			
			29.67 \$396.42			
			47.77 \$565.80			
			12.00 \$272.23			
HTGR-Integrated Gas-to-Ammonia Average NG: \$6.50/MSCF	\$2,302,360,099		\$2,532,944,099		\$2,917,250,765	
	7.78	\$227.04	6.73	\$227.04	5.31	\$227.04
	24.15	\$396.42	21.81	\$396.42	18.80	\$396.42
	36.81	\$565.80	33.48	\$565.80	29.20	\$565.80
	12.00	\$272.68	12.00	\$286.12	12.00	\$308.51
HTSE-to- Ammonia N ₂ from Comb. Average NG: \$6.50/MSCF	\$5,675,626,481		\$6,935,956,906		\$9,036,507,614	
	-0.15	\$227.04	-1.50	\$227.04	-\$3.15	\$227.04
	9.05	\$396.42	6.85	\$396.42	4.34	\$396.42
	15.70	\$565.80	12.64	\$565.80	9.28	\$565.80
	12.00	\$463.82	12.00	\$537.26	12.00	\$659.67
HTSE-to- Ammonia N ₂ from ASU Average NG: \$6.50/MSCF	\$5,202,407,985		\$6,302,210,656		\$8,135,215,109	
	1.06	\$227.04	-0.31	\$227.04	-\$2.00	\$227.04
	10.45	\$396.42	8.16	\$396.42	5.56	\$396.42
	17.46	\$565.80	14.27	\$565.80	10.74	\$565.80
	12.00	\$429.45	12.00	\$493.54	12.00	\$600.36
Conventional Gas-to-Ammonia High NG: \$12.00/MSCF			\$1,660,373,573			
			N/A \$227.04			
			19.06 \$396.42			
			39.25 \$565.80			
			12.00 \$348.85			

NUCLEAR-INTEGRATED AMMONIA PRODUCTION ANALYSIS

Identifier: TEV-666

Revision: 2

Effective Date: 05/25/2010

Page: 59 of 69

Table 21. Gas-to-ammonia and HTSE-to-ammonia IRR results (no sequestration).

	TCI -30% HTGR		TCI		TCI +50% HTGR	
	IRR	\$/ton urea	IRR	\$/ton urea	IRR	\$/ton urea
HTGR-Integrated Gas-to-Ammonia High NG: \$12.00/MSCF	\$2,302,360,099		\$2,532,944,099		\$2,917,250,765	
	-2.07	\$227.04	-2.66	\$227.04	-3.50	\$227.04
	18.24	\$396.42	16.41	\$396.42	14.03	\$396.42
	32.02	\$565.80	29.07	\$565.80	25.28	\$565.80
	12.00	\$335.37	12.00	\$348.81	12.00	\$371.20
HTSE-to-Ammonia N₂ from Comb. High NG: \$12.00/MSCF	\$5,675,626,481		\$6,935,956,906		\$9,036,507,614	
	-3.00	\$227.04	-4.19	\$227.04	-\$5.66	\$227.04
	7.58	\$396.42	5.55	\$396.42	3.22	\$396.42
	14.48	\$565.80	11.59	\$565.80	8.40	\$565.80
	12.00	\$495.17	12.00	\$568.61	12.00	\$691.01
HTSE-to-Ammonia N₂ from ASU High NG: \$12.00/MSCF	\$5,202,407,985		\$6,302,210,656		\$8,135,215,109	
	-1.68	\$227.04	-2.88	\$227.04	-\$4.39	\$227.04
	8.91	\$396.42	6.81	\$396.42	4.39	\$396.42
	16.17	\$565.80	13.16	\$565.80	9.81	\$565.80
	12.00	\$460.80	12.00	\$524.89	12.00	\$631.70




Figure 15. Gas-to-ammonia and HTSE-to-ammonia IRR economic results (average natural gas price, no sequestration).

NUCLEAR-INTEGRATED AMMONIA PRODUCTION ANALYSIS	Identifier: TEV-666 Revision: 2 Effective Date: 05/25/2010 Page: 60 of 69
---	--

Because the nuclear-integrated gas-to-ammonia case does not combust natural gas in the primary reformer, CO₂ emissions are reduced in this configuration compared to the conventional gas-to-ammonia case. Hence, implementation of a carbon tax will improve the economics of this case in comparison to conventional case. As seen in Table 22 and Figure 16, the selling price of urea is equal for both cases with a CO₂ tax of approximately \$75/ton. For a tax in excess of this amount, the nuclear-integrated case economically outperforms the conventional case. Note that this result is valid independent of whether CO₂ is sequestered downstream of the water-gas shift converters (i.e., sequestration in this location is equally applicable to either the conventional or nuclear-integrated gas-to-ammonia case).

Table 22. Gas-to-ammonia and HTSE-to-ammonia carbon tax results (average natural gas price, no sequestration).

Carbon Tax \$/ton		TCI -30% HTGR	TCI Urea Price (\$/ton)	TCI +50% HTGR
Conventional Gas-to-Ammonia	0		272.23	
	50		302.09	
	100		331.96	
	150		361.82	
	200		391.69	
HTGR-Integrated Gas-to-Ammonia	0	272.68	286.12	308.51
	50	293.29	306.73	329.12
	100	313.90	327.34	349.73
	150	334.51	347.95	370.34
	200	355.12	368.56	390.96
HTSE-to-Ammonia N₂ from Comb.	0	463.82	537.26	659.67
	50	463.92	537.36	659.77
	100	464.02	537.47	659.87
	150	464.13	537.57	659.98
	200	464.23	537.67	660.08
HTSE-to-Ammonia N₂ from ASU	0	429.45	493.54	600.36
	50	429.56	493.64	600.46
	100	429.66	493.75	600.56
	150	429.76	493.85	600.66
	200	429.86	493.95	600.77

NUCLEAR-INTEGRATED AMMONIA PRODUCTION ANALYSIS

Identifier: TEV-666

Revision: 2

Effective Date: 05/25/2010

Page: 61 of 69




Figure 16. Impact of a carbon tax on gas-to-ammonia and HTSE-to-ammonia economics (average natural gas price, no sequestration).

Figure 17 presents results from the sensitivity analysis which varies natural gas price. For this analysis, the IRR is fixed by varying the selling prices of urea and ammonium nitrate. As the cost of natural gas increases, the HTGR-integrated case compares more favorably with the conventional gas-to-ammonia case. This is due to a sharper increase in manufacturing costs for the conventional case due to higher natural gas usage than for the HTGR-integrated case. However, in the absence of a carbon tax, economics of the nuclear-integrated case do not outperform the conventional case until natural gas prices rise to about \$12/MSCF. If the cost of implementing HTGR technology can be reduced by 30%, these results change considerably. As shown in Figure 18, with a reduced HTGR implementation cost, the nuclear-integrated case outperforms the conventional gas-to-ammonia case when natural gas prices rise above \$6.75/MSCF.

NUCLEAR-INTEGRATED AMMONIA PRODUCTION ANALYSIS

Identifier: TEV-666
Revision: 2
Effective Date: 05/25/2010

Page: 62 of 69




Figure 17. Gas-to-ammonia and HTSE-to-ammonia, urea price as a function of natural gas price (HTGR TCI, no CO₂ tax).

NUCLEAR-INTEGRATED AMMONIA PRODUCTION ANALYSIS

Identifier: TEV-666
Revision: 2
Effective Date: 05/25/2010

Page: 63 of 69




Figure 18. Gas-to-ammonia and HTSE-to-ammonia, urea price as a function of natural gas price (-30% HTGR TCI, no CO₂ tax).

To further emphasize the impact of a carbon tax, Figure 19 and Figure 20 plot the required selling price of urea as a function of natural gas price for a 12% IRR. Figure 19 assumes a \$50/ton CO₂ tax while Figure 20 assumes a \$100/ton CO₂ tax. For a CO₂ tax of \$50/ton, economics of the nuclear-integrated case outperform the conventional case only for natural gas prices above \$8.25/MSCF. However, for a CO₂ tax of \$100/ton, economics of the nuclear-integrated case outperform the conventional case for all natural gas prices above \$4.50/MSCF. Hence, it can be concluded that if carbon taxes are mandated in the future, favorability of the nuclear-integrated case improves significantly in comparison to the conventional gas-to-ammonia case.

NUCLEAR-INTEGRATED AMMONIA PRODUCTION ANALYSIS

Identifier: TEV-666
Revision: 2
Effective Date: 05/25/2010

Page: 64 of 69




Figure 19. Gas-to-ammonia and HTSE-to-ammonia, urea price as a function of natural gas price (HTGR TCI, \$50/ton CO₂ tax).

NUCLEAR-INTEGRATED AMMONIA PRODUCTION ANALYSIS

Identifier: TEV-666

Revision: 2

Effective Date: 05/25/2010

Page: 65 of 69




Figure 20. Gas-to-ammonia and HTSE-to-ammonia, urea price as a function of natural gas price (HTGR TCI, \$100/ton CO₂ tax).

6. COAL-TO-AMMONIA CONCLUSIONS

Based on analysis of the conventional coal-to-ammonia case, a need for high-temperature heat integration was not identified for the coal-fed case. In addition, because light water reactors can supply power in this scenario, a strong need for integration with HTGRs is not apparent. Hence, modeling of a nuclear-integrated coal-to-ammonia case was not pursued. Note, however, that other gasification technologies (hydrogasification) could be considered, and these technologies may be more complementary for HTGR integration.

Because a suitable nuclear-integrated coal-to-ammonia case was not identified, an economic analysis was performed only for the conventional coal-to-ammonia case. Results indicate that a return of 12% can be achieved for a urea production price of \$259.07/ton. Without sequestration, the urea production price increases sharply as a function of the carbon tax imposed; a urea selling price of \$407.64/ton is required to achieve a 12% return when a \$100/ton carbon tax is imposed.

NUCLEAR-INTEGRATED AMMONIA PRODUCTION ANALYSIS	Identifier: TEV-666 Revision: 2 Effective Date: 05/25/2010 Page: 66 of 69
---	---

7. GAS-TO-AMMONIA CONCLUSIONS

Results for the nuclear-integrated natural gas-to-ammonia case look promising. One 450 MW_t HTGR would be required to support this configuration. By substituting nuclear heat for natural gas combustion in the primary reformer, natural gas consumption is decreased by 18%. CO₂ emissions decrease by 70% compared to the conventional gas-to-ammonia case.

Results for the HTSE hydrogen cases also look promising from an emissions perspective. CO₂ emissions are cut to very low levels, and the need to sequester carbon is eliminated. In addition, natural gas consumption is reduced to only the amount required to supply carbon for urea production. These configurations would require roughly four 600 MW_t HTGRs to support plant operation. It is apparent that, of the two HTSE hydrogen cases considered, the option utilizing cryogenic air separation for nitrogen production is more attractive from the perspective of capital equipment cost.

Economically, the nuclear-integrated gas-to-ammonia option provides economic stability with respect to fluctuations in natural gas prices. Although the IRR is slightly lower than for conventional gas-to-ammonia, it is still significantly above 12% for all but the lowest fertilizer prices seen over the last decade. Furthermore, as the cost of natural gas increases, and if a carbon tax is implemented, the nuclear-integrated case compares more favorably with the conventional gas-to-ammonia case. For a modest carbon tax of \$50/ton CO₂, economics for the nuclear-integrated case outperform the conventional case when natural gas prices rise above \$8.25/MSCF. For a more substantial carbon tax of \$100/ton CO₂, economics for the nuclear-integrated case outperform the conventional case when natural gas prices rise above \$4.50/MSCF. In addition, if the cost of the HTGR can be reduced by 30%, the HTGR-integrated case outperforms the conventional gas-to-ammonia case when the price of natural gas rises above \$6.75/MSCF (regardless of a carbon tax). Hence, it is clear that the economic performance of the nuclear-integrated case can outperform the conventional gas-to-ammonia case in a number of scenarios including: (1) a combination of elevated natural gas prices and adoption of a modest carbon tax, and (2) further development and commercialization of HTGR technology are able to reduce the price of implementation by 30%.

Economics for the HTSE-to-ammonia cases do not look as favorable. Although these options are attractive due to simplification of gas cleanup requirements, they significantly increase the capital cost of the plant. This is due principally to the need for four nuclear reactors to support both hydrogen and electrical demands of the plant. In order to be economically attractive, urea prices would need to be around \$500/ton to achieve a 12% return. Even if further development and commercialization of HTGR technology are able to reduce the price of implementation by 30%, the selling price of urea would still need to be in excess of \$400/ton to achieve a 12% return for the HTSE-to-ammonia cases.

NUCLEAR-INTEGRATED AMMONIA PRODUCTION ANALYSIS	Identifier: TEV-666	
	Revision: 2	
	Effective Date: 05/25/2010	Page: 67 of 69

8. FUTURE WORK AND RECOMMENDATIONS

The following items should be performed in the future to further refine the process and economic modeling performed for the ammonia cases:

- Refined estimates of the HTGR capital cost, annual fuel costs, and annual O&M costs should be developed to refine the economic results.
- A separate study should be conducted to assess the optimal siting of the HTGR with respect to the ammonia facilities, balancing safety concerns associated with separation distance and heat losses associated with transporting high-temperature heat long distances.
- Rigorous Aspen Plus submodels of the HTGR and HTSE units should be developed to fully couple heat and power integration from the HTGR.
- The simplified water treatment hierarchy should be replaced with more rigorous water treatment models based on vendor input.
- It is likely that process and economic results for the nuclear-integrated cases could be improved if the HTGR temperature could be increased from 750 to 950°C. Hence, a study to quantify the performance improvement is recommended.
- Due to differences in how utility companies and ammonia producers currently evaluate economics of proposed projects, and due to the high capital costs associated with integrating these technologies, additional work is recommended to identify and evaluate more realistic business models for this integration.

9. REFERENCES

- AACE, 2005, *Cost Estimate Classification System – As Applied in Engineering, Procurement, and Construction for the Process Industries*, AACE International Recommended Practice No. 18R-97.
- Aspen Plus, Version 2006, Burlington, Massachusetts: Aspen Tech, 2006.
- Breckenridge, William, et. al., 2000, “Use of Selexol Process in Coke Gasification to Ammonia Project,” *Laurance Reid Gas Conditioning Conference, The University of Oklahoma, Norman, Oklahoma, February 27–March 1, 2000*.
- Burr, Barry and Lili Lyddon, Bryan Research and Engineering, 2008, “A Comparison of Physical Solvents for Acid Gas Removal.”
- Clarke, Stephen I. and William J. Mazzafrro, 2005, “Nitric Acid,” *Kirk-Othmer Encyclopedia of Chemical Technology*, John Wiley & Sons.

NUCLEAR-INTEGRATED AMMONIA PRODUCTION ANALYSIS	Identifier: TEV-666 Revision: 2 Effective Date: 05/25/2010 Page: 68 of 69
---	---

Demick, Larry, 2009, *HTGR Cost Information*, personal communications.

Eggerman, Tim, 2010, "Ammonia," *Kirk-Othmer Encyclopedia of Chemical Technology*, John Wiley & Sons.

EIA, 2010, *Monthly United States Natural Gas Industrial Price*,
<http://tonto.eia.doe.gov/dnav/ng/hist/n3035us3m.htm>, March 29, 2010, April 16, 2010.

Excel 2007, Version 12.0, Redmond, Washington: Microsoft Corporation, 2007.

GA, 2002, *The Gas Turbine – Modular Helium Reactor: A Promising Option for Near Term Deployment*, GA-A23952.

INL, 2007, "Next Generation Nuclear Plant Pre-Conceptual Design Report," INL/EXT-07-12967.

Jones, David S. J., and Peter R. Rujado, 2006, *Handbook of Petroleum Processing*, Dordrecht: Springer.

Kohl, Arthur L., and Richard B. Nielsen, 1997, *Gas Purification (5th Edition)*, Houston: Elsevier.

Leeper, C. Stephen A, 1981, *Wet Cooling Towers: 'Rule-of-Thumb' Design and Simulation*, EGG-GTH-5775.

Linde, 2008, "Cryogenic Air Separation History and Technological Process," Product Brochure.

Mavrovic, Ivo, A. Ray Shirley, and G. R. "Buck" Coleman, 2000, "Urea," *Kirk-Othmer Encyclopedia of Chemical Technology*, John Wiley & Sons.

McKellar, Michael G., 2010, "Nuclear-Integrated Hydrogen Production Analysis," TEV-673.

NEI, 2008, "The Cost of New Generating Capacity in Perspective," White Paper.

NETL, 2000, *Shell Gasifier IGCC Base Cases*. PED-IGCC-98-002.

NETL, 2007, *Cost and Performance Baseline for Fossil Energy Plants*, DOE/NETL-2007/1281.

Parsons, 1999, *Waste Management Project Contingency Analysis*, DOE/FETC-99/1100.

Perry, Robert H., and Don W. Green, 2008, *Perry's Chemical Engineers' Handbook (8th Edition)*, New York: McGraw Hill.

NUCLEAR-INTEGRATED AMMONIA PRODUCTION ANALYSIS	Identifier:	TEV-666	
	Revision:	2	
	Effective Date:	05/25/2010	Page: 69 of 69

Peters, Max S., and Klaus D. Timmerhaus, 2002, *Plant Design and Economics for Chemical Engineers (5th Edition)*, New York: McGraw Hill.

Shell, 2004, "The Shell Coal Gasification Process for the U.S. Industry," *Gasification Technologies Conference, Washington D.C., October, 2004*.

Shell, 2005, "Shell Coal Gasification Process Using Low Rank Coal," *Gasification Technologies Conference, San Francisco, CA, October 2005*.

Speight, James G., "Ammonium Nitrate," *Chemical Process and Design Handbook*, McGraw-Hill.

Sullivan, William G., Elin M. Wicks, and James T. Luxhoj, 2003, *Engineering Economy*. Upper Saddle River: Printice Hall.

Thermoflow Suite, Version 19, Sudbury, Massachusetts: Thermoflow, 2009.

USDA, 2010, "U.S. Fertilizer Use and Price,"
<http://www.ers.usda.gov/Data/FertilizerUse/Tables/Table7.xls>, March 22, 2010, April 26, 2010.

10. APPENDIXES

Appendix A, Detailed Modeling Results and Flowsheets

Appendix B, Ammonia Capital Cost Estimates

Appendix C, [Electronic] Coal to Ammonia Conventional Stream Results.xls

Appendix D, [Electronic] NG to Ammonia Conventional Stream Results.xls

Appendix E, [Electronic] NG to Ammonia Nuclear Integration Stream Results.xls

Appendix F, [Electronic] HTSE to Ammonia – N₂ from Combustion Stream Results.xls

Appendix G, [Electronic] HTSE to Ammonia – N₂ from Cryo ASU Stream Results.xls


Idaho National Laboratory

NUCLEAR-INTEGRATED AMMONIA PRODUCTION ANALYSIS	Identifier:	TEV-666
	Revision:	2
	Effective Date:	05/25/2010


Appendix A
Detailed Modeling Results and Flowsheets

Ammonia Derivative Case Summary


	Coal Conventional	Natural Gas Conventional	Natural Gas Nuclear Assisted	HTSE N2 from Combustion	HTSE N2 from ASU
Inputs					
Coal Feed Rate (ton/day)	4,591	0	0	0	0
Natural Gas Feed Rate (MMSCFD)	n/a	88	72	36	36
# 600 MWt HTGRs Required	n/a	n/a	0.75	4.10	3.58
Intermediate Products					
Ammonia (ton/day)	3,358	3,361	3,360	3,360	3,360
Nitric Acid (ton/day)	5,186	5,192	5,192	5,192	5,192
Outputs					
Urea (ton/day)	2,939	2,939	2,939	2,939	2,939
Ammonium Nitrate (ton/day)	3,779	3,779	3,779	3,779	3,779
Oxygen (ton/day)	0	0	0	2,508	2,435
Utility Summary					
Total Power (MW)	-141.8	-108.8	-106.2	-879.0	-769.5
Electrolyzers	n/a	n/a	n/a	-918.1	-778.1
Air Separation	-73.5	n/a	n/a	n/a	-23.2
Nitrogen Generation (non-ASU)	n/a	n/a	n/a	-18.8	n/a
Coal Milling & Drying	-2.5	n/a	n/a	n/a	n/a
Gasification Island	-2.5	n/a	n/a	n/a	n/a
Natural Gas Reforming	n/a	-21.6	-19.9	n/a	n/a
Syngas Purification	-5.4	-4.4	-4.5	n/a	n/a
Claus Plant	0.0	n/a	n/a	n/a	n/a
Sulfur Reduction (SCOT)	-0.7	n/a	n/a	n/a	n/a
Non-Nuclear Power Island	44.7	26.7	29.5	156.0	128.0
CO ₂ Production/Purification/Compression	-7.4	-13.0	-13.1	-5.6	-5.6
Ammonia Synthesis	-43.2	-45.2	-46.8	-39.0	-38.5
Nitric Acid Synthesis	-15.1	-15.1	-15.1	-15.1	-15.1
Ammonium Nitrate Synthesis	-24.9	-24.9	-24.9	-24.9	-24.9
Urea Synthesis	-4.4	-4.4	-4.4	-4.4	-4.4
Cooling Towers	-2.1	-1.5	-1.5	-2.5	-2.3
Water Treatment	-4.8	-5.4	-5.6	-6.6	-5.6
Total Water Balance (gpm)	-4,466	-3,928	-3,984	-6,334	-5,555
Evaporation Rate (gpm)	-4,891	-3,601	-3,657	-5,979	-5,386
CO ₂ Emissions					
Captured (ton/day CO ₂)	0	1,762	1,786	0	0
Emitted (ton/day CO ₂)	7,987	1,449	430	11	11
Nuclear Integration Summary					
Electricity Demand (MW)	n/a	n/a	106.2	879.0	769.5
HTSE	n/a	n/a	n/a	918.1	778.1
Balance of Plant	n/a	n/a	106.2	-39.1	-8.6
Nuclear Heat Demand (MMBTU/hr)	n/a	n/a	649.2	894.6	758.2
Electrolyzers	n/a	n/a	n/a	894.6	758.2
Natural Gas Reforming	n/a	n/a	649.2	n/a	n/a
Fossil Topping Heat Supplied (MMBTU/hr)	n/a	n/a	n/a	50.4	42.7
Electrolysis Products					
Total Hydrogen (ton/day)	n/a	n/a	n/a	715	606
Total Oxygen (ton/day)	n/a	n/a	n/a	5,637	4,778



Ammonia Derivative Modeling Summary Comparison				
SIZE LTR	Date April 22, 2010	DWG NO AMMONIA-SUM-1	REV 2	
PREPARED BY R. Wood	TYPE	Summary Diagram	SHEET 1 OF 1	



1 2 3 4



Coal to Ammonia and Derivative Products

SIZE	Date	DWG NO	REV
LTR	April 29, 2010	COAL-TO-NH3-PFD-2	2


PREPARED BY R. Wood

TYPE Process Flow Diagram

SHEET 1 OF 2

1 2 3 4

1 2 3 4



Coal to Ammonia and Derivative Products

SIZE	Date	DWG NO	REV
LTR	April 29, 2010	COAL-TO-NH3-PFD-2	2
PREPARED BY	R. Wood	TYPE	Process Flow Diagram
			SHEET 2 OF 2

Conventional Coal-to-Ammonia Results Calculator Block SUMMARY

FEED & PRODUCT SUMMARY:

FEEDS:

RAW COAL FEED RATE =	4590.8 TON/DY
COAL HHV AS FED =	10934. BTU/LB
COAL MOISTURE AS FED =	13.70 %

PROXIMATE ANALYSIS (DRY BASIS):

MOISTURE	13.70 %
FIXED CARBON	40.12 %
VOLATILE MATTER	49.28 %
ASH	10.60 %

ULTIMATE ANALYSIS (DRY BASIS):

ASH	10.60 %
CARBON	70.27 %
HYDROGEN	4.84 %
NITROGEN	1.36 %
CHLORINE	0.11 %
SULFUR	3.72 %
OXYGEN	9.10 %

SULFANAL ANALYSIS (DRY BASIS):

PYRITIC	1.94 %
SULFATE	0.08 %
ORGANIC	1.70 %

INTERMEDIATES:

COAL FEED RATE AFTER DRYING =	4214.8 TON/DY
COAL HHV AFTER DRYING =	11910. BTU/LB
COAL MOISTURE AFTER DRYNG =	6.00 %

RAW SYNGAS MASS FLOW =	686715. LB/HR
RAW SYNGAS VOLUME FLOW =	7. MMSCFD @ 60° F
GASIFIER COLD GAS EFFICIENCY =	80.36 %
RAW SYNGAS COMPOSITION:	

H2	29.0 MOL. %
CO	53.7 MOL. %
CO2	4.0 MOL. %
N2	6.1 MOL. %
H2O	5.6 MOL. %
H2S	10519. PPMV
CH4	79. PPMV

QUENCHED SYNGAS MASS FLOW =	738545. LB/HR
QUENCHED SYNGAS VOLUME FLOW =	9. MMSCFD @ 60° F
QUENCHED SYNGAS COMPOSITION:	

H2	26.9 MOL. %
CO	49.8 MOL. %
CO2	3.8 MOL. %
N2	7.6 MOL. %
H2O	10.7 MOL. %
H2S	9766. PPMV
CH4	71. PPMV

CLEANED SYNGAS MASS FLOW =	283672. LB/HR
CLEANED SYNGAS VOLUME FLOW =	9. MMSCFD @ 60° F
CLEANED SYNGAS HHV =	7863. BTU/SCF
CLEANED SYNGAS COMPOSITION:	

H2	75.0 MOL. %
----	-------------

Conventional Coal-to-Ammonia Results

CO	0.0 MOL.%
CO2	0.0 MOL.%
N2	25.0 MOL.%
H2O	0.0 MOL.%
H2S	0. PPMV
CH4	0. PPMV

AMMONIA MASS FLOW =	279845. LB/HR
AMMONIA MASS FLOW =	3358. TON/DY
AMMONIA PURITY =	100.00 MOL.%
AMMONIA PRODUCED / COAL FED =	0.73 LB/LB

NITRIC ACID MASS FLOW =	432186. LB/HR
NITRIC ACID MASS FLOW =	5186. TON/DY
NITRIC ACID PURITY =	57.93 WT.%
HNO3 PRODUCED / NH3 FED =	5.97 LB/LB

FINAL PRODUCTS:

AMMONIA MASS FLOW =	0. LB/HR
AMMONIA MASS FLOW =	0. TON/DY
AMMONIA PURITY =	100.00 MOL.%

NITRIC ACID MASS FLOW =	0. LB/HR
NITRIC ACID MASS FLOW =	0. TON/DY
NITRIC ACID PURITY =	57.93 WT.%

UREA MASS FLOW =	244907. LB/HR
UREA MASS FLOW =	2939. TON/DY
UREA PRODUCED / AMMONIA FED =	1.74 LB/LB
UREA PRODUCED / CO2 FED =	1.34 LB/LB

AMMONIUM NITRATE MASS FLOW =	314876. LB/HR
AMMONIUM NITRATE MASS FLOW =	3779. TON/DY
NH4NO3 PRODUCED / NITRIC ACID FED =	0.73 LB/LB
NH4NO3 PRODUCED / AMMONIA FED =	4.70 LB/LB

POWER SUMMARY:

ELECTRICAL GENERATORS:

STEAM TURBINE POWER GENERATION =	46.5 MW
GENERATOR SUBTOTAL =	46.5 MW

ELECTRICAL CONSUMERS:

COAL PROCESSING POWER CONSUMPTION =	2.5 MW
ASU POWER CONSUMPTION =	73.5 MW
GASIFIER POWER CONSUMPTION =	2.5 MW
GAS CLEANING POWER CONSUMPTION =	5.4 MW
CLAUS POWER CONSUMPTION =	0.0 MW
SCOT POWER CONSUMPTION =	0.7 MW
POWER BLOCK POWER CONSUMPTION =	1.8 MW
CO2 PROCESSING POWER CONSUMPTION =	7.4 MW
AMMONIA SYNTH. POWER CONSUMPTION =	43.2 MW
UREA SYNTHESIS POWER CONSUMPTION =	4.4 MW
HNO3 SYNTHESIS POWER CONSUMPTION =	15.1 MW
NH4NO3 SYNTH. POWER CONSUMPTION =	24.9 MW
COOLING TOWER POWER CONSUMPTION =	2.1 MW
WATER TREATMENT POWER CONSUMPTION =	4.8 MW
CONSUMER SUBTOTAL =	188.3 MW

NET PLANT POWER CONSUMPTION =	141.8 MW
-------------------------------	----------

Conventional Coal-to-Ammonia Results

WATER BALANCE:

EVAPORATIVE LOSSES:

CMD WATER NOT RECOVERED =	84.1 GPM
COOLING TOWER EVAPORATION =	4558.6 GPM
ZLD SYSTEM EVAPORATION =	248.1 GPM
TOTAL EVAPORATIVE LOSSES =	4890.7 GPM

WATER CONSUMED:

GASIFIER ISLAND MAKEUP =	88.9 GPM
BOILER FEED WATER MAKEUP =	789.1 GPM
NITRIC ACID FEED WATER =	197.8 GPM
COOLING TOWER MAKEUP =	4795.8 GPM
TOTAL WATER CONSUMED =	5871.6 GPM

WATER GENERATED:

GASIFIER ISLAND BLOWDOWN =	15.9 GPM
SYNGAS CONDENSER BLOWDOWN =	183.9 GPM
SOUR WATER BLOWDOWN=	11.2 GPM
BOILER BLOWDOWN =	3.1 GPM
CO2 PURIFICATION BLOWDOWN =	0.7 GPM
UREA PRODUCTION BLOWDOWN =	128.6 GPM
NH4NO3 PRODUCTION BLOWDOWN =	369.8 GPM
COOLING TOWER BLOWDOWN =	938.8 GPM
TOTAL WATER GENERATED =	1652.0 GPM

PLANT WATER SUMMARY:

NET MAKEUP WATER REQUIRED =	4465.9 GPM
WATER CONSUMED / COAL FED =	5.84 LB/LB

CO2 BALANCE:

CO2 INCORPORATED INTO UREA PRODUCT =	2177. TON/DY
CO2 INCORPORATED INTO UREA PRODUCT =	38. MMSCFD @ 60°F
CO2 PURITY =	99.5 %
CO2 EMITTED (TOTAL) =	7987. TON/DY
CO2 EMITTED (TOTAL) =	138. MMSCFD @ 60°F
FROM HRSG =	7457. TON/DY
FROM CMD =	159. TON/DY
FROM UREA VENTS =	28. TON/DY
EXCESS FROM SELEXOL =	343. TON/DY
CO2 EMITTED / COAL FED =	1.74 LB/LB

Calculator Block AIRPROPS

HUMIDITY DATA FOR STREAM AIR-ASU:

HUMIDITY RATIO =	43.5 GRAINS/LB
RELATIVE HUMIDITY =	39.9 %

Calculator Block PH Hierarchy: NH4NO3



TARGET NEUTRALIZER PH =	1.500
ACTUAL NEUTRALIZER PH =	1.499

Calculator Block RATIO Hierarchy: UREA


TARGET REACTOR NH3/CO2 RATIO =	2.950
ACTUAL REACTOR NH3/CO2 RATIO =	2.923

Coal to Ammonia and Derivatives - Dry-Fed Entrained Flow Gasifier


(Derivatives produced in the correct ratio to make UAN32)




Coal Milling & Drying




Dry-Fed Gasifier w/ Heat Recovery




Syngas Cleaning & Conditioning



CO₂ Purification




O2 Claus (COPE) Process




Note: Aspen seems to be lacking some thermodynamic properties for S2, S3, S4, S5, S6, S7, and S8 related to vapor pressure that are necessary to perform a flash calculation. For this reason, blocks "PHASE-1", "PHASE-2", and "PHASE-3" are used to convert all of these compounds to S prior to the flash blocks. Note that there is some enthalpy change associated with this simplification, and it is neglected in this simulation.


Catalytic Sulfur Reduction (SCOT or Beavon Process w/o H2S Absorber)




Ammonia Synthesis @ 3000 psi




	Temperature (F)
	Pressure (psi)
	Mass Flow Rate (lb/hr)
Q	Duty (MMBtu/hr)
W	Power(kW)



Urea Synthesis via the H.P. Stamicarbon CO2 Stripping Process



Monopressure Nitric Acid Production



The diagram illustrates a complex chemical process involving the production of a product from various feedstocks. Key components include:

- Feedstocks:** NH3-AN(IN), HNO3-AN(IN), and AN-STIM(IN).
- Process Flow:** The process starts with the feedstocks entering various tanks (e.g., NH3-TANK, HNO3-TANK) and pumps (e.g., NH3-PUMP, HNO3-PUMP). These streams then pass through heat exchangers (e.g., NH3-HEAT, HNO3-HEAT) and mixers (e.g., Q-MIX, Q-MIXER) before entering a separator (SEPARATR).
- Intermediate Products:** The separator produces two main streams: a liquid stream (LIQ-MIX1) and a vapor stream (VAP-MIX1). These streams are further processed through various units, including heat exchangers (e.g., LIQ-HEAT, VAP-HEAT), pumps (e.g., LIQ-PUMP, VAP-PUMP), and tanks (e.g., LIQ-TANK, VAP-TANK).
- Final Products:** The process concludes with the production of two main products: AN-WATER(OUT) and AN-AIR(OUT).
- Legend:** A legend box in the lower-left quadrant defines the symbols used in the diagram:
 - Temperature (F)
 - Pressure (psi)
 - Mass Flow Rate (lb/hr)
 - Q Duty (MMBtu/hr)
 - W Power (kW)

The diagram is a detailed representation of a chemical process, showing the flow of materials and energy between various units. The units are labeled with their names and flow rates, and the streams are labeled with their names and flow rates. The legend box provides a key to the symbols used in the diagram.


	Temperature (F)
	Pressure (psi)
	Mass Flow Rate (lb/hr)
Q	Duty (MMBtu/hr)
W	Power(kW)





Cooling Tower


	Temperature (F)
	Pressure (psi)
	Mass Flow Rate (lb/hr)
	Energy Flow Rate (Btu/hr)
	Power (kW)

The results for the makeup water flow are within 3% of the results generated by GT Pro. The results for the blow-down water flow are within 1% of the results generated by GT Pro. The power consumption of the cooling tower fan is within 40% of the GT Pro results, the air flow is within 1% of the GT Pro results.




Simplified Water Treatment






1 2 3 4



Natural Gas to Ammonia and Derivative Products			
SIZE	Date	DWG NO	REV
LTR	April 29, 2010	NG-TO-NH3-PFD-2	2
PREPARED BY		TYPE	SHEET
R. Wood		Process Flow Diagram	1 OF 2

1
2
3
4



Natural Gas to Ammonia and Derivative Products			
SIZE	Date	DWG NO	REV
LTR	April 29, 2010	NG-TO-NH3-PFD-2	2
PREPARED BY	R. Wood	TYPE	Process Flow Diagram
SHEET			2 OF 2

1
2
3
4

Conventional Gas-to-Ammonia Results Calculator Block SUMMARY

FEED SUMMARY:

NATURAL GAS PROPERTIES:

MASS FLOW =	1989. TON/DY
VOLUME FLOW =	88. MMSCFD @ 60°F
HHV =	23063. BTU/LB
HHV =	1044. BTU/SCF @ 60°F
ENERGY FLOW =	91733. MMBTU/DY

COMPOSITION:

METHANE =	93.571 MOL.%
ETHANE =	3.749 MOL.%
PROPANE =	0.920 MOL.%
BUTANE =	0.260 MOL.%
PENTANE =	0.040 MOL.%
HEXANE =	0.010 MOL.%
NITROGEN =	1.190 MOL.%
OXYGEN =	0.010 MOL.%
CO2 =	0.250 MOL.%
C4H10S =	1. PPMV
C2H6S =	0. PPMV
H2S =	0. PPMV

INTERMEDIATE PRODUCT SUMMARY:

RAW SYNGAS MASS FLOW =	903998. LB/HR
RAW SYNGAS VOLUME FLOW =	520. MMSCFD @ 60°F
RAW SYNGAS COMPOSITION:	
H2	36.3 MOL.%
CO	8.2 MOL.%
CO2	5.1 MOL.%
N2	14.7 MOL.%
AR	0.2 MOL.%
H2O	35.0 MOL.%
CH4	0.5 MOL.%

CLEANED SYNGAS MASS FLOW =	294757. LB/HR
CLEANED SYNGAS VOLUME FLOW =	308. MMSCFD @ 60°F
CLEANED SYNGAS COMPOSITION:	
H2	73.8 MOL.%
N2	24.8 MOL.%
AR	0.3 MOL.%
CH4	1.1 MOL.%
CO	0. PPMV
CO2	0. PPMV
H2O	1. PPMV

AMMONIA MASS FLOW =	280047. LB/HR
AMMONIA MASS FLOW =	3361. TON/DY
AMMONIA PURITY =	99.99 MOL.%
AMMONIA PRODUCED / NAT. GAS FED =	1.69 LB/LB

NITRIC ACID MASS FLOW =	432702. LB/HR
NITRIC ACID MASS FLOW =	5192. TON/DY
NITRIC ACID PURITY =	57.93 WT.%
HNO3 PRODUCED / NH3 FED =	1.55 LB/LB

FINAL PRODUCT SUMMARY:

AMMONIA MASS FLOW =	0. LB/HR
AMMONIA MASS FLOW =	0. TON/DY

Conventional Gas-to-Ammonia Results AMMONIA PURITY = 99.99 MOL.%

NITRIC ACID MASS FLOW = 0. LB/HR
 NITRIC ACID MASS FLOW = 0. TON/DY
 NITRIC ACID PURITY = 57.93 WT.%

UREA MASS FLOW = 244925. LB/HR
 UREA MASS FLOW = 2939. TON/DY
 UREA PRODUCED / AMMONIA FED = 1.74 LB/LB
 UREA PRODUCED / CO2 FED = 1.34 LB/LB

AMMONIUM NITRATE MASS FLOW = 314950. LB/HR
 AMMONIUM NITRATE MASS FLOW = 3779. TON/DY
 NH4NO3 PRODUCED / NITRIC ACID FED = 0.73 LB/LB
 NH4NO3 PRODUCED / AMMONIA FED = 4.69 LB/LB

STEAM EXPORT AVAILABLE:
 SATURATED STEAM FLOW = 376229. LB/HR
 PRESSURE = 30. PSIA

POWER SUMMARY:

ELECTRICAL GENERATORS:
 STEAM TURBINE POWER GENERATION = 28.9 MW
 GENERATOR SUBTOTAL = 28.9 MW

ELECTRICAL CONSUMERS:
 NG REFORMER POWER CONSUMPTION = 21.6 MW
 GAS CLEANING POWER CONSUMPTION = 4.4 MW
 POWER BLOCK POWER CONSUMPTION = 2.2 MW
 CO2 PROCESSING POWER CONSUMPTION = 13.0 MW
 AMMONIA SYNTH. POWER CONSUMPTION = 45.2 MW
 UREA SYNTHESIS POWER CONSUMPTION = 4.4 MW
 HNO3 SYNTHESIS POWER CONSUMPTION = 15.1 MW
 NH4NO3 SYNTH. POWER CONSUMPTION = 24.9 MW
 COOLING TOWER POWER CONSUMPTION = 1.5 MW
 WATER TREATMENT POWER CONSUMPTION = 5.4 MW
 CONSUMER SUBTOTAL = 137.7 MW

NET PLANT POWER CONSUMPTION = 108.8 MW

WATER BALANCE:

EVAPORATIVE LOSSES:
 COOLING TOWER EVAPORATION = 3270.0 GPM
 ZLD SYSTEM EVAPORATION = 330.5 GPM
 TOTAL EVAPORATIVE LOSSES = 3600.6 GPM

WATER CONSUMED:
 BOILER FEED WATER MAKEUP = 1674.8 GPM
 AMMONIA WASH WATER = 0.0 GPM
 NITRIC ACID FEED WATER = 198.0 GPM
 COOLING TOWER MAKEUP = 3441.9 GPM
 TOTAL WATER CONSUMED = 5314.8 GPM

WATER GENERATED:
 NG REFORMER BLOWDOWN = 542.3 GPM
 UREA PRODUCTION BLOWDOWN = 128.6 GPM
 NH4NO3 PRODUCTION BLOWDOWN = 370.2 GPM
 COOLING TOWER BLOWDOWN = 676.8 GPM
 TOTAL WATER GENERATED = 1717.8 GPM

Conventional Gas-to-Ammonia Results

PLANT WATER SUMMARY:

NET MAKEUP WATER REQUIRED = 3927.6 GPM
 WATER CONSUMED / NG FED = 11.86 LB/LB

CO2 BALANCE:

CO2 INCORPORATED INTO UREA PRODUCT = 2177. TON/DY
 CO2 INCORPORATED INTO UREA PRODUCT = 38. MMSCFD @ 60°F
 CO2 PURITY = 99.4 %

 CO2 CAPTURED (SEQ. OR EOR) = 1762. TON/DY
 CO2 CAPTURED (SEQ. OR EOR) = 30. MMSCFD @ 60°F
 CO2 PURITY = 99.4 %

 CO2 EMITTED (TOTAL) = 1449. TON/DY
 CO2 EMITTED (TOTAL) = 25. MMSCFD @ 60°F
 FROM REFORMER = 1421. TON/DY
 FROM UREA VENTS = 28. TON/DY
 CO2 EMITTED / NG FED = 0.73 LB/LB

Calculator Block AIRPROPS

HUMIDITY DATA FOR STREAM PRI-AIR:

HUMIDITY RATIO = 43.5 GRAINS/LB
 RELATIVE HUMIDITY = 39.9 %

Calculator Block NG-RFMR Hierarchy: REFORMER

SULFUR REMOVAL CONDITIONS:

INLET BED TEMPERATURE = 662. °F

PRIMARY REFORMER CONDITIONS:

INLET TEMPERATURE = 1000. °F
 STEAM TO CARBON MOLAR RATIO = 3.30
 NATURAL GAS BURNED FOR HEAT = 22.70 %
 OUTLET TEMPERATURE = 1454. °F
 METHANE CONVERSION = 53.3 %

SECONDARY REFORMER CONDITIONS:

INLET GAS TEMPERATURE = 1454. °F
 INLET AIR TEMPERATURE = 1000. °F
 STEAM TO CARBON MOLAR RATIO = 2.40
 OXYGEN TO CARBON MOLAR RATIO = 0.28
 OUTLET TEMPERATURE = 1750. °F
 H2/CO = 4.40

OUTLET COMPOSITION:

H2 36.2844 MOL.%
 CO 8.2398 MOL.%
 CO2 5.0602 MOL.%
 H2O 35.0414 MOL.%
 CH4 0.4807 MOL.%
 N2 14.6614 MOL.%

Calculator Block PH Hierarchy: NH4NO3




TARGET NEUTRALIZER PH = 1.500

Conventional Gas-to-Ammonia Results
ACTUAL NEUTRALIZER PH = 1.499


Calculator Block RATIO Hierarchy: UREA

TARGET REACTOR NH₃/CO₂ RATIO = 2.950
ACTUAL REACTOR NH₃/CO₂ RATIO = 2.951


Natural Gas to Ammonia and Derivatives Baseline (Derivatives produced in the correct ratio to make UAN32)





Natural Gas Two-Step Reforming




Syngas Cleaning & Conditioning




CO2 Compression




Ammonia Synthesis @ 3000 psi




	Temperature (F)
	Pressure (psi)
	Mass Flow Rate (lb/hr)
	Duty (MMBtu/hr)
Q	Duty (MMBtu/hr)
W	Power(kW)




Urea Synthesis via the H.P. Stamlicarbon CO2 Stripping Process



Monopressure Nitric Acid Production




Ammonium Nitrate Production (Uhde-I.G. Farbenindustrie Process)





	Temperature (F)
	Pressure (psi)
	Mass Flow Rate (lb/hr)
Q	Duty (MMBtu/hr)
W	Power (kW)




Cooling Tower




Simplified Water Treatment





Coal to Ammonia and Derivative Products
Nuclear Integration Opportunities

SIZE LTR	Date April 29, 2010	DWG NO COAL-TO-NH3-NUCLEAR-BFD-2	REV 2
PREPARED BY R. Wood	TYPE Block Flow Diagram	SHEET 1 OF 1	




**Coal to Ammonia and Derivative Products
Nuclear Integration Opportunities**

SIZE	Date	DWG NO	REV
LTR	April 29, 2010	COAL-TO-NH3-NUCLEAR-PFD-2	2

PREPARED BY	TYPE	Process Flow Diagram	SHEET
R. Wood			1 OF 2

Nuclear Heat Integration
Nuclear Power Integration


1
2
3
4



Coal to Ammonia and Derivative Products Nuclear Integration Opportunities


SIZE	Date	DWG NO	REV
LTR	April 29, 2010	COAL-TO-NH3-NUCLEAR-PFD-2	2
PREPARED BY	R. Wood	TYPE	Process Flow Diagram
SHEET	2 OF 2		

1
2
3
4



Natural Gas to Ammonia and Derivative Products Nuclear Integration Opportunities			
SIZE	Date	DWG NO	REV
LTR	April 29, 2010	NG-TO-NH3-NUCLEAR-BFD-2	2
PREPARED BY R. Wood		TYPE	SHEET 1 OF 1
		Block Flow Diagram	

1 2 3 4




**Natural Gas to Ammonia and Derivative Products
Nuclear Integration Opportunities**

SIZE	Date	DWG NO	REV
LTR	April 29, 2010	NG-TO-NH3-NUCLEAR-PFD-2	2
PREPARED BY	TYPE	Process Flow Diagram	SHEET 1 OF 2
R. Wood			

1 2 3 4

1 2 3 4



Natural Gas to Ammonia and Derivative Products Nuclear Integration Opportunities

SIZE	Date	DWG NO	REV
LTR	April 29, 2010	NG-TO-NH3-NUCLEAR-PFD-2	2
PREPARED BY		TYPE	SHEET
R. Wood		Process Flow Diagram	2 OF 2

Nuclear Gas-to-Ammonia Results

Calculator Block SUMMARY

FEED SUMMARY:

NATURAL GAS PROPERTIES:

MASS FLOW =	1622. TON/DY
VOLUME FLOW =	72. MMSCFD @ 60°F
HHV =	23063. BTU/LB
HHV =	1044. BTU/SCF @ 60°F
ENERGY FLOW =	74818. MMBTU/DY

COMPOSITION:

METHANE =	93.571 MOL.%
ETHANE =	3.749 MOL.%
PROPANE =	0.920 MOL.%
BUTANE =	0.260 MOL.%
PENTANE =	0.040 MOL.%
HEXANE =	0.010 MOL.%
NITROGEN =	1.190 MOL.%
OXYGEN =	0.010 MOL.%
CO2 =	0.250 MOL.%
C4H10S =	1. PPMV
C2H6S =	0. PPMV
H2S =	0. PPMV

INTERMEDIATE PRODUCT SUMMARY:

RAW SYNGAS MASS FLOW =	941756. LB/HR
RAW SYNGAS VOLUME FLOW =	538. MMSCFD @ 60°F
RAW SYNGAS COMPOSITION:	
H2	35.6 MOL.%
CO	7.4 MOL.%
CO2	5.5 MOL.%
N2	14.4 MOL.%
AR	0.2 MOL.%
H2O	35.7 MOL.%
CH4	1.1 MOL.%

CLEANED SYNGAS MASS FLOW =	304786. LB/HR
CLEANED SYNGAS VOLUME FLOW =	313. MMSCFD @ 60°F
CLEANED SYNGAS COMPOSITION:	
H2	72.8 MOL.%
N2	24.7 MOL.%
AR	0.3 MOL.%
CH4	2.2 MOL.%
CO	0. PPMV
CO2	0. PPMV
H2O	1. PPMV

AMMONIA MASS FLOW =	280012. LB/HR
AMMONIA MASS FLOW =	3360. TON/DY
AMMONIA PURITY =	99.99 MOL.%
AMMONIA PRODUCED / NAT. GAS FED =	2.07 LB/LB

NITRIC ACID MASS FLOW =	432657. LB/HR
NITRIC ACID MASS FLOW =	5192. TON/DY
NITRIC ACID PURITY =	57.93 WT.%
HNO3 PRODUCED / NH3 FED =	1.55 LB/LB

FINAL PRODUCT SUMMARY:

AMMONIA MASS FLOW =	0. LB/HR
AMMONIA MASS FLOW =	0. TON/DY

Nuclear Gas-to-Ammonia Results

AMMONIA PURITY =	99.99 MOL.%
NITRIC ACID MASS FLOW =	0. LB/HR
NITRIC ACID MASS FLOW =	0. TON/DY
NITRIC ACID PURITY =	57.93 WT.%
UREA MASS FLOW =	244897. LB/HR
UREA MASS FLOW =	2939. TON/DY
UREA PRODUCED / AMMONIA FED =	1.74 LB/LB
UREA PRODUCED / CO2 FED =	1.34 LB/LB
AMMONIUM NITRATE MASS FLOW =	314918. LB/HR
AMMONIUM NITRATE MASS FLOW =	3779. TON/DY
NH4NO3 PRODUCED / NITRIC ACID FED =	0.73 LB/LB
NH4NO3 PRODUCED / AMMONIA FED =	4.69 LB/LB
STEAM EXPORT AVAILABLE:	
SATURATED STEAM FLOW =	379864. LB/HR
PRESSURE =	30. PSIA

POWER SUMMARY:

ELECTRICAL GENERATORS:	
STEAM TURBINE POWER GENERATION =	31.8 MW
GENERATOR SUBTOTAL =	31.8 MW
ELECTRICAL CONSUMERS:	
NG REFORMER POWER CONSUMPTION =	19.9 MW
GAS CLEANING POWER CONSUMPTION =	4.5 MW
POWER BLOCK POWER CONSUMPTION =	2.3 MW
CO2 PROCESSING POWER CONSUMPTION =	13.1 MW
AMMONIA SYNTH. POWER CONSUMPTION =	46.8 MW
UREA SYNTHESIS POWER CONSUMPTION =	4.4 MW
HNO3 SYNTHESIS POWER CONSUMPTION =	15.1 MW
NH4NO3 SYNTH. POWER CONSUMPTION =	24.9 MW
COOLING TOWER POWER CONSUMPTION =	1.5 MW
WATER TREATMENT POWER CONSUMPTION =	5.6 MW
CONSUMER SUBTOTAL =	138.0 MW
NET PLANT POWER CONSUMPTION =	106.2 MW

WATER BALANCE:

EVAPORATIVE LOSSES:	
COOLING TOWER EVAPORATION =	3315.8 GPM
ZLD SYSTEM EVAPORATION =	340.8 GPM
TOTAL EVAPORATIVE LOSSES =	3656.5 GPM
WATER CONSUMED:	
BOILER FEED WATER MAKEUP =	1732.8 GPM
AMMONIA WASH WATER =	0.0 GPM
NITRIC ACID FEED WATER =	198.0 GPM
COOLING TOWER MAKEUP =	3489.9 GPM
TOTAL WATER CONSUMED =	5421.0 GPM
WATER GENERATED:	
NG REFORMER BLOWDOWN =	592.6 GPM
UREA PRODUCTION BLOWDOWN =	128.5 GPM
NH4NO3 PRODUCTION BLOWDOWN =	370.2 GPM
COOLING TOWER BLOWDOWN =	686.2 GPM
TOTAL WATER GENERATED =	1777.6 GPM

Nuclear Gas-to-Ammonia Results

PLANT WATER SUMMARY:

NET MAKEUP WATER REQUIRED = 3984.2 GPM
 WATER CONSUMED / NG FED = 14.75 LB/LB

CO2 BALANCE:

CO2 INCORPORATED INTO UREA PRODUCT = 2177. TON/DY
 CO2 INCORPORATED INTO UREA PRODUCT = 38. MMSCFD @ 60°F
 CO2 PURITY = 99.3 %

 CO2 CAPTURED (SEQ. OR EOR) = 1786. TON/DY
 CO2 CAPTURED (SEQ. OR EOR) = 31. MMSCFD @ 60°F
 CO2 PURITY = 99.3 %

 CO2 EMITTED (TOTAL) = 430. TON/DY
 CO2 EMITTED (TOTAL) = 7. MMSCFD @ 60°F
 FROM REFORMER = 403. TON/DY
 FROM UREA VENTS = 28. TON/DY
 CO2 EMITTED / NG FED = 0.27 LB/LB

NUCLEAR INTEGRATION REQUIREMENTS:

TOTAL ELECTRICITY DEMAND = 106.2 MW

 TOTAL HEAT DEMAND = 190.3 MW
 TOTAL HEAT DEMAND = 649.2 MMBTU/HR

 HELIUM FLOWRATE REQUIRED = 1627010. LB/HR
 HELIUM FLOWRATE REQUIRED = 205.00 KG/S

 HELIUM SUPPLY TEMPERATURE = 1292. DEG. F.
 HELIUM SUPPLY TEMPERATURE = 700. DEG. C.

 HELIUM RETURN TEMPERATURE = 970. DEG. F.
 HELIUM RETURN TEMPERATURE = 521. DEG. C.

Calculator Block AIRPROPS

HUMIDITY DATA FOR STREAM PRI-AIR:
 HUMIDITY RATIO = 43.5 GRAINS/LB
 RELATIVE HUMIDITY = 39.9 %

Calculator Block PH Hierarchy: NH4NO3

TARGET NEUTRALIZER PH = 1.500
 ACTUAL NEUTRALIZER PH = 1.499

Calculator Block NG-RFMR Hierarchy: REFORMER

SULFUR REMOVAL CONDITIONS:

INLET BED TEMPERATURE = 662. °F

PRIMARY REFORMER CONDITIONS:

INLET TEMPERATURE = 1000. °F
 STEAM TO CARBON MOLAR RATIO = 3.30
 NATURAL GAS BURNED FOR HEAT = 0.00 %
 OUTLET TEMPERATURE = 1400. °F

Nuclear Gas-to-Ammonia Results
METHANE CONVERSION = 45.6 %

SECONDARY REFORMER CONDITIONS:

INLET GAS TEMPERATURE = 1400. °F
INLET AIR TEMPERATURE = 1000. °F
STEAM TO CARBON MOLAR RATIO = 2.48
OXYGEN TO CARBON MOLAR RATIO = 0.27
OUTLET TEMPERATURE = 1650. °F
H2/CO = 4.81

OUTLET COMPOSITION:

H2	35.6158	MOL.%
CO	7.4062	MOL.%
CO2	5.4932	MOL.%
H2O	35.7229	MOL.%
CH4	1.1428	MOL.%
N2	14.3765	MOL.%

Calculator Block RATIO Hierarchy: UREA


TARGET REACTOR NH3/CO2 RATIO = 2.950
ACTUAL REACTOR NH3/CO2 RATIO = 2.953




Color Legend

Water or Steam
 CO₂ Emissions Source
 Helium from HTGR


Natural Gas to Ammonia and Derivatives - Nuclear Integration (Derivatives produced in the correct ratio to make UAN32)



Natural Gas Reforming



	Temperature (F)
	Pressure (psi)
	Mass Flow Rate (lb/hr)
	Duty (MMBtu/hr)
	Power (kW)




Used to include
Selexol steam
usage in utility
calcs.


Used to include
Selextol power
requirement in
utility calcs.

CO2 Compression


	Temperature (F)
	Pressure (psi)
	Mass Flow Rate (lb/hr)
	Duty (MMBtu/hr)
	Power(kW)




Ammonia Synthesis @ 3000 psi




Temperature (F)	
Pressure (psi)	
Mass Flow Rate (lb/hr)	
Duty (MMBtu/hr)	
Q	
W	
Power(kW)	




Urea Synthesis via the H.P. Stamicarbon CO₂ Stripping Process



Monopressure Nitric Acid Production



Ammonium Nitrate Production (Uhde-I.G. Farbenindustrie Process)




	Temperature (F)
	Pressure (psi)
	Mass Flow Rate (lb/hr)
	Duty (MMBtu/hr)
	Power (kW)




Cooling Tower

The results for the makeup water flow are within 3% of the results generated by GT Pro. The results for the blowdown water flow are within 1% of the results generated by GT Pro. The power consumption of the cooling tower fan is within 40% of the GT Pro results, the air flow is within 1% of the GT Pro results.




	Temperature (°F)
	Pressure (psi)
	Mass Flow Rate (lb/hr)
	Q Duty (MMBtu/hr)
	W Power (kW)





Nuclear High-Temperature Electrolysis to Ammonia Derivatives Option 1 - N₂ from Combustion			
SIZE	Date	DWG NO	REV
LTR	April 30, 2010	HTE-TO-NH3-OPT1-BFD-2	2
PREPARED BY	R. Wood	TYPE	Block Flow Diagram
		SHEET	1 OF 1

1 2 3 4



1 2 3 4

HTSE-to-Ammonia Results - Option 1
Calculator Block SUMMARY

FEED SUMMARY:

NATURAL GAS PROPERTIES:

MASS FLOW =	811. TON/DY
VOLUME FLOW =	36. MMSCFD @ 60°F
HHV =	23063. BTU/LB
HHV =	1044. BTU/SCF @ 60°F
ENERGY FLOW =	37405. MMBTU/DY

COMPOSITION:

METHANE =	93.571 MOL.%
ETHANE =	3.749 MOL.%
PROPANE =	0.920 MOL.%
BUTANE =	0.260 MOL.%
PENTANE =	0.040 MOL.%
HEXANE =	0.010 MOL.%
NITROGEN =	1.190 MOL.%
OXYGEN =	0.010 MOL.%
CO2 =	0.250 MOL.%
C4H10S =	1. PPMV
C2H6S =	0. PPMV
H2S =	0. PPMV

INTERMEDIATE PRODUCT SUMMARY:

RAW SYNGAS MASS FLOW =	287339. LB/HR
RAW SYNGAS VOLUME FLOW =	303. MMSCFD @ 60°F
RAW SYNGAS COMPOSITION:	
H2	74.7 MOL.%
CO	0.0 MOL.%
CO2	0.0 MOL.%
N2	24.9 MOL.%
AR	0.3 MOL.%
H2O	0.1 MOL.%
CH4	0.0 MOL.%

CLEANED SYNGAS MASS FLOW =	286569. LB/HR
CLEANED SYNGAS VOLUME FLOW =	303. MMSCFD @ 60°F
CLEANED SYNGAS COMPOSITION:	
H2	74.8 MOL.%
N2	24.9 MOL.%
AR	0.3 MOL.%
CH4	0.0 MOL.%
CO	0. PPMV
CO2	0. PPMV
H2O	0. PPMV

AMMONIA MASS FLOW =	280019. LB/HR
AMMONIA MASS FLOW =	3360. TON/DY
AMMONIA PURITY =	99.99 MOL.%

NITRIC ACID MASS FLOW =	432644. LB/HR
NITRIC ACID MASS FLOW =	5192. TON/DY
NITRIC ACID PURITY =	57.93 WT.%
HNO3 PRODUCED / NH3 FED =	1.55 LB/LB

FINAL PRODUCT SUMMARY:

AMMONIA MASS FLOW =	0. LB/HR
AMMONIA MASS FLOW =	0. TON/DY
AMMONIA PURITY =	99.99 MOL.%

HTSE-to-Ammonia Results - Option 1

NITRIC ACID MASS FLOW =	0. LB/HR
NITRIC ACID MASS FLOW =	0. TON/DY
NITRIC ACID PURITY =	57.93 WT.%

UREA MASS FLOW =	244883. LB/HR
UREA MASS FLOW =	2939. TON/DY
UREA PRODUCED / AMMONIA FED =	1.74 LB/LB
UREA PRODUCED / CO2 FED =	1.33 LB/LB

AMMONIUM NITRATE MASS FLOW =	314908. LB/HR
AMMONIUM NITRATE MASS FLOW =	3779. TON/DY
NH4NO3 PRODUCED / NITRIC ACID FED =	0.73 LB/LB
NH4NO3 PRODUCED / AMMONIA FED =	4.69 LB/LB

POWER SUMMARY:

ELECTRICAL GENERATORS:	
STEAM TURBINE POWER GENERATION =	159.1 MW
GENERATOR SUBTOTAL =	159.1 MW

ELECTRICAL CONSUMERS:	
N2 GENERATION POWER CONSUMPTION =	18.8 MW
HTE POWER CONSUMPTION =	918.1 MW
POWER BLOCK POWER CONSUMPTION =	3.1 MW
CO2 PROCESSING POWER CONSUMPTION =	5.6 MW
AMMONIA SYNTH. POWER CONSUMPTION =	39.0 MW
UREA SYNTHESIS POWER CONSUMPTION =	4.4 MW
HNO3 SYNTHESIS POWER CONSUMPTION =	15.1 MW
NH4NO3 SYNTH. POWER CONSUMPTION =	24.9 MW
COOLING TOWER POWER CONSUMPTION =	2.5 MW
WATER TREATMENT POWER CONSUMPTION =	6.6 MW
CONSUMER SUBTOTAL =	1037.9 MW

NET PLANT POWER CONSUMPTION =	878.8 MW
-------------------------------	----------

WATER BALANCE:

EVAPORATIVE LOSSES:	
COOLING TOWER EVAPORATION =	5595.4 GPM
ZLD SYSTEM EVAPORATION =	383.1 GPM
TOTAL EVAPORATIVE LOSSES =	5978.5 GPM

WATER CONSUMED:	
BOILER FEED WATER MAKEUP =	915.0 GPM
NITRIC ACID FEED WATER =	198.0 GPM
COOLING TOWER MAKEUP =	5890.0 GPM
HTE WATER REQUIREMENT =	1057.8 GPM
AMMONIA WASH WATER REQUIREMENT =	0.1 GPM
TOTAL WATER CONSUMED =	8060.9 GPM

WATER GENERATED:	
CO2 COMPRESSION BLOWDOWN =	288.7 GPM
UREA PRODUCTION BLOWDOWN =	128.9 GPM
NH4NO3 PRODUCTION BLOWDOWN =	370.2 GPM
COOLING TOWER BLOWDOWN =	1158.1 GPM
H2 BURNER WATER BLOWDOWN =	164.1 GPM
TOTAL WATER GENERATED =	2110.0 GPM

PLANT WATER SUMMARY:	
NET MAKEUP WATER REQUIRED =	6334.0 GPM

HTSE-to-Ammonia Results - Option 1

CO2 BALANCE:

CO2 EMITTED (TOTAL) =	11. TON/DY
CO2 EMITTED (TOTAL) =	0.2 MMSCFD @ 60°F

NUCLEAR INTEGRATION REQUIREMENTS:

TOTAL ELECTRICITY DEMAND =	878.8 MW
FROM HTE =	918.1 MW
FROM BALANCE OF PLANT =	-39.3 MW
HYDROGEN DEMAND =	715.1 TON/DY
PURITY =	99.9159 MOL.%
TOTAL OXYGEN PRODUCTION =	5636.8 TON/DY
FROM HTE =	5636.8 TON/DY
PURITY =	99.8910 MOL.%
PLANT O2 DEMAND =	3131.1 TON/DY
EXCESS O2 FOR SALE =	2505.7 TON/DY
TOPPING HEAT SUPPLIED =	50.4 MMBTU/HR
SUPPLY TEMPERATURE =	1874. °F
RETURN TEMPERATURE =	1825. °F

Calculator Block AIRPROPS

HUMIDITY DATA FOR STREAM PRI-AIR:	
HUMIDITY RATIO =	43.5 GRAINS/LB
RELATIVE HUMIDITY =	39.9 %

Calculator Block REACTOR Hierarchy: AMMONIA

AMMONIA CATALYST BED SIZING CALCULATIONS (BASED ON IRON CATALYST KINETICS):

REACTOR 1:	
DIAMETER =	10.84 FT
LENGTH =	54.19 FT
VOLUME =	5000. FT3

REACTOR 2:	
DIAMETER =	18.37 FT
LENGTH =	91.84 FT
VOLUME =	24333. FT3

REACTOR 3:	
DIAMETER =	22.98 FT
LENGTH =	114.87 FT
VOLUME =	47630. FT3

TOTAL CATALYST REQUIRED = 76963. FT3

Calculator Block PH Hierarchy: NH4NO3

TARGET NEUTRALIZER PH =	1.500
ACTUAL NEUTRALIZER PH =	1.499

Calculator Block RATIO Hierarchy: UREA

HTSE-to-Ammonia Results - Option 1

TARGET REACTOR NH₃/CO₂ RATIO = 2.950
ACTUAL REACTOR NH₃/CO₂ RATIO = 2.971


High Temperature Steam Electrolysis to Ammonia and Derivatives

N2 from H2 Combustion



(Derivatives produced in the correct ratio to make UAN32)

Temperature (F)
Pressure (psi)
Mass Flow Rate (lb/hr)
Duty (MMBtu/hr)


Color Legend
Water or Steam
CO2 Emissions Source




Simplified HTE Model




N2 Generation via H2-Air Combustion



Syngas Cleaning & Conditioning





CO2 Generation




The diagram illustrates a complex chemical process involving the synthesis and conversion of ammonia. Key components include:

- Ammonia Converters:** A dashed blue box containing three reactors (REACTR-1, REACTR-2, REACTR-3) and associated heat exchangers (STM-GEN1, STM-GEN2, STM-GEN3) and distillation columns (SIZING-1, SIZING-2, SIZING-3).
- Recovery Hierarchy:** A section on the right showing the recovery of various components, including NH3-PROD, NH3-COND, and NH3-OUT.
- Heat Recovery:** Multiple heat exchangers (e.g., RECUP-1A, RECUP-1B, RECUP-2A, RECUP-2B) are used to pre-heat and pre-cool streams, improving energy efficiency.
- Distillation Columns:** Several columns (e.g., DRUM-1, DRUM-2, DRUM-3) are used for separating components based on boiling points.
- Compressors and Pumps:** Units like BST-COMP and PR-COMP are used to maintain the required pressure throughout the process.
- Streams:** Numerous streams are labeled with names (e.g., SYN-1, SYN-2, SYN-3, SYN-4, SYN-5, SYN-6, SYN-7, SYN-8, SYN-9, SYN-10, SYN-11, SYN-12, SYN-13, SYN-14, SYN-15, SYN-16, SYN-17, SYN-18, SYN-19, SYN-20, SYN-21, SYN-22, SYN-23, SYN-24, SYN-25, SYN-26, SYN-27, SYN-28, SYN-29, SYN-30, SYN-31, SYN-32, SYN-33, SYN-34, SYN-35, SYN-36, SYN-37, SYN-38, SYN-39, SYN-40, SYN-41, SYN-42, SYN-43, SYN-44, SYN-45, SYN-46, SYN-47, SYN-48, SYN-49, SYN-50, SYN-51, SYN-52, SYN-53, SYN-54, SYN-55, SYN-56, SYN-57, SYN-58, SYN-59, SYN-60, SYN-61, SYN-62, SYN-63, SYN-64, SYN-65, SYN-66, SYN-67, SYN-68, SYN-69, SYN-70, SYN-71, SYN-72, SYN-73, SYN-74, SYN-75, SYN-76, SYN-77, SYN-78, SYN-79, SYN-80, SYN-81, SYN-82, SYN-83, SYN-84, SYN-85, SYN-86, SYN-87, SYN-88, SYN-89, SYN-90, SYN-91, SYN-92, SYN-93, SYN-94, SYN-95, SYN-96, SYN-97, SYN-98, SYN-99, SYN-100) and flow rates (e.g., 100, 200, 300, 400, 500, 600, 700, 800, 900, 1000, 1100, 1200, 1300, 1400, 1500, 1600, 1700, 1800, 1900, 2000, 2100, 2200, 2300, 2400, 2500, 2600, 2700, 2800, 2900, 3000, 3100, 3200, 3300, 3400, 3500, 3600, 3700, 3800, 3900, 4000, 4100, 4200, 4300, 4400, 4500, 4600, 4700, 4800, 4900, 5000, 5100, 5200, 5300, 5400, 5500, 5600, 5700, 5800, 5900, 6000, 6100, 6200, 6300, 6400, 6500, 6600, 6700, 6800, 6900, 7000, 7100, 7200, 7300, 7400, 7500, 7600, 7700, 7800, 7900, 8000, 8100, 8200, 8300, 8400, 8500, 8600, 8700, 8800, 8900, 9000, 9100, 9200, 9300, 9400, 9500, 9600, 9700, 9800, 9900, 10000).


Product Recovery



Urea Synthesis via the H.P. Stamicarbon CO₂ Stripping Process



Monopressure Nitric Acid Production



The diagram illustrates a complex chemical process involving multiple unit operations and material streams. Key components include:

- Heat Recovery:** NH3-HEAT (Q=45.4) and COND-1 (Q=114.8) are used for heating and cooling duties.
- Separation:** A SEPARATOR unit is used to split streams into different phases.
- Storage and Transport:** Various tanks (e.g., AN-TANK, COND-TANK) and pumps (e.g., NH3-PUMP, COND-PUMP) facilitate the movement of materials.
- Control and Monitoring:** A legend box in the center provides a key for symbols used in the diagram, including Temperature (F), Pressure (psi), Mass Flow Rate (lb/hr), Duty (MMBtu/hr), and Power (W).

Legend:

- Temperature (F)
- Pressure (psi)
- Mass Flow Rate (lb/hr)
- Duty (MMBtu/hr)
- Power (W)


	Temperature (F)
	Pressure (psi)
	Mass Flow Rate (lb/hr)
Q	Duty (MMBtu/hr)
W	Power (kW)




Cooling Tower


	Temperature (F)
	Pressure (psi)
	Mass Flow Rate (lb/hr)
	Duty (MMBtu/hr)
	Duty (MMBtu/hr)
	Power (kW)
Q	
W	

The results for the makeup water flow are within 3% of the results generated by GT Pro. The results for the blow-down water flow are within 1% of the results generated by GT Pro. The power consumption of the cooling tower fan is within 40% of the GT Pro results, the air flow is within 1 % of the GT Pro results.




Simplified Water Treatment





 Nuclear High-Temperature Electrolysis to Ammonia Derivatives Option 2 - N₂ from Cryogenic Air Separation			
SIZE	Date	DWG NO	REV
LTR	April 30, 2010	HTE-TO-NH3-OPT2-BFD-2	2
PREPARED BY		TYPE	SHEET
R. Wood		Block Flow Diagram	1 OF 1


1 2 3 4



Nuclear High-Temperature Electrolysis to Ammonia and Derivative Products			
Option 2 – N ₂ from Cryogenic Air Separation Unit			
SIZE	Date	DWG NO	REV
LTR	April 30, 2010	HTE-TO-NH3-OPT2-PFD-2	2
PREPARED BY		TYPE	SHEET
R. Wood		Process Flow Diagram	1 OF 2

1 2 3 4

1 2 3 4



Nuclear High-Temperature Electrolysis to Ammonia and Derivative Products			
Option 2 - N ₂ from Cryogenic Air Separation Unit			
DATE	APRIL 30, 2010	DWG NO	HTE-TO-NH3-OPT2-PFD-2
REV	2	TYPE	R. Wood
SIZE	LTR	PREPARED BY	R. Wood
PROCESS FLOW DIAGRAM			SHEET 2 OF 2

1 2 3 4

HTSE-to-Ammonia Results - Option 2
Calculator Block SUMMARY

FEED SUMMARY:

NATURAL GAS PROPERTIES:

MASS FLOW =	811. TON/DY
VOLUME FLOW =	36. MMSCFD @ 60°F
HHV =	23063. BTU/LB
HHV =	1044. BTU/SCF @ 60°F
ENERGY FLOW =	37404. MMBTU/DY

COMPOSITION:

METHANE =	93.571 MOL.%
ETHANE =	3.749 MOL.%
PROPANE =	0.920 MOL.%
BUTANE =	0.260 MOL.%
PENTANE =	0.040 MOL.%
HEXANE =	0.010 MOL.%
NITROGEN =	1.190 MOL.%
OXYGEN =	0.010 MOL.%
CO2 =	0.250 MOL.%
C4H10S =	1. PPMV
C2H6S =	0. PPMV
H2S =	0. PPMV

INTERMEDIATE PRODUCT SUMMARY:

RAW SYNGAS MASS FLOW =	283141. LB/HR
RAW SYNGAS VOLUME FLOW =	302. MMSCFD @ 60°F
RAW SYNGAS COMPOSITION:	
H2	74.9 MOL.%
CO	0.0 MOL.%
CO2	0.0 MOL.%
N2	25.0 MOL.%
AR	0.0 MOL.%
H2O	0.1 MOL.%
CH4	0.0 MOL.%

CLEANED SYNGAS MASS FLOW =	282763. LB/HR
CLEANED SYNGAS VOLUME FLOW =	302. MMSCFD @ 60°F
CLEANED SYNGAS COMPOSITION:	
H2	75.0 MOL.%
N2	25.0 MOL.%
AR	0.0 MOL.%
CH4	0.0 MOL.%
CO	0. PPMV
CO2	0. PPMV
H2O	0. PPMV

AMMONIA MASS FLOW =	279973. LB/HR
AMMONIA MASS FLOW =	3360. TON/DY
AMMONIA PURITY =	100.00 MOL.%

NITRIC ACID MASS FLOW =	432633. LB/HR
NITRIC ACID MASS FLOW =	5192. TON/DY
NITRIC ACID PURITY =	57.93 WT.%
HNO3 PRODUCED / NH3 FED =	1.55 LB/LB

FINAL PRODUCT SUMMARY:

AMMONIA MASS FLOW =	0. LB/HR
AMMONIA MASS FLOW =	0. TON/DY
AMMONIA PURITY =	100.00 MOL.%

HTSE-to-Ammonia Results - Option 2

NITRIC ACID MASS FLOW =	0. LB/HR
NITRIC ACID MASS FLOW =	0. TON/DY
NITRIC ACID PURITY =	57.93 WT.%

UREA MASS FLOW =	244876. LB/HR
UREA MASS FLOW =	2939. TON/DY
UREA PRODUCED / AMMONIA FED =	1.74 LB/LB
UREA PRODUCED / CO2 FED =	1.33 LB/LB

AMMONIUM NITRATE MASS FLOW =	314900. LB/HR
AMMONIUM NITRATE MASS FLOW =	3779. TON/DY
NH4NO3 PRODUCED / NITRIC ACID FED =	0.73 LB/LB
NH4NO3 PRODUCED / AMMONIA FED =	4.69 LB/LB

POWER SUMMARY:

ELECTRICAL GENERATORS:	
STEAM TURBINE POWER GENERATION =	131.0 MW
GENERATOR SUBTOTAL =	131.0 MW

ELECTRICAL CONSUMERS:	
ASU POWER CONSUMPTION =	23.2 MW
HTE POWER CONSUMPTION =	778.1 MW
POWER BLOCK POWER CONSUMPTION =	3.0 MW
CO2 PROCESSING POWER CONSUMPTION =	5.6 MW
AMMONIA SYNTH. POWER CONSUMPTION =	38.5 MW
UREA SYNTHESIS POWER CONSUMPTION =	4.4 MW
HNO3 SYNTHESIS POWER CONSUMPTION =	15.1 MW
NH4NO3 SYNTH. POWER CONSUMPTION =	24.9 MW
COOLING TOWER POWER CONSUMPTION =	2.3 MW
WATER TREATMENT POWER CONSUMPTION =	5.6 MW
CONSUMER SUBTOTAL =	900.6 MW

NET PLANT POWER CONSUMPTION =	769.5 MW
-------------------------------	----------

WATER BALANCE:

EVAPORATIVE LOSSES:	
COOLING TOWER EVAPORATION =	5079.4 GPM
ZLD SYSTEM EVAPORATION =	307.0 GPM
TOTAL EVAPORATIVE LOSSES =	5386.4 GPM

WATER CONSUMED:	
BOILER FEED WATER MAKEUP =	645.3 GPM
NITRIC ACID FEED WATER =	198.0 GPM
COOLING TOWER MAKEUP =	5346.8 GPM
HTE WATER REQUIREMENT =	896.5 GPM
AMMONIA WASH WATER REQUIREMENT =	0.0 GPM
TOTAL WATER CONSUMED =	7086.7 GPM

WATER GENERATED:	
CO2 COMPRESSION BLOWDOWN =	288.7 GPM
UREA PRODUCTION BLOWDOWN =	128.9 GPM
NH4NO3 PRODUCTION BLOWDOWN =	370.1 GPM
COOLING TOWER BLOWDOWN =	1051.3 GPM
TOTAL WATER GENERATED =	1839.0 GPM

PLANT WATER SUMMARY:	
NET MAKEUP WATER REQUIRED =	5554.7 GPM

HTSE-to-Ammonia Results - Option 2

CO2 BALANCE:

CO2 EMITTED (TOTAL) =	11. TON/DY
CO2 EMITTED (TOTAL) =	0.2 MMSCFD @ 60°F

NUCLEAR INTEGRATION REQUIREMENTS:

TOTAL ELECTRICITY DEMAND =	769.5 MW
FROM HTE =	778.1 MW
FROM BALANCE OF PLANT =	-8.5 MW
HYDROGEN DEMAND =	606.1 TON/DY
PURITY =	99.9159 MOL.%
TOTAL OXYGEN PRODUCTION =	5566.0 TON/DY
FROM ASU =	788.6 TON/DY
PURITY =	99.4556 MOL.%
FROM HTE =	4777.5 TON/DY
PURITY =	99.8910 MOL.%
PLANT O2 DEMAND =	3131.0 TON/DY
EXCESS O2 FOR SALE =	2435.0 TON/DY
TOPPING HEAT SUPPLIED =	42.7 MMBTU/HR
SUPPLY TEMPERATURE =	1874. °F
RETURN TEMPERATURE =	1833. °F

Calculator Block AIRPROPS

HUMIDITY DATA FOR STREAM AIR-ASU:	
HUMIDITY RATIO =	43.5 GRAINS/LB
RELATIVE HUMIDITY =	39.9 %

Calculator Block PH Hierarchy: NH4NO3

TARGET NEUTRALIZER PH =	1.500
ACTUAL NEUTRALIZER PH =	1.499



Calculator Block RATIO Hierarchy: UREA

TARGET REACTOR NH3/CO2 RATIO =	2.950
ACTUAL REACTOR NH3/CO2 RATIO =	2.971


	Temperature (F)
	Pressure (psi)
	Mass Flow Rate (lb/hr)
	Duty (MMBtu/hr)
	Power (kW)




Simplified HTE Model




Air Separation Unit 99.5% O2 Purity




Syngas Cleaning & Conditioning





CO2 Generation




Ammonia Synthesis @ 3000 psi




Product Recovery



Urea Synthesis via the H.P. Stamicarbon CO2 Stripping Process



Monopressure Nitric Acid Production



The diagram illustrates a complex chemical process involving the synthesis and purification of a product. Key components include:

- Feed Streams:** NH3-AN(IN), HNO3-AN(IN), and AN-STIM(IN).
- Reaction and Separation:** NH3-HEAT, NEUTRIZE, SEPARATR, and various tanks (AN-TANK, AN-CONC1, AN-CONC2).
- Distillation and Purification:** CONDENSR, VNT-MIX1, VNT-MIX2, and multiple condenser/pump stages (COND-1 to COND-4).
- Heat Recovery and Management:** HNO3-HEAT, NH3-PUMP, and various heat exchangers (Q=114.8, Q=26.9, Q=40.9, Q=45.4, Q=2374.5, Q=2374.5).
- Final Products and Wastewater:** AN-WATER(OUT), AN-AIR(IN), and various vent streams.


Note: Two-stage evaporator is likely required to achieve >99% purity. For simplicity, a single stage is modeled here.

Note: Solidification is simplistically represented here. A prill tower would be followed by an air dryer to cool the product to 40 °C.


	Temperature (F)
	Pressure (psi)
	Mass Flow Rate (lb/hr)
Q	Duty (MMBtu/hr)
W	Power (kW)



Cooling Tower



Simplified Water Treatment



Idaho National Laboratory

NUCLEAR-INTEGRATED AMMONIA PRODUCTION ANALYSIS	Identifier:	TEV-666
	Revision:	2
	Effective Date:	05/25/2010

Appendix B
Ammonia Capital Cost Estimates

INTEROFFICE MEMORANDUM



Date: April 20, 2010

To: M. W. Patterson, Project Manager

From: B. W. Wallace, Cost Estimator *BWW*

Subject: NGNP Process Integration Estimates MA36-A through MA36-R

Per your request, Cost Estimating prepared cost estimates (Class 5) for the above-mentioned subject. The total estimated costs (TEC) rounded to the nearest \$10 million, including contingency for these estimates are as follows:

MA36-A NGNP – Conventional Coal to Liquid	\$5,060,000,000
MA36-B NGNP – Nuclear Coal to Liquid	\$16,540,000,000
MA36-C NGNP – Conventional Gas to Liquid.....	\$1,920,000,000
MA36-D NGNP – Nuclear Gas to Liquid	\$3,010,000,000
MA36-E NGNP – Conventional Coal to Synthetic Natural Gas	\$1,920,000,000
MA36-F NGNP – Nuclear Coal to Synthetic Natural Gas	\$8,460,000,000
MA36-G NGNP – Conventional Coal to Methanol to Gas	\$5,940,000,000
MA36-H NGNP – Nuclear Coal to Methanol to Gas	\$18,470,000,000
MA36-I NGNP – Conventional Gas to Methanol to Gas	\$1,690,000,000
MA36-J NGNP – Nuclear Gas to Methanol to Gas.....	\$3,030,000,000
MA36-L NGNP – Conventional Coal to Ammonia	\$2,150,000,000
MA36-M NGNP – Conventional Gas to Ammonia	\$1,660,000,000
MA36-N NGNP – Nuclear Gas to Ammonia	\$2,530,000,000
MA36-O NGNP – HTSE Ammonia w/o ASU	\$6,940,000,000
MA36-P NGNP – HTSE Ammonia w/ ASU.....	\$6,300,000,000
MA36-Q NGNP – Conventional Steam Assisted Gravity Drained..	\$1,060,000,000
MA36-R NGNP – Nuclear Steam Assisted Gravity Drained	\$2,720,000,000

Please note the following:

- A. These estimates are intended for use as an input to economic analysis models that will be used in a feasibility study. An allowance for contingency instead of management reserve has been included in the estimates to align more closely with commercial practices and terminology.
- B. These estimates reflect the nth of a kind (NOAK) projects. Use of NOAK in these estimates represented a condition where construction of both the integrated capability and the high temperature gas reactor (HTGR) is common place and represents routine construction.
- C. All costs represent 2009 values, and construction costs are considered to be overnight costs. Forward looking factors for escalation are not included in the estimates.
- D. These cost estimates have been evaluated in the AACEI classification matrix as Class 5 estimates (*ref. DOE G. 430.1-IX, Appendix J*). The primary characteristic used in this guideline to define the classification category is the degree of project definition at this time.

The intent of this classification is to assist in the interpretation of the quality and value of the information available to prepare these cost estimates and the expected accuracy levels that can be produced. Per AACEI, a Class 5 indicates the lowest amount of project information, quality, and value with a graded approach to a Class 1, which indicates the highest amount of project information, quality, and value.

- E. In addition to multiple internal reviews performed with the appropriate project team technical lead, an external review of the cost estimates has been performed by Washington Division United Research Services (URS) Corporation. A meeting with URS and the Next-Generation Nuclear Plant (NGNP) Process Integration team on April 7, 2010, allowed the project team and this estimator to discuss, in detail, the perceived scope, basis of estimates, assumptions, project risks, and the resources that make up this cost estimate. Comments from this review have been incorporated into these estimates to reflect a project team consensus of the documents.
- F. It is intended that these estimates reflect commercial construction of the facilities addressed. It is not intended, nor are there provisions included in the estimates that would make them appropriate for construction at Idaho National Laboratory.

Refer to the cost estimating summary, detail, markup, and labor sheets with the cost breakdowns. Also included for your use are the cost estimate recapitulation sheets describing the basis and assumptions used in development of this estimate.

These estimates, the work, and the work breakdown structure are based on the information perceived by this estimator as to the scope of work to be completed. Any changes to the methodology used to prepare these estimates could have a significant effect on the cost estimates and/or schedules and should be reviewed by me. If you have any questions or comments, do not hesitate to contact me at 526-5896 or e-mail Bruce.Wallace@inl.gov.

Attachments

cc: (electronic only)
A. M. Gandrik
R. R. Honsinger
V. C. Maio
J. B. Martin
M. G. McKellar
L. O. Nelson
M. M. Plum
R. A. Wood

Estimate Files MA36-A through MA36-J and MA36-L through MA36-R



M. W. Patterson
April 20, 2010
Page 3

Uniform File Code: 8309

Disposition Authority: A16-1.5-b

Retention Schedule: Cut off at the end of each fiscal year. Destroy 10 years after cutoff.

NOTE: Original disposition authority, retention schedule, and Uniform Filing Code applied by the sender may not be appropriate for all recipients. Make adjustments as needed.

NGNP Conventional Coal to Ammonia


Project Name: NGNP Process Integration
Process: Conventional Coal to Ammonia
Estimate Number: MA36-L

Client: M. Patterson
Prepared By: B. Wallace, R. Honsinger, J. Martin
Estimate Type: Class 5

Process Component	Subtotal From Detail Sheets	Engineering %	Engineering	Contingency %	Contingency	Total Cost
Air Separation Unit (ASU)	\$ 115,688,970	10%	\$ 11,568,897	18%	\$ 22,906,416	\$ 150,164,283
Coal Preparation	\$ 58,317,443	10%	\$ 5,831,744	18%	\$ 11,546,854	\$ 75,696,041
Gasification	\$ 187,583,875	10%	\$ 18,758,388	18%	\$ 37,141,607	\$ 243,483,870
Water Gas Shift Reactor	\$ 44,540,936	10%	\$ 4,454,094	18%	\$ 8,819,105	\$ 57,814,135
Selextol	\$ 51,726,242	10%	\$ 5,172,624	18%	\$ 10,241,796	\$ 67,140,662
Pressure Swing Adsorption (PSA)	\$ 56,185,670	10%	\$ 5,618,567	18%	\$ 11,124,763	\$ 72,929,000
Methanation	\$ 9,514,938	10%	\$ 951,494	18%	\$ 1,883,958	\$ 12,350,390
Claus & SCOT	\$ 47,476,883	10%	\$ 4,747,688	18%	\$ 9,400,423	\$ 61,624,994
CO2 Compression	\$ 8,864,886	10%	\$ 886,489	18%	\$ 1,755,247	\$ 11,506,622
Ammonia Synthesis	\$ 297,054,672	10%	\$ 29,705,467	18%	\$ 58,816,825	\$ 385,576,965
Urea Synthesis	\$ 288,347,019	10%	\$ 28,834,702	18%	\$ 57,092,710	\$ 374,274,430
Nitric Acid Synthesis	\$ 271,980,990	10%	\$ 27,198,099	18%	\$ 53,852,236	\$ 353,031,325
Ammonium Nitrate Synthesis	\$ 173,948,476	10%	\$ 17,394,848	18%	\$ 34,441,798	\$ 225,785,122
Steam Turbines	\$ 23,430,044	10%	\$ 2,343,004	18%	\$ 4,639,149	\$ 30,412,197
Heat Recovery Steam Generator (HRSG)	\$ 14,011,353	10%	\$ 1,401,135	18%	\$ 2,774,248	\$ 18,186,737
Cooling Towers	\$ 4,433,502	10%	\$ 443,350	18%	\$ 877,833	\$ 5,754,685
Total Cost - Conventional Coal to Ammonia						\$ 2,145,731,456
Total Cost Rounded to the Nearest \$10M						\$ 2,150,000,000

Checked By: 	Remarks
Approved By: 	

COST ESTIMATE SUPPORT DATA RECAPITULATION

Project Title: NGNP Process Integration – Conventional Coal to Ammonia
Estimator: B. W. Wallace/CEP, R. R. Honsinger/CEP, J. B. Martin/CCT
Date: April 20, 2010
Estimate Type: Class 5
File: MA36-L
Approved By: 

Page 1 of 7

- I. **PURPOSE:** *Brief description of the intent of how the estimate is to be used (i.e., for engineering study, comparative analysis, request for funding, proposal, etc.).*

It is expected that the capital costs identified in these estimates will be used in a model producing an economic analysis for each specific integrated application and subsequently will be considered in a related feasibility study.

- II. **SCOPE OF WORK:** *Brief statement of the project's objective. Thorough overview and description of the proposed project. Identify work to be accomplished, as well as any specific work to be excluded.*

A. **Objective:**

Develop Class 5 estimates as defined by the Association for Advancement of Cost Engineering (AACEi) that will identify the current capital cost associated with a coal-to-ammonia process.

B. **Included:**

The scope of work required to achieve this objective includes the following:

1. Engineering
2. Construction of a new coal-to-ammonia refinery that consists of the following:
 - a. Air separation unit
 - b. Coal preparation
 - c. Gasification process
 - d. Water gas shift reactors
 - e. Selexol process
 - f. Pressure swing adsorption
 - g. Methanation
 - h. Claus and SCOT processes
 - i. CO₂ compression
 - j. Ammonia synthesis
 - k. Urea synthesis
 - l. Nitric acid synthesis
 - m. Ammonium nitrate synthesis
 - n. Steam turbines, internal to process
 - o. Heat recovery steam generator, internal to process
 - p. Cooling towers, internal to process
 - q. Allowances for Balance of Plant (BOP)/offsite/outside of battery limits (OSBL), including the following:

COST ESTIMATE SUPPORT DATA RECAPITULATION

– Continued –

Project Title: NGNP Process Integration – Conventional Coal to Ammonia
File: MA36-L

Page 2 of 7

- (1.) Site development/improvements
- (2.) Provisions for general and administrative buildings and structures
- (3.) Provisions for OSBL piping
- (4.) Provisions for OSBL instrumentation and control
- (5.) Provisions for OSBL electrical
- (6.) Provisions for facility supply and OSBL water systems
- (7.) Provisions for site development/improvements
- (8.) Project/construction management.

C. **Excluded:**

This scope of work specifically excludes the following elements:

1. Licensing and permitting costs
2. Operational costs
3. Land costs
4. Sales taxes
5. Royalties
6. Owner's fees and owner's costs.

III. **ESTIMATE METHODOLOGY:** *Overall methodology and rationale of how the estimate was developed (i.e., parametric, forced detail, bottoms up, etc.). Total dollars/hours and rough order magnitude (ROM) allocations of the methodologies used to develop the cost estimate.*

Consistent with the AACEi Class 5 estimates, the level of definition and engineering development available at the time they were prepared, their intended use in a feasibility study, and the time and resources available for their completion, the costs included in this estimate have been developed using parametric evaluations. These evaluations have used publicly available and published project costs to represent similar islands utilized in this project. Analysis and selection of the published costs used have been performed by the project technical lead and Cost Estimating. Suitability for use in this effort was determined considering the correctness and completeness of the data available, the manner in which total capital costs were represented, the age of the previously performed work, and the similarity to the capacity/trains required by this project. The specific sources, selected and used in this cost estimate, are identified in the capital cost estimate detail sheets.

Adjustments have been made to these published costs using escalation factors identified in the Chemical Engineering Price Cost Index. Scaling of the published island costs has been accomplished using the six-tenths capacity factoring method. Any normalization to provide for geographic factors was considered using geographic factors available from RS Means Construction Cost Data references. Cost-estimating relationships have been used to identify allowances to complete the costs.

BOP/OSBL costs were determined by the project team, considering data provided by Shell Gasifier IGCC Base Case report NETL 2000, *Conceptual Cost Estimating Manual* Second Edition by John S. Page, and additional adjusted sources. Because the allowances

COST ESTIMATE SUPPORT DATA RECAPITULATION

– Continued –

Project Title: NGNP Process Integration – Conventional Coal to Ammonia
File: MA36-L

Page 3 of 7

identified did not show significant variability, the allowances identified in the NETL 2000 report were chosen for this effort in order to minimize the mixing of data sources.

IV. **BASIS OF THE ESTIMATE:** *Overall explanation of sources for resource pricing and schedules.*

- A. **Quantification Basis:** *The source for the measurable quantities in the estimate that can be used in support of earned value management. Source documents may include drawings, design reports, engineers' notes, and other documentation upon which the estimate is originated.*

All islands and capacities have been provided to Cost Estimating by the respective project expert.

- B. **Planning Basis:** *The source for the execution and strategies of the work that can be used to support the project execution plan, acquisition strategy, schedules, and market conditions and other documentation upon which the estimate is originated.*

1. All islands represent nth of a kind projects.
2. Projects will be constructed and operated by commercial entities.
3. All projects will be located in the U.S. Gulf Coast refinery region.
4. Costs are presented as overnight costs.
5. The cost estimate does not consider or address funding or labor resource restrictions. Sufficient funding and labor resources will be available in a manner that allows optimum usage of the funding and resources as estimated and scheduled.

- C. **Cost Basis:** *The source for the costing on the estimate that can be used in support of earned value management, funding profiles, and schedule of values. Sources may include published costing references, judgment, actual costs, preliminary quotes or other documentation upon which the estimate is originated.*

1. All costs are represented as current value costs. Factors for forward-looking escalation and inflation factors are not included in this estimate.
2. Where required, published cost factors, as identified in the Chemical Engineering Plant Cost Index, will be applied to previous years' values to determine current year values.
3. Geographic location factors, as identified in RS Means Construction Cost Data reference manual, were considered for each source cost.
4. Apt, Jay, et al., *An Engineering-Economic Analysis of Syngas Storage*, NETL, July 2008.
5. AACEi, *Recommended Practices*, website, visited November 16, 2009, <http://www.aacei.org/technical/rp.shtml>.
6. Brown, L. C., et al., "Alternative Flowsheets for the Sulfur-Iodine Thermochemical Hydrogen Cycle," *General Atomics*, February 2003.

COST ESTIMATE SUPPORT DATA RECAPITULATION

– Continued –

Project Title: NGNP Process Integration – Conventional Coal to Ammonia
File: MA36-L

Page 4 of 7

7. CEPCI, *Chemical Engineering Magazine*, “Chemical Engineering Plant Cost Index,” November 2009: 64.
8. Choi, 1996, Choi, Gerald N., et al, *Design/Economics of a Once-Through Natural Gas Fischer-Tropsch Plant with Power Co-Production*, Bechtel, 1996.
9. Dooley, J., et al, *Carbon Dioxide Capture and Geologic Storage*, Battelle, April 2006.
10. Douglas, Fred R., et al., *Conduction Technical and Economic Evaluations – as Applied for the Process and Utility Industries*, AACEi, April 1991.
11. FLUOR/UOP, 2004, Mak, John Y., et al., *Synthesis Gas Purification in Gasification to Ammonia/Urea Complex*, FLUOR/UOP, 2004.
12. Friedland, Robert J., et al., *Hydrogen Production Through Electrolysis*, NREL, June 2002.
13. Gray, 2004, Gray, David, et al, *Polygeneration of SNG, Hydrogen, Power, and Carbon Dioxide from Texas Lignite*, MTR-04, 2004-18, NETL, December 2004.
14. Harvego, E. A., et al., *Economic Analysis of a Nuclear Reactor Powered High-Temperature Electrolysis Hydrogen Production Plant*, INL, August 2008.
15. Harvego, E. A., et al., *Economic Analysis of the Reference Design for a Nuclear-Driven High-Temperature-Electrolysis Hydrogen Production Plant*, INL, January 2008.
16. Ivy, Johanna, *Summary of Electrolytic Hydrogen Production*, NREL September 2004.
17. Ibsen, Kelly, et al., *Equipment Design and Cost Estimation for Small Modular Biomass Systems, Synthesis Gas Cleanup, and Oxygen Separation Equipment*, NREL, May 2006.
18. Klett, Michael G., et al., *The Cost of Mercury Removal in an IGCC Plant*, NETL, September 2002.
19. Kreutz, 2008, Kreutz, Thomas G., et al, “Fischer-Tropsch Fuels from Coal and Biomass,” *25th Annual International Pittsburgh Coal Conference*, Pittsburgh, Princeton University, October 2008.
20. Loh, H. P., et al., *Process Equipment Cost Estimation*, DOE/NETL-2002/1169, NETL, 2002.
21. NETL, 2000, Shelton, W., et al., *Shell Gasifier IGCC Base Cases*, PED-IGCC-98-002, NETL, June 2000.
22. NETL, 2007a, Van Bibber, Lawrence, *Baseline Technical and Economic Assessment of a Commercial Scale Fischer-Tropsch Liquids Facility*, DOE/NETL-207/1260, NETL, April 2007.
23. NETL, 2007b, Woods, Mark C., et al., *Cost and Performance Baseline for Fossil Energy Plants*, NETL, August 2007.
24. NREL, 2005, Saur, Genevieve, *Wind-To-Hydrogen Project: Electrolyzer Capital Cost Study*, NREL, December 2008.
25. O’Brien, J. E., et al., *High-Temperature Electrolysis for Large-Scale Hydrogen and Syngas Production from Nuclear Energy – System Simulation and Economics*, INL, May 2009.
26. O’Brien, J. E., et al., *Parametric Study of Large-Scale Production of Syngas via High-Temperature Co-Electrolysis*, INL, January 2009.

COST ESTIMATE SUPPORT DATA RECAPITULATION

– Continued –

Project Title: NGNP Process Integration – Conventional Coal to Ammonia

File: MA36-L

Page 5 of 7

27. Page, John S., *Conceptual Cost Estimating Manual – 2nd ed.*, Houston: Gulf Publishing Company, 1996.
28. Pietlock, Bernard A., et al., *Developing Location Factors by Factoring- as Applied in Architecture, Engineering, Procurement, and Construction*, AACEi, October 2006.
29. Ramsden, Todd, et al., *Current (2005) Hydrogen Production from Central Grid Electrolysis*, NREL, May 2008.
30. Ramsden, Todd, et al., *Longer-Term (2025) Hydrogen Production from Central Grid Electrolysis*, NREL, May 2008.
31. Richardson Construction Estimating Standards, *Process Plant Cooling Towers*, Cost Data Online, September 16, 2009, website, visited December 15, 2009, <http://www.costdataonline.com/>.
32. Sohal, M. S., et al., *Challenges in Generating Hydrogen by High Temperature Electrolysis Using Solid Oxide Cells*, INL, March 2008.
33. Steinberg, Meyer, *Conversion of Coal to Substitute Natural Gas (SNG)*, HCE, 2005.
34. Udengaard, 2008, Udengaard, Niels R., et al., *Convert Coal, petcoke into valuable SNG*, Haldor Topsoe, April 2008.
35. van der Ploeg, H. J., et al., *The Shell Coal Gasification Process for the US Industry*, Shell, October 2004.
36. WorleyParsons, 2002, Rameshni, Mahin, *Cost Effective Options to Expand SRU Capacity Using Oxygen*, WorleyParsons, May 2002.

V. **ESTIMATE QUALITY ASSURANCE:** *A listing of all estimate reviews that have taken place and the actions taken from those reviews.*

A review of the cost estimate was held on January 14, 2010, with the project team and the cost estimators. This review allowed for the project team to review and comment, in detail, on the perceived scope, basis of estimates, assumptions, project risks, and resources that make up this cost estimate. Comments from this review have been incorporated into this estimate to reflect a project team consensus of this document.

VI. **ASSUMPTIONS:** *Condition statements accepted or supposed true without proof of demonstration; statements adding clarification to scope. An assumption has a direct impact on total estimated cost.*

General Assumptions:

- A. All costs are represented in 2009 values.
- B. Costs that were included from sources representing years prior to 2009 have been normalized to 2009 values using the Chemical Engineering Plant Cost Index. This index was selected due to its widespread recognition and acceptance and its specific orientation toward work associated with chemical and refinery plants.
- C. Capital costs are based on process islands. The majority of these islands are interchangeable, after factoring for the differing capacities, flowsheet-to-flowsheet.
- D. All chemical processing and refinery processes will be located in the U.S. Gulf Coast region.

COST ESTIMATE SUPPORT DATA RECAPITULATION

– Continued –

Project Title: NGNP Process Integration – Conventional Coal to Ammonia
File: MA36-L

Page 6 of 7

- E. All costs considered to be balance of plant costs that can be specifically identified have been factored out of the reported source data and added into the estimate in a manner consistent with that identified in the NETL 2000 IGCC Base Cost report. Inclusion of the source costs in this manner normalizes all reported cost information to the bare-erected costs.

Coal to Ammonia

- A. The air separation unit for this process requires an increase in oxygen output purity from 95 to 99.5%. A factor, based on INL simulations, of $1.36^{0.6}$ was applied to the sources, which assumed 95% oxygen purity.
- B. The NETL 2000 report lists the quench compressor separately from the gasification unit. The NETL 2007b report includes the cost of the quench compressor with the cost of the gasification unit. The costs were normalized to include both the quench compressor and gasification unit.
- C. The WorleyParsons 2002 report includes engineering costs in the costs presented. Information from this report was factored by 0.9 to normalize the data by excluding the engineering allowance.

VII. CONTINGENCY GUIDELINE IMPLEMENTATION:

Contingency Methodologies: *Explanation of methodology used in determining overall contingency. Identify any specific drivers or items of concern.*

At a project risk review on December 9, 2009, the project team discussed risks to the project. An 18% allowance for capital construction contingency has been included at an island level based on the discussion and is included in the summary sheet. The contingency level that was included in the island cost source documents and additional threats and opportunities identified here were considered during this review. The contingency identified was considered by the project team and included in Cost and Performance Baseline for Fossil Energy Plants DOE/NETL-2007/1281 and similar reports. Typically, contingency allowance provided in these reports ranged from 15% to 20%. Since much of the data contained in this estimate has been derived from these reports, the project team has also chosen a level of contingency consistent with them.

- A. **Threats:** *Uncertain events that are potentially negative or reduce the probability that the desired outcome will happen.*
1. The level of project definition/development that was available at the time the estimate was prepared represents a substantial risk to the project and is likely to occur. The high level at which elements were considered and included has the potential to include additional elements that are within the work scope but not sufficiently provided for or addressed at this level.
 2. The estimate methodology employed is one of a stochastic parametrically evaluated process. This process used publicly available published costs that were related to the process required, costs were normalized using price indices,

COST ESTIMATE SUPPORT DATA RECAPITULATION

– Continued –

Project Title: NGNP Process Integration – Conventional Coal to Ammonia
File: MA36-L

Page 7 of 7

and the cost was scaled to provide the required capacity. The cost-estimating relationships that were used represent typical costs for balance of plant allowances, but source cost data from which the initial island costs were derived were not completely descriptive of the elements included, not included, or simply referred to with different nomenclature or combined with other elements. While every effort has been made to correctly normalize and factor the costs for use in this effort, the risk exists that not all of these were correctly captured due to the varied information available.

3. This project is heavily dependent on metals, concrete, petroleum, and petroleum products. Competition for these commodities in today's environment due to global expansion, uncertainty, and product shortages affect the basic concepts of the supply and demand theories, thus increasing costs.
4. Impacts due to large quantities of materials, special alloy materials, fabrication capability, and labor availability could all represent conditions that may increase the total cost of the project.

B. **Opportunities:** *Uncertain events that could improve the results or improve the probability that the desired outcome will happen.*

1. Additional research and work performed with both vendors and potential owner/operators for a specific process or refinery may identify efficiencies and production means that have not been available for use in this analysis.
2. Recent historical data may identify and include technological advancements and efficiencies not included or reflected in the publicly available source data used in this effort.

Note: Contingency does not increase the overall accuracy of the estimate; it does, however, reduce the level of risk associated with the estimate. Contingency is intended to cover the inadequacies in the complete project scope definition, estimating methods, and estimating data. Contingency specifically excludes changes in project scope, unexpected work stoppages (e.g., strikes, disasters, and earthquakes) and excessive or unexpected inflation or currency fluctuations.

VIII. **OTHER COMMENTS/CONCERNS SPECIFIC TO THE ESTIMATE:**

None.

Detail Item Report - Air Separation Unit (ASU)

Project Name: NGNP Process Integration
Process: Conventional Coal to Ammonia
Estimate Number: MA36-L

Client: M. Patterson
Prepared By: B. Wallace, R. Honsinger, J. Martin
Estimate Type: Class 5

Sources Considered:

Source	Reported Capacity	Reported Trains	Report Cost Year	Reported Cost	Reporting Year Cost Per Train	Normalized Cost Per Train using CEPCI Index	Capacity Required	Trains Req'd.	Capacity per Train	Factored Cost per Train from Normalized Cost	Total Current Cost for Required Trains
Shell IGCC Base Case (NETL 2000)	213,207 lb/hr	1	1999	\$ 51,204,000	\$ 51,204,000	\$ 67,118,402	274,826 lb/hr	1	274,826 lb/hr	\$ 78,161,957	\$ 93,998,034
NETL Baseline Report (NETL 2007a)	1,728,789 lb/hr	2	2006	\$ 287,187,000	\$ 143,593,500	\$ 147,157,470	274,826 lb/hr	1	274,826 lb/hr	\$ 73,992,859	\$ 88,984,251
Princeton Report (Kreutz 2008)	201,264 lb/hr	1	2007	\$ 105,000,000	\$ 105,000,000	\$ 102,322,040	274,826 lb/hr	1	274,826 lb/hr	\$ 123,351,439	\$ 148,343,174
Hydrogen Report (Gray 2004)	296,583 lb/hr	1	2004	\$ 76,000,000	\$ 76,000,000	\$ 87,600,180	274,826 lb/hr	1	274,826 lb/hr	\$ 83,685,853	\$ 83,685,853
Shell GTC Report (Shell 2004)	385,259 lb/hr	1	2004	\$ 53,760,000	\$ 53,760,000	\$ 61,965,601	274,826 lb/hr	1	274,826 lb/hr	\$ 50,598,038	\$ 60,849,502
Shell IGCC Power Plant with CO2 Capture (NETL 2007b)	373,498 lb/hr	2	2006	\$ 144,337,000	\$ 72,168,500	\$ 73,959,712	274,826 lb/hr	1	274,826 lb/hr	\$ 93,255,602	\$ 112,149,741

Source Selected:

Source	Reported Capacity	Reported Trains	Report Cost Year	Reported Cost	Reporting Year Cost Per Train	Normalized Cost Per Train using CEPCI Index	Capacity Required	Trains Req'd.	Capacity per Train	Factored Cost per Train from Normalized Cost	Total Current Cost for Required Trains
Average of normalized and factored costs from NETL 2007a and Gray 2004											
										\$ 78,839,356	\$ 86,335,052

Balance of Plant:

Description	Markup	Cost Per Train	Total Cost
Water Systems		\$ 5,597,594	\$ 6,129,789
Civil/Structural/Buildings	7.10%	\$ 7,253,221	\$ 7,942,825
Piping	9.20%	\$ 5,597,594	\$ 6,129,789
Control and Instrumentation	7.10%	\$ 2,049,823	\$ 2,244,711
Electrical Systems	2.60%	\$ 6,307,148	\$ 6,906,804
	8.00%	\$ 26,805,381	\$ 29,353,918
		\$ 105,644,737	\$ 115,688,970
Total Balance of Plant			
Total Balance of Plant Plus the Selected Source			

Rationale for Selection:

NETL Baseline Report (NETL 2007a) and Hydrogen Report (Gray 2004) have been selected. An average cost of the two has been selected in order to not represent an overly aggressive or conservative cost. The markups listed under 'Balance of Plant' are based on NETL 2000. These markup values are comparable to additional published estimating guides, such as Page 1996.

Note: The ASU cost was adjusted by a factor of "1.36*0.6" to account for the increase in oxygen output purity from 95% to 99.5%. The factor is based on INL simulations calculating the increase in capacity that would be needed to have the required purity output. The Gray 2004 report uses an oxygen purity of 99% and was not adjusted by the factor of "1.36*0.6."

Project Name:	NGNP Process Integration
Process:	Conventional Coal to Ammonia
Estimate Number:	MA36-L

Client: M. Patterson
Prepared By: B. Wallace, R. Honsinger, J. Martin
Estimate Type: Class 5

[illegible]

Source	Reported Capacity	Reported Trains	Report Cost Year	Reported Cost	Reporting Year Cost Per Train	Normalized Cost Per Train using CEPCI Index	Capacity Required	Trains Req'd.	Capacity per Train	Factored Cost per Train from Normalized Cost	Total Current Cost for Required Trains
Average of normalized and factored cost from Grav 2004 and Shell 2004 reports										\$ 43,520,480	\$ 43,520,480

[illegible]

The Gray 2004 and the Shell 2004 reports identified recent actual costs that appear to be consistent with this project's needs. An average cost of the two has been selected in order to not represent an overly aggressive or conservative cost. Cost factoring reflects the 6/10 rule. The markups listed under 'Balance of Plant' are based on NETL 2000. These markup values are comparable to additional published estimating guides, such as Page 1996

Detail Item Report - Gasification

Project Name: NGNP Process Integration
Process: Conventional Coal to Ammonia
Estimate Number: MA36-L

Client: M. Patterson
Prepared By: B. Wallace, R. Honsinger, J. Martin
Estimate Type: Class 5

Sources Considered:

Source	Reported Capacity	Reported Trains	Report Cost Year	Reported Cost	Reporting Year Cost Per Train	Normalized Cost Per Train using CEPCI Index	Capacity Required	Trains Req'd.	Capacity per Train	Factored Cost per Train from Normalized Cost	Total Current Cost for Required Trains
Gasifier											
Shell IGCC Base Case (NETL 2000)	2,977	1	1999	\$ 87,802,000	\$ 87,802,000	\$ 115,091,203	4,215	1	4,215	\$ 141,788,502	\$ 141,788,502
Hydrogen Report (Gray 2004)	5,990	1	2004	\$ 174,000,000	\$ 174,000,000	\$ 200,558,307	4,215	1	4,215	\$ 162,424,203	\$ 162,424,203
Shell IGCC Power Plant with CO2 Capture (NETL 2007b)	5,310	2	2006	\$ 196,948,000	\$ 98,474,000	\$ 100,918,110	4,215	1	4,215	\$ 133,168,072	\$ 133,168,072
Shell GTC Report (Shell 2004)	5,201	2	2004	\$ 202,240,000	\$ 101,120,000	\$ 116,554,345	4,215	1	4,215	\$ 155,725,787	\$ 155,725,787
Quench Compressor											
Shell IGCC Base Case (NETL 2000)	194,116	1	1999	\$ 1,900,000	\$ 1,900,000	\$ 2,490,527	624,199	1	624,199	\$ 5,019,360	\$ 5,019,360

Source Selected:

Source	Reported Capacity	Reported Trains	Report Cost Year	Reported Cost	Reporting Year Cost Per Train	Normalized Cost Per Train using CEPCI Index	Capacity Required	Trains Req'd.	Capacity per Train	Factored Cost per Train from Normalized Cost	Total Current Cost for Required Trains
Average of normalized and factored costs from NETL 2000 and NETL 2007b reports										\$ 139,987,967	\$ 139,987,967

Balance of Plant:

Description	Markup	Cost Per Train	Total Cost
Water Systems		\$ 9,939,146	\$ 9,939,146
Civil/Structural/Buildings	7.10%	\$ 12,878,893	\$ 12,878,893
Piping	9.20%	\$ 9,939,146	\$ 9,939,146
Control and Instrumentation	7.10%	\$ 3,639,687	\$ 3,639,687
Electrical Systems	2.60%	\$ 11,199,037	\$ 11,199,037
	8.00%	\$ 47,595,909	\$ 47,595,909
		\$ 187,583,875	\$ 187,583,875
Total Balance of Plant			
Total Balance of Plant Plus the Selected Source			

Rationale for Selection:

Shell IGCC Base Case (NETL 2000) and Shell IGCC Power Plant with CO2 Capture (NETL 2007b) are consistent in factored normalized cost per train, and in the size of trains required. An average cost of the two has been selected in order to not represent an overly aggressive or conservative cost. Hydrogen Report (Gray 2004) was excluded as an unexplained and inconsistent outlier cost point. Cost factoring reflects the 6/10 rule. The markups listed under 'Balance of Plant' are based on NETL 2000. These markup values are comparable to additional published estimating guides, such as Page 1996.

Note: The reported cost of Gray 2004 is \$87,000,000 for the gasification unit, and does not include a heat recovery unit. This cost has been doubled, based on information from an active vendor. UDHE, to account for the addition cost of the heat recovery unit. The quench compressor is listed as an independent line item in the NETL 2000 report. It is factored separately here to better fit the new process model. NETL 2007b includes quench compressor.

Detail Item Report - Water Gas Shift Reactor

Project Name: NGNP Process Integration
Process: Conventional Coal to Ammonia
Estimate Number: MA36-L

Client: M. Patterson
Prepared By: B. Wallace, R. Honsinger, J. Martin
Estimate Type: Class 5

Sources Considered:

Source	Reported Capacity	Reported Trains	Report Cost Year	Reported Cost	Reporting Year Cost Per Train	Normalized Cost Per Train using CEPCI Index	Capacity Required	Trains Req'd.	Capacity per Train	Factored Cost per Train from Normalized Cost	Total Current Cost for Required Trains
Princeton Report (Kreutz 2008)	815 MW	1	2007	\$ 11,760,000	\$ 11,760,000	\$ 11,480,069	1,171 MW	1	1,171 MW	\$ 14,245,269	\$ 14,245,269
Hydrogen Report (Gray 2004)	48,243 lbmol/hr	1	2004	\$ 23,000,000	\$ 23,000,000	\$ 26,510,581	70,333 /hr	1	70,333 hr	\$ 33,239,504	\$ 33,239,504
Shell IGCC Power Plant with CO2 Capture (NETL 2007b)	1,714,460 lb/hr	4	2006	\$ 12,367,000	\$ 3,091,750	\$ 3,168,487	1,360,918 lb/hr	1	1,360,918 lb/hr	\$ 6,337,393	\$ 6,337,393

Source Selected:

Source	Reported Capacity	Reported Trains	Report Cost Year	Reported Cost	Reporting Year Cost Per Train	Normalized Cost Per Train using CEPCI Index	Capacity Required	Trains Req'd.	Capacity per Train	Factored Cost per Train from Normalized Cost	Total Current Cost for Required Trains
Hydrogen Report (Gray 2004)	48,243 lbmol/hr	1	2004	\$ 23,000,000	\$ 23,000,000	\$ 26,510,581	70,333 /hr	1	70,333 hr	\$ 33,239,504	\$ 33,239,504

Balance of Plant:

Description	Markup	Cost Per Train	Total Cost
Water Systems	7.10%	\$ 2,360,005	\$ 2,360,005
Civil/Structural/Buildings	9.20%	\$ 3,058,034	\$ 3,058,034
Piping	7.10%	\$ 2,360,005	\$ 2,360,005
Control and Instrumentation	2.60%	\$ 864,227	\$ 864,227
Electrical Systems	8.00%	\$ 2,659,160	\$ 2,659,160
		\$ 11,301,432	\$ 11,301,432
		\$ 44,540,936	\$ 44,540,936

Rationale for Selection:

Princeton Report (Kreutz 2008) is the most recent cost available, the capacity per train most closely reflects this project's needs. The markups listed under 'Balance of Plant' are based on NETL 2000. These markup values are comparable to additional published estimating guides, such as Page 1996.

Detail Item Report - Selexol

Project Name: NGNP Process Integration
 Process: Conventional Coal to Ammonia
 Estimate Number: MA36-L
 Client: M. Patterson
 Prepared By: B. Wallace, R. Honsinger, J. Martin
 Estimate Type: Class 5

Sources Considered:

Source	Reported Capacity	Reported Trains	Report Cost Year	Reported Cost	Reporting Year Cost Per Train	Normalized Cost Per Train using CEPCI Index	Capacity Required	Trains Req'd.	Capacity per Train	Factored Cost per Train from Normalized Cost	Total Current Cost for Required Trains
Fluor/UOP Report (Fluor/UOP 2004)	31,226 lbmol/hr	1	2003	\$ 22,862,000	\$ 22,862,000	\$ 29,117,771	49,957 lbmol/hr	1	49,957	\$ 38,601,673	\$ 38,601,673
Co-Production of Hydrogen Presentation (Chiesa 2003)	327 tph	1	2002	\$ 32,800,000	\$ 32,800,000	\$ 42,450,961	96 tph	1	96	\$ 20,308,766	\$ 20,308,766

Source Selected:

Source	Reported Capacity	Reported Trains	Report Cost Year	Reported Cost	Reporting Year Cost Per Train	Normalized Cost Per Train using CEPCI Index	Capacity Required	Trains Req'd.	Capacity per Train	Factored Cost per Train from Normalized Cost	Total Current Cost for Required Trains
Fluor/UOP Report (Fluor/UOP 2004)	31,226 lbmol/hr	1	2003	\$ 22,862,000	\$ 22,862,000	\$ 29,117,771	49,957 lbmol/hr	1	49,957	\$ 38,601,673	\$ 38,601,673

Outside of Battery Limits - Including Balance of Plant and Offsites:

Description	Markup	Cost Per Train	Total Cost
Water Systems	7.10%	\$ 2,740,719	\$ 2,740,719
Civil/Structural/Buildings	9.20%	\$ 3,551,354	\$ 3,551,354
Piping	7.10%	\$ 2,740,719	\$ 2,740,719
Control and Instrumentation	2.60%	\$ 1,003,643	\$ 1,003,643
Electrical Systems	8.00%	\$ 3,088,134	\$ 3,088,134
		\$ 13,124,569	\$ 13,124,569
		\$ 51,726,242	\$ 51,726,242

Rationale for Selection:

Fluor/UOP 2004 was selected as the most recent cost point, because the reported capacity is similar the required capacity per train. The markups listed under 'Outside of Battery Limits' are based on NETL 2000. These markup values are comparable to additional published estimating guides, such as Page 1996.

Detail Item Report - Pressure Swing Adsorption (PSA)

Project Name: Process: Estimate Number:	NGNP Process Integration Conventional Coal to Ammonia MA36-L	Client: Prepared By: Estimate Type:	M. Patterson B. Wallace, R. Honsinger, J. Martin Class 5
--	---	--	--

Sources Considered:

Source	Reported Capacity	Reported Trains	Report Cost Year	Reported Cost	Reporting Year Cost Per Train	Normalized Cost Per Train using CEPCI Index	Capacity Required	Trains Req'd.	Capacity per Train	Factored Cost per Train from Normalized Cost	Total Current Cost for Required Trains
Fluor/UOP Report (Fluor/UOP 2004)	27,498	1	2003	\$ 25,000,000	\$ 25,000,000	\$ 31,840,796	43,504	1	43,504 lbmol/hr	\$ 41,929,605	\$ 41,929,605

Source Selected:

Source	Reported Capacity	Reported Trains	Report Cost Year	Reported Cost	Reporting Year Cost Per Train	Normalized Cost Per Train using CEPCI Index	Capacity Required	Trains Req'd.	Capacity per Train	Factored Cost per Train from Normalized Cost	Total Current Cost for Required Trains
Fluor/UOP Report (Fluor/UOP 2004)	27,498	1	2003	\$ 25,000,000	\$ 25,000,000	\$ 31,840,796	43,504	1	43,504 lbmol/hr	\$ 41,929,605	\$ 41,929,605

Balance of Plant:

Description	Markup	Cost Per Train	Total Cost
Water Systems	7.10%	\$ 2,977,002	\$ 2,977,002
Civil/Structural/Buildings	9.20%	\$ 3,857,524	\$ 3,857,524
Piping	7.10%	\$ 2,977,002	\$ 2,977,002
Control and Instrumentation	2.60%	\$ 1,090,170	\$ 1,090,170
Electrical Systems	8.00%	\$ 3,354,368	\$ 3,354,368
		\$ 14,256,066	\$ 14,256,066
		\$ 56,185,670	\$ 56,185,670
Total Balance of Plant			
Total Balance of Plant Plus the Selected Source			

Rationale for Selection:

Single source cost point. The markups listed under 'Balance of Plant' are based on NETL 2000. These markup values are comparable to additional published estimating guides, such as Page 1996.

Detail Item Report - Methanation

Project Name: NGNP Process Integration
Process: Conventional Coal to Ammonia
Estimate Number: MA36-L

Client: M. Patterson
Prepared By: B. Wallace, R. Honsinger, J. Martin
Estimate Type: Class 5

Sources Considered:

Source	Reported Capacity	Reported Trains	Report Cost Year	Reported Cost	Reporting Year Cost Per Train	Normalized Cost Per Train using CEPCI Index	Capacity Required	Trains Req'd.	Capacity per Train	Factored Cost per Train from Normalized Cost	Total Current Cost for Required Trains
DOE FE Report (DOE 1978)	1,000 tpd	1	1978	\$ 1,467,000	\$ 1,467,000	\$ 3,432,834	3,358	1	3,358 tpd	\$ 7,100,700	\$ 7,100,700

Source Selected:

Source	Reported Capacity	Reported Trains	Report Cost Year	Reported Cost	Reporting Year Cost Per Train	Normalized Cost Per Train using CEPCI Index	Capacity Required	Trains Req'd.	Capacity per Train	Factored Cost per Train from Normalized Cost	Total Current Cost for Required Trains
DOE FE Report (DOE 1978)	1,000 tpd	1	1978	\$ 1,467,000	\$ 1,467,000	\$ 3,432,834	3,358	1	3,358 tpd	\$ 7,100,700	\$ 7,100,700

Balance of Plant:

Description	Markup	Cost Per Train	Total Cost
Water Systems	7.10%	\$ 504,150	\$ 504,150
Civil/Structural/Buildings	9.20%	\$ 653,264	\$ 653,264
Piping	7.10%	\$ 504,150	\$ 504,150
Control and Instrumentation	2.60%	\$ 184,618	\$ 184,618
Electrical Systems	8.00%	\$ 568,056	\$ 568,056
		Total Balance of Plant	\$ 2,414,238
		Total Balance of Plant Plus the Selected Source	\$ 9,514,938

Rationale for Selection:

Single source island cost identified by the project technical lead. The markups listed under 'Balance of Plant' are based on NETL 2000. These markup values are comparable to additional published estimating guides, such as Page 1996.

Detail Item Report - Claus and SCOT

Project Name: NGNP Process Integration
 Process: Conventional Coal to Ammonia
 Estimate Number: MA36-L

Client: M. Patterson
 Prepared By: B. Wallace, R. Honsinger, J. Martin
 Estimate Type: Class 5

Sources Considered:

Source	Reported Capacity	Reported Trains	Report Cost Year	Reported Cost	Reporting Year Cost Per Train	Normalized Cost Per Train using CEPCI Index	Capacity Required	Trains Req'd.	Capacity per Train	Factored Cost per Train from Normalized Cost	Total Current Cost for Required Trains
Claus and SCOT											
Princeton Report (Kreutz 2008)	12,586	1	2007	\$ 33,800,000	\$ 33,800,000	\$ 32,937,952	12,762	1	12,762	\$ 33,213,543	\$ 33,213,543
Shell IGCC Power Plant with CO2 Capture (NETL 2007b)	142	1	2006	\$ 22,794,000	\$ 22,794,000	\$ 24,926,373	153	1	153	\$ 26,093,339	\$ 26,093,339
Claus											
Shell IGCC Base Cases (NETL 2000)	6,496	1	1999	\$ 9,964,000	\$ 9,964,000	\$ 13,060,850	12,762	1	12,762	\$ 19,586,061	\$ 19,586,061
Cost Effective Options to Expand SRU Capacity Using Oxygen (WorleyParsons 2002)	79	1	1999	\$ 11,970,000	\$ 11,970,000	\$ 15,690,323	153	1	153	\$ 23,276,222	\$ 23,276,222
SCOT											
Shell IGCC Base Cases (NETL 2000)	6,496	1	1999	\$ 4,214,000	\$ 4,214,000	\$ 5,523,728	12,762	1	12,762	\$ 8,283,386	\$ 8,283,386
Cost Effective Options to Expand SRU Capacity Using Oxygen (WorleyParsons 2002)	143	1	1999	\$ 8,910,000	\$ 8,910,000	\$ 11,679,263	153	1	153	\$ 12,154,288	\$ 12,154,288

Source Selected:

Source	Reported Capacity	Reported Trains	Report Cost Year	Reported Cost	Reporting Year Cost Per Train	Normalized Cost Per Train using CEPCI Index	Capacity Required	Trains Req'd.	Capacity per Train	Factored Cost per Train from Normalized Cost	Total Current Cost for Required Trains
WorleyParsons 2002: Combined Claus and SCOT costs										\$ 35,430,510	\$ 35,430,510

Detail Item Report - Claus and SCOT

Project Name: NGNP Process Integration Process: Conventional Coal to Ammonia Estimate Number: MA36-L	Client: M. Patterson Prepared By: B. Wallace, R. Honsinger, J. Martin Estimate Type: Class 5
---	---

Balance of Plant:

Description	Markup					Cost Per Train	Total Cost
Water Systems	7.10%					\$ 2,515,566	\$ 2,515,566
Civil/Structural/Buildings	9.20%					\$ 3,259,607	\$ 3,259,607
Piping	7.10%					\$ 2,515,566	\$ 2,515,566
Control and Instrumentation	2.60%					\$ 921,193	\$ 921,193
Electrical Systems	8.00%					\$ 2,834,441	\$ 2,834,441
					Total Balance of Plant	\$ 12,046,373	\$ 12,046,373
					Total Balance of Plant Plus the Selected Source	\$ 47,476,883	\$ 47,476,883

Rationale for Selection:

The WorleyParsons 2002 cost point was selected because of WorleyParsons' status as a working vendor in this industry. It is expected that this is the highest quality information available at this time. The markups listed under 'Balance of Plant' are based on NETL 2000. These markup values are comparable to additional published estimating guides, such as Page 1996.

Note: Costs from WorleyParsons 2002 have been multiplied by 0.9 to adjust for the included engineering costs. This factor was consistent with general process industry standards, and was selected with project team consensus.

Detail Item Report - CO2 Compression

Project Name: NGNP Process Integration Process: Conventional Coal to Ammonia Estimate Number: MA36-L	Client: M. Patterson Prepared By: B. Wallace, R. Honsinger, J. Martin Estimate Type: Class 5	
---	---	--

Sources Considered:

Source	Reported Capacity	Reported Trains	Report Cost Year	Reported Cost	Reporting Year Cost Per Train	Normalized Cost Per Train using CEPCI Index	Capacity Required	Trains Req'd.	Capacity per Train	Factored Cost per Train from Normalized Cost	Total Current Cost for Required Trains
Subcritical											
Princeton Report (Kreutz 2008)	10	1	2007	\$ 6,310,000	\$ 6,310,000	\$ 6,149,067	6	MW	1	\$ 4,730,392	\$ 4,730,392
Supercritical											
Princeton Report (Kreutz 2008)	13	1	2007	\$ 9,520,000	\$ 9,520,000	\$ 9,277,198	1	MW	1	\$ 1,885,194	\$ 1,885,194

Source Selected:

Source	Reported Capacity	Reported Trains	Report Cost Year	Reported Cost	Reporting Year Cost Per Train	Normalized Cost Per Train using CEPCI Index	Capacity Required	Trains Req'd.	Capacity per Train	Factored Cost per Train from Normalized Cost	Total Current Cost for Required Trains
Kreutz 2008: Combined Subcritical and Supercritical Processes											
										\$ 6,615,586	\$ 6,615,586

Balance of Plant:

Description	Markup	Cost Per Train	Total Cost
Water Systems	7.10%	\$ 469,707	\$ 469,707
Civil/Structural/Buildings	9.20%	\$ 608,634	\$ 608,634
Piping	7.10%	\$ 469,707	\$ 469,707
Control and Instrumentation	2.60%	\$ 172,005	\$ 172,005
Electrical Systems	8.00%	\$ 529,247	\$ 529,247
		\$ 2,249,299	\$ 2,249,299
		\$ 8,864,886	\$ 8,864,886
Total Balance of Plant			
Total Balance of Plant Plus the Selected Source			

Rationale for Selection:

Single source cost point. Both subcritical and supercritical process costs were included under the CO2 Compression heading. The markups listed under 'Balance of Plant' are based on NETL 2000. These markup values are comparable to additional published estimating guides, such as Page 1996.

Detail Item Report - Ammonia Synthesis

Project Name: Process: Estimate Number:	NGNP Process Integration Conventional Coal to Ammonia MA36-L	Client: Prepared By: Estimate Type:	M. Patterson B. Wallace, R. Honsinger, J. Martin Class 5
--	---	--	---

Sources Considered:

Source	Reported Capacity	Reported Trains	Report Cost Year	Reported Cost	Reporting Year Cost Per Train	Normalized Cost Per Train using CEPCI Index	Capacity Required	Trains Req'd.	Capacity per Train	Factored Cost per Train from Normalized Cost	Total Current Cost for Required Trains
Vendor - Verbal 2009	360	1	2009	\$ 44,000,000	\$ 44,000,000	\$ 44,000,000	3,358	2	1,679	\$ 110,841,296	\$ 221,682,591
Economics Ammonia Coal Gasification (Morel 1977)	1,000	1	1977	\$ 50,748,000	\$ 50,748,000	\$ 80,243,904	3,358	2	1,679	\$ 109,507,147	\$ 219,014,295
Stamcarbon, Middle East Fertilizer Symposium, March 2009	4,297	1	2008	\$ 800,000,000	\$ 800,000,000	\$ 779,596,498	3,358	2	1,679	\$ 443,599,396	\$ 887,198,792
Ammonia, Chem Systems, 1998	1,653	1	1998	\$ 160,000,000	\$ 160,000,000	\$ 210,320,924	3,358	2	1,679	\$ 212,264,936	\$ 424,529,872

Source Selected:

Source	Reported Capacity	Reported Trains	Report Cost Year	Reported Cost	Reporting Year Cost Per Train	Normalized Cost Per Train using CEPCI Index	Capacity Required	Trains Req'd.	Capacity per Train	Factored Cost per Train from Normalized Cost	Total Current Cost for Required Trains
Vendor - Verbal 2009	360	1	2009	\$ 44,000,000	\$ 44,000,000	\$ 44,000,000	3,358	2	1,679	\$ 110,841,296	\$ 221,682,591

Balance of Plant:

Description	Markup	Cost Per Train	Total Cost
Water Systems	7.10%	\$ 7,869,732	\$ 15,739,464
Civil/Structural/Buildings	9.20%	\$ 10,197,399	\$ 20,394,798
Piping	7.10%	\$ 7,869,732	\$ 15,739,464
Control and Instrumentation	2.60%	\$ 2,881,874	\$ 5,763,747
Electrical Systems	8.00%	\$ 8,867,304	\$ 17,734,607
		Total Balance of Plant	\$ 37,686,041
		Total Balance of Plant Plus the Selected Source	\$ 148,527,336

Rationale for Selection:

The verbal cost was selected as recommended by the project team expert. The Stamcarbon information shows a roughly 350% increase in prices between 2003 and 2008 emphasizing the importance of using the most recent information available. The markups listed under 'Outside of Battery Limits' are based on NETL 2000. These markup values are comparable to additional published estimating guides, such as Page 1996.

Detail Item Report - Urea Synthesis

Project Name: NGNP Process Integration
 Process: Conventional Coal to Ammonia
 Estimate Number: MA36-L

Client: M. Patterson
 Prepared By: B. Wallace, R. Honsinger, J. Martin
 Estimate Type: Class 5

Sources Considered:

Source	Reported Capacity	Reported Trains	Report Cost Year	Reported Cost	Reporting Year Cost Per Train	Normalized Cost Per Train using CEPCI Index	Capacity Required	Trains Req'd.	Capacity per Train	Factored Cost per Train from Normalized Cost	Total Current Cost for Required Trains
Vendor - Verbal 2009	625	1	2009	\$ 85,000,000	\$ 85,000,000	\$ 85,000,000	2,939	1	2,939	\$ 215,184,342	\$ 215,184,342
Perry's Chemical Engineering Handbook, 7th Edition	200	1	1994	\$ 8,800,000	\$ 8,800,000	\$ 12,240,152	2,939	1	2,939	\$ 61,388,719	\$ 61,388,719
PNL	4881	1	2009	\$ 182,000,000	\$ 182,000,000	\$ 182,000,000	2,939	1	2,939	\$ 137,653,721	\$ 137,653,721
Stamcarbon, Middle East Fertilizer Symposium, March 2009	3,582	1	2008	\$ 550,000,000	\$ 550,000,000	\$ 535,972,592	2,939	1	2,939	\$ 475,978,115	\$ 475,978,115

Source Selected:

Source	Reported Capacity	Reported Trains	Report Cost Year	Reported Cost	Reporting Year Cost Per Train	Normalized Cost Per Train using CEPCI Index	Capacity Required	Trains Req'd.	Capacity per Train	Factored Cost per Train from Normalized Cost	Total Current Cost for Required Trains
Vendor - Verbal 2009	625	1	2009	\$ 85,000,000	\$ 85,000,000	\$ 85,000,000	2,939	1	2,939	\$ 215,184,342	\$ 215,184,342

Balance of Plant:

Description	Markup	Cost Per Train	Total Cost
Water Systems	7.10%	\$ 15,278,088	\$ 15,278,088
Civil/Structural/Buildings	9.20%	\$ 19,796,959	\$ 19,796,959
Piping	7.10%	\$ 15,278,088	\$ 15,278,088
Control and Instrumentation	2.60%	\$ 5,594,793	\$ 5,594,793
Electrical Systems	8.00%	\$ 17,214,747	\$ 17,214,747
		\$ 73,162,676	\$ 73,162,676
		\$ 288,347,019	\$ 288,347,019

Rationale for Selection:

The verbal cost was selected as recommended by the project team expert. The Stamcarbon information shows a roughly 350% increase in prices between 2003 and 2008 emphasizing the importance of using the most recent information available. The markups listed under 'Outside of Battery Limits' are based on NETL 2000. These markup values are comparable to additional published estimating guides, such as Page 1996.

Detail Item Report - Nitric Acid Synthesis

Project Name: NGNP Process Integration Process: Conventional Coal to Ammonia Estimate Number: MA36-L	Client: M. Patterson Prepared By: B. Wallace, R. Honsinger, J. Martin Estimate Type: Class 5	
---	---	--

Sources Considered:

Source	Reported Capacity	Reported Trains	Report Cost Year	Reported Cost	Reporting Year Cost Per Train	Normalized Cost Per Train using CEPCI Index	Capacity Required	Trains Req'd.	Capacity per Train	Factored Cost per Train from Normalized Cost	Total Current Cost for Required Trains
Perry's Chemical Engineering Handbook, 7th Edition	334 tpd	1	1994	\$ 6,600,000	\$ 6,600,000	\$ 9,180,114	5,186 tpd	6	864 tpd	\$ 16,239,973	\$ 97,439,841
Fertilizer Manual	359 tpd	1	1998	\$ 15,200,000	\$ 15,200,000	\$ 19,980,488	5,186 tpd	6	864 tpd	\$ 33,828,481	\$ 202,970,888

Source Selected:

Source	Reported Capacity	Reported Trains	Report Cost Year	Reported Cost	Reporting Year Cost Per Train	Normalized Cost Per Train using CEPCI Index	Capacity Required	Trains Req'd.	Capacity per Train	Factored Cost per Train from Normalized Cost	Total Current Cost for Required Trains
Fertilizer Manual	359 tpd	1	1998	\$ 15,200,000	\$ 15,200,000	\$ 19,980,488	5,186 tpd	6	864 tpd	\$ 33,828,481	\$ 202,970,888

Balance of Plant:

Description	Markup	Cost Per Train	Total Cost
Water Systems	7.10%	\$ 2,401,822	\$ 14,410,933
Civil/Structural/Buildings	9.20%	\$ 3,112,220	\$ 18,673,322
Piping	7.10%	\$ 2,401,822	\$ 14,410,933
Control and Instrumentation	2.60%	\$ 879,541	\$ 5,277,243
Electrical Systems	8.00%	\$ 2,706,279	\$ 16,237,671
		\$ 11,501,684	\$ 69,010,102
		\$ 45,330,165	\$ 271,980,990
Total Balance of Plant			
Total Balance of Plant Plus the Selected Source			

Rationale for Selection:

The Fertilizer Manual was selected for being both the newest cost point and the most conservative. The data from Perry's Chemical Engineering Handbook is based on earlier data from Peters and Timmerhaus, making it even less desirable. The markups listed under 'Outside of Battery Limits' are comparable to additional published estimating guides, such as Page 1996.

Detail Item Report - Ammonium Nitrate Synthesis

Project Name: Process: Estimate Number:	NGNP Process Integration Conventional Coal to Ammonia MA36-L	Client: Prepared By: Estimate Type:
		M. Patterson B. Wallace, R. Honsinger, J. Martin Class 5

Sources Considered:

Source	Reported Capacity	Reported Trains	Report Cost Year	Reported Cost	Reporting Year Cost Per Train	Normalized Cost Per Train using CEPCI Index	Capacity Required	Trains Req'd.	Capacity per Train	Factored Cost per Train from Normalized Cost	Total Current Cost for Required Trains
Perry's Chemical Engineering Handbook, 7th Edition	334 tpd	1	1994	\$ 6,000,000	\$ 6,000,000	\$ 8,345,558	3,779 tpd	3	1,260 tpd	\$ 18,507,052	\$ 55,521,157
Fertilizer Manual	1,395 tpd	1	1998	\$ 35,000,000	\$ 35,000,000	\$ 46,007,702	3,779 tpd	3	1,260 tpd	\$ 43,270,765	\$ 129,812,295
EPA Report	1,200 tpd	1	1981	\$ 9,480,000	\$ 9,480,000	\$ 13,434,154	3,779 tpd	3	1,260 tpd	\$ 13,831,044	\$ 41,493,133

Source Selected:

Source	Reported Capacity	Reported Trains	Report Cost Year	Reported Cost	Reporting Year Cost Per Train	Normalized Cost Per Train using CEPCI Index	Capacity Required	Trains Req'd.	Capacity per Train	Factored Cost per Train from Normalized Cost	Total Current Cost for Required Trains
Fertilizer Manual	1,395.24 tpd	1.00	1998.00	35000000.00	35000000.00	46007702.18	3779.00 tpd	3.00	1259.67 tpd	43270765.12	129812295.36

Balance of Plant:

Description	Markup	Cost Per Train	Total Cost
Water Systems	7.10%	\$ 3,072,224	\$ 9,216,673
Civil/Structural/Buildings	9.20%	\$ 3,980,910	\$ 11,942,731
Piping	7.10%	\$ 3,072,224	\$ 9,216,673
Control and Instrumentation	2.60%	\$ 1,125,040	\$ 3,375,120
Electrical Systems	8.00%	\$ 3,461,661	\$ 10,384,984
		\$ 14,712,060	\$ 44,136,180
		\$ 57,982,825	\$ 173,948,476

Rationale for Selection:

The Fertilizer Manual was selected for being both the newest cost point and the most conservative. The data from Perry's Chemical Engineering Handbook is based on earlier data from Peters and Timmerhaus, making it even less desirable. The markups listed under 'Outside of Battery Limits' are comparable to additional published estimating guides, such as Page 1996.

Detail Item Report - Steam Turbines

Project Name: NGNP Process Integration
Process: Conventional Coal to Ammonia
Estimate Number: MA36-L

Client: M. Patterson
Prepared By: B. Wallace, R. Honsinger, J. Martin
Estimate Type: Class 5

Sources Considered:

Source	Reported Capacity	Reported Trains	Report Cost Year	Reported Cost	Reporting Year Cost Per Train	Normalized Cost Per Train using CEPCI Index	Capacity Required	Trains Req'd.	Capacity per Train	Factored Cost per Train from Normalized Cost	Total Current Cost for Required Trains
Steam Turbine and HRSG											
Shell IGCC Base Cases (NETL 2000)	189	1	1999	\$ 50,671,000	\$ 50,671,000	\$ 66,419,744	47	1	47	\$ 28,634,650	\$ 28,634,650
Steam Turbine											
NETL Baseline Report (NETL 2007a)	401	4	2006	\$ 74,651,000	\$ 18,662,750	\$ 19,125,957	47	1	47	\$ 12,062,694	\$ 12,062,694
Princeton Report (Kreutz 2008)	275	1	2007	\$ 66,700,000	\$ 66,700,000	\$ 64,998,858	47	1	47	\$ 22,375,764	\$ 22,375,764
Shell IGCC Power Plant with CO2 Capture (NETL 2007b)	230	1	2006	\$ 44,515,000	\$ 44,515,000	\$ 45,619,856	47	1	47	\$ 17,485,107	\$ 17,485,107

Source Selected:

Source	Reported Capacity	Reported Trains	Report Cost Year	Reported Cost	Reporting Year Cost Per Train	Normalized Cost Per Train using CEPCI Index	Capacity Required	Trains Req'd.	Capacity per Train	Factored Cost per Train from Normalized Cost	Total Current Cost for Required Trains
Shell IGCC Power Plant with CO2 Capture (NETL 2007b)	230	1	2006	\$ 44,515,000	\$ 44,515,000	\$ 45,619,856	47	1	47	\$ 17,485,107	\$ 17,485,107

Balance of Plant:

Description	Markup	Cost Per Train	Total Cost
Water Systems		\$ 1,241,443	\$ 1,241,443
Civil/Structural/Buildings	7.10%	\$ 1,608,630	\$ 1,608,630
Piping	9.20%	\$ 1,241,443	\$ 1,241,443
Control and Instrumentation	7.10%	\$ 454,613	\$ 454,613
Electrical Systems	2.60%	\$ 1,398,809	\$ 1,398,809
	8.00%	\$ 5,944,936	\$ 5,944,936
		\$ 23,430,044	\$ 23,430,044
Total Balance of Plant			
Total Balance of Plant Plus the Selected Source			

Rationale for Selection:

Shell IGCC PowerPlant with CO2 Capture (NETL 2007b) is a recently reported cost point that closely reflects this project's requirements. The Princeton Report (Kreutz 2008) source for the steam turbine cost point is the NETL 2007b report. The markups listed under 'Balance of Plant' are based on NETL 2000. These markup values are comparable to additional published estimating guides, such as Page 1996.

Client: M. Patterson
Prepared By: B. Wallace, R. Honsinger, J. Martin
Estimate Type: Class 5

Source	Reported Capacity	Reported Trains	Report Cost Year	Reported Cost	Reporting Year Cost Per Train	Normalized Cost Per Train using CEPCI Index	Capacity Required	Trains Req'd.	Capacity per Train	Factored Cost per Train from Normalized Cost	Total Current Cost for Required Trains
Steam Turbine and HRSG											
Shell IGCC Base Cases (NETL 2000)	189	1	1999	\$ 50,671,000	\$ 50,671,000	\$ 66,419,744	47 MW	1	47 MW	\$ 28,634,650	\$ 28,634,650
HRSG											
NETL Baseline Report (NETL 2007a)	5,155,983	3	2006	\$ 27,581,000	\$ 9,193,667	\$ 9,421,852	1,117,170 lb/hr	1	1,117,170 lb/hr	\$ 7,276,017	\$ 7,276,017
Princeton Report (Kreutz 2008)	355	1	2007	\$ 52,000,000	\$ 52,000,000	\$ 50,673,772	49 MW	1	49 MW	\$ 15,411,146	\$ 15,411,146
Shell IGCC Power Plant with CO2 Capture (NETL 2007b)	8,438,000	2	2006	\$ 45,291,000	\$ 22,645,500	\$ 23,207,558	1,117,170 lb/hr	1	1,117,170 lb/hr	\$ 10,456,234	\$ 10,456,234

Source	Reported Capacity	Reported Trains	Report Cost Year	Reported Cost	Reporting Year Cost Per Train	Normalized Cost Per Train using CEPCI Index	Capacity Required	Trains Req'd.	Capacity per Train	Factored Cost per Train from Normalized Cost	Total Current Cost for Required Trains
Shell IGCC Power Plant with CO2 Capture (NETL 2007b)	8,438,000 lb/hr	2	2006	\$ 45,291,000	\$ 22,645,500	\$ 23,207,558	1,117,170 lb/hr	1	1,117,170 lb/hr	\$ 10,456,234	\$ 10,456,234

Description	Markup						Cost Per Train	Total Cost
Water Systems	7.10%						\$ 742,393	\$ 742,393
Civil/Structural/Buildings	9.20%						\$ 961,974	\$ 961,974
Piping	7.10%						\$ 742,393	\$ 742,393
Control and Instrumentation	2.60%						\$ 271,862	\$ 271,862
Electrical Systems	8.00%						\$ 836,499	\$ 836,499
							Total Balance of Plant	
							\$ 3,555,120	\$ 3,555,120
							Total Balance of Plant Plus the Selected Source	
							\$ 14,011,353	\$ 14,011,353
							\$ 14,011,353	\$ 14,011,353

Shell IGCC PowerPlant with CO₂ Capture (NETL 2007b) is a recently reported cost point that closely reflects this project's requirements. The Princeton Report (Kreutz 2008) source for the steam turbine cost point is the NETL 2007b report. The markups listed under 'Balance of Plant' are based on NETL 2000. These markup values are comparable to additional published estimating guides, such as Page 1996.

Project Name: NGNP Process Integration
Process: Conventional Coal to Ammonia
Estimate Number: MA36-L

Client: M. Patterson
Prepared By: B. Wallace, R. Honsinger, J. Martin
Estimate Type: Class 5

[illegible]

Source	Reported Capacity		Reported Trains	Report Cost Year	Reported Cost	Reporting Year Cost Per Train	Normalized Cost Per Train using CEPCI Index	Capacity per Train		Trains Req'd.	Factored Cost per Train from Normalized Cost	Total Current Cost for Required Trains
	140,001	gpm							gpm			
Cooling Tower Depot			5	2009	\$ 3,452,790	\$ 690,558	\$ 690,558	130,392	26,078	5	\$ 661,717	\$ 3,308,583

[illegible]

Single source cost. Publicly available current data. Calculated capital costs based on publically available cost data from a vendor regularly engaged in the building of cooling towers.

NGNP Conventional Gas to Ammonia Summary


Project Name: **NGNP Process Integration**
 Process: **Conventional Gas to Ammonia**
 Estimate Number: **MA36-M**

Client: **M. Patterson**
 Prepared By: **B. Wallace, R. Honsinger, J. Martin**
 Estimate Type: **Class 5**

Process Component	Subtotal From Detail Sheets	Engineering %	Engineering	Contingency %	Contingency	Total Cost
Steam Methane Reforming	\$ 118,901,263	10%	\$ 11,890,126	18%	\$ 23,542,450	\$ 154,333,839
Water Gas Shift Reactor	\$ 39,287,822	10%	\$ 3,928,782	18%	\$ 7,778,989	\$ 50,995,593
Selexol	\$ 46,435,179	10%	\$ 4,643,518	18%	\$ 9,194,165	\$ 60,272,862
Methanation	\$ 9,520,038	10%	\$ 952,004	18%	\$ 1,884,967	\$ 12,357,009
CO2 Compression	\$ 12,478,201	10%	\$ 1,247,820	18%	\$ 2,470,684	\$ 16,196,705
Ammonia Synthesis	\$ 297,213,875	10%	\$ 29,721,388	18%	\$ 58,848,347	\$ 385,783,610
Urea Synthesis	\$ 288,347,019	10%	\$ 28,834,702	18%	\$ 57,092,710	\$ 374,274,430
Nitric Acid Synthesis	\$ 272,169,749	10%	\$ 27,216,975	18%	\$ 53,889,610	\$ 353,276,334
Ammonium Nitrate Synthesis	\$ 173,948,476	10%	\$ 17,394,848	18%	\$ 34,441,798	\$ 225,785,122
Steam Turbines	\$ 17,613,271	10%	\$ 1,761,327	18%	\$ 3,487,428	\$ 22,862,026
Heat Recovery Steam Generator (HRSG)	\$ -	10%	\$ -	18%	\$ -	\$ -
Cooling Towers	\$ 3,263,515	10%	\$ 326,352	18%	\$ 646,176	\$ 4,236,043
Total Cost - Conventional Gas to Ammonia						\$ 1,660,373,573
Total Cost Rounded to the Nearest \$10M						\$ 1,660,000,000

Checked By: 	Remarks
Approved By: 	

COST ESTIMATE SUPPORT DATA RECAPITULATION

Project Title: NGNP Process Integration – Conventional Gas to Ammonia
Estimator: B. W. Wallace/CEP, R. R. Honsinger/CEP, J. B. Martin/CCT
Date: April 20, 2010
Estimate Type: Class 5
File: MA36-M
Approved By: 

Page 1 of 7

- I. **PURPOSE:** *Brief description of the intent of how the estimate is to be used (i.e., for engineering study, comparative analysis, request for funding, proposal, etc.).*

It is expected that the capital costs identified in these estimates will be used in a model producing an economic analysis for each specific integrated application and subsequently will be considered in a related feasibility study.

- II. **SCOPE OF WORK:** *Brief statement of the project's objective. Thorough overview and description of the proposed project. Identify work to be accomplished, as well as any specific work to be excluded.*

A. **Objective:**

Develop Class 5 estimates as defined by the Association for Advancement of Cost Engineering (AACEi) that will identify the current capital cost associated with a gas-to-ammonia process.

B. **Included:**

The scope of work required to achieve this objective includes the following:

1. Engineering
2. Construction of a new gas-to-ammonia refinery that consists of the following:
 - a. Steam methane reformer
 - b. Water gas shift reactors
 - c. Selexol process
 - d. Methanation
 - e. CO₂ compression
 - f. Ammonia synthesis
 - g. Urea synthesis
 - h. Nitric acid synthesis
 - i. Ammonium nitrate synthesis
 - j. Steam turbines, internal to process
 - k. Heat recovery steam generator, internal to process
 - l. Cooling towers, internal to process
 - m. Allowances for Balance of Plant (BOP)/offsite/outside of battery limits (OSBL), including the following:
 - (1.) Site development/improvements
 - (2.) Provisions for general and administrative buildings and structures
 - (3.) Provisions for OSBL piping
 - (4.) Provisions for OSBL instrumentation and control

COST ESTIMATE SUPPORT DATA RECAPITULATION

– Continued –

Project Title: NGNP Process Integration – Conventional Gas to Ammonia
File: MA36-M

Page 2 of 7

- (5.) Provisions for OSBL electrical
- (6.) Provisions for facility supply and OSBL water systems
- (7.) Provisions for site development/improvements
- (8.) Project/construction management.

C. **Excluded:**

This scope of work specifically excludes the following elements:

- 1. Licensing and permitting costs
- 2. Operational costs
- 3. Land costs
- 4. Sales taxes
- 5. Royalties
- 6. Owner's fees and owner's costs.

III. **ESTIMATE METHODOLOGY:** *Overall methodology and rationale of how the estimate was developed (i.e., parametric, forced detail, bottoms up, etc.). Total dollars/hours and rough order magnitude (ROM) allocations of the methodologies used to develop the cost estimate.*

Consistent with the AACEi Class 5 estimates, the level of definition and engineering development available at the time they were prepared, their intended use in a feasibility study, and the time and resources available for their completion, the costs included in this estimate have been developed using parametric evaluations. These evaluations have used publicly available and published project costs to represent similar islands utilized in this project. Analysis and selection of the published costs used have been performed by the project technical lead and Cost Estimating. Suitability for use in this effort was determined considering the correctness and completeness of the data available, the manner in which total capital costs were represented, the age of the previously performed work, and the similarity to the capacity/trains required by this project. The specific sources, selected and used in this cost estimate, are identified in the capital cost estimate detail sheets.

Adjustments have been made to these published costs using escalation factors identified in the Chemical Engineering Price Cost Index. Scaling of the published island costs has been accomplished using the six-tenths capacity factoring method. Any normalization to provide for geographic factors was considered using geographic factors available from RS Means Construction Cost Data references. Cost-estimating relationships have been used to identify allowances to complete the costs.

BOP/OSBL costs were determined by the project team, considering data provided by Shell Gasifier IGCC Base Case report NETL 2000, *Conceptual Cost Estimating Manual* Second Edition by John S. Page, and additional adjusted sources. Because the allowances identified did not show significant variability, the allowances identified in the NETL 2000 report were chosen for this effort in order to minimize the mixing of data sources.

COST ESTIMATE SUPPORT DATA RECAPITULATION

– Continued –

Project Title: NGNP Process Integration – Conventional Gas to Ammonia
File: MA36-M

Page 3 of 7

IV. **BASIS OF THE ESTIMATE:** *Overall explanation of sources for resource pricing and schedules.*

- A. **Quantification Basis:** *The source for the measurable quantities in the estimate that can be used in support of earned value management. Source documents may include drawings, design reports, engineers' notes, and other documentation upon which the estimate is originated.*

All islands and capacities have been provided to Cost Estimating by the respective project expert.

- B. **Planning Basis:** *The source for the execution and strategies of the work that can be used to support the project execution plan, acquisition strategy, schedules, and market conditions and other documentation upon which the estimate is originated.*

1. All islands represent nth of a kind projects.
2. Projects will be constructed and operated by commercial entities.
3. All projects will be located in the U.S. Gulf Coast refinery region.
4. Costs are presented as overnight costs.
5. The cost estimate does not consider or address funding or labor resource restrictions. Sufficient funding and labor resources will be available in a manner that allows optimum usage of the funding and resources as estimated and scheduled.

- C. **Cost Basis:** *The source for the costing on the estimate that can be used in support of earned value management, funding profiles, and schedule of values. Sources may include published costing references, judgment, actual costs, preliminary quotes or other documentation upon which the estimate is originated.*

1. All costs are represented as current value costs. Factors for forward-looking escalation and inflation factors are not included in this estimate.
2. Where required, published cost factors, as identified in the Chemical Engineering Plant Cost Index, will be applied to previous years' values to determine current year values.
3. Geographic location factors, as identified in RS Means Construction Cost Data reference manual, were considered for each source cost.
4. Apt, Jay, et al., *An Engineering-Economic Analysis of Syngas Storage*, NETL, July 2008.
5. AACEi, *Recommended Practices*, website, visited November 16, 2009, <http://www.aacei.org/technical/rp.shtml>.
6. Brown, L. C., et al., "Alternative Flowsheets for the Sulfur-Iodine Thermochemical Hydrogen Cycle," *General Atomics*, February 2003.
7. CEPCL, *Chemical Engineering Magazine*, "Chemical Engineering Plant Cost Index," November 2009: 64.
8. Choi, 1996, Choi, Gerald N., et al, *Design/Economics of a Once-Through Natural Gas Fischer-Tropsch Plant with Power Co-Production*, Bechtel, 1996.

COST ESTIMATE SUPPORT DATA RECAPITULATION

– Continued –

Project Title: NGNP Process Integration – Conventional Gas to Ammonia
File: MA36-M

Page 4 of 7

9. Dooley, J., et al, *Carbon Dioxide Capture and Geologic Storage*, Battelle, April 2006.
10. Douglas, Fred R., et al., *Conduction Technical and Economic Evaluations – as Applied for the Process and Utility Industries*, AACEi, April 1991.
11. FLUOR/UOP, 2004, Mak, John Y., et al., *Synthesis Gas Purification in Gasification to Ammonia/Urea Complex*, FLUOR/UOP, 2004.
12. Friedland, Robert J., et al., *Hydrogen Production Through Electrolysis*, NREL, June 2002.
13. Gray, 2004, Gray, David, et al, *Polygeneration of SNG, Hydrogen, Power, and Carbon Dioxide from Texas Lignite*, MTR-04, 2004-18, NETL, December 2004.
14. Harvego, E. A., et al., *Economic Analysis of a Nuclear Reactor Powered High-Temperature Electrolysis Hydrogen Production Plant*, INL, August 2008.
15. Harvego, E. A., et al., *Economic Analysis of the Reference Design for a Nuclear-Driven High-Temperature-Electrolysis Hydrogen Production Plant*, INL, January 2008.
16. Ivy, Johanna, *Summary of Electrolytic Hydrogen Production*, NREL September 2004.
17. Ibsen, Kelly, et al., *Equipment Design and Cost Estimation for Small Modular Biomass Systems, Synthesis Gas Cleanup, and Oxygen Separation Equipment*, NREL, May 2006.
18. Klett, Michael G., et al., *The Cost of Mercury Removal in an IGCC Plant*, NETL, September 2002.
19. Kreutz, 2008, Kreutz, Thomas G., et al, “Fischer-Tropsch Fuels from Coal and Biomass,” *25th Annual International Pittsburgh Coal Conference*, Pittsburgh, Princeton University, October 2008.
20. Loh, H. P., et al., *Process Equipment Cost Estimation*, DOE/NETL-2002/1169, NETL, 2002.
21. NETL, 2000, Shelton, W., et al., *Shell Gasifier IGCC Base Cases*, PED-IGCC-98-002, NETL, June 2000.
22. NETL, 2007a, Van Bibber, Lawrence, *Baseline Technical and Economic Assessment of a Commercial Scale Fischer-Tropsch Liquids Facility*, DOE/NETL-207/1260, NETL, April 2007.
23. NETL, 2007b, Woods, Mark C., et al., *Cost and Performance Baseline for Fossil Energy Plants*, NETL, August 2007.
24. NREL, 2005, Saur, Genevieve, *Wind-To-Hydrogen Project: Electrolyzer Capital Cost Study*, NREL, December 2008.
25. O’Brien, J. E., et al., *High-Temperature Electrolysis for Large-Scale Hydrogen and Syngas Production from Nuclear Energy – System Simulation and Economics*, INL, May 2009.
26. O’Brien, J. E., et al., *Parametric Study of Large-Scale Production of Syngas via High-Temperature Co-Electrolysis*, INL, January 2009.
27. Page, John S., *Conceptual Cost Estimating Manual – 2nd ed.*, Houston: Gulf Publishing Company, 1996.

COST ESTIMATE SUPPORT DATA RECAPITULATION

– Continued –

Project Title: NGNP Process Integration – Conventional Gas to Ammonia
File: MA36-M

Page 5 of 7

28. Pietlock, Bernard A., et al., *Developing Location Factors by Factoring- as Applied in Architecture, Engineering, Procurement, and Construction*, AACEi, October 2006.
29. Ramsden, Todd, et al., *Current (2005) Hydrogen Production from Central Grid Electrolysis*, NREL, May 2008.
30. Ramsden, Todd, et al., *Longer-Term (2025) Hydrogen Production from Central Grid Electrolysis*, NREL, May 2008.
31. Richardson Construction Estimating Standards, *Process Plant Cooling Towers*, Cost Data Online, September 16, 2009, website, visited December 15, 2009, <http://www.costdataonline.com/>.
32. Sohal, M. S., et al., *Challenges in Generating Hydrogen by High Temperature Electrolysis Using Solid Oxide Cells*, INL, March 2008.
33. Steinberg, Meyer, *Conversion of Coal to Substitute Natural Gas (SNG)*, HCE, 2005.
34. Udengaard, 2008, Udengaard, Niels R., et al., *Convert Coal, petcoke into valuable SNG*, Haldor Topsoe, April 2008.
35. van der Ploeg, H. J., et al., *The Shell Coal Gasification Process for the US Industry*, Shell, October 2004.
36. WorleyParsons, 2002, Rameshni, Mahin, *Cost Effective Options to Expand SRU Capacity Using Oxygen*, WorleyParsons, May 2002.

V. **ESTIMATE QUALITY ASSURANCE:** *A listing of all estimate reviews that have taken place and the actions taken from those reviews.*

A review of the cost estimate was held on January 14, 2010, with the project team and the cost estimators. This review allowed for the project team to review and comment, in detail, on the perceived scope, basis of estimates, assumptions, project risks, and resources that make up this cost estimate. Comments from this review have been incorporated into this estimate to reflect a project team consensus of this document.

VI. **ASSUMPTIONS:** *Condition statements accepted or supposed true without proof of demonstration; statements adding clarification to scope. An assumption has a direct impact on total estimated cost.*

General Assumptions:

- A. All costs are represented in 2009 values.
- B. Costs that were included from sources representing years prior to 2009 have been normalized to 2009 values using the Chemical Engineering Plant Cost Index. This index was selected due to its widespread recognition and acceptance and its specific orientation toward work associated with chemical and refinery plants.
- C. Capital costs are based on process islands. The majority of these islands are interchangeable, after factoring for the differing capacities, flowsheet-to-flowsheet.
- D. All chemical processing and refinery processes will be located in the U.S. Gulf Coast region.
- E. All costs considered to be balance of plant costs that can be specifically identified have been factored out of the reported source data and added into the estimate in a

COST ESTIMATE SUPPORT DATA RECAPITULATION

– Continued –

Project Title: NGNP Process Integration – Conventional Gas to Ammonia
File: MA36-M

Page 6 of 7

manner consistent with that identified in the NETL 2000 IGCC Base Cost report. Inclusion of the source costs in this manner normalizes all reported cost information to the bare-erected costs.

Gas to Ammonia

The NREL 2006 report presented the steam methane reformer cost with the cost of the water gas shift reactors. This cost was normalized to exclude the cost of the water gas shift reactors.

VII. CONTINGENCY GUIDELINE IMPLEMENTATION:

Contingency Methodologies: *Explanation of methodology used in determining overall contingency. Identify any specific drivers or items of concern.*

At a project risk review on December 9, 2009, the project team discussed risks to the project. An 18% allowance for capital construction contingency has been included at an island level based on the discussion and is included in the summary sheet. The contingency level that was included in the island cost source documents and additional threats and opportunities identified here were considered during this review. The contingency identified was considered by the project team and included in Cost and Performance Baseline for Fossil Energy Plants DOE/NETL-2007/1281 and similar reports. Typically, contingency allowance provided in these reports ranged from 15% to 20%. Since much of the data contained in this estimate has been derived from these reports, the project team has also chosen a level of contingency consistent with them.

A. **Threats:** *Uncertain events that are potentially negative or reduce the probability that the desired outcome will happen.*

1. The level of project definition/development that was available at the time the estimate was prepared represents a substantial risk to the project and is likely to occur. The high level at which elements were considered and included has the potential to include additional elements that are within the work scope but not sufficiently provided for or addressed at this level.
2. The estimate methodology employed is one of a stochastic parametrically evaluated process. This process used publicly available published costs that were related to the process required, costs were normalized using price indices, and the cost was scaled to provide the required capacity. The cost-estimating relationships that were used represent typical costs for balance of plant allowances, but source cost data from which the initial island costs were derived were not completely descriptive of the elements included, not included, or simply referred to with different nomenclature or combined with other elements. While every effort has been made to correctly normalize and factor the costs for use in this effort, the risk exists that not all of these were correctly captured due to the varied information available.

COST ESTIMATE SUPPORT DATA RECAPITULATION

– Continued –

Project Title: NGNP Process Integration – Conventional Gas to Ammonia
File: MA36-M

Page 7 of 7

3. This project is heavily dependent on metals, concrete, petroleum, and petroleum products. Competition for these commodities in today's environment due to global expansion, uncertainty, and product shortages affect the basic concepts of the supply and demand theories, thus increasing costs.
4. Impacts due to large quantities of materials, special alloy materials, fabrication capability, and labor availability could all represent conditions that may increase the total cost of the project.

B. **Opportunities:** *Uncertain events that could improve the results or improve the probability that the desired outcome will happen.*

1. Additional research and work performed with both vendors and potential owner/operators for a specific process or refinery may identify efficiencies and production means that have not been available for use in this analysis.
2. Recent historical data may identify and include technological advancements and efficiencies not included or reflected in the publicly available source data used in this effort.

Note: Contingency does not increase the overall accuracy of the estimate; it does, however, reduce the level of risk associated with the estimate. Contingency is intended to cover the inadequacies in the complete project scope definition, estimating methods, and estimating data. Contingency specifically excludes changes in project scope, unexpected work stoppages (e.g., strikes, disasters, and earthquakes) and excessive or unexpected inflation or currency fluctuations.

VIII. **OTHER COMMENTS/CONCERNS SPECIFIC TO THE ESTIMATE:**

None.

Detail Item Report - Methane Reforming

Project Name: NGNP Process Integration
Process: Conventional Gas to Ammonia
Estimate Number: MA36-M

Client: M. Patterson
Prepared By: B. Wallace, R. Honsinger, J. Martin
Estimate Type: Class 5

Sources Considered:

Source	Reported Capacity	Reported Trains	Report Cost Year	Reported Cost	Reporting Year Cost Per Train	Normalized Cost Per Train using CEPCI Index	Capacity Required	Trains Req'd.	Capacity per Train	Factored Cost per Train from Normalized Cost	Total Current Cost for Required Trains
Natural Gas to Liquids Conversion Project (Raytheon 2000)	150	1	1999	\$ 79,000,000	\$ 79,000,000	\$ 103,553,507	MMS CFD 88	1	MMS CFD 88	\$ 75,196,852	\$ 88,732,286
NETL Natural Gas Report (Choi 1996)	100	1	1996	\$ 22,800,000	\$ 22,800,000	\$ 30,583,181	MMS CFD 88	1	MMS CFD 88	\$ 28,325,152	\$ 28,325,152
Gas Usage & Value The Technology and Economics of Natural Gas Use in the Process Industries (PennWell Corporation 2006)	4,700	2	1985	\$ 168,150,000	\$ 84,075,000	\$ 132,328,312	3,227 tpd	1	3,227 tpd	\$ 160,063,178	\$ 160,063,178
NREL Report (NREL 2006)	183	1	2002	\$ 175,391,586	\$ 175,391,586	\$ 226,998,210	MMS CFD 88	1	MMS CFD 88	\$ 146,395,026	\$ 146,395,026

Source Selected:

Source	Reported Capacity	Reported Trains	Report Cost Year	Reported Cost	Reporting Year Cost Per Train	Normalized Cost Per Train using CEPCI Index	Capacity Required	Trains Req'd.	Capacity per Train	Factored Cost per Train from Normalized Cost	Total Current Cost for Required Trains
Natural Gas to Liquids Conversion Project (Raytheon 2000)	150	1	1999	\$ 79,000,000	\$ 79,000,000	\$ 103,553,507	MMS CFD 88	1	MMS CFD 88	\$ 75,196,852	\$ 88,732,286

Detail Item Report - Methane Reforming

Project Name: NGNP Process Integration
 Process: Conventional Gas to Ammonia
 Estimate Number: MA36-M

Client: M. Patterson
 Prepared By: B. Wallace, R. Honsinger, J. Martin
 Estimate Type: Class 5

Balance of Plant:

Description	Markup				Cost Per Train	Total Cost
Water Systems	7.10%				\$ 5,338,977	\$ 6,299,992
Civil/Structural/Buildings	9.20%				\$ 6,918,110	\$ 8,163,370
Piping	7.10%				\$ 5,338,977	\$ 6,299,992
Control and Instrumentation	2.60%				\$ 1,955,118	\$ 2,307,039
Electrical Systems	8.00%				\$ 6,015,748	\$ 7,098,583
				Total Balance of Plant	\$ 25,566,930	\$ 30,168,977
				Total Balance of Plant Plus the Selected Source	\$ 100,763,782	\$ 118,901,263

Rationale for Selection:

Raytheon 2000 was selected as the most recent cost point, with technology most similar to the intended process. The adjusted PennWell Corporation 2006 cost point concurs with the Raytheon 2000 value. Costs presented in the Raytheon report have been increased by 18% to account for the difference between an autothermal process and traditional steam methane reforming process. The markups listed under 'Balance of Plant' are based on NETL 2006. These markup values are comparable to additional published estimating guides, such as Page 1996.

Note: PennWell Corporation 2006 includes both the natural gas reformer and methanol synthesis units. The average cost for methanol synthesis, as calculated in this report, was subtracted from the total current cost for required trains cell so that this may be considered as a cost point for natural gas reforming. The NREL 2006 cost was scaled from the originally presented value to exclude the cost of the water gas shift reactors.

Detail Item Report - Water Gas Shift Reactor

Project Name: Process: Estimate Number:	NGNP Process Integration Conventional Gas to Ammonia MA36-M	Client: Prepared By: Estimate Type:	M. Patterson B. Wallace, R. Honsinger, J. Martin Class 5
--	--	--	--

Sources Considered:

Source	Reported Capacity	Reported Trains	Report Cost Year	Reported Cost	Reporting Year Cost Per Train	Normalized Cost Per Train using CEPCI Index	Capacity Required	Trains Req'd.	Capacity per Train	Factored Cost per Train from Normalized Cost	Total Current Cost for Required Trains
Hydrogen Report (Gray 2004)	lbmol/hr	1	2004	\$ 23,000,000	\$ 23,000,000	\$ 26,510,581	57,059 /hr	1	57,059 lb/hr	\$ 29,319,270	\$ 29,319,270
Shell IGCC Power Plant with CO2 Capture (NETL 2007b)	1,714,460 lb/hr	4	2006	\$ 12,367,000	\$ 3,091,750	\$ 3,168,487	893,700 lb/hr	1	903,998 lb/hr	\$ 4,958,062	\$ 4,958,062

Source Selected:

Source	Reported Capacity	Reported Trains	Report Cost Year	Reported Cost	Reporting Year Cost Per Train	Normalized Cost Per Train using CEPCI Index	Capacity Required	Trains Req'd.	Capacity per Train	Factored Cost per Train from Normalized Cost	Total Current Cost for Required Trains
Hydrogen Report (Gray 2004)	48,243 lbmol/hr	1	2004	\$ 23,000,000	\$ 23,000,000	\$ 26,510,581	57,059 /hr	1	57,059 lb/hr	\$ 29,319,270	\$ 29,319,270

Balance of Plant:

Description	Markup	Cost Per Train	Total Cost
Water Systems	7.10%	\$ 2,081,668	\$ 2,081,668
Civil/Structural/Buildings	9.20%	\$ 2,697,373	\$ 2,697,373
Piping	7.10%	\$ 2,081,668	\$ 2,081,668
Control and Instrumentation	2.60%	\$ 762,301	\$ 762,301
Electrical Systems	8.00%	\$ 2,345,542	\$ 2,345,542
		\$ 9,968,552	\$ 9,968,552
		\$ 39,287,822	\$ 39,287,822
Total Balance of Plant			
Total Balance of Plant Plus the Selected Source			

Rationale for Selection:

Gray 2004 is the most recent applicable cost available, the capacity per train most closely reflects this project's needs. The markups listed under 'Balance of Plant' are based on NETL 2000. These markup values are comparable to additional published estimating guides, such as Page 1996.

Detail Item Report - Selexol

Project Name: NGNP Process Integration
 Process: Conventional Gas to Ammonia
 Estimate Number: MA36-M
 Client: M. Patterson
 Prepared By: B. Wallace, R. Honsinger, J. Martin
 Estimate Type: Class 5

Sources Considered:

Source	Reported Capacity	Reported Trains	Report Cost Year	Reported Cost	Reporting Year Cost Per Train	Normalized Cost Per Train using CEPCI Index	Capacity Required	Trains Req'd.	Capacity per Train	Factored Cost per Train from Normalized Cost	Total Current Cost for Required Trains
Fluor/UOP Report (Fluor/UOP 2004)	31,226 lbmol/hr	1	2003	\$ 22,862,000	\$ 22,862,000	\$ 29,117,771	41,734 lbmol/hr	1	41,734	\$ 34,653,118	\$ 34,653,118
Co-Production of Hydrogen Presentation (Chiesa 2003)	327 tph	1	2002	\$ 32,800,000	\$ 32,800,000	\$ 42,450,961	149 tph	1	149	\$ 26,516,623	\$ 26,516,623

Source Selected:

Source	Reported Capacity	Reported Trains	Report Cost Year	Reported Cost	Reporting Year Cost Per Train	Normalized Cost Per Train using CEPCI Index	Capacity Required	Trains Req'd.	Capacity per Train	Factored Cost per Train from Normalized Cost	Total Current Cost for Required Trains
Fluor/UOP Report (Fluor/UOP 2004)	31,226 lbmol/hr	1	2003	\$ 22,862,000	\$ 22,862,000	\$ 29,117,771	41,734 lbmol/hr	1	41,734	\$ 34,653,118	\$ 34,653,118

Balance of Plant:

Description	Markup	Cost Per Train	Total Cost
Water Systems	7.10%	\$ 2,460,371	\$ 2,460,371
Civil/Structural/Buildings	9.20%	\$ 3,188,087	\$ 3,188,087
Piping	7.10%	\$ 2,460,371	\$ 2,460,371
Control and Instrumentation	2.60%	\$ 900,981	\$ 900,981
Electrical Systems	8.00%	\$ 2,772,249	\$ 2,772,249
		\$ 11,782,060	\$ 11,782,060
		\$ 46,435,179	\$ 46,435,179
Total of Balance of Plant			
Total of Balance of Plant - Plus the Selected Source			

Rationale for Selection:

Fluor/UOP 2004 was selected as the most recent cost point, because the reported capacity is similar the required capacity per train. The markups listed under 'Balance of Plant' are based on NETL 2000. These markup values are comparable to additional published estimating guides, such as Page 1996.

Detail Item Report - Methanation

Project Name: NGNP Process Integration
Process: Conventional Gas to Ammonia
Estimate Number: MA36-M

Client: M. Patterson
Prepared By: B. Wallace, R. Honsinger, J. Martin
Estimate Type: Class 5

Sources Considered:

Source	Reported Capacity	Reported Trains	Report Cost Year	Reported Cost	Reporting Year Cost Per Train	Normalized Cost Per Train using CEPCI Index	Capacity Required	Trains Req'd.	Capacity per Train	Factored Cost per Train from Normalized Cost	Total Current Cost for Required Trains
DOE FE Report (DOE 1978)	1,000 tpd	1	1978	\$ 1,467,000	\$ 1,467,000	\$ 3,432,834	3,361	1	3,361 tpd	\$ 7,104,506	\$ 7,104,506

Source Selected:

Source	Reported Capacity	Reported Trains	Report Cost Year	Reported Cost	Reporting Year Cost Per Train	Normalized Cost Per Train using CEPCI Index	Capacity Required	Trains Req'd.	Capacity per Train	Factored Cost per Train from Normalized Cost	Total Current Cost for Required Trains
DOE FE Report (DOE 1978)	1,000 tpd	1	1978	\$ 1,467,000	\$ 1,467,000	\$ 3,432,834	3,361	1	3,361 tpd	\$ 7,104,506	\$ 7,104,506

Balance of Plant:

Description	Markup	Cost Per Train	Total Cost
Water Systems		\$ 504,420	\$ 504,420
Civil/Structural/Buildings	7.10%	\$ 653,615	\$ 653,615
Piping	9.20%	\$ 504,420	\$ 504,420
Control and Instrumentation	7.10%	\$ 184,717	\$ 184,717
Electrical Systems	2.60%	\$ 568,360	\$ 568,360
	8.00%	\$ 2,415,532	\$ 2,415,532
		Total Balance of Plant	
		Total Balance of Plant Plus the Selected Source	\$ 9,520,038

Rationale for Selection:

Single source island cost identified by the project technical lead. The markups listed under 'Balance of Plant' are based on NETL 2000. These markup values are comparable to additional published estimating guides, such as Page 19a6

Detail Item Report - CO2 Compression

Project Name: NGNP Process Integration
Process: Conventional Gas to Ammonia
Estimate Number: MA36-M

Client: M. Patterson
Prepared By: B. Wallace, R. Honsinger, J. Martin
Estimate Type: Class 5

Sources Considered:

Source	Reported Capacity	Reported Trains	Report Cost Year	Reported Cost	Reporting Year Cost Per Train	Normalized Cost Per Train using CEPCI Index	Capacity Required	Trains Req'd.	Capacity per Train	Factored Cost per Train from Normalized Cost	Total Current Cost for Required Trains
Subcritical											
Princeton Report (Kreutz 2008)	10	1	2007	\$ 6,310,000	\$ 6,310,000	\$ 6,149,067	11	MW	11	\$ 6,645,555	\$ 6,645,555
Supercritical											
Princeton Report (Kreutz 2008)	13	1	2007	\$ 9,520,000	\$ 9,520,000	\$ 9,277,198	2	MW	2	\$ 2,666,536	\$ 2,666,536

Source Selected:

Source	Reported Capacity	Reported Trains	Report Cost Year	Reported Cost	Reporting Year Cost Per Train	Normalized Cost Per Train using CEPCI Index	Capacity Required	Trains Req'd.	Capacity per Train	Factored Cost per Train from Normalized Cost	Total Current Cost for Required Trains
Kreutz 2008: Combined Subcritical and Supercritical Processes											
										\$ 9,312,091	\$ 9,312,091

Balance of Plant:

Description	Markup	Cost Per Train	Total Cost
Water Systems	7.10%	\$ 661,158	\$ 661,158
Civil/Structural/Buildings	9.20%	\$ 856,712	\$ 856,712
Piping	7.10%	\$ 661,158	\$ 661,158
Control and Instrumentation	2.60%	\$ 242,114	\$ 242,114
Electrical Systems	8.00%	\$ 744,967	\$ 744,967
		\$ 3,166,111	\$ 3,166,111
		\$ 12,478,201	\$ 12,478,201
Total Balance of Plant			
Total Balance of Plant Plus the Selected Source			

Rationale for Selection:

Single source cost point. Both subcritical and supercritical process costs were included under the CO2 Compression heading. The markups listed under 'Balance of Plant' are based on NETL 2000. These markup values are comparable to additional published estimating guides, such as Page 1996.

Detail Item Report - Ammonia Synthesis

Project Name: NGNP Process Integration
Process: Conventional Gas to Ammonia
Estimate Number: MA36-M

Client: M. Patterson
Prepared By: B. Wallace, R. Honsinger, J. Martin
Estimate Type: Class 5

Sources Considered:

Source	Reported Capacity	Reported Trains	Report Cost Year	Reported Cost	Reporting Year Cost Per Train	Normalized Cost Per Train using CEPCI Index	Capacity Required	Trains Req'd.	Capacity per Train	Factored Cost per Train from Normalized Cost	Total Current Cost for Required Trains
Vendor - Verbal 2009	360	1	2009	\$ 44,000,000	\$ 44,000,000	\$ 44,000,000	3,361	2	1,681	\$ 110,900,700	\$ 221,801,399
Economics Ammonia Coal Gasification (Morel 1977)	1,000	1	1977	\$ 50,748,000	\$ 50,748,000	\$ 80,243,904	3,361	2	1,681	\$ 109,565,836	\$ 219,131,673
Stamcarbon, Middle East Fertilizer Symposium, March 2009	4,297	1	2008	\$ 800,000,000	\$ 800,000,000	\$ 779,596,498	3,361	2	1,681	\$ 443,847,499	\$ 887,694,999
Ammonia, Chem Systems, 1998	1,653	1	1998	\$ 160,000,000	\$ 160,000,000	\$ 210,320,924	3,361	2	1,681	\$ 212,413,385	\$ 424,826,770

Source Selected:

Source	Reported Capacity	Reported Trains	Report Cost Year	Reported Cost	Reporting Year Cost Per Train	Normalized Cost Per Train using CEPCI Index	Capacity Required	Trains Req'd.	Capacity per Train	Factored Cost per Train from Normalized Cost	Total Current Cost for Required Trains
Vendor - Verbal 2009	360	1	2009	\$ 44,000,000	\$ 44,000,000	\$ 44,000,000	3,361	2	1,681	\$ 110,900,700	\$ 221,801,399

Balance of Plant:

Description	Markup	Cost Per Train	Total Cost
Water Systems	7.10%	\$ 7,873,950	\$ 15,747,899
Civil/Structural/Buildings	9.20%	\$ 10,202,864	\$ 20,405,729
Piping	7.10%	\$ 7,873,950	\$ 15,747,899
Control and Instrumentation	2.60%	\$ 2,883,418	\$ 5,766,836
Electrical Systems	8.00%	\$ 8,872,056	\$ 17,744,112
		\$ 37,706,238	\$ 75,412,476
		\$ 148,606,938	\$ 297,213,875

Rationale for Selection:

The verbal cost was selected as recommended by the project team expert. The Stamcarbon information shows a roughly 350% increase in prices between 2003 and 2008 emphasizing the importance of using the most recent information available. The markups listed under 'Balance of Plant' are based on NETL 2000. These markup values are comparable to additional published estimating guides, such as Page 1996.

Detail Item Report - Urea Synthesis

Project Name: NGNP Process Integration
Process: Conventional Gas to Ammonia
Estimate Number: MA36-M

Client: M. Patterson
Prepared By: B. Wallace, R. Honsinger, J. Martin
Estimate Type: Class 5

Sources Considered:

Source	Reported Capacity	Reported Trains	Report Cost Year	Reported Cost	Reporting Year Cost Per Train	Normalized Cost Per Train using CEPCI Index	Capacity Required	Trains Req'd.	Capacity per Train	Factored Cost per Train from Normalized Cost	Total Current Cost for Required Trains
Vendor - Verbal 2009	625 tpd	1	2009	\$ 85,000,000	\$ 85,000,000	\$ 85,000,000	2,939 tpd	1	2,939 tpd	\$ 215,184,342	\$ 215,184,342
Perry's Chemical Engineering Handbook, 7th Edition	200 tpd	1	1994	\$ 8,800,000	\$ 8,800,000	\$ 12,240,152	2,939 tpd	1	2,939 tpd	\$ 61,388,719	\$ 61,388,719
PNL	4681 tpd	1	2009	\$ 182,000,000	\$ 182,000,000	\$ 182,000,000	2,939 tpd	1	2,939 tpd	\$ 137,653,721	\$ 137,653,721
Stamcarbon, Middle East Fertilizer Symposium, March 2009	3,582 tpd	1	2008	\$ 550,000,000	\$ 550,000,000	\$ 535,972,592	2,939 tpd	1	2,939 tpd	\$ 475,978,115	\$ 475,978,115

Source Selected:

Source	Reported Capacity	Reported Trains	Report Cost Year	Reported Cost	Reporting Year Cost Per Train	Normalized Cost Per Train using CEPCI Index	Capacity Required	Trains Req'd.	Capacity per Train	Factored Cost per Train from Normalized Cost	Total Current Cost for Required Trains
Vendor - Verbal 2009	625 tpd	1	2009	\$ 85,000,000	\$ 85,000,000	\$ 85,000,000	2,939 tpd	1	2,939 tpd	\$ 215,184,342	\$ 215,184,342

Balance of Plant:

Description	Markup	Cost Per Train	Total Cost
Water Systems	7.10%	\$ 15,278,088	\$ 15,278,088
Civil/Structural/Buildings	9.20%	\$ 19,796,959	\$ 19,796,959
Piping	7.10%	\$ 15,278,088	\$ 15,278,088
Control and Instrumentation	2.60%	\$ 5,594,793	\$ 5,594,793
Electrical Systems	8.00%	\$ 17,214,747	\$ 17,214,747
		\$ 73,162,676	\$ 73,162,676
		\$ 288,347,019	\$ 288,347,019

Rationale for Selection:

The verbal cost was selected as recommended by the project team expert. The Stamcarbon information shows a roughly 350% increase in prices between 2003 and 2008 emphasizing the importance of using the most recent information available. The markups listed under 'Balance of Plant' are based on NETL 2000. These markup values are comparable to additional published estimating guides, such as Page 1996.

Detail Item Report - Nitric Acid Synthesis

Project Name: Process: Estimate Number:	NGNP Process Integration Conventional Gas to Ammonia MA36-M	Client: Prepared By: Estimate Type:	M. Patterson B. Wallace, R. Honsinger, J. Martin Class 5
--	--	--	--

Sources Considered:

Source	Reported Capacity	Reported Trains	Report Cost Year	Reported Cost	Reporting Year Cost Per Train	Normalized Cost Per Train using CEPCI Index	Capacity Required	Trains Req'd.	Capacity per Train	Factored Cost per Train from Normalized Cost	Total Current Cost for Required Trains
Perry's Chemical Engineering Handbook, 7th Edition	334 tpd	1	1994	\$ 6,600,000	\$ 6,600,000	\$ 9,180,114	5,192 tpd	6	865	\$ 16,252,129	\$ 97,512,774
Fertilizer Manual	359.38 tpd	1	1998	\$ 15,200,000	\$ 15,200,000	\$ 19,980,488	5,192 tpd	6	865	\$ 33,851,959	\$ 203,111,753

Source Selected:

Source	Reported Capacity	Reported Trains	Report Cost Year	Reported Cost	Reporting Year Cost Per Train	Normalized Cost Per Train using CEPCI Index	Capacity Required	Trains Req'd.	Capacity per Train	Factored Cost per Train from Normalized Cost	Total Current Cost for Required Trains
Fertilizer Manual	359.38 tpd	1	1998	\$ 15,200,000	\$ 15,200,000	\$ 19,980,488	5,192 tpd	6	865	\$ 33,851,959	\$ 203,111,753

Balance of Plant:

Description	Markup	Cost Per Train	Total Cost
Water Systems	7.10%	\$ 2,403,489	\$ 14,420,934
Civil/Structural/Buildings	9.20%	\$ 3,114,380	\$ 18,686,281
Piping	7.10%	\$ 2,403,489	\$ 14,420,934
Control and Instrumentation	2.60%	\$ 880,151	\$ 5,280,906
Electrical Systems	8.00%	\$ 2,708,157	\$ 16,248,940
		\$ 11,509,666	\$ 69,057,996
		\$ 45,361,625	\$ 272,169,749

Rationale for Selection:

The Fertilizer Manual was selected for being both the newest cost point and the most conservative. The data from Perry's Chemical Engineering Handbook is based on earlier data from Peters and Timmerhaus, making it even less desirable. The markups listed under 'Balance of Plant' are based on NETL 2000. These markup values are comparable to additional published estimating guides, such as Page 1996.

Detail Item Report - Ammonium Nitrate Synthesis

Project Name: NGNP Process Integration Process: Conventional Gas to Ammonia Estimate Number: MA36-M	Client: M. Patterson Prepared By: B. Wallace, R. Honsinger, J. Martin Estimate Type: Class 5	
--	---	--

Sources Considered:

Source	Reported Capacity	Reported Trains	Report Cost Year	Reported Cost	Reporting Year Cost Per Train	Normalized Cost Per Train using CEPCI Index	Capacity Required	Trains Req'd.	Capacity per Train	Factored Cost per Train from Normalized Cost	Total Current Cost for Required Trains
Perry's Chemical Engineering Handbook, 7th Edition	334.0303	1	1994	\$ 6,000,000	\$ 6,000,000	\$ 8,345,558	3,779	3	1,260	\$ 18,507,052	\$ 55,521,157
Fertilizer Manual	1395.24	1	1998	\$ 35,000,000	\$ 35,000,000	\$ 46,007,702	3,779	3	1,260	\$ 43,270,765	\$ 129,812,295
EPA Report	1200	1	1981	\$ 9,480,000	\$ 9,480,000	\$ 13,434,154	3,779	3	1,260	\$ 13,831,044	\$ 41,493,133

Source Selected:

Source	Reported Capacity	Reported Trains	Report Cost Year	Reported Cost	Reporting Year Cost Per Train	Normalized Cost Per Train using CEPCI Index	Capacity Required	Trains Req'd.	Capacity per Train	Factored Cost per Train from Normalized Cost	Total Current Cost for Required Trains
Fertilizer Manual	1395.24	1	1998	\$ 35,000,000	\$ 35,000,000	\$ 46,007,702	3,779	3	1,260	\$ 43,270,765	\$ 129,812,295

Balance of Plant:

Description	Markup	Cost Per Train	Total Cost
Water Systems	7.10%	\$ 3,072,224	\$ 9,216,673
Civil/Structural/Buildings	9.20%	\$ 3,980,910	\$ 11,942,731
Piping	7.10%	\$ 3,072,224	\$ 9,216,673
Control and Instrumentation	2.60%	\$ 1,125,040	\$ 3,375,120
Electrical Systems	8.00%	\$ 3,461,661	\$ 10,384,984
		\$ 14,712,060	\$ 44,136,180
		\$ 57,982,825	\$ 173,948,476

Rationale for Selection:

The Fertilizer Manual was selected for being both the newest cost point and the most conservative. The data from Perry's Chemical Engineering Handbook is based on earlier data from Peters and Timmerhaus, making it even less desirable. The markups listed under 'Balance of Plant' are based on NETL 2000. These markup values are comparable to additional published estimating guides, such as Page 1996.

Client: M. Patterson
Prepared By: B. Wallace, R. Honsinger, J. Martin
Estimate Type: Class 5

Source	Reported Capacity	Reported Trains	Report Cost Year	Reported Cost	Reporting Year Cost Per Train	Normalized Cost Per Train using CEPCI Index	Capacity Required	Trains Req'd.	Capacity per Train	Factored Cost per Train from Normalized Cost	Total Current Cost for Required Trains
Steam Turbine and HRSG											
	189	MW	1	1999	\$ 50,671,000	\$ 50,671,000	29	MW	1	\$ 21,539,455	\$ 21,539,455
Steam Turbine											
	401	MW	4	2006	\$ 74,651,000	\$ 18,662,750	29	MW	1	\$ 9,067,994	\$ 9,067,994
	275	MW	1	2007	\$ 66,700,000	\$ 66,700,000	29	MW	1	\$ 16,820,729	\$ 16,820,729
	230	MW	1	2006	\$ 44,515,000	\$ 44,515,000	29	MW	1	\$ 13,144,232	\$ 13,144,232

[illegible][illegible]

Shell IGCC PowerPlant with CO₂ Capture (NETL 2007b) is a recently reported cost point that closely reflects this project's requirements. The Princeton Report (Kreutz 2008) source for the steam turbine cost point is the NETL 2007b report. The markups listed under 'Balance of Plant' are based on NETL 2000. These markup values are comparable to additional published estimating guides, such as Page 1996.

Client: M. Patterson
Prepared By: B. Wallace, R. Honsinger, J. Martin
Estimate Type: Class 5

Source	Reported Capacity	Reported Trains	Report Cost Year	Reported Cost	Reporting Year Cost Per Train	Normalized Cost Per Train using CEPCI Index	Capacity Required	Trains Req'd.	Capacity per Train	Factored Cost per Train from Normalized Cost	Total Current Cost for Required Trains
Steam Turbine and HRSG											
Shell IGCC Base Cases (NETL 2000)	189	1	1999	\$ 50,671,000	\$ 50,671,000	\$ 66,419,744	29	MW	1	\$ 21,525,776	\$ 21,525,776
HRSG											
NETL Baseline Report (NETL 2007a)	5,155,983	3	2006	\$ 27,581,000	\$ 9,193,667	\$ 9,421,852	-	lb/hr	1	\$ -	\$ -
Princeton Report (Kreutz 2008)	355	1	2007	\$ 52,000,000	\$ 52,000,000	\$ 50,673,772	-	MW	1	\$ -	\$ -
Shell IGCC Power Plant with CO2 Capture (NETL 2007b)	8,438,000	2	2006	\$ 45,291,000	\$ 22,645,500	\$ 23,207,558	-	lb/hr	1	\$ -	\$ -

Source	Reported Capacity	Reported Trains	Report Cost Year	Reported Cost	Reporting Year Cost Per Train	Normalized Cost Per Train using CEPCI Index	Capacity Required	Trains Req'd.	Capacity per Train	Factored Cost per Train from Normalized Cost	Total Current Cost for Required Trains
Shell IGCC Power Plant with CO2 Capture (NETL 2007b)	8,438,000 lb/hr	2	2006	\$ 45,291,000	\$ 22,645,500	\$ 23,207,558	- lb/hr	1	- lb/hr	\$ -	\$ -

[illegible]

Shell IGCC PowerPlant with CO₂ Capture (NETL 2007b) is a recently reported cost point that closely reflects this project's requirements. The Princeton Report (Krautz 2008) source for the steam turbine cost point is the NETL 2007b report. The markups listed under 'Balance of Plant' are based on NETL 2000. These markup values are comparable to additional published estimating guides, such as Page 1996.

Client: M. Patterson
Prepared By: B. Wallace, R. Honsinger, J. Martin
Estimate Type: Class 5

[illegible]

Source	Reported Capacity		Reported Trains	Report Cost Year	Reported Cost	Reporting Year Cost Per Train	Normalized Cost Per Train using CEPCI Index	Capacity Required	Trains Reqd.	Capacity per Train	Factored Cost per Train from Normalized Cost	Total Current Cost for Required Trains
	123,824	gpm										
Cooling Tower Depol			5	2009	\$ 3,141,680	\$ 628,336	\$ 628,336	93,996 gpm	4	23,499 gpm	\$ 608,865	\$ 2,435,459

[illegible]

Single source cost. Publicly available current data. Calculated capital costs based on publicly available cost data from a vendor regularly engaged in the building of cooling towers. The markups listed under 'Balance of Plant' are based on NETL 2000. These markup values are comparable to additional published estimating guides, such as Page 1996.

NGNP Nuclear Gas to Ammonia Summary


Project Name: **NGNP Process Integration**
 Process: **Nuclear Gas to Ammonia**
 Estimate Number: **MA36-N**

Client: **M. Patterson**
 Prepared By: **B. Wallace, R. Honsinger, J. Martin**
 Estimate Type: **Class 5**

Process Component	Subtotal From Detail Sheets	Engineering %	Engineering	Contingency %	Contingency	Total Cost
High Temperature Gas Reactor (HTGR)	\$ 768,613.333	0%	\$ -	0%	\$ -	\$ 768,613.333
Rankine Power Cycle	\$ 90,964.386	10%	\$ 9,096.439	18%	\$ 18,010.948	\$ 118,071.773
Steam Methane Reforming	\$ 105,413.531	10%	\$ 10,541.353	18%	\$ 20,871.879	\$ 136,826.763
Water Gas Shift Reactor	\$ 40,122.232	10%	\$ 4,012.223	18%	\$ 7,944.202	\$ 52,078.657
Selexol	\$ 46,833.260	10%	\$ 4,683.326	18%	\$ 9,272.985	\$ 60,789.571
Methanation	\$ 9,518.338	10%	\$ 951.834	18%	\$ 1,884.631	\$ 12,354.803
CO2 Compression	\$ 12,527.029	10%	\$ 1,252.703	18%	\$ 2,480.352	\$ 16,260.083
Ammonia Synthesis	\$ 297,160.814	10%	\$ 29,716.081	18%	\$ 58,837.841	\$ 385,714.736
Urea Synthesis	\$ 288,347.019	10%	\$ 28,834.702	18%	\$ 57,092.710	\$ 374,274.430
Nitric Acid Synthesis	\$ 272,169.749	10%	\$ 27,216.975	18%	\$ 53,889.610	\$ 353,276.334
Ammonium Nitrate Synthesis	\$ 173,948.476	10%	\$ 17,394.848	18%	\$ 34,441.798	\$ 225,785.122
Steam Turbines	\$ 18,653.382	10%	\$ 1,865.338	18%	\$ 3,693.370	\$ 24,212.090
Heat Recovery Steam Generator (HRSG)	\$ -	10%	\$ -	18%	\$ -	\$ -
Cooling Towers	\$ 3,610.480	10%	\$ 361.048	18%	\$ 714.875	\$ 4,686.404
Total Cost - Nuclear Gas to Ammonia						\$ 2,532,944.099
Total Cost Rounded to the Nearest \$10M						\$ 2,530,000.000

Checked By:  Approved By: 	Remarks
---	---------

COST ESTIMATE SUPPORT DATA RECAPITULATION

Project Title: NGNP Process Integration – Nuclear Gas to Ammonia
Estimator: B. W. Wallace/CEP, R. R. Honsinger/CEP, J. B. Martin/CCT
Date: April 20, 2010
Estimate Type: Class 5
File: MA36-N
Approved By: 

Page 1 of 9

- I. **PURPOSE:** *Brief description of the intent of how the estimate is to be used (i.e., for engineering study, comparative analysis, request for funding, proposal, etc.).*

It is expected that the capital costs identified in these estimates will be used in a model producing an economic analysis for each specific integrated application and subsequently will be considered in a related feasibility study.

- II. **SCOPE OF WORK:** *Brief statement of the project's objective. Thorough overview and description of the proposed project. Identify work to be accomplished, as well as any specific work to be excluded.*

A. **Objective:**

Develop Class 5 estimates as defined by the Association for Advancement of Cost Engineering (AACEi) that will identify the current capital cost associated with high-temperature gas reactors (HTGRs) integrated with a gas-to-ammonia process.

B. **Included:**

The scope of work required to achieve this objective includes the following:

1. Engineering
2. The allowance provided for the HTGR represents a complete and operable system. All elements required for construction of this nuclear reactor capability, including an initial steam generator, security systems, contingency, and owner's costs are included in the turn-key allowance. Owner's costs are included only in the case of the reactor capability. It is considered that the total value represents all inside of battery limits (ISBL) elements, outside of battery limits (OSBL) elements, site development, and all ancillary control and operational functions and capabilities.
3. Construction of a new integrated refinery capability to produce ammonia from natural gas that consists of the following:
 - a. Overnight island-type costs for HTGRs
 - b. Steam methane reformer
 - c. Water gas shift reactors
 - d. Selexol process
 - e. Methanation
 - f. CO₂ compression
 - g. Ammonia synthesis
 - h. Urea synthesis
 - i. Nitric acid synthesis

COST ESTIMATE SUPPORT DATA RECAPITULATION

– Continued –

Project Title: NGNP Process Integration – Nuclear Gas to Ammonia
File: MA36-N

Page 2 of 9

- j. Ammonium nitrate synthesis
- k. Steam turbines, internal to process
- l. Heat recovery steam generator, internal to process
- m. Cooling towers, internal to process
- n. Allowances for Balance of Plant (BOP)/offsite/OSBL, including the following:
 - (1.) Site development/improvements
 - (2.) Provisions for general and administrative buildings and structures
 - (3.) Provisions for OSBL piping
 - (4.) Provisions for OSBL instrumentation and control
 - (5.) Provisions for OSBL electrical
 - (6.) Provisions for facility supply and OSBL water systems
 - (7.) Provisions for site development/improvements
 - (8.) Project/construction management.

C. Excluded:

This scope of work specifically excludes the following elements:

- 1. Licensing and permitting costs
- 2. Operational costs
- 3. Land costs
- 4. Sales taxes
- 5. Royalties
- 6. Owner's fees and owner's costs, except those included for the HTGR
- 7. The allowance provided for the HTGR capability excludes all costs associated with materials development, or costs that would not be appropriately associated with an nth of a kind (NOAK) reactor/facility.

III. ESTIMATE METHODOLOGY: *Overall methodology and rationale of how the estimate was developed (i.e., parametric, forced detail, bottoms up, etc.). Total dollars/hours and rough order magnitude (ROM) allocations of the methodologies used to develop the cost estimate.*

Consistent with the AACEi Class 5 estimates, the level of definition and engineering development available at the time they were prepared, their intended use in a feasibility study, and the time and resources available for their completion, the costs included in this estimate have been developed using parametric evaluations. These evaluations have used publicly available and published project costs to represent similar islands utilized in this project. Analysis and selection of the published costs used have been performed by the project technical lead and Cost Estimating. Suitability for use in this effort was determined considering the correctness and completeness of the data available, the manner in which total capital costs were represented, the age of the previously performed work, and the similarity to the capacity/trains required by this project. The specific sources, selected and used in this cost estimate, are identified in the capital cost estimate detail sheets.

Adjustments have been made to these published costs using escalation factors identified in the Chemical Engineering Price Cost Index. Scaling of the published island costs has been

COST ESTIMATE SUPPORT DATA RECAPITULATION

– Continued –

Project Title: NGNP Process Integration – Nuclear Gas to Ammonia
File: MA36-N

Page 3 of 9

accomplished using the six-tenths capacity factoring method. Costs included for the HTGR and power cycles have been identified and provided by the respective BEA subject matter experts. The total cost for each of these items has been linearly calculated from the respective base unit costs. Any normalization to provide for geographic factors was considered using geographic factors available from RS Means Construction Cost Data references. Cost-estimating relationships have been used to identify allowances to complete the costs.

It was identified to the Next Generation Nuclear Plant (NGNP) Process Integration team that the methodology employed by NGNP to develop the nuclear capability included constituents of parametric modeling, vendor quotes, actual costs, and proprietary costing databases. These preconceptual design estimates were reviewed by NGNP Project Engineering for credibility with regard to assumptions and bases of estimate and performed multiple studies to reconcile variations in the scope and assumptions within the three estimates.

BOP/OSBL costs were determined by the project team, considering data provided by Shell Gasifier IGCC Base Case report NETL 2000, *Conceptual Cost Estimating Manual* Second Edition by John S. Page, and additional adjusted sources. Because the allowances identified did not show significant variability, the allowances identified in the NETL 2000 report were chosen for this effort in order to minimize the mixing of data sources.

IV. BASIS OF THE ESTIMATE: *Overall explanation of sources for resource pricing and schedules.*

A. **Quantification Basis:** *The source for the measurable quantities in the estimate that can be used in support of earned value management. Source documents may include drawings, design reports, engineers' notes, and other documentation upon which the estimate is originated.*

All islands and capacities have been provided to Cost Estimating by the respective project expert.

B. **Planning Basis:** *The source for the execution and strategies of the work that can be used to support the project execution plan, acquisition strategy, schedules, and market conditions and other documentation upon which the estimate is originated.*

1. All islands and HTGRs represent NOAK projects.
2. Projects will be constructed and operated by commercial entities.
3. All projects, with the exception of the Steam-Assisted Gravity Drainage Project, will be located in the U.S. Gulf Coast refinery region.
4. Costs are presented as overnight costs.
5. The cost estimate does not consider or address funding or labor resource restrictions. Sufficient funding and labor resources will be available in a manner that allows optimum usage of the funding and resources as estimated and scheduled.

COST ESTIMATE SUPPORT DATA RECAPITULATION

– Continued –

Project Title: NGNP Process Integration – Nuclear Gas to Ammonia
File: MA36-N

Page 4 of 9

C. **Cost Basis:** *The source for the costing on the estimate that can be used in support of earned value management, funding profiles, and schedule of values. Sources may include published costing references, judgment, actual costs, preliminary quotes or other documentation upon which the estimate is originated.*

1. All costs are represented as current value costs. Factors for forward-looking escalation and inflation factors are not included in this estimate.
2. Where required, published cost factors, as identified in the Chemical Engineering Plant Cost Index, will be applied to previous years' values to determine current year values.
3. Geographic location factors, as identified in RS Means Construction Cost Data reference manual, were considered for each source cost.
4. The cost provided for the HTGR reflects internal BEA cost data that was developed for the HTGR and presented to the NGNP Process Integration team by L. Demmick. Considered in the cost is a pre-conceptual cost estimate prepared by three separate contractor teams. All contractor teams proposed 4-unit NOAK plants with thermal power levels between 2,000 MW_t and 2,400 MW_t at a cost of roughly \$4B, including owner's cost. This equates to \$1,667 to \$2,000 per kW_t. For the purposes of this report, the nominal cost of an HTGR will be set at the upper end of this range, \$2,000 per kW_t. This is a complete turnkey cost and includes engineering and construction of a NOAK HTGR, the power cycle, and contingency. The total HTGR cost for each process is calculated linearly as \$1,708,333 per MW_{th} of required capacity, excluding the cost of the power cycles.
5. The cost included for the power cycle was provided by the INL project team expert. The power cycle cost is based on the definition of a 240-MWe capacity and \$618,176 per MWe. The total power cycle cost for each process is calculated linearly as \$618,176 per MWe of required capacity. BOP, engineering, and contingency costs are added to the base cost.
6. Apt, Jay, et al., *An Engineering-Economic Analysis of Syngas Storage*, NETL, July 2008.
7. AACEi, *Recommended Practices*, website, visited November 16, 2009, <http://www.aacei.org/technical/rp.shtml>.
8. Brown, L. C., et al., "Alternative Flowsheets for the Sulfur-Iodine Thermochemical Hydrogen Cycle," *General Atomics*, February 2003.
9. CEPPI, *Chemical Engineering Magazine*, "Chemical Engineering Plant Cost Index," November 2009: 64.
10. Choi, 1996, Choi, Gerald N., et al, *Design/Economics of a Once-Through Natural Gas Fischer-Tropsch Plant with Power Co-Production*, Bechtel, 1996.
11. Dooley, J., et al, *Carbon Dioxide Capture and Geologic Storage*, Battelle, April 2006.
12. Douglas, Fred R., et al., *Conduction Technical and Economic Evaluations – as Applied for the Process and Utility Industries*, AACEi, April 1991.
13. FLUOR/UOP, 2004, Mak, John Y., et al., *Synthesis Gas Purification in Gasification to Ammonia/Urea Complex*, FLUOR/UOP, 2004.

COST ESTIMATE SUPPORT DATA RECAPITULATION

– Continued –

Project Title: NGNP Process Integration – Nuclear Gas to Ammonia
File: MA36-N

Page 5 of 9

14. Friedland, Robert J., et al., *Hydrogen Production Through Electrolysis*, NREL, June 2002.
15. Gray, 2004, Gray, David, et al, *Polygeneration of SNG, Hydrogen, Power, and Carbon Dioxide from Texas Lignite*, MTR-04, 2004-18, NETL, December 2004.
16. Harvego, E. A., et al., *Economic Analysis of a Nuclear Reactor Powered High-Temperature Electrolysis Hydrogen Production Plant*, INL, August 2008.
17. Harvego, E. A., et al., *Economic Analysis of the Reference Design for a Nuclear-Driven High-Temperature-Electrolysis Hydrogen Production Plant*, INL, January 2008.
18. Ivy, Johanna, *Summary of Electrolytic Hydrogen Production*, NREL September 2004.
19. Ibsen, Kelly, et al., *Equipment Design and Cost Estimation for Small Modular Biomass Systems, Synthesis Gas Cleanup, and Oxygen Separation Equipment*, NREL, May 2006.
20. Klett, Michael G., et al., *The Cost of Mercury Removal in an IGCC Plant*, NETL, September 2002.
21. Kreutz, 2008, Kreutz, Thomas G., et al, “Fischer-Tropsch Fuels from Coal and Biomass,” *25th Annual International Pittsburgh Coal Conference*, Pittsburgh, Princeton University, October 2008.
22. Loh, H. P., et al., *Process Equipment Cost Estimation*, DOE/NETL-2002/1169, NETL, 2002.
23. NETL, 2000, Shelton, W., et al., *Shell Gasifier IGCC Base Cases*, PED-IGCC-98-002, NETL, June 2000.
24. NETL, 2007a, Van Bibber, Lawrence, *Baseline Technical and Economic Assessment of a Commercial Scale Fischer-Tropsch Liquids Facility*, DOE/NETL-207/1260, NETL, April 2007.
25. NETL, 2007b, Woods, Mark C., et al., *Cost and Performance Baseline for Fossil Energy Plants*, NETL, August 2007.
26. NREL, 2005, Saur, Genevieve, *Wind-To-Hydrogen Project: Electrolyzer Capital Cost Study*, NREL, December 2008.
27. O’Brien, J. E., et al., *High-Temperature Electrolysis for Large-Scale Hydrogen and Syngas Production from Nuclear Energy – System Simulation and Economics*, INL, May 2009.
28. O’Brien, J. E., et al., *Parametric Study of Large-Scale Production of Syngas via High-Temperature Co-Electrolysis*, INL, January 2009.
29. Page, John S., *Conceptual Cost Estimating Manual – 2nd ed.*, Houston: Gulf Publishing Company, 1996.
30. Pietlock, Bernard A., et al., *Developing Location Factors by Factoring- as Applied in Architecture, Engineering, Procurement, and Construction*, AACEi, October 2006.
31. Ramsden, Todd, et al., *Current (2005) Hydrogen Production from Central Grid Electrolysis*, NREL, May 2008.
32. Ramsden, Todd, et al., *Longer-Term (2025) Hydrogen Production from Central Grid Electrolysis*, NREL, May 2008.

COST ESTIMATE SUPPORT DATA RECAPITULATION

– Continued –

Project Title: NGNP Process Integration – Nuclear Gas to Ammonia
File: MA36-N

Page 6 of 9

33. Richardson Construction Estimating Standards, *Process Plant Cooling Towers*, Cost Data Online, September 16, 2009, website, visited December 15, 2009, <http://www.costdataonline.com/>.
34. Sohal, M. S., et al., *Challenges in Generating Hydrogen by High Temperature Electrolysis Using Solid Oxide Cells*, INL, March 2008.
35. Steinberg, Meyer, *Conversion of Coal to Substitute Natural Gas (SNG)*, HCE, 2005.
36. Udengaard, 2008, Udengaard, Niels R., et al., *Convert Coal, petcoke into valuable SNG*, Haldor Topsoe, April 2008.
37. van der Ploeg, H. J., et al., *The Shell Coal Gasification Process for the US Industry*, Shell, October 2004.
38. WorleyParsons, 2002, Rameshni, Mahin, *Cost Effective Options to Expand SRU Capacity Using Oxygen*, WorleyParsons, May 2002.

V. **ESTIMATE QUALITY ASSURANCE:** *A listing of all estimate reviews that have taken place and the actions taken from those reviews.*

A review of the cost estimate was held on January 14, 2010, with the project team and the cost estimators. This review allowed for the project team to review and comment, in detail, on the perceived scope, basis of estimates, assumptions, project risks, and resources that make up this cost estimate. Comments from this review have been incorporated into this estimate to reflect a project team consensus of this document.

VI. **ASSUMPTIONS:** *Condition statements accepted or supposed true without proof of demonstration; statements adding clarification to scope. An assumption has a direct impact on total estimated cost.*

General Assumptions:

- A. All costs are represented in 2009 values.
- B. Costs that were included from sources representing years prior to 2009 have been normalized to 2009 values using the Chemical Engineering Plant Cost Index. This index was selected due to its widespread recognition and acceptance and its specific orientation toward work associated with chemical and refinery plants.
- C. Capital costs are based on process islands. The majority of these islands are interchangeable, after factoring for the differing capacities, flowsheet-to-flowsheet.
- D. All chemical processing and refinery processes will be located in the U.S. Gulf Coast region.
- E. All costs considered to be BOP costs that can be specifically identified have been factored out of the reported source data and added into the estimate in a manner consistent with that identified in the NETL 2000 IGCC Base Cost report. Inclusion of the source costs in this manner normalizes all reported cost information to the bare-erected costs.

HTGR:

- A. The linearly scalable cost included for an HTGR reflects an NOAK reactor with a 750°C-operating temperature.

COST ESTIMATE SUPPORT DATA RECAPITULATION

– Continued –

Project Title: NGNP Process Integration – Nuclear Gas to Ammonia
File: MA36-N

Page 7 of 9

- B. HTGR is considered to be linearly scalable, by required capacity, per the direction of the project team. This allows the process integration feasibility studies to showcase the financial analysis of the process without the added burden of integer quantity 600-MWth HTGRs.
- C. The allowance represents a turnkey condition for the reactor and its supporting infrastructure.
- D. A high-temperature, high-pressure steam generator is included in the cost represented for HTGR.
- E. A contingency allowance is included in the HTGR cost, but is not identified as a separate line item in this estimate. This allowance was identified and included by the NGNP HTGR project team.
- F. Total cost range, including contingency, for HTGR is -50%, +100%.
- G. Cost included for the power cycle reflects NOAK research and manufacturing developments to allow for assumed high pressures and temperatures.
- H. The power cycle is considered to be linearly scalable, by required capacity, per the direction of the project team. This allows the process integration feasibility studies to showcase the financial analysis of the process.

Gas to Ammonia

The NREL 2006 report presented the steam methane reformer cost with the cost of the water gas shift reactors. This cost was normalized to exclude the cost of the water gas shift reactors.

VII. CONTINGENCY GUIDELINE IMPLEMENTATION:

Contingency Methodologies: *Explanation of methodology used in determining overall contingency. Identify any specific drivers or items of concern.*

At a project risk review on December 9, 2009, the project team discussed risks to the project. An 18% allowance for capital construction contingency has been included at an island level based on the discussion and is included in the summary sheet. The contingency level that was included in the island cost source documents and additional threats and opportunities identified here were considered during this review. The contingency identified was considered by the project team and included in Cost and Performance Baseline for Fossil Energy Plants DOE/NETL-2007/1281 and similar reports. Typically, contingency allowance provided in these reports ranged from 15% to 20%. Since much of the data contained in this estimate has been derived from these reports, the project team has also chosen a level of contingency consistent with them.

While the level of contingency provided for the HTGR capability is not identified as a line item, the cost data provided to the NGNP Process Integration team was identified as including an appropriate allocation for contingency. No additional contingency has been added to this element.

COST ESTIMATE SUPPORT DATA RECAPITULATION

– Continued –

Project Title: NGNP Process Integration – Nuclear Gas to Ammonia
File: MA36-N

Page 8 of 9

A. **Threats:** *Uncertain events that are potentially negative or reduce the probability that the desired outcome will happen.*

1. The singularly largest threat to this estimate surrounds the lump sum cost included for the HTGR reactor(s). While the overriding assumption is that the HTGR will be NOAK, currently, a complete HTGR has not been commissioned.
2. The level of project definition/development that was available at the time the estimate was prepared represents a substantial risk to the project and is likely to occur. The high level at which elements were considered and included has the potential to include additional elements that are within the work scope but not sufficiently provided for or addressed at this level.
3. The estimate methodology employed is one of a stochastic parametrically evaluated process. This process used publicly available published costs that were related to the process required, costs were normalized using price indices, and the cost was scaled to provide the required capacity. The cost-estimating relationships that were used represent typical costs for BOP allowances, but source cost data from which the initial island costs were derived were not completely descriptive of the elements included, not included, or simply referred to with different nomenclature or combined with other elements. While every effort has been made to correctly normalize and factor the costs for use in this effort, the risk exists that not all of these were correctly captured due to the varied information available.
4. This project is heavily dependent on metals, concrete, petroleum, and petroleum products. Competition for these commodities in today's environment due to global expansion, uncertainty, and product shortages affect the basic concepts of the supply and demand theories, thus increasing costs.
5. Impacts due to large quantities of materials, special alloy materials, fabrication capability, and labor availability could all represent conditions that may increase the total cost of the project.

B. **Opportunities:** *Uncertain events that could improve the results or improve the probability that the desired outcome will happen.*

1. Additional research and work performed with both vendors and potential owner/operators for a specific process or refinery may identify efficiencies and production means that have not been available for use in this analysis.
2. Recent historical data may identify and include technological advancements and efficiencies not included or reflected in the publicly available source data used in this effort.

Note: Contingency does not increase the overall accuracy of the estimate; it does, however, reduce the level of risk associated with the estimate. Contingency is intended to cover the inadequacies in the complete project scope definition, estimating methods, and estimating data. Contingency specifically excludes changes in project scope, unexpected work

COST ESTIMATE SUPPORT DATA RECAPITULATION

– Continued –

Project Title: NGNP Process Integration – Nuclear Gas to Ammonia
File: MA36-N

Page 9 of 9

stoppages (e.g., strikes, disasters, and earthquakes) and excessive or unexpected inflation or currency fluctuations.

VIII. **OTHER COMMENTS/CONCERNS SPECIFIC TO THE ESTIMATE:**

None.

Client: M. Patterson
Prepared By: B. Wallace, R. Honsinger, J. Martin
Estimate Type: Class 5

Detail Item Report - Rankine Cycle - Case 11, Supercritical PC Case

Project Name: NGNP Process Integration
Process: Nuclear Gas to Ammonia
Estimate Number: MA36-N

Client: M. Patterson
Prepared By: B. Wallace, R. Honsinger, J. Martin
Estimate Type: Class 5

Sources Considered:

Source	Reported Capacity	Reported Trains	Report Cost Year	Reported Cost	Reporting Year Cost Per Train	Normalized Cost Per Train using CEPCI Index	Capacity Required	Trains Req'd.	Capacity per Train	Factored Cost per Train from Normalized Cost	Total Current Cost for Required Trains
INL Internal Cost Data (INL 2009)	240	MWe	1	2009	\$ 148,362,255	\$ 148,362,255	106	MWe	1	MWe \$ 90,964,386	\$ 90,964,386

Summary:

Source	Reported Capacity	Reported Trains	Report Cost Year	Reported Cost	Reporting Year Cost Per Train	Normalized Cost Per Train using CEPCI Index	Capacity Required	Trains Req'd.	Capacity per Train	Factored Cost per Train from Normalized Cost	Total Current Cost for Required Trains
INL Internal Cost Data (INL 2009)	240	MWe	1	2009	\$ 148,362,255	\$ 148,362,255	106	MWe	1	MWe \$ 90,964,386	\$ 90,964,386

Balance of Plant:

Description	% of Total Cost	Cost Per Train	Total Cost
Water Systems	0.00%	\$ -	\$ -
Civil/Structural/Buildings	0.00%	\$ -	\$ -
Piping	0.00%	\$ -	\$ -
Control and Instrumentation	0.00%	\$ -	\$ -
Electrical Systems	0.00%	\$ -	\$ -
		Total Balance of Plant	\$ -
		Total Balance of Plant Plus the Selected Source	\$ 90,964,386

Basis of Estimate Notes:

Single source cost. The reported costs are from the INL project team expert. The reported cost represents a Rankine power cycle, excluding the steam generator. The cost is based on information found in NETL 2007b, which has been adjusted and customized for this project by the INL project team expert. The allowances listed under 'Balance of Plant' are based on NETL 2000. These allowance values are comparable to additional published estimating guides, such as Page 1996. The allowances have been adjusted and customized for this project based on estimator judgment. The reduced civil/structural/buildings allowance accounts for the buildings that are included in the Rankine power cycle cost. Water and electrical systems BOP allowances are included in the reported cost for the Rankine power cycle.

Detail Item Report - Methane Reforming

Project Name: NGNP Process Integration
Process: Nuclear Gas to Ammonia
Estimate Number: MA36-N

Client: M. Patterson
Prepared By: B. Wallace, R. Honsinger, J. Martin
Estimate Type: Class 5

Sources Considered:

Source	Reported Capacity	Reported Trains	Report Cost Year	Reported Cost	Reporting Year Cost Per Train	Normalized Cost Per Train using CEPCI Index	Capacity Required	Trains Req'd.	Capacity per Train	Factored Cost per Train from Normalized Cost	Total Current Cost for Required Trains
Natural Gas to Liquids Conversion Project (Raytheon 2000)	150	1	1999	\$ 79,000,000	\$ 79,000,000	\$ 103,553,507	72	MMS CFD 1	72	66,666,792	\$ 78,666,814
NETL Natural Gas Report (Choi 1996)	100	1	1996	\$ 22,800,000	\$ 22,800,000	\$ 30,583,181	72	MMS CFD 1	72	25,112,049	\$ 25,112,049
Gas Usage & Value The Technology and Economics of Natural Gas Use in the Process Industries (PennWell Corporation 2006)	4,700	2	1985	\$ 168,150,000	\$ 84,075,000	\$ 132,328,312	2,538	tpd	1,269	91,430,065	\$ 182,860,130
NREL Report (NREL 2006)	183	1	2002	\$ 175,391,586	\$ 175,391,586	\$ 226,998,210	72	MMS CFD 2	36	85,572,315	\$ 171,144,630

Source Selected:

Source	Reported Capacity	Reported Trains	Report Cost Year	Reported Cost	Reporting Year Cost Per Train	Normalized Cost Per Train using CEPCI Index	Capacity Required	Trains Req'd.	Capacity per Train	Factored Cost per Train from Normalized Cost	Total Current Cost for Required Trains
Natural Gas to Liquids Conversion Project (Raytheon 2000)	150	1	1999	\$ 79,000,000	\$ 79,000,000	\$ 103,553,507	72	MMS CFD 1	72	66,666,792	\$ 78,666,814

Balance of Plant:

Description	% of Total Cost	Cost Per Train	Total Cost
Water Systems	7.10%	\$ 4,733,342	\$ 5,585,344
Civil/Structural/Buildings	9.20%	\$ 6,133,345	\$ 7,237,347
Piping	7.10%	\$ 4,733,342	\$ 5,585,344
Control and Instrumentation	2.60%	\$ 1,733,337	\$ 2,045,337
Electrical Systems	8.00%	\$ 5,333,343	\$ 6,293,345
		\$ 22,666,709	\$ 26,746,717
		\$ 89,333,501	\$ 105,413,531

Rationale for Selection:

Raytheon 2000 was selected as the most recent cost point, with technology most similar to the intended process. The adjusted PennWell Corporation 2006 cost point concurs with the Raytheon 2000 value. Costs presented in the Raytheon report have been increased by 18% to account for the difference between an autothermal process and traditional steam methane reforming process. The allowances listed under 'Balance of Plant' are based on NETL 2000. These allowance values are comparable to additional published estimating guides, such as Page 1996.

Note: PennWell Corporation 2006 includes both the natural gas reformer and methanol synthesis units. The average cost for methanol synthesis, as calculated in this report, was subtracted from the total current cost for required trains cell so that this may be considered as a cost point for natural gas reforming. The NREL 2006 cost was scaled from the originally presented value to exclude the cost of the water gas shift reactors.

Client: M. Patterson
Prepared By: B. Wallace, R. Honsinger, J. Martin
Estimate Type: Class 5

Source	Reported Capacity	Reported Trains	Report Cost Year	Reported Cost	Reporting Year	Normalized Cost Per Train using CEPCI Index	Capacity Required	Trains Req'd.	Capacity per Train	Factored Cost per Train from Normalized Cost	Total Current Cost for Required Trains
Princeton Report (Kreutz 2008)	MMB TU/day						MMB TU/day				
	66,742	1	2007	\$ 11,760,000	\$ 11,760,000	\$ 11,460,069	-	1	-	\$ -	\$ -
	48,243	1	2004	\$ 23,000,000	\$ 23,000,000	\$ 26,510,581	59,093 lbmol/hr	1	59,093	\$ 29,941,964	\$ 29,941,964
Shell IGCC Power Plant with CO2 Capture (NETL 2007b)	1,714,460	4	2006	\$ 12,367,000	\$ 3,091,750	\$ 3,168,487	941,756 lb/hr	1	941,756	\$ 5,081,296	\$ 5,081,296

Source	Reported Capacity	Reported Trains	Report Cost Year	Reported Cost	Reporting Year Cost Per Train	Normalized Cost Per Train using CEPCI Index	Capacity Required	Trains Regd.	Capacity per Train	Factored Cost per Train from Normalized Cost	Total Current Cost for Required Trains
Hydrogen Report (Grav 2004)	48,243	1	2004	\$ 23,000,000	\$ 23,000,000	\$ 26,510,581	lbmol/hr		lbmol/hr	\$ 29,941,964	\$ 29,941,964
	59,093						1	59,093			

[illegible]

Hydrogen Report (Gray 2004) has been selected for use based on the advice of the technical lead. It is considered to be the most similar in design and function to the water gas shift required for this project. The allowances listed under 'Balance of Plant' are based on NETL 2000. These allowance values are comparable to additional published estimating guides, such as Page 1996.

Detail Item Report - Selexol

Project Name: NGNP Process Integration
 Process: Nuclear Gas to Ammonia
 Estimate Number: MA36-N

Client: M. Patterson
 Prepared By: B. Wallace, R. Honsinger, J. Martin
 Estimate Type: Class 5

Sources Considered:

Source	Reported Capacity	Reported Trains	Report Cost Year	Reported Cost	Reporting Year Cost Per Train	Normalized Cost Per Train using CEPCI Index	Capacity Required	Trains Req'd.	Capacity per Train	Factored Cost per Train from Normalized Cost	Total Current Cost for Required Trains
Fluor/UOP Report (Fluor/UOP 2004)	31,226 lbmol/hr	1	2003	\$ 22,862,000	\$ 22,862,000	\$ 29,117,771	42,332 lbmo/lhr	1	42,332 lbmol/hr	\$ 34,950,194	\$ 34,950,194
Co-Production of Hydrogen Presentation (Chiesa 2003)	327 tph	1	2002	\$ 32,800,000	\$ 32,800,000	\$ 42,450,961	150 tph	1	150 tph	\$ 26,615,433	\$ 26,615,433

Source Selected:

Source	Reported Capacity	Reported Trains	Report Cost Year	Reported Cost	Reporting Year Cost Per Train	Normalized Cost Per Train using CEPCI Index	Capacity Required	Trains Req'd.	Capacity per Train	Factored Cost per Train from Normalized Cost	Total Current Cost for Required Trains
Fluor/UOP Report (Fluor/UOP 2004)	31,226 lbmol/hr	1	2003	\$ 22,862,000	\$ 22,862,000	\$ 29,117,771	42,332 lbmo/lhr	1	42,332 lbmol/hr	\$ 34,950,194	\$ 34,950,194

Balance of Plant:

Description	% of Total Cost	Cost Per Train	Total Cost
Water Systems	7.10%	\$ 2,481,464	\$ 2,481,464
Civil/Structural/Buildings	9.20%	\$ 3,215,418	\$ 3,215,418
Piping	7.10%	\$ 2,481,464	\$ 2,481,464
Control and Instrumentation	2.60%	\$ 908,705	\$ 908,705
Electrical Systems	8.00%	\$ 2,796,015	\$ 2,796,015
		\$ 11,883,066	\$ 11,883,066
		\$ 46,833,260	\$ 46,833,260
		Total Balance of Plant	
		Total Balance of Plant Plus the Selected Source	

Rationale for Selection:

Fluor/UOP 2004 was selected as the most recent cost point, because the reported capacity is similar the required capacity per train. The allowances listed under 'Balance of Plant' are based on NETL 2000. These allowance values are comparable to additional published estimating guides, such as Page 1996.

Detail Item Report - Methanation

Project Name: NGNP Process Integration
Process: Nuclear Gas to Ammonia
Estimate Number: MA36-N

Client: M. Patterson
Prepared By: B. Wallace, R. Honsinger, J. Martin
Estimate Type: Class 5

Sources Considered:

Source	Reported Capacity	Reported Trains	Report Cost Year	Reported Cost	Reporting Year Cost Per Train	Normalized Cost Per Train using CEPCI Index	Capacity Required	Trains Req'd.	Capacity per Train	Factored Cost per Train from Normalized Cost	Total Current Cost for Required Trains
DOE FE Report (DOE 1978)	1,000 tpd	1	1978	\$ 1,467,000	\$ 1,467,000	\$ 3,432,834	3,360	1	3,360 tpd	\$ 7,103,237	\$ 7,103,237

Source Selected:

Source	Reported Capacity	Reported Trains	Report Cost Year	Reported Cost	Reporting Year Cost Per Train	Normalized Cost Per Train using CEPCI Index	Capacity Required	Trains Req'd.	Capacity per Train	Factored Cost per Train from Normalized Cost	Total Current Cost for Required Trains
DOE FE Report (DOE 1978)	1,000 tpd	1	1978	\$ 1,467,000	\$ 1,467,000	\$ 3,432,834	3,360	1	3,360 tpd	\$ 7,103,237	\$ 7,103,237

Balance of Plant:

Description	% of Total Cost	Cost Per Train	Total Cost
Water Systems	7.10%	\$ 504,330	\$ 504,330
Civil/Structural/Buildings	9.20%	\$ 653,498	\$ 653,498
Piping	7.10%	\$ 504,330	\$ 504,330
Control and Instrumentation	2.60%	\$ 184,684	\$ 184,684
Electrical Systems	8.00%	\$ 568,259	\$ 568,259
		Total Balance of Plant	\$ 2,415,101
		Total Balance of Plant Plus the Selected Source	\$ 9,518,338

Rationale for Selection:

Single source island cost identified by the project technical lead. The allowances listed under 'Balance of Plant' are based on NETL 2000. These allowance values are comparable to additional published estimating guides, such as Page 1996.

Detail Item Report - CO2 Compression

Project Name: NGNP Process Integration
Process: Nuclear Gas to Ammonia
Estimate Number: MA36-N

Client: M. Patterson
Prepared By: B. Wallace, R. Honsinger, J. Martin
Estimate Type: Class 5

Sources Considered:

Source	Reported Capacity	Reported Trains	Report Cost Year	Reported Cost	Reporting Year Cost Per Train	Normalized Cost Per Train using CEPCI Index	Capacity Required	Trains Req'd.	Capacity per Train	Factored Cost per Train from Normalized Cost	Total Current Cost for Required Trains
Subcritical											
Princeton Report (Kreutz 2008)	10	1	2007	\$ 6,310,000	\$ 6,310,000	\$ 6,149,067	11	MW	11	\$ 6,671,585	\$ 6,671,585
Supercritical											
Princeton Report (Kreutz 2008)	13	1	2007	\$ 9,520,000	\$ 9,520,000	\$ 9,277,198	2	MW	2	\$ 2,676,943	\$ 2,676,943

Source Selected:

Source	Reported Capacity	Reported Trains	Report Cost Year	Reported Cost	Reporting Year Cost Per Train	Normalized Cost Per Train using CEPCI Index	Capacity Required	Trains Req'd.	Capacity per Train	Factored Cost per Train from Normalized Cost	Total Current Cost for Required Trains
Kreutz 2008: Combined Subcritical and Supercritical Processes											
										\$ 9,348,529	\$ 9,348,529

Balance of Plant:

Description	% of Total Cost	Cost Per Train	Total Cost
Water Systems	7.10%	\$ 663,746	\$ 663,746
Civil/Structural/Buildings	9.20%	\$ 860,065	\$ 860,065
Piping	7.10%	\$ 663,746	\$ 663,746
Control and Instrumentation	2.60%	\$ 243,062	\$ 243,062
Electrical Systems	8.00%	\$ 747,882	\$ 747,882
		Total Balance of Plant	\$ 3,178,500
		Total Balance of Plant Plus the Selected Source	\$ 12,527,029

Rationale for Selection:

Single source cost point. Both subcritical and supercritical process costs were included under the CO2 Compression heading. The allowances listed under 'Balance of Plant' are based on NETL 2000. These allowance values are comparable to additional published estimating guides, such as Page 1996.

Detail Item Report - Ammonia Synthesis

Project Name: NGNP Process Integration
 Process: Nuclear Gas to Ammonia
 Estimate Number: MA36-N

Client: M. Patterson
 Prepared By: B. Wallace, R. Honsinger, J. Martin
 Estimate Type: Class 5

Sources Considered:

Source	Reported Capacity	Reported Trains	Report Cost Year	Reported Cost	Reporting Year Cost Per Train	Normalized Cost Per Train using CEPCI Index	Capacity Required	Trains Req'd.	Capacity per Train	Factored Cost per Train from Normalized Cost	Total Current Cost for Required Trains
Vendor - Verbal 2009	360	1	2009	\$ 44,000,000	\$ 44,000,000	\$ 44,000,000	3,360	2	1,680	\$ 110,880,901	\$ 221,761,801
Economics Ammonia Coal Gasification (Morel 1977)	1,000	1	1977	\$ 50,748,000	\$ 50,748,000	\$ 80,243,904	3,360	2	1,680	\$ 109,546,276	\$ 219,092,551
Stamcarbon, Middle East Fertilizer Symposium, March 2009	4,297	1	2008	\$ 800,000,000	\$ 800,000,000	\$ 779,596,498	3,360	2	1,680	\$ 443,768,260	\$ 887,536,519
Ammonia, Chem Systems, 1998	1,653	1	1998	\$ 160,000,000	\$ 160,000,000	\$ 210,320,924	3,360	2	1,680	\$ 212,375,463	\$ 424,750,926

Source Selected:

Source	Reported Capacity	Reported Trains	Report Cost Year	Reported Cost	Reporting Year Cost Per Train	Normalized Cost Per Train using CEPCI Index	Capacity Required	Trains Req'd.	Capacity per Train	Factored Cost per Train from Normalized Cost	Total Current Cost for Required Trains
Vendor - Verbal 2009	360	1	2009	\$ 44,000,000	\$ 44,000,000	\$ 44,000,000	3,360	2	1,680	\$ 110,880,901	\$ 221,761,801

Balance of Plant:

Description	% of Total Cost	Cost Per Train	Total Cost
Water Systems	7.10%	\$ 7,872,544	\$ 15,745,088
Civil/Structural/Buildings	9.20%	\$ 10,201,043	\$ 20,402,086
Piping	7.10%	\$ 7,872,544	\$ 15,745,088
Control and Instrumentation	2.60%	\$ 2,882,903	\$ 5,765,807
Electrical Systems	8.00%	\$ 8,870,472	\$ 17,740,944
		Total Balance of Plant	\$ 37,699,506
		Total Balance of Plant Plus the Selected Source	\$ 148,580,407
			\$ 297,160,814

Rationale for Selection:

The verbal cost was selected as recommended by the project team expert. The Stamcarbon information shows a roughly 350% increase in prices between 2003 and 2008 emphasizing the importance of using the most recent information available. The allowances listed under 'Balance of Plant' are based on NETL 2000. These allowance values are comparable to additional published estimating guides, such as Page 1996.

Detail Item Report - Urea Synthesis

Project Name: NGNP Process Integration
Process: Nuclear Gas to Ammonia
Estimate Number: MA36-N

Client: M. Patterson
Prepared By: B. Wallace, R. Honsinger, J. Martin
Estimate Type: Class 5

Sources Considered:

Source	Reported Capacity	Reported Trains	Report Cost Year	Reported Cost	Reporting Year Cost Per Train	Normalized Cost Per Train using CEPCI Index	Capacity Required	Trains Req'd.	Capacity per Train	Factored Cost per Train from Normalized Cost	Total Current Cost for Required Trains
Vendor - Verbal 2009	625	1	2009	\$ 85,000,000	\$ 85,000,000	\$ 85,000,000	2,939	1	2,939	\$ 215,184,342	\$ 215,184,342
Perry's Chemical Engineering Handbook, 7th Edition	200	1	1994	\$ 8,800,000	\$ 8,800,000	\$ 12,240,152	2,939	1	2,939	\$ 61,388,719	\$ 61,388,719
PNL	4881	1	2009	\$ 182,000,000	\$ 182,000,000	\$ 182,000,000	2,939	1	2,939	\$ 137,653,721	\$ 137,653,721
Stamcarbon, Middle East Fertilizer Symposium, March 2009	3,582	1	2008	\$ 550,000,000	\$ 550,000,000	\$ 535,972,592	2,939	1	2,939	\$ 475,978,115	\$ 475,978,115

Source Selected:

Source	Reported Capacity	Reported Trains	Report Cost Year	Reported Cost	Reporting Year Cost Per Train	Normalized Cost Per Train using CEPCI Index	Capacity Required	Trains Req'd.	Capacity per Train	Factored Cost per Train from Normalized Cost	Total Current Cost for Required Trains
Vendor - Verbal 2009	625	1	2009	\$ 85,000,000	\$ 85,000,000	\$ 85,000,000	2,939	1	2,939	\$ 215,184,342	\$ 215,184,342

Balance of Plant:

Description	% of Total Cost	Cost Per Train	Total Cost
Water Systems	7.10%	\$ 15,278,088	\$ 15,278,088
Civil/Structural/Buildings	9.20%	\$ 19,796,959	\$ 19,796,959
Piping	7.10%	\$ 15,278,088	\$ 15,278,088
Control and Instrumentation	2.60%	\$ 5,594,793	\$ 5,594,793
Electrical Systems	8.00%	\$ 17,214,747	\$ 17,214,747
		\$ 73,162,676	\$ 73,162,676
		\$ 288,347,019	\$ 288,347,019

Rationale for Selection:

The verbal cost was selected as recommended by the project team expert. The Stamcarbon information shows a roughly 350% increase in prices between 2003 and 2008 emphasizing the importance of using the most recent information available. The allowances listed under 'Balance of Plant' are based on NETL 2000. These allowance values are comparable to additional published estimating guides, such as Page 1996.

Detail Item Report - Nitric Acid Synthesis

Project Name: NGNP Process Integration
Process: Nuclear Gas to Ammonia
Estimate Number: MA36-N

Client: M. Patterson
Prepared By: B. Wallace, R. Honsinger, J. Martin
Estimate Type: Class 5

Sources Considered:

Source	Reported Capacity	Reported Trains	Report Cost Year	Reported Cost	Reporting Year Cost Per Train	Normalized Cost Per Train using CEPCI Index	Capacity Required	Trains Req'd.	Capacity per Train	Factored Cost per Train from Normalized Cost	Total Current Cost for Required Trains
Perry's Chemical Engineering Handbook, 7th Edition	334 tpd	1	1994	\$ 6,600,000	\$ 6,600,000	\$ 9,180,114	5,192 tpd	6	865	\$ 16,251,244	\$ 97,507,466
Fertilizer Manual	359 tpd	1	1998	\$ 15,200,000	\$ 15,200,000	\$ 19,980,488	5,192 tpd	6	865	\$ 33,851,959	\$ 203,111,753

Source Selected:

Source	Reported Capacity	Reported Trains	Report Cost Year	Reported Cost	Reporting Year Cost Per Train	Normalized Cost Per Train using CEPCI Index	Capacity Required	Trains Req'd.	Capacity per Train	Factored Cost per Train from Normalized Cost	Total Current Cost for Required Trains
Fertilizer Manual	359 tpd	1	1998	\$ 15,200,000	\$ 15,200,000	\$ 19,980,488	5,192 tpd	6	865	\$ 33,851,959	\$ 203,111,753

Balance of Plant:

Description	% of Total Cost	Cost Per Train	Total Cost
Water Systems	7.10%	\$ 2,403,489	\$ 14,420,934
Civil/Structural/Buildings	9.20%	\$ 3,114,380	\$ 18,686,281
Piping	7.10%	\$ 2,403,489	\$ 14,420,934
Control and Instrumentation	2.60%	\$ 880,151	\$ 5,280,906
Electrical Systems	8.00%	\$ 2,708,157	\$ 16,248,940
		\$ 11,509,666	\$ 69,057,996
		\$ 45,361,625	\$ 272,169,749
Total Balance of Plant			
Total Balance of Plant Plus the Selected Source			

Rationale for Selection:

The Fertilizer Manual was selected for being both the newest cost point and the most conservative. The data from Perry's Chemical Engineering Handbook is based on earlier data from Peters and Timmerhaus, making it even less desirable. The allowances listed under 'Balance of Plant' are based on NETL 2000. These allowance values are comparable to additional published estimating guides, such as Page 1996.

Detail Item Report - Ammonium Nitrate Synthesis

Project Name: NGNP Process Integration Process: Nuclear Gas to Ammonia Estimate Number: MA36-N	Client: M. Patterson Prepared By: B. Wallace, R. Honsinger, J. Martin Estimate Type: Class 5	
---	---	--

Sources Considered:

Source	Reported Capacity	Reported Trains	Report Cost Year	Reported Cost	Reporting Year Cost Per Train	Normalized Cost Per Train using CEPCI Index	Capacity Required	Trains Req'd.	Capacity per Train	Factored Cost per Train from Normalized Cost	Total Current Cost for Required Trains
Perry's Chemical Engineering Handbook, 7th Edition	334 tpd	1	1994	\$ 6,000,000	\$ 6,000,000	\$ 8,345,558	3,779 tpd	3	1,260 tpd	\$ 18,507,052	\$ 55,521,157
Fertilizer Manual	1,395 tpd	1	1998	\$ 35,000,000	\$ 35,000,000	\$ 46,007,702	3,779 tpd	3	1,260 tpd	\$ 43,270,765	\$ 129,812,295
EPA Report	1,200 tpd	1	1981	\$ 9,480,000	\$ 9,480,000	\$ 13,434,154	3,779 tpd	3	1,260 tpd	\$ 13,831,044	\$ 41,493,133

Source Selected:

Source	Reported Capacity	Reported Trains	Report Cost Year	Reported Cost	Reporting Year Cost Per Train	Normalized Cost Per Train using CEPCI Index	Capacity Required	Trains Req'd.	Capacity per Train	Factored Cost per Train from Normalized Cost	Total Current Cost for Required Trains
Fertilizer Manual	1,395 tpd	1	1998	\$ 35,000,000	\$ 35,000,000	\$ 46,007,702	3,779 tpd	3	1,260 tpd	\$ 43,270,765	\$ 129,812,295

Balance of Plant:

Description	% of Total Cost	Cost Per Train	Total Cost
Water Systems	7.10%	\$ 3,072,224	\$ 9,216,673
Civil/Structural/Buildings	9.20%	\$ 3,980,910	\$ 11,942,731
Piping	7.10%	\$ 3,072,224	\$ 9,216,673
Control and Instrumentation	2.60%	\$ 1,125,040	\$ 3,375,120
Electrical Systems	8.00%	\$ 3,461,661	\$ 10,384,984
		Total Balance of Plant	\$ 14,712,060
		Total Balance of Plant Plus the Selected Source	\$ 57,982,825
			\$ 173,948,476

Rationale for Selection:

The Fertilizer Manual was selected for being both the newest cost point and the most conservative. The data from Perry's Chemical Engineering Handbook is based on earlier data from Peters and Timmerhaus, making it even less desirable. The allowances listed under 'Balance of Plant' are based on NETL 2000. These allowance values are comparable to additional published estimating guides, such as Page 1996.

Client: M. Patterson
Prepared By: B. Wallace, R. Honsinger, J. Martin
Estimate Type: Class 5

Source	Reported Capacity	Reported Trains	Report Cost Year	Reported Cost	Reporting Year Cost Per Train	Normalized Cost Per Train using CEPCI Index	Capacity Required	Trains Req'd.	Capacity per Train	Factored Cost per Train from Normalized Cost	Total Current Cost for Required Trains
Steam Turbine and HRSG											
	189	1	1999	\$ 50,671,000	\$ 50,671,000	\$ 66,419,744	32 MW	1	32 MW	\$ 22,796,931	\$ 22,796,931
Steam Turbine											
	401	4	2006	\$ 74,651,000	\$ 18,662,750	\$ 19,125,957	32 MW	1	32 MW	\$ 9,603,484	\$ 9,603,484
	275	1	2007	\$ 66,700,000	\$ 66,700,000	\$ 64,998,858	32 MW	1	32 MW	\$ 17,814,038	\$ 17,814,038
	230	1	2006	\$ 44,515,000	\$ 44,515,000	\$ 45,619,856	32 MW	1	32 MW	\$ 13,920,435	\$ 13,920,435

Source	Reported Capacity	Reported Trains	Report Cost Year	Reported Cost	Reporting Year Cost Per Train	Normalized Cost Per Train using CEPCI Index	Capacity Required	Trains Req'd.	Capacity per Train	Factored Cost per Train from Normalized Cost	Total Current Cost for Required Trains
Shell IGCC Power Plant with CO2 Capture (NETL 2007b)	230 MW	1	2006	\$ 44,515,000	\$ 44,515,000	\$ 45,619,856	32 MW	1	32 MW	\$ 13,920,435	\$ 13,920,435

[illegible]

Shell IGCC PowerPlant with CO2 Capture (NETL 2007b) is a recently reported cost point that closely reflects this project's requirements. The Princeton Report (Kreutz 2008) source for the steam turbine cost point is the NETL 2007b report. The allowances listed under 'Balance of Plant' are based on NETL 2000. These allowance values are comparable to additional published estimating guides, such as Page 1996.

Client: M. Patterson
Prepared By: B. Wallace, R. Honsinger, J. Martin
Estimate Type: Class 5

Source	Reported Capacity	Reported Trains	Report Cost Year	Reported Cost	Reporting Year Cost Per Train	Normalized Cost Per Train using CEPCI Index	Capacity Required	Trains Req'd.	Capacity per Train	Factored Cost per Train from Normalized Cost	Total Current Cost for Required Trains
Steam Turbine and HRSG											
	189	1	1999	\$ 50,671,000	\$ 50,671,000	\$ 66,419,744	-	MW	1	\$ -	\$ -
HRSG											
	5,155,983	3	2006	\$ 27,581,000	\$ 9,193,667	\$ 9,421,852	-	lb/hr	1	\$ -	\$ -
	355	1	2007	\$ 52,000,000	\$ 52,000,000	\$ 50,673,772	-	MW	1	\$ -	\$ -
Shell IGCC Power Plant with CO2 Capture (NETL 2007b)	8,438,000	2	2006	\$ 45,291,000	\$ 22,645,500	\$ 23,207,558	-	lb/hr	1	\$ -	\$ -

Source	Reported Capacity	Reported Trains	Report Cost Year	Reported Cost	Reporting Year Cost Per Train	Normalized Cost Per Train using CEPCI Index	Capacity Required		Trains Req'd.	Capacity per Train	Factored Cost per Train from Normalized Cost	Total Current Cost for Required Trains
Shell IGCC Power Plant with CO2 Capture (NETL 2007b)												
	8,438,000 lb/hr	2	2006	\$ 45,291,000	\$ 22,645,500	\$ 23,207,558	-	lb/hr	1	-	\$ -	-

[illegible]

Shell IGCC PowerPlant with CO2 Capture (NETL 2007b) is a recently reported cost point that closely reflects this project's requirements. The Princeton Report (Kreutz 2008) source for the steam turbine cost point is the NETL 2007b report. The allowances listed under 'Balance of Plant' are based on NETL 2000. These allowance values are comparable to additional published estimating guides, such as Page 1996.

Client: M. Patterson
Prepared By: B. Wallace, R. Honsinger, J. Martin
Estimate Type: Class 5

[illegible]

Source	Reported Capacity		Reported Trains	Report Cost Year	Reported Cost	Reporting Year Cost Per Train	Normalized Cost Per Train using CEPCI Index	Capacity Required		Trains Reqd.	Capacity per Train		Factored Cost per Train from Normalized Cost	Total Current Cost for Required Trains
	123,006	gpm						95,310	gpm		31,770	gpm		
Cooling Tower Depol			3	2009	\$ 3,140,030	\$ 1,046,677	\$ 1,046,677	95,310	gpm	3	31,770	gpm	\$ 898,129	\$ 2,694,388

[illegible]

Single source cost. Publically available current data. Calculated capital costs based on publically available cost data from a vendor regularly engaged in the building of cooling towers. The allowances listed under "Balance of Plant" are based on NETL 2000. These allowance values are comparable to additional published estimating guides, such as Page 1996.

NGNP HTSE Ammonia w/o ASU Summary


Project Name: NGNP Process Integration
 Process: HTSE Ammonia w/o ASU
 Estimate Number: MA36-O

Client: M. Patterson
 Prepared By: B. Wallace, R. Honsinger, J. Martin
 Estimate Type: Class 5

Process Component	Subtotal From Detail Sheets	Engineering %	Engineering	Contingency %	Contingency	Total Cost
High Temperature Gas Reactor (HTGR)	\$ 4,201,101,415	0%	\$ -	0%	\$ -	\$ 4,201,101,415
Rankine Power Cycle	\$ 615,345,051	10%	\$ 61,534,505	18%	\$ 121,838,320	\$ 798,717,876
High Temperature Steam Electrolysis (HTSE)	\$ 363,429,475	10%	\$ 36,342,947	18%	\$ 71,959,036	\$ 471,731,458
N2 Generation	\$ 17,287,060	10%	\$ 1,728,706	18%	\$ 3,422,838	\$ 22,438,603
CO2 Generation	\$ 15,022,364	10%	\$ 1,502,236	18%	\$ 2,974,428	\$ 19,499,029
Methanation	\$ 9,518,338	10%	\$ 951,834	18%	\$ 1,884,631	\$ 12,354,803
Ammonia Synthesis	\$ 297,160,814	10%	\$ 29,716,081	18%	\$ 58,837,841	\$ 385,714,736
Urea Synthesis	\$ 288,347,019	10%	\$ 28,834,702	18%	\$ 57,092,710	\$ 374,274,430
Nitric Acid Synthesis	\$ 272,169,749	10%	\$ 27,216,975	18%	\$ 53,889,610	\$ 353,276,334
Ammonium Nitrate Synthesis	\$ 173,948,476	10%	\$ 17,394,848	18%	\$ 34,441,798	\$ 225,785,122
Steam Turbines	\$ 49,012,114	10%	\$ 4,901,211	18%	\$ 9,704,398	\$ 63,617,723
Heat Recovery Steam Generator (HRSG)	\$ -	10%	\$ -	18%	\$ -	\$ -
Cooling Towers	\$ 5,735,762	10%	\$ 573,576	18%	\$ 1,135,681	\$ 7,445,019
Total Cost - HTSE Ammonia w/o ASU						\$ 6,935,956,549
Total Cost Rounded to the Nearest \$10M						\$ 6,940,000,000

Checked By: 	Remarks
Approved By: 	

COST ESTIMATE SUPPORT DATA RECAPITULATION

Project Title: NGNP Process Integration – HTSE Ammonia without ASU
Estimator: B. W. Wallace/CEP, R. R. Honsinger/CEP, J. B. Martin/CCT
Date: April 20, 2010
Estimate Type: Class 5
File: MA36-O
Approved By: 

Page 1 of 9

- I. **PURPOSE:** *Brief description of the intent of how the estimate is to be used (i.e., for engineering study, comparative analysis, request for funding, proposal, etc.).*

It is expected that the capital costs identified in these estimates will be used in a model producing an economic analysis for each specific integrated application and subsequently will be considered in a related feasibility study.

- II. **SCOPE OF WORK:** *Brief statement of the project's objective. Thorough overview and description of the proposed project. Identify work to be accomplished, as well as any specific work to be excluded.*

A. **Objective:**

Develop Class 5 estimates as defined by the Association for Advancement of Cost Engineering (AACEi) that will identify the current capital cost associated with high-temperature gas reactors (HTGRs) integrated with a nuclear ammonia without an air separation unit process.

B. **Included:**

The scope of work required to achieve this objective includes the following:

1. Engineering
2. The allowance provided for the HTGR represents a complete and operable system. All elements required for construction of this nuclear reactor capability, including an initial steam generator, security systems, contingency, and owner's costs are included in the turn-key allowance. Owner's costs are included only in the case of the reactor capability. It is considered that the total value represents all inside of battery limits (ISBL) elements, outside of battery limits (OSBL) elements, site development, and all ancillary control and operational functions and capabilities.
3. Construction of a new integrated refinery capability to produce ammonia that consists of the following:
 - a. Overnight island-type costs for HTGRs
 - b. High-temperature steam electrolysis (HTSE) hydrogen production unit
 - c. H₂ combustor (N₂ generation)
 - d. Natural gas combustor (CO₂ generation)
 - e. Methanation
 - f. Ammonia synthesis
 - g. Urea synthesis
 - h. Nitric acid synthesis

COST ESTIMATE SUPPORT DATA RECAPITULATION

– Continued –

Project Title: NGNP Process Integration – HTSE Ammonia without ASU
File: MA36-O

Page 2 of 9

- i. Ammonium nitrate synthesis
- j. Steam turbines, internal to process
- k. Heat recovery steam generator, internal to process
- l. Cooling towers, internal to process
- m. Allowances for Balance of Plant (BOP)/offsite/OSBL, including the following:
 - (1.) Site development/improvements
 - (2.) Provisions for general and administrative buildings and structures
 - (3.) Provisions for OSBL piping
 - (4.) Provisions for OSBL instrumentation and control
 - (5.) Provisions for OSBL electrical
 - (6.) Provisions for facility supply and OSBL water systems
 - (7.) Provisions for site development/improvements
 - (8.) Project/construction management.

C. Excluded:

This scope of work specifically excludes the following elements:

- 1. Licensing and permitting costs
- 2. Operational costs
- 3. Land costs
- 4. Sales taxes
- 5. Royalties
- 6. Owner's fees and owner's costs, except those included for the HTGR
- 7. The allowance provided for the HTGR capability excludes all costs associated with materials development, or costs that would not be appropriately associated with an nth of a kind (NOAK) reactor/facility.

III. ESTIMATE METHODOLOGY: *Overall methodology and rationale of how the estimate was developed (i.e., parametric, forced detail, bottoms up, etc.). Total dollars/hours and rough order magnitude (ROM) allocations of the methodologies used to develop the cost estimate.*

Consistent with the AACEi Class 5 estimates, the level of definition and engineering development available at the time they were prepared, their intended use in a feasibility study, and the time and resources available for their completion, the costs included in this estimate have been developed using parametric evaluations. These evaluations have used publicly available and published project costs to represent similar islands utilized in this project. Analysis and selection of the published costs used have been performed by the project technical lead and Cost Estimating. Suitability for use in this effort was determined considering the correctness and completeness of the data available, the manner in which total capital costs were represented, the age of the previously performed work, and the similarity to the capacity/trains required by this project. The specific sources, selected and used in this cost estimate, are identified in the capital cost estimate detail sheets.

Adjustments have been made to these published costs using escalation factors identified in the Chemical Engineering Price Cost Index. Scaling of the published island costs has been

COST ESTIMATE SUPPORT DATA RECAPITULATION

– Continued –

Project Title: NGNP Process Integration – HTSE Ammonia without ASU
File: MA36-O

Page 3 of 9

accomplished using the six-tenths capacity factoring method. Costs included for the HTGR, power cycles, and HTSE, have been identified and provided by the respective BEA subject matter experts. The total cost for each of these items has been linearly calculated from the respective base unit costs. Any normalization to provide for geographic factors was considered using geographic factors available from RS Means Construction Cost Data references. Cost-estimating relationships have been used to identify allowances to complete the costs.

It was identified to the Next Generation Nuclear Plant (NGNP) Process Integration team that the methodology employed by NGNP to develop the nuclear capability included constituents of parametric modeling, vendor quotes, actual costs, and proprietary costing databases. These preconceptual design estimates were reviewed by NGNP Project Engineering for credibility with regard to assumptions and bases of estimate and performed multiple studies to reconcile variations in the scope and assumptions within the three estimates.

BOP/OSBL costs were determined by the project team, considering data provided by Shell Gasifier IGCC Base Case report NETL 2000, *Conceptual Cost Estimating Manual* Second Edition by John S. Page, and additional adjusted sources. Because the allowances identified did not show significant variability, the allowances identified in the NETL 2000 report were chosen for this effort in order to minimize the mixing of data sources.

IV. BASIS OF THE ESTIMATE: *Overall explanation of sources for resource pricing and schedules.*

A. **Quantification Basis:** *The source for the measurable quantities in the estimate that can be used in support of earned value management. Source documents may include drawings, design reports, engineers' notes, and other documentation upon which the estimate is originated.*

All islands and capacities have been provided to Cost Estimating by the project respective expert.

B. **Planning Basis:** *The source for the execution and strategies of the work that can be used to support the project execution plan, acquisition strategy, schedules, and market conditions and other documentation upon which the estimate is originated.*

1. All islands and HTGRs represent NOAK projects.
2. Projects will be constructed and operated by commercial entities.
3. All projects, with the exception of the Steam-Assisted Gravity Drainage Project, will be located in the U.S. Gulf Coast refinery region.
4. Costs are presented as overnight costs.
5. The cost estimate does not consider or address funding or labor resource restrictions. Sufficient funding and labor resources will be available in a manner that allows optimum usage of the funding and resources as estimated and scheduled.

COST ESTIMATE SUPPORT DATA RECAPITULATION

– Continued –

Project Title: NGNP Process Integration – HTSE Ammonia without ASU
File: MA36-O

Page 4 of 9

- C. **Cost Basis:** *The source for the costing on the estimate that can be used in support of earned value management, funding profiles, and schedule of values. Sources may include published costing references, judgment, actual costs, preliminary quotes or other documentation upon which the estimate is originated.*
1. All costs are represented as current value costs. Factors for forward-looking escalation and inflation factors are not included in this estimate.
 2. Where required, published cost factors, as identified in the Chemical Engineering Plant Cost Index, will be applied to previous years' values to determine current year values.
 3. Geographic location factors, as identified in RS Means Construction Cost Data reference manual, were considered for each source cost.
 4. The cost provided for the HTGR reflects internal BEA cost data that was developed for the HTGR and presented to the NGNP Process Integration team by L. Demmick. Considered in the cost is a pre-conceptual cost estimate prepared by three separate contractor teams. All contractor teams proposed 4-unit NOAK plants with thermal power levels between 2,000 MW_t and 2,400 MW_t at a cost of roughly \$4B, including owner's cost. This equates to \$1,667 to \$2,000 per kW_t. For the purposes of this report, the nominal cost of an HTGR will be set at the upper end of this range, \$2,000 per kW_t. This is a complete turnkey cost and includes engineering and construction of a NOAK HTGR, the power cycle, and contingency. The total HTGR cost for each process is calculated linearly as \$1,708,333 per MW_{th} of required capacity, excluding the cost of the power cycles.
 5. The cost included for the power cycle was provided by the INL project team expert. The power cycle cost is based on the definition of a 240-MWe capacity and \$618,176 per MWe. The total power cycle cost for each process is calculated linearly as \$618,176 per MWe of required capacity. BOP, engineering, and contingency costs are added to the base cost.
 6. The cost included for HTSE was provided by the INL project team expert. The total HTSE cost for each process is calculated linearly as \$36,120,156 per kg/s of required capacity. BOP, engineering, and contingency costs are added to the base cost.
 7. Apt, Jay, et al., *An Engineering-Economic Analysis of Syngas Storage*, NETL, July 2008.
 8. AACEi, *Recommended Practices*, website, visited November 16, 2009, <http://www.aacei.org/technical/rp.shtml>.
 9. Brown, L. C., et al., "Alternative Flowsheets for the Sulfur-Iodine Thermochemical Hydrogen Cycle," *General Atomics*, February 2003.
 10. CEPCI, *Chemical Engineering Magazine*, "Chemical Engineering Plant Cost Index," November 2009: 64.
 11. Choi, 1996, Choi, Gerald N., et al, *Design/Economics of a Once-Through Natural Gas Fischer-Tropsch Plant with Power Co-Production*, Bechtel, 1996.
 12. Dooley, J., et al, *Carbon Dioxide Capture and Geologic Storage*, Battelle, April 2006.

COST ESTIMATE SUPPORT DATA RECAPITULATION

– Continued –

Project Title: NGNP Process Integration – HTSE Ammonia without ASU
File: MA36-O

Page 5 of 9

13. Douglas, Fred R., et al., *Conduction Technical and Economic Evaluations – as Applied for the Process and Utility Industries*, AACEi, April 1991.
14. FLUOR/UOP, 2004, Mak, John Y., et al., *Synthesis Gas Purification in Gasification to Ammonia/Urea Complex*, FLUOR/UOP, 2004.
15. Friedland, Robert J., et al., *Hydrogen Production Through Electrolysis*, NREL, June 2002.
16. Gray, 2004, Gray, David, et al., *Polygeneration of SNG, Hydrogen, Power, and Carbon Dioxide from Texas Lignite*, MTR-04, 2004-18, NETL, December 2004.
17. Harvego, E. A., et al., *Economic Analysis of a Nuclear Reactor Powered High-Temperature Electrolysis Hydrogen Production Plant*, INL, August 2008.
18. Harvego, E. A., et al., *Economic Analysis of the Reference Design for a Nuclear-Driven High-Temperature-Electrolysis Hydrogen Production Plant*, INL, January 2008.
19. Ivy, Johanna, *Summary of Electrolytic Hydrogen Production*, NREL September 2004.
20. Ibsen, Kelly, et al., *Equipment Design and Cost Estimation for Small Modular Biomass Systems, Synthesis Gas Cleanup, and Oxygen Separation Equipment*, NREL, May 2006.
21. Klett, Michael G., et al., *The Cost of Mercury Removal in an IGCC Plant*, NETL, September 2002.
22. Kreutz, 2008, Kreutz, Thomas G., et al., “Fischer-Tropsch Fuels from Coal and Biomass,” *25th Annual International Pittsburgh Coal Conference*, Pittsburgh, Princeton University, October 2008.
23. Loh, H. P., et al., *Process Equipment Cost Estimation*, DOE/NETL-2002/1169, NETL, 2002.
24. NETL, 2000, Shelton, W., et al., *Shell Gasifier IGCC Base Cases*, PED-IGCC-98-002, NETL, June 2000.
25. NETL, 2007a, Van Bibber, Lawrence, *Baseline Technical and Economic Assessment of a Commercial Scale Fischer-Tropsch Liquids Facility*, DOE/NETL-207/1260, NETL, April 2007.
26. NETL, 2007b, Woods, Mark C., et al., *Cost and Performance Baseline for Fossil Energy Plants*, NETL, August 2007.
27. NREL, 2005, Saur, Genevieve, *Wind-To-Hydrogen Project: Electrolyzer Capital Cost Study*, NREL, December 2008.
28. O’Brien, J. E., et al., *High-Temperature Electrolysis for Large-Scale Hydrogen and Syngas Production from Nuclear Energy – System Simulation and Economics*, INL, May 2009.
29. O’Brien, J. E., et al., *Parametric Study of Large-Scale Production of Syngas via High-Temperature Co-Electrolysis*, INL, January 2009.
30. Page, John S., *Conceptual Cost Estimating Manual – 2nd ed.*, Houston: Gulf Publishing Company, 1996.
31. Pietlock, Bernard A., et al., *Developing Location Factors by Factoring- as Applied in Architecture, Engineering, Procurement, and Construction*, AACEi, October 2006.

COST ESTIMATE SUPPORT DATA RECAPITULATION

– Continued –

Project Title: NGNP Process Integration – HTSE Ammonia without ASU
File: MA36-O

Page 6 of 9

32. Ramsden, Todd, et al., *Current (2005) Hydrogen Production from Central Grid Electrolysis*, NREL, May 2008.
33. Ramsden, Todd, et al., *Longer-Term (2025) Hydrogen Production from Central Grid Electrolysis*, NREL, May 2008.
34. Richardson Construction Estimating Standards, *Process Plant Cooling Towers*, Cost Data Online, September 16, 2009, website, visited December 15, 2009, <http://www.costdataonline.com/>.
35. Sohal, M. S., et al., *Challenges in Generating Hydrogen by High Temperature Electrolysis Using Solid Oxide Cells*, INL, March 2008.
36. Steinberg, Meyer, *Conversion of Coal to Substitute Natural Gas (SNG)*, HCE, 2005.
37. Udengaard, 2008, Udengaard, Niels R., et al., *Convert Coal, petcoke into valuable SNG*, Haldor Topsoe, April 2008.
38. van der Ploeg, H. J., et al., *The Shell Coal Gasification Process for the US Industry*, Shell, October 2004.
39. WorleyParsons, 2002, Rameshni, Mahin, *Cost Effective Options to Expand SRU Capacity Using Oxygen*, WorleyParsons, May 2002.

V. **ESTIMATE QUALITY ASSURANCE:** *A listing of all estimate reviews that have taken place and the actions taken from those reviews.*

A review of the cost estimate was held on January 14, 2010, with the project team and the cost estimators. This review allowed for the project team to review and comment, in detail, on the perceived scope, basis of estimates, assumptions, project risks, and resources that make up this cost estimate. Comments from this review have been incorporated into this estimate to reflect a project team consensus of this document.

VI. **ASSUMPTIONS:** *Condition statements accepted or supposed true without proof of demonstration; statements adding clarification to scope. An assumption has a direct impact on total estimated cost.*

General Assumptions:

- A. All costs are represented in 2009 values.
- B. Costs that were included from sources representing years prior to 2009 have been normalized to 2009 values using the Chemical Engineering Plant Cost Index. This index was selected due to its widespread recognition and acceptance and its specific orientation toward work associated with chemical and refinery plants.
- C. Capital costs are based on process islands. The majority of these islands are interchangeable, after factoring for the differing capacities, flowsheet-to-flowsheet.
- D. All chemical processing and refinery processes will be located in the U.S. Gulf Coast region.
- E. All costs considered to be BOP costs that can be specifically identified have been factored out of the reported source data and added into the estimate in a manner consistent with that identified in the NETL 2000 IGCC Base Cost report. Inclusion of the source costs in this manner normalizes all reported cost information to the bare-erected costs.

COST ESTIMATE SUPPORT DATA RECAPITULATION

– Continued –

Project Title: NGNP Process Integration – HTSE Ammonia without ASU
File: MA36-O

Page 7 of 9

HTGR:

- A. The linearly scalable cost included for an HTGR reflects an NOAK reactor with a 750°C-operating temperature.
- B. HTGR is considered to be linearly scalable, by required capacity, per the direction of the project team. This allows the process integration feasibility studies to showcase the financial analysis of the process without the added burden of integer quantity 600-MWth HTGRs.
- C. The allowance represents a turnkey condition for the reactor and its supporting infrastructure.
- D. A high-temperature, high-pressure steam generator is included in the cost represented for HTGR.
- E. A contingency allowance is included in the HTGR cost, but is not identified as a separate line item in this estimate. This allowance was identified and included by the NGNP HTGR project team.
- F. Total cost range, including contingency, for HTGR is -50%, +100%.
- G. Cost included for the power cycle reflects NOAK research and manufacturing developments to allow for assumed high pressures and temperatures.
- H. The power cycle is considered to be linearly scalable, by required capacity, per the direction of the project team. This allows the process integration feasibility studies to showcase the financial analysis of the process.
- I. The cost included for HTSE reflects NOAK research and manufacturing developments, which will increase the expected lifespan of the electrolysis cells.
- J. The HTSE is considered to be linearly scalable, by required capacity, per the direction of the project team. This allows the process integration feasibility studies to showcase the financial analysis of the process.

HTSE Ammonia without Air Separation Unit

Some estimated island costs are based on figures from a verbal conversation with Casale, a leading world vendor of process industry services. These costs were used in cases where other acceptable costs were not available.

VII. CONTINGENCY GUIDELINE IMPLEMENTATION:

Contingency Methodologies: *Explanation of methodology used in determining overall contingency. Identify any specific drivers or items of concern.*

At a project risk review on December 9, 2009, the project team discussed risks to the project. An 18% allowance for capital construction contingency has been included at an island level based on the discussion and is included in the summary sheet. The contingency level that was included in the island cost source documents and additional threats and opportunities identified here were considered during this review. The contingency identified was considered by the project team and included in Cost and Performance Baseline for Fossil Energy Plants DOE/NETL-2007/1281 and similar reports. Typically, contingency allowance provided in these reports ranged from 15% to 20%. Since much of

COST ESTIMATE SUPPORT DATA RECAPITULATION

– Continued –

Project Title: NGNP Process Integration – HTSE Ammonia without ASU
File: MA36-O

Page 8 of 9

the data contained in this estimate has been derived from these reports, the project team has also chosen a level of contingency consistent with them.

While the level of contingency provided for the HTGR capability is not identified as a line item, the cost data provided to the NGNP Process Integration team was identified as including an appropriate allocation for contingency. No additional contingency has been added to this element.

A. **Threats:** *Uncertain events that are potentially negative or reduce the probability that the desired outcome will happen.*

1. The singularly largest threat to this estimate surrounds the lump sum cost included for the HTGR reactor(s). This is followed by the HTSE process, where applicable. While the overriding assumption is that these elements will be NOAK, currently, a complete HTGR has not been commissioned and the HTSE has been successfully developed in an integrated laboratory-scale model, but has not been completed in either pilot plant or production scales.
2. The level of project definition/development that was available at the time the estimate was prepared represents a substantial risk to the project and is likely to occur. The high level at which elements were considered and included has the potential to include additional elements that are within the work scope but not sufficiently provided for or addressed at this level.
3. The estimate methodology employed is one of a stochastic parametrically evaluated process. This process used publicly available published costs that were related to the process required, costs were normalized using price indices, and the cost was scaled to provide the required capacity. The cost-estimating relationships that were used represent typical costs for BOP allowances, but source cost data from which the initial island costs were derived were not completely descriptive of the elements included, not included, or simply referred to with different nomenclature or combined with other elements. While every effort has been made to correctly normalize and factor the costs for use in this effort, the risk exists that not all of these were correctly captured due to the varied information available.
4. This project is heavily dependent on metals, concrete, petroleum, and petroleum products. Competition for these commodities in today's environment due to global expansion, uncertainty, and product shortages affects the basic concepts of the supply and demand theories, thus increasing costs.
5. Impacts due to large quantities of materials, special alloy materials, fabrication capability, and labor availability could all represent conditions that may increase the total cost of the project.

COST ESTIMATE SUPPORT DATA RECAPITULATION

– Continued –

Project Title: NGNP Process Integration – HTSE Ammonia without ASU
File: MA36-O

Page 9 of 9

B. **Opportunities:** *Uncertain events that could improve the results or improve the probability that the desired outcome will happen.*

1. Additional research and work performed with both vendors and potential owner/operators for a specific process or refinery may identify efficiencies and production means that have not been available for use in this analysis.
2. Recent historical data may identify and include technological advancements and efficiencies not included or reflected in the publicly available source data used in this effort.

Note: Contingency does not increase the overall accuracy of the estimate; it does, however, reduce the level of risk associated with the estimate. Contingency is intended to cover the inadequacies in the complete project scope definition, estimating methods, and estimating data. Contingency specifically excludes changes in project scope, unexpected work stoppages (e.g., strikes, disasters, and earthquakes) and excessive or unexpected inflation or currency fluctuations.

VIII. **OTHER COMMENTS/CONCERNS SPECIFIC TO THE ESTIMATE:**

None.

Client: M. Patterson
Prepared By: B. Wallace, R. Honsinger, J. Martin
Estimate Type: Class 5

Project Name:
Process:
Estimate Number:

NGNP Process Integration
HTSE Ammonia w/o ASU
MA36-O

Client:
Prepared By:
Estimate Type:

M. Patterson
B. Wallace, R. Honsinger, J. Martin
Class 5

Sources Considered:

[illegible]

Summary:

Source	Reported Capacity		Reported Trains	Report Cost Year	Reported Cost	Reporting Year Cost Per Train	Normalized Cost Per Train using CEPCI Index	Capacity Required		Trains Reqd.	Capacity per Train		Factored Cost per Train from Normalized Cost	Total Current Cost for Required Trains
INL Internal Cost Data (INL 2009)	240	MWe	1	2009	\$ 148,362,255	\$ 148,362,255	\$ 148,362,255	879	MWe	5	176	MWe	\$ 123,069,010	\$ 615,345,051

Balance of Plant:

[illegible]

Basis of Estimate Notes:

Single source cost. The reported costs are from the INL project team expert. The reported cost represents a Rankine power cycle, excluding the steam generator. The cost is based on information found in NETL 2007b, which has been adjusted and customized for this project by the INL project team expert. The allowances listed under "Balance of Plant" are based on NETL 2000. These allowance values are comparable to additional published estimating guides, such as Page 1996. The allowances have been adjusted and customized for this project based on estimator judgment. The reduced civil/structural/buildings allowance accounts for the buildings that are included in the Rankine power cycle cost. Water and electrical systems BOP allowances are included in the reported cost for the Rankine power cycle.

Detail Item Report - High Temperature Steam Electrolysis (HTSE)

Project Name: NGNP Process Integration
Process: HTSE Ammonia w/o ASU
Estimate Number: MA36-O

Client: M. Patterson
Prepared By: B. Wallace, R. Honsinger, J. Martin
Estimate Type: Class 5

Sources Considered:

Source	Reported Capacity	Reported Trains	Report Cost Year	Reported Cost	Reporting Year Cost Per Train	Normalized Cost Per Train using CEPCI Index	Capacity Required	Trains Req'd.	Capacity per Train	Factored Cost per Train from Normalized Cost	Total Current Cost for Required Trains
INL Feasibility Study (INL 2009)	1.00	kg/s	1	2009	\$ 36,120,156	\$ 36,120,156	7.51	kg/s		\$ 271,216,026	\$ 271,216,026

Source Selected:

Source	Reported Capacity	Reported Trains	Report Cost Year	Reported Cost	Reporting Year Cost Per Train	Normalized Cost Per Train using CEPCI Index	Capacity Required	Trains Req'd.	Capacity per Train	Factored Cost per Train from Normalized Cost	Total Current Cost for Required Trains
INL Feasibility Study (INL 2009)	1.00	kg/s	1	2009	\$ 36,120,156	\$ 36,120,156	7.51	kg/s		\$ 271,216,026	\$ 271,216,026

Balance of Plant:

Description	% of Total Cost	Cost Per Train	Total Cost
Water Systems		\$ 19,256,338	\$ 19,256,338
Civil/Structural/Buildings	7.10%	\$ 24,951,874	\$ 24,951,874
Piping	9.20%	\$ 19,256,338	\$ 19,256,338
Control and Instrumentation	7.10%	\$ 7,051,617	\$ 7,051,617
Electrical Systems	2.60%	\$ 21,697,282	\$ 21,697,282
	8.00%	\$ 92,213,449	\$ 92,213,449
		Total Balance of Plant	
		Total Balance of Plant Plus the Selected Source	\$ 363,429,475

Rationale for Selection:

Single source cost. The reported costs are from the INL project team expert. The allowances listed under 'Balance of Plant' are based on NETL 2000. These allowance values are comparable to additional published estimating guides, such as Page 1996.

Detail Item Report - N2 Generation

Project Name: NGNP Process Integration
Process: HTSE Ammonia w/o ASU
Estimate Number: MA36-O

Client: M. Patterson
Prepared By: B. Wallace, R. Honsinger, J. Martin
Estimate Type: Class 5

Sources Considered:

Source	Reported Capacity	Reported Trains	Report Cost Year	Reported Cost	Reporting Year Cost Per Train	Normalized Cost Per Train using CEPCI Index	Capacity Required	Trains Req'd.	Capacity per Train	Factored Cost per Train from Normalized Cost	Total Current Cost for Required Trains
N2 Generator Cost (Wood 2009)	239,265 lb/hr	1	2007	\$13,317,500	\$ 13,317,500	\$ 12,977,845	236,902 lb/hr	1	236,902	\$ 12,900,791	\$ 12,900,791

Source Selected:

Source	Reported Capacity	Reported Trains	Report Cost Year	Reported Cost	Reporting Year Cost Per Train	Normalized Cost Per Train using CEPCI Index	Capacity Required	Trains Req'd.	Capacity per Train	Factored Cost per Train from Normalized Cost	Total Current Cost for Required Trains
N2 Generator Cost (Wood 2009)	239,265 lb/hr	1	2007	\$13,317,500	\$ 13,317,500	\$ 12,977,845	236,902 lb/hr	1	236,902	\$ 12,900,791	\$ 12,900,791

Balance of Plant:

Description	% of Total Cost	Cost Per Train	Total Cost
Water Systems		\$ 915,956	\$ 915,956
Civil/Structural/Buildings	7.10%	\$ 1,186,873	\$ 1,186,873
Piping	9.20%	\$ 915,956	\$ 915,956
Control and Instrumentation	7.10%	\$ 335,421	\$ 335,421
Electrical Systems	2.60%	\$ 1,032,063	\$ 1,032,063
	8.00%	\$ 4,386,269	\$ 4,386,269
		Total Balance of Plant	
		Total Balance of Plant Plus the Selected Source	\$ 17,287,060

Rationale for Selection:

Single source cost point. The allowances listed under 'Balance of Plant' are based on NETL 2000. These allowance values are comparable to additional published estimating guides, such as Page 1996.

Detail Item Report - CO2 Generation

Project Name: NGNP Process Integration
Process: HTSE Ammonia w/o ASU
Estimate Number: MA36-O

Client: M. Patterson
Prepared By: B. Wallace, R. Honsinger, J. Martin
Estimate Type: Class 5

Sources Considered:

Source	Reported Capacity	Reported Trains	Report Cost Year	Reported Cost	Reporting Year Cost Per Train	Normalized Cost Per Train using CEPCI Index	Capacity Required	Trains Req'd.	Capacity per Train	Factored Cost per Train from Normalized Cost	Total Current Cost for Required Trains
CO2 Compression - Subcritical Princeton Report (Kreutz 2008)	10	1	2007	\$ 6,310,000	\$ 6,310,000	\$ 6,149,067	2	MW	2	MW \$ 2,329,179	\$ 2,329,179
CO2 Compression - Supercritical Princeton Report (Kreutz 2008)	13	1	2007	\$ 9,520,000	\$ 9,520,000	\$ 9,277,198	0.3	MW	0.3	MW \$ 987,887	\$ 987,887
CO2 Generation CO2 Generator (Wood 2009)	184,095	1	2007	\$ 8,102,200	\$ 8,102,200	\$ 7,895,558	184,021	lb/hr	184,021	lb/hr \$ 7,893,654	\$ 7,893,654

Source Selected:

Source	Reported Capacity	Reported Trains	Report Cost Year	Reported Cost	Reporting Year Cost Per Train	Normalized Cost Per Train using CEPCI Index	Capacity Required	Trains Req'd.	Capacity per Train	Factored Cost per Train from Normalized Cost	Total Current Cost for Required Trains
Kreutz 2008: Combined Subcritical and Supercritical Processes										\$ 11,210,720	\$ 11,210,720

Balance of Plant:

Description	% of Total Cost	Cost Per Train	Total Cost
Water Systems	7.10%	\$ 795,961	\$ 795,961
Civil/Structural/Buildings	9.20%	\$ 1,031,386	\$ 1,031,386
Piping	7.10%	\$ 795,961	\$ 795,961
Control and Instrumentation	2.60%	\$ 291,479	\$ 291,479
Electrical Systems	8.00%	\$ 896,858	\$ 896,858
		Total Balance of Plant	\$ 3,811,645
		Total Balance of Plant Plus the Selected Source	\$ 15,022,364

Rationale for Selection:

Single source cost point. The only CO2 generation source considered was Wood 2009. This cost was supplemented with CO2 compression costs from Kreutz 2008 to represent a full island cost. Both subcritical and supercritical process costs were included under the CO2 Compression heading. The allowances listed under 'Balance of Plant' are based on NETL 2000. These allowance values are comparable to additional published estimating guides, such as Page 1996.

Detail Item Report - Methanation

Project Name: NGNP Process Integration
 Process: HTSE Ammonia w/o ASU
 Estimate Number: MA36-O

Client: M. Patterson
 Prepared By: B. Wallace, R. Honsinger, J. Martin
 Estimate Type: Class 5

Sources Considered:

Source	Reported Capacity	Reported Trains	Report Cost Year	Reported Cost	Reporting Year Cost Per Train	Normalized Cost Per Train using CEPCI Index	Capacity Required	Trains Req'd.	Capacity per Train	Factored Cost per Train from Normalized Cost	Total Current Cost for Required Trains
DOE FE Report (DOE 1978)	1,000	1	1978	\$ 1,467,000	\$ 1,467,000	\$ 3,432,834	3,360	1	3,360 tpd	\$ 7,103,237	\$ 7,103,237

Source Selected:

Source	Reported Capacity	Reported Trains	Report Cost Year	Reported Cost	Reporting Year Cost Per Train	Normalized Cost Per Train using CEPCI Index	Capacity Required	Trains Req'd.	Capacity per Train	Factored Cost per Train from Normalized Cost	Total Current Cost for Required Trains
DOE FE Report (DOE 1978)	1,000	1	1978	\$ 1,467,000	\$ 1,467,000	\$ 3,432,834	3,360	1	3,360 tpd	\$ 7,103,237	\$ 7,103,237

Balance of Plant:

Description	% of Total Cost	Cost Per Train	Total Cost
Water Systems		\$ 504,330	\$ 504,330
Civil/Structural/Buildings	7.10%	\$ 653,498	\$ 653,498
Piping	9.20%	\$ 504,330	\$ 504,330
Control and Instrumentation	7.10%	\$ 184,684	\$ 184,684
Electrical Systems	2.60%	\$ 568,259	\$ 568,259
	8.00%	\$ 2,415,101	\$ 2,415,101
		Total Balance of Plant	
		Total Balance of Plant Plus the Selected Source	\$ 9,518,338

Rationale for Selection:

Single source island cost identified by the project technical lead. The allowances listed under 'Balance of Plant' are based on NETL 2000. These allowance values are comparable to additional published estimating guides, such as Page 1996.

Detail Item Report - Ammonia Synthesis

Project Name: NGNP Process Integration
Process: HTSE Ammonia w/o ASU
Estimate Number: MA36-O

Client: M. Patterson
Prepared By: B. Wallace, R. Honsinger, J. Martin
Estimate Type: Class 5

Sources Considered:

Source	Reported Capacity	Reported Trains	Report Cost Year	Reported Cost	Reporting Year Cost Per Train	Normalized Cost Per Train using CEPCI Index	Capacity Required	Trains Req'd.	Capacity per Train	Factored Cost per Train from Normalized Cost	Total Current Cost for Required Trains
Vendor - Verbal 2009	360	1	2009	\$ 44,000,000	\$ 44,000,000	\$ 44,000,000	3,360	2	1,680	\$ 110,880,901	\$ 221,761,801
Economics Ammonia Coal Gasification (Morel 1977)	1,000	1	1977	\$ 50,748,000	\$ 50,748,000	\$ 80,243,904	3,360	2	1,680	\$ 109,546,276	\$ 219,092,551
Stamcarbon, Middle East Fertilizer Symposium, March 2009	4,297	1	2008	\$ 800,000,000	\$ 800,000,000	\$ 779,596,498	3,360	2	1,680	\$ 443,768,260	\$ 887,536,519
Ammonia, Chem Systems, 1998	1,653	1	1998	\$ 160,000,000	\$ 160,000,000	\$ 210,320,924	3,360	2	1,680	\$ 212,375,463	\$ 424,750,926

Source Selected:

Source	Reported Capacity	Reported Trains	Report Cost Year	Reported Cost	Reporting Year Cost Per Train	Normalized Cost Per Train using CEPCI Index	Capacity Required	Trains Req'd.	Capacity per Train	Factored Cost per Train from Normalized Cost	Total Current Cost for Required Trains
Vendor - Verbal 2009	360	1	2009	\$ 44,000,000	\$ 44,000,000	\$ 44,000,000	3,360	2	1,680	\$ 110,880,901	\$ 221,761,801

Balance of Plant:

Description	% of Total Cost	Cost Per Train	Total Cost
Water Systems	7.10%	\$ 7,872,544	\$ 15,745,088
Civil/Structural/Buildings	9.20%	\$ 10,201,043	\$ 20,402,086
Piping	7.10%	\$ 7,872,544	\$ 15,745,088
Control and Instrumentation	2.60%	\$ 2,882,903	\$ 5,765,807
Electrical Systems	8.00%	\$ 8,870,472	\$ 17,740,944
		Total Balance of Plant	\$ 37,699,506
		Total Balance of Plant Plus the Selected Source	\$ 148,580,407
			\$ 297,160,814

Rationale for Selection:

The verbal cost was selected as recommended by the project team expert. The Stamcarbon information shows a roughly 350% increase in prices between 2003 and 2008 emphasizing the importance of using the most recent information available. The allowances listed under 'Balance of Plant' are based on NETL 2000. These allowance values are comparable to additional published estimating guides, such as Page 1996.

Detail Item Report - Urea Synthesis

Project Name: NGNP Process Integration
Process: HTSE Ammonia w/o ASU
Estimate Number: MA36-O

Client: M. Patterson
Prepared By: B. Wallace, R. Honsinger, J. Martin
Estimate Type: Class 5

Sources Considered:

Source	Reported Capacity	Reported Trains	Report Cost Year	Reported Cost	Reporting Year Cost Per Train	Normalized Cost Per Train using CEPCI Index	Capacity Required	Trains Req'd.	Capacity per Train	Factored Cost per Train from Normalized Cost	Total Current Cost for Required Trains
Vendor - Verbal 2009	625	1	2009	\$ 85,000,000	\$ 85,000,000	\$ 85,000,000	2,939	1	2,939	\$ 215,184,342	\$ 215,184,342
Perry's Chemical Engineering Handbook, 7th Edition	200	1	1994	\$ 8,800,000	\$ 8,800,000	\$ 12,240,152	2,939	1	2,939	\$ 61,388,719	\$ 61,388,719
PNL	4681	1	2009	\$ 182,000,000	\$ 182,000,000	\$ 182,000,000	2,939	1	2,939	\$ 137,653,721	\$ 137,653,721
Stamcarbon, Middle East Fertilizer Symposium, March 2009	3,582	1	2008	\$ 550,000,000	\$ 550,000,000	\$ 535,972,592	2,939	1	2,939	\$ 475,978,115	\$ 475,978,115

Source Selected:

Source	Reported Capacity	Reported Trains	Report Cost Year	Reported Cost	Reporting Year Cost Per Train	Normalized Cost Per Train using CEPCI Index	Capacity Required	Trains Req'd.	Capacity per Train	Factored Cost per Train from Normalized Cost	Total Current Cost for Required Trains
Vendor - Verbal 2009	625	1	2009	\$ 85,000,000	\$ 85,000,000	\$ 85,000,000	2,939	1	2,939	\$ 215,184,342	\$ 215,184,342

Balance of Plant:

Description	% of Total Cost	Cost Per Train	Total Cost
Water Systems	7.10%	\$ 15,278,088	\$ 15,278,088
Civil/Structural/Buildings	9.20%	\$ 19,796,959	\$ 19,796,959
Piping	7.10%	\$ 15,278,088	\$ 15,278,088
Control and Instrumentation	2.60%	\$ 5,594,793	\$ 5,594,793
Electrical Systems	8.00%	\$ 17,214,747	\$ 17,214,747
		\$ 73,162,676	\$ 73,162,676
		\$ 288,347,019	\$ 288,347,019

Rationale for Selection:

The verbal cost was selected as recommended by the project team expert. The Stamcarbon information shows a roughly 350% increase in prices between 2003 and 2008 emphasizing the importance of using the most recent information available. The allowances listed under 'Balance of Plant' are based on NETL 2000. These allowance values are comparable to additional published estimating guides, such as Page 1996.

Detail Item Report - Nitric Acid Synthesis

Project Name: NGNP Process Integration
Process: HTSE Ammonia w/o ASU
Estimate Number: MA36-O

Client: M. Patterson
Prepared By: B. Wallace, R. Honsinger, J. Martin
Estimate Type: Class 5

Sources Considered:

Source	Reported Capacity	Reported Trains	Report Cost Year	Reported Cost	Reporting Year Cost Per Train	Normalized Cost Per Train using CEPCI Index	Capacity Required	Trains Req'd.	Capacity per Train	Factored Cost per Train from Normalized Cost	Total Current Cost for Required Trains
Perry's Chemical Engineering Handbook, 7th Edition	334 tpd	1	1994	\$ 6,600,000	\$ 6,600,000	\$ 9,180,114	5,192 tpd	6	865 tpd	\$ 16,252,129	\$ 97,512,774
Fertilizer Manual	359 tpd	1	1998	\$ 15,200,000	\$ 15,200,000	\$ 19,980,488	5,192 tpd	6	865 tpd	\$ 33,851,959	\$ 203,111,753

Source Selected:

Source	Reported Capacity	Reported Trains	Report Cost Year	Reported Cost	Reporting Year Cost Per Train	Normalized Cost Per Train using CEPCI Index	Capacity Required	Trains Req'd.	Capacity per Train	Factored Cost per Train from Normalized Cost	Total Current Cost for Required Trains
Fertilizer Manual	359 tpd	1	1998	\$ 15,200,000	\$ 15,200,000	\$ 19,980,488	5,192 tpd	6	865 tpd	\$ 33,851,959	\$ 203,111,753

Balance of Plant:

Description	% of Total Cost	Cost Per Train	Total Cost
Water Systems	7.10%	\$ 2,403,489	\$ 14,420,934
Civil/Structural/Buildings	9.20%	\$ 3,114,380	\$ 18,686,281
Piping	7.10%	\$ 2,403,489	\$ 14,420,934
Control and Instrumentation	2.60%	\$ 880,151	\$ 5,280,906
Electrical Systems	8.00%	\$ 2,708,157	\$ 16,248,940
		\$ 11,509,666	\$ 69,057,996
		\$ 45,361,625	\$ 272,169,749
Total Balance of Plant Plus the Selected Source			

Rationale for Selection:

The Fertilizer Manual was selected for being both the newest cost point and the most conservative. The data from Perry's Chemical Engineering Handbook is based on earlier data from Peters and Timmerhaus, making it even less desirable. The allowances listed under 'Balance of Plant' are based on NETL 2000. These allowance values are comparable to additional published estimating guides, such as Page 1996.

Detail Item Report - Ammonium Nitrate Synthesis

Project Name: NGNP Process Integration
 Process: HTSE Ammonia w/o ASU
 Estimate Number: MA36-O

Client: M. Patterson
 Prepared By: B. Wallace, R. Honsinger, J. Martin
 Estimate Type: Class 5

Sources Considered:

Source	Reported Capacity	Reported Trains	Report Cost Year	Reported Cost	Reporting Year Cost Per Train	Normalized Cost Per Train using CEPCI Index	Capacity Required	Trains Req'd.	Capacity per Train	Factored Cost per Train from Normalized Cost	Total Current Cost for Required Trains
Perry's Chemical Engineering Handbook, 7th Edition	334 tpd	1	1994	\$ 6,000,000	\$ 6,000,000	\$ 8,345,558	3,779 tpd	3	1,260 tpd	\$ 18,507,052	\$ 55,521,157
Fertilizer Manual	1,395 tpd	1	1998	\$ 35,000,000	\$ 35,000,000	\$ 46,007,702	3,779 tpd	3	1,260 tpd	\$ 43,270,765	\$ 129,812,295
EPA Report	1,200 tpd	1	1981	\$ 9,480,000	\$ 9,480,000	\$ 13,434,154	3,779 tpd	3	1,260 tpd	\$ 13,831,044	\$ 41,493,133

Source Selected:

Source	Reported Capacity	Reported Trains	Report Cost Year	Reported Cost	Reporting Year Cost Per Train	Normalized Cost Per Train using CEPCI Index	Capacity Required	Trains Req'd.	Capacity per Train	Factored Cost per Train from Normalized Cost	Total Current Cost for Required Trains
Fertilizer Manual	1,395 tpd	1	1998	\$ 35,000,000	\$ 35,000,000	\$ 46,007,702	3,779 tpd	3	1,260 tpd	\$ 43,270,765	\$ 129,812,295

Balance of Plant:

Description	% of Total Cost	Cost Per Train	Total Cost
Water Systems	7.10%	\$ 3,072,224	\$ 9,216,673
Civil/Structural/Buildings	9.20%	\$ 3,980,910	\$ 11,942,731
Piping	7.10%	\$ 3,072,224	\$ 9,216,673
Control and Instrumentation	2.60%	\$ 1,125,040	\$ 3,375,120
Electrical Systems	8.00%	\$ 3,461,661	\$ 10,384,984
		Total Balance of Plant	\$ 14,712,060
		Total Balance of Plant Plus the Selected Source	\$ 57,982,825
			\$ 173,948,476

Rationale for Selection:

The Fertilizer Manual was selected for being both the newest cost point and the most conservative. The data from Perry's Chemical Engineering Handbook is based on earlier data from Peters and Timmerhaus, making it even less desirable. The allowances listed under 'Balance of Plant' are based on NETL 2000. These allowance values are comparable to additional published estimating guides, such as Page 1996.

Client: M. Patterson
Prepared By: B. Wallace, R. Honsinger, J. Martin
Estimate Type: Class 5

Source	Reported Capacity	Reported Trains	Report Cost Year	Reported Cost	Reporting Year Cost Per Train	Normalized Cost Per Train using CEPCI Index	Capacity Required	Trains Req'd.	Capacity per Train	Factored Cost per Train from Normalized Cost	Total Current Cost for Required Trains
Steam Turbine and HRSG											
	189	MW	1	1999	\$ 50,671,000	\$ 50,671,000	159	MW	1	\$ 59,899,366	\$ 59,899,366
Steam Turbine											
	401	MW	4	2006	\$ 74,651,000	\$ 18,662,750	159	MW	1	\$ 25,233,335	\$ 25,233,335
	275	MW	1	2007	\$ 66,700,000	\$ 66,700,000	159	MW	1	\$ 46,806,721	\$ 46,806,721
	230	MW	1	2006	\$ 44,515,000	\$ 44,515,000	159	MW	1	\$ 36,576,204	\$ 36,576,204

Source	Reported Capacity	Reported Trains	Report Cost Year	Reported Cost	Reporting Year Cost Per Train	Normalized Cost Per Train using CEPCI Index	Capacity Required	Trains Req'd.	Capacity per Train	Factored Cost per Train from Normalized Cost	Total Current Cost for Required Trains
Shell IGCC Power Plant with CO2 Capture (NETL 2007b)	230 MW	1	2006	\$ 44,515,000	\$ 44,515,000	\$ 45,619,856	159 MW	1	159 MW	\$ 36,576,204	\$ 36,576,204

[illegible]

Shell IGCC PowerPlant with CO2 Capture (NETL 2007b) is a recently reported cost point that closely reflects this project's requirements. The Princeton Report (Kreutz 2008) source for the steam turbine cost point is the NETL (2007b) report. The allowances listed under 'Balance of Plant' are based on NETL 2000. These allowance values are comparable to additional published estimating guides, such as Page 1996.

Client: M. Patterson
Prepared By: B. Wallace, R. Honsinger, J. Martin
Estimate Type: Class 5

Source	Reported Capacity	Reported Trains	Report Cost Year	Reported Cost	Reporting Year Cost Per Train	Normalized Cost Per Train using CEPCI Index	Capacity Required	Trains Req'd.	Capacity per Train	Factored Cost per Train from Normalized Cost	Total Current Cost for Required Trains
Steam Turbine and HRSG											
Shell IGCC Base Cases (NETL 2000)	189	1	1999	\$ 50,671,000	\$ 50,671,000	\$ 66,419,744	-	MW	1	-	\$ -
HRSG											
NETL Baseline Report (NETL 2007a)	5,155,983	3	2006	\$ 27,581,000	\$ 9,193,667	\$ 9,421,852	-	lb/hr	1	-	\$ -
Princeton Report (Kreutz 2008)	355	1	2007	\$ 52,000,000	\$ 52,000,000	\$ 50,673,772	-	MW	1	-	\$ -
Shell IGCC Power Plant with CO2 Capture (NETL 2007b)	8,438,000	2	2006	\$ 45,291,000	\$ 22,645,500	\$ 23,207,558	-	lb/hr	1	-	\$ -

Source	Reported Capacity	Reported Trains	Report Cost Year	Reported Cost	Reporting Year Cost Per Train	Normalized Cost Per Train using CEPCI Index	Capacity Required		Trains Req'd.	Capacity per Train		Factored Cost per Train from Normalized Cost	Total Current Cost for Required Trains
Shell IGCC Power Plant with CO ₂ Capture (NETL 2007b)													
	8,438,000	lb/hr	2	2006	\$ 45,291,000	\$ 22,645,500	-	lb/hr	1	-	lb/hr	\$ -	\$ -

[illegible]

Shell IGCC PowerPlant with CO2 Capture (NETL 2007b) is a recently reported cost point that closely reflects this project's requirements. The Princeton Report (Kreutz 2008) source for the steam turbine cost point is the NETL 2007b report. The allowances listed under 'Balance of Plant' are based on NETL 2000. These allowance values are comparable to additional published estimating guides, such as Page 1996.

Detail Item Report - Cooling Towers

Project Name: NGNP Process Integration
Process: HTSE Ammonia w/o ASU
Estimate Number: MA36-O

Client: M. Patterson
Prepared By: B. Wallace, R. Honsinger, J. Martin
Estimate Type: Class 5

Sources Considered:

Source	Reported Capacity	Reported Trains	Report Cost Year	Reported Cost	Reporting Year Cost Per Train	Normalized Cost Per Train using CEPCI Index	Capacity Required	Trains Req'd.	Capacity per Train	Factored Cost per Train from Normalized Cost	Total Current Cost for Required Trains
Cooling Tower Depot	182,142 gpm	5	2009	\$ 4,611,840	\$ 922,368	\$ 922,368	160,853 gpm	5	32,171 gpm	\$ 856,084	\$ 4,280,419

Source Selected:

Source	Reported Capacity	Reported Trains	Report Cost Year	Reported Cost	Reporting Year Cost Per Train	Normalized Cost Per Train using CEPCI Index	Capacity Required	Trains Req'd.	Capacity per Train	Factored Cost per Train from Normalized Cost	Total Current Cost for Required Trains
Cooling Tower Depot	182,142 gpm	5	2009	\$ 4,611,840	\$ 922,368	\$ 922,368	160,853 gpm	5	32,171 gpm	\$ 856,084	\$ 4,280,419

Balance of Plant:

Description	% of Total Cost	Cost Per Train	Total Cost
Water Systems	7.10%	\$ 60,782	\$ 303,910
Civil/Structural/Buildings	9.20%	\$ 78,760	\$ 393,799
Piping	7.10%	\$ 60,782	\$ 303,910
Control and Instrumentation	2.60%	\$ 22,258	\$ 111,291
Electrical Systems	8.00%	\$ 68,487	\$ 342,434
		Total Balance of Plant	\$ 291,069
		Total Balance of Plant Plus the Selected Source	\$ 1,147,152
			\$ 5,735,762

Rationale for Selection:

Single source cost. Publically available current data. Calculated capital costs based on publically available cost data from a vendor regularly engaged in the building of cooling towers. The allowances listed under 'Balance of Plant' are based on NETL 2000. These allowance values are comparable to additional published estimating guides, such as Page 1996.

NGNP HTSE Ammonia with ASU Summary


Project Name: NGNP Process Integration
 Process: HTSE Ammonia with ASU
 Estimate Number: MA36-P

Client: M. Patterson
 Prepared By: B. Wallace, R. Honsinger, J. Martin
 Estimate Type: Class 5

Process Component	Subtotal From Detail Sheets	Engineering %	Engineering	Contingency %	Contingency	Total Cost
High Temperature Gas Reactor (HTGR)	\$ 3,666,008.904	0%	\$ -	0%	\$ -	\$ 3,666,008.904
Rankine Power Cycle	\$ 568,211.288	10%	\$ 56,821.129	18%	\$ 112,505.835	\$ 737,538.252
High Temperature Steam Electrolysis (HTSE)	\$ 308,019.178	10%	\$ 30,801.918	18%	\$ 60,987.797	\$ 399,808.893
Air Separation Unit (ASU)	\$ 49,029.331	10%	\$ 4,902.933	18%	\$ 9,707.808	\$ 63,640.072
CO2 Generation	\$ 15,022.226	10%	\$ 1,502.223	18%	\$ 2,974.401	\$ 19,498.850
Methanation	\$ 9,518.338	10%	\$ 951.834	18%	\$ 1,884.631	\$ 12,354.803
Ammonia Synthesis	\$ 297,160.814	10%	\$ 29,716.081	18%	\$ 58,837.841	\$ 385,714.736
Urea Synthesis	\$ 288,347.019	10%	\$ 28,834.702	18%	\$ 57,092.710	\$ 374,274.430
Nitric Acid Synthesis	\$ 272,169.749	10%	\$ 27,216.975	18%	\$ 53,889.610	\$ 353,276.334
Ammonium Nitrate Synthesis	\$ 173,948.476	10%	\$ 17,394.848	18%	\$ 34,441.798	\$ 225,785.122
Steam Turbines	\$ 43,617.835	10%	\$ 4,361.783	18%	\$ 8,636.331	\$ 56,615.949
Cooling Towers	\$ 5,927.569	10%	\$ 592.757	18%	\$ 1,173.659	\$ 7,693.985
Total Cost - HTSE Ammonia with ASU						\$ 6,302,210.330
Total Cost Rounded to the Nearest \$10M						\$ 6,300,000,000

Checked By: 	Remarks
Approved By: 	

COST ESTIMATE SUPPORT DATA RECAPITULATION

Project Title: NGNP Process Integration – HTSE Ammonia with ASU
Estimator: B. W. Wallace/CEP, R. R. Honsinger/CEP, J. B. Martin/CCT
Date: April 20, 2010
Estimate Type: Class 5
File: MA36-P
Approved By: 

Page 1 of 9

- I. **PURPOSE:** *Brief description of the intent of how the estimate is to be used (i.e., for engineering study, comparative analysis, request for funding, proposal, etc.).*

It is expected that the capital costs identified in these estimates will be used in a model producing an economic analysis for each specific integrated application and subsequently will be considered in a related feasibility study.

- II. **SCOPE OF WORK:** *Brief statement of the project's objective. Thorough overview and description of the proposed project. Identify work to be accomplished, as well as any specific work to be excluded.*

A. **Objective:**

Develop Class 5 estimates as defined by the Association for Advancement of Cost Engineering (AACEi) that will identify the current capital cost associated with high-temperature gas reactors (HTGRs) integrated with a nuclear ammonia with the air separation unit process.

B. **Included:**

The scope of work required to achieve this objective includes the following:

1. Engineering
2. The allowance provided for the HTGR represents a complete and operable system. All elements required for construction of this nuclear reactor capability, including an initial steam generator, security systems, contingency, and owner's costs are included in the turn-key allowance. Owner's costs are included only in the case of the reactor capability. It is considered that the total value represents all inside of battery limits (ISBL) elements, outside of battery limits (OSBL) elements, site development, and all ancillary control and operational functions and capabilities.
3. Construction of a new integrated refinery capability to produce ammonia that consists of the following:
 - a. Overnight island-type costs for HTGRs
 - b. High-temperature steam electrolysis (HTSE) hydrogen production unit
 - c. Air separation unit
 - d. Natural gas combustor (CO₂ generation)
 - e. Methanation
 - f. Ammonia synthesis
 - g. Urea synthesis
 - h. Nitric acid synthesis

COST ESTIMATE SUPPORT DATA RECAPITULATION

– Continued –

Project Title: NGNP Process Integration – HTSE Ammonia with ASU
File: MA36-P

Page 2 of 9

- i. Ammonium nitrate synthesis
- j. Steam turbines, internal to process
- k. Heat recovery steam generator, internal to process
- l. Cooling towers, internal to process
- m. Allowances for Balance of Plant (BOP)/offsite/OSBL, including the following:
 - (1.) Site development/improvements
 - (2.) Provisions for general and administrative buildings and structures
 - (3.) Provisions for OSBL piping
 - (4.) Provisions for OSBL instrumentation and control
 - (5.) Provisions for OSBL electrical
 - (6.) Provisions for facility supply and OSBL water systems
 - (7.) Provisions for site development/improvements
 - (8.) Project/construction management.

C. Excluded:

This scope of work specifically excludes the following elements:

- 1. Licensing and permitting costs
- 2. Operational costs
- 3. Land costs
- 4. Sales taxes
- 5. Royalties
- 6. Owner's fees and owner's costs, except those included for the HTGR
- 7. The allowance provided for the HTGR capability excludes all costs associated with materials development, or costs that would not be appropriately associated with an nth of a kind (NOAK) reactor/facility.

III. ESTIMATE METHODOLOGY: *Overall methodology and rationale of how the estimate was developed (i.e., parametric, forced detail, bottoms up, etc.). Total dollars/hours and rough order magnitude (ROM) allocations of the methodologies used to develop the cost estimate.*

Consistent with the AACEi Class 5 estimates, the level of definition and engineering development available at the time they were prepared, their intended use in a feasibility study, and the time and resources available for their completion, the costs included in this estimate have been developed using parametric evaluations. These evaluations have used publicly available and published project costs to represent similar islands utilized in this project. Analysis and selection of the published costs used have been performed by the project technical lead and Cost Estimating. Suitability for use in this effort was determined considering the correctness and completeness of the data available, the manner in which total capital costs were represented, the age of the previously performed work, and the similarity to the capacity/trains required by this project. The specific sources, selected and used in this cost estimate, are identified in the capital cost estimate detail sheets.

Adjustments have been made to these published costs using escalation factors identified in the Chemical Engineering Price Cost Index. Scaling of the published island costs has been

COST ESTIMATE SUPPORT DATA RECAPITULATION

– Continued –

Project Title: NGNP Process Integration – HTSE Ammonia with ASU
File: MA36-P

Page 3 of 9

accomplished using the six-tenths capacity factoring method. Costs included for the HTGR, power cycles, and HTSE, have been identified and provided by the respective BEA subject matter experts. The total cost for each of these items has been linearly calculated from the respective base unit costs. Any normalization to provide for geographic factors was considered using geographic factors available from RS Means Construction Cost Data references. Cost-estimating relationships have been used to identify allowances to complete the costs.

It was identified to the Next Generation Nuclear Plant (NGNP) Process Integration team that the methodology employed by NGNP to develop the nuclear capability included constituents of parametric modeling, vendor quotes, actual costs, and proprietary costing databases. These preconceptual design estimates were reviewed by NGNP Project Engineering for credibility with regard to assumptions and bases of estimate and performed multiple studies to reconcile variations in the scope and assumptions within the three estimates.

BOP/OSBL costs were determined by the project team, considering data provided by Shell Gasifier IGCC Base Case report NETL 2000, *Conceptual Cost Estimating Manual* Second Edition by John S. Page, and additional adjusted sources. Because the allowances identified did not show significant variability, the allowances identified in the NETL 2000 report were chosen for this effort in order to minimize the mixing of data sources.

IV. BASIS OF THE ESTIMATE: *Overall explanation of sources for resource pricing and schedules.*

A. **Quantification Basis:** *The source for the measurable quantities in the estimate that can be used in support of earned value management. Source documents may include drawings, design reports, engineers' notes, and other documentation upon which the estimate is originated.*

All islands and capacities have been provided to Cost Estimating by the respective project expert.

B. **Planning Basis:** *The source for the execution and strategies of the work that can be used to support the project execution plan, acquisition strategy, schedules, and market conditions and other documentation upon which the estimate is originated.*

1. All islands and HTGRs represent NOAK projects.
2. Projects will be constructed and operated by commercial entities.
3. All projects, with the exception of the Steam-Assisted Gravity Drainage Project, will be located in the U.S. Gulf Coast refinery region.
4. Costs are presented as overnight costs.
5. The cost estimate does not consider or address funding or labor resource restrictions. Sufficient funding and labor resources will be available in a manner that allows optimum usage of the funding and resources as estimated and scheduled.

COST ESTIMATE SUPPORT DATA RECAPITULATION

– Continued –

Project Title: NGNP Process Integration – HTSE Ammonia with ASU
File: MA36-P

Page 4 of 9

C. **Cost Basis:** *The source for the costing on the estimate that can be used in support of earned value management, funding profiles, and schedule of values. Sources may include published costing references, judgment, actual costs, preliminary quotes or other documentation upon which the estimate is originated.*

1. All costs are represented as current value costs. Factors for forward-looking escalation and inflation factors are not included in this estimate.
2. Where required, published cost factors, as identified in the Chemical Engineering Plant Cost Index, will be applied to previous years' values to determine current year values.
3. Geographic location factors, as identified in RS Means Construction Cost Data reference manual, were considered for each source cost.
4. The cost provided for the HTGR reflects internal BEA cost data that was developed for the HTGR and presented to the NGNP Process Integration team by L. Demmick. Considered in the cost is a pre-conceptual cost estimate prepared by three separate contractor teams. All contractor teams proposed 4-unit NOAK plants with thermal power levels between 2,000 MW_t and 2,400 MW_t at a cost of roughly \$4B, including owner's cost. This equates to \$1,667 to \$2,000 per kW_t. For the purposes of this report, the nominal cost of an HTGR will be set at the upper end of this range, \$2,000 per kW_t. This is a complete turnkey cost and includes engineering and construction of a NOAK HTGR, the power cycle, and contingency. The total HTGR cost for each process is calculated linearly as \$1,708,333 per MW_{th} of required capacity, excluding the cost of the power cycles.
5. The cost included for the power cycle was provided by the INL project team expert. The power cycle cost is based on the definition of a 240-MWe capacity and \$618,176 per MWe. The total power cycle cost for each process is calculated linearly as \$618,176 per MWe of required capacity. BOP, engineering, and contingency costs are added to the base cost.
6. The cost included for HTSE was provided by the INL project team expert. The total HTSE cost for each process is calculated linearly as \$36,120,156 per kg/s of required capacity. BOP, engineering, and contingency costs are added to the base cost.
7. Apt, Jay, et al., *An Engineering-Economic Analysis of Syngas Storage*, NETL, July 2008.
8. AACEi, *Recommended Practices*, website, visited November 16, 2009, <http://www.aacei.org/technical/rp.shtml>.
9. Brown, L. C., et al., "Alternative Flowsheets for the Sulfur-Iodine Thermochemical Hydrogen Cycle," *General Atomics*, February 2003.
10. CEPCI, *Chemical Engineering Magazine*, "Chemical Engineering Plant Cost Index," November 2009: 64.
11. Choi, 1996, Choi, Gerald N., et al, *Design/Economics of a Once-Through Natural Gas Fischer-Tropsch Plant with Power Co-Production*, Bechtel, 1996.
12. Dooley, J., et al, *Carbon Dioxide Capture and Geologic Storage*, Battelle, April 2006.

COST ESTIMATE SUPPORT DATA RECAPITULATION

– Continued –

Project Title: NGNP Process Integration – HTSE Ammonia with ASU
File: MA36-P

Page 5 of 9

13. Douglas, Fred R., et al., *Conduction Technical and Economic Evaluations – as Applied for the Process and Utility Industries*, AACEi, April 1991.
14. FLUOR/UOP, 2004, Mak, John Y., et al., *Synthesis Gas Purification in Gasification to Ammonia/Urea Complex*, FLUOR/UOP, 2004.
15. Friedland, Robert J., et al., *Hydrogen Production Through Electrolysis*, NREL, June 2002.
16. Gray, 2004, Gray, David, et al., *Polygeneration of SNG, Hydrogen, Power, and Carbon Dioxide from Texas Lignite*, MTR-04, 2004-18, NETL, December 2004.
17. Harvego, E. A., et al., *Economic Analysis of a Nuclear Reactor Powered High-Temperature Electrolysis Hydrogen Production Plant*, INL, August 2008.
18. Harvego, E. A., et al., *Economic Analysis of the Reference Design for a Nuclear-Driven High-Temperature-Electrolysis Hydrogen Production Plant*, INL, January 2008.
19. Ivy, Johanna, *Summary of Electrolytic Hydrogen Production*, NREL September 2004.
20. Ibsen, Kelly, et al., *Equipment Design and Cost Estimation for Small Modular Biomass Systems, Synthesis Gas Cleanup, and Oxygen Separation Equipment*, NREL, May 2006.
21. Klett, Michael G., et al., *The Cost of Mercury Removal in an IGCC Plant*, NETL, September 2002.
22. Kreutz, 2008, Kreutz, Thomas G., et al., “Fischer-Tropsch Fuels from Coal and Biomass,” *25th Annual International Pittsburgh Coal Conference*, Pittsburgh, Princeton University, October 2008.
23. Loh, H. P., et al., *Process Equipment Cost Estimation*, DOE/NETL-2002/1169, NETL, 2002.
24. NETL, 2000, Shelton, W., et al., *Shell Gasifier IGCC Base Cases*, PED-IGCC-98-002, NETL, June 2000.
25. NETL, 2007a, Van Bibber, Lawrence, *Baseline Technical and Economic Assessment of a Commercial Scale Fischer-Tropsch Liquids Facility*, DOE/NETL-207/1260, NETL, April 2007.
26. NETL, 2007b, Woods, Mark C., et al., *Cost and Performance Baseline for Fossil Energy Plants*, NETL, August 2007.
27. NREL, 2005, Saur, Genevieve, *Wind-To-Hydrogen Project: Electrolyzer Capital Cost Study*, NREL, December 2008.
28. O’Brien, J. E., et al., *High-Temperature Electrolysis for Large-Scale Hydrogen and Syngas Production from Nuclear Energy – System Simulation and Economics*, INL, May 2009.
29. O’Brien, J. E., et al., *Parametric Study of Large-Scale Production of Syngas via High-Temperature Co-Electrolysis*, INL, January 2009.
30. Page, John S., *Conceptual Cost Estimating Manual – 2nd ed.*, Houston: Gulf Publishing Company, 1996.
31. Pietlock, Bernard A., et al., *Developing Location Factors by Factoring- as Applied in Architecture, Engineering, Procurement, and Construction*, AACEi, October 2006.

COST ESTIMATE SUPPORT DATA RECAPITULATION

– Continued –

Project Title: NGNP Process Integration – HTSE Ammonia with ASU
File: MA36-P

Page 6 of 9

32. Ramsden, Todd, et al., *Current (2005) Hydrogen Production from Central Grid Electrolysis*, NREL, May 2008.
33. Ramsden, Todd, et al., *Longer-Term (2025) Hydrogen Production from Central Grid Electrolysis*, NREL, May 2008.
34. Richardson Construction Estimating Standards, *Process Plant Cooling Towers*, Cost Data Online, September 16, 2009, website, visited December 15, 2009, <http://www.costdataonline.com/>.
35. Sohal, M. S., et al., *Challenges in Generating Hydrogen by High Temperature Electrolysis Using Solid Oxide Cells*, INL, March 2008.
36. Steinberg, Meyer, *Conversion of Coal to Substitute Natural Gas (SNG)*, HCE, 2005.
37. Udengaard, 2008, Udengaard, Niels R., et al., *Convert Coal, petcoke into valuable SNG*, Haldor Topsoe, April 2008.
38. van der Ploeg, H. J., et al., *The Shell Coal Gasification Process for the US Industry*, Shell, October 2004.
39. WorleyParsons, 2002, Rameshni, Mahin, *Cost Effective Options to Expand SRU Capacity Using Oxygen*, WorleyParsons, May 2002.

V. **ESTIMATE QUALITY ASSURANCE:** *A listing of all estimate reviews that have taken place and the actions taken from those reviews.*

A review of the cost estimate was held on January 14, 2010, with the project team and the cost estimators. This review allowed for the project team to review and comment, in detail, on the perceived scope, basis of estimates, assumptions, project risks, and resources that make up this cost estimate. Comments from this review have been incorporated into this estimate to reflect a project team consensus of this document.

VI. **ASSUMPTIONS:** *Condition statements accepted or supposed true without proof of demonstration; statements adding clarification to scope. An assumption has a direct impact on total estimated cost.*

General Assumptions:

- A. All costs are represented in 2009 values.
- B. Costs that were included from sources representing years prior to 2009 have been normalized to 2009 values using the Chemical Engineering Plant Cost Index. This index was selected due to its widespread recognition and acceptance and its specific orientation toward work associated with chemical and refinery plants.
- C. Capital costs are based on process islands. The majority of these islands are interchangeable, after factoring for the differing capacities, flowsheet-to-flowsheet.
- D. All chemical processing and refinery processes will be located in the U.S. Gulf Coast region.
- E. All costs considered to be BOP costs that can be specifically identified have been factored out of the reported source data and added into the estimate in a manner consistent with that identified in the NETL 2000 IGCC Base Cost report. Inclusion of the source costs in this manner normalizes all reported cost information to the bare-erected costs.

COST ESTIMATE SUPPORT DATA RECAPITULATION

– Continued –

Project Title: NGNP Process Integration – HTSE Ammonia with ASU
File: MA36-P

Page 7 of 9

HTGR:

- A. The linearly scalable cost included for an HTGR reflects an NOAK reactor with a 750°C-operating temperature.
- B. HTGR is considered to be linearly scalable, by required capacity, per the direction of the project team. This allows the process integration feasibility studies to showcase the financial analysis of the process without the added burden of integer quantity 600-MWth HTGRs.
- C. The allowance represents a turnkey condition for the reactor and its supporting infrastructure.
- D. A high-temperature, high-pressure steam generator is included in the cost represented for HTGR.
- E. A contingency allowance is included in the HTGR cost, but is not identified as a separate line item in this estimate. This allowance was identified and included by the NGNP HTGR project team.
- F. Total cost range, including contingency, for HTGR is -50%, +100%.
- G. Cost included for the power cycle reflects NOAK research and manufacturing developments to allow for assumed high pressures and temperatures.
- H. The power cycle is considered to be linearly scalable, by required capacity, per the direction of the project team. This allows the process integration feasibility studies to showcase the financial analysis of the process.
- I. The cost included for HTSE reflects NOAK research and manufacturing developments, which will increase the expected lifespan of the electrolysis cells.
- J. The HTSE is considered to be linearly scalable, by required capacity, per the direction of the project team. This allows the process integration feasibility studies to showcase the financial analysis of the process.

HTSE Ammonia with Air Separation Unit

Some estimated island costs are based on figures from a verbal conversation with Casale, a leading world vendor of process industry services. These costs were used in cases where other acceptable costs were not available.

VII. CONTINGENCY GUIDELINE IMPLEMENTATION:

Contingency Methodologies: *Explanation of methodology used in determining overall contingency. Identify any specific drivers or items of concern.*

At a project risk review on December 9, 2009, the project team discussed risks to the project. An 18% allowance for capital construction contingency has been included at an island level based on the discussion and is included in the summary sheet. The contingency level that was included in the island cost source documents and additional threats and opportunities identified here were considered during this review. The contingency identified was considered by the project team and included in Cost and Performance Baseline for Fossil Energy Plants DOE/NETL-2007/1281 and similar reports. Typically, contingency allowance provided in these reports ranged from 15% to 20%. Since much of

COST ESTIMATE SUPPORT DATA RECAPITULATION

– Continued –

Project Title: NGNP Process Integration – HTSE Ammonia with ASU
File: MA36-P

Page 8 of 9

the data contained in this estimate has been derived from these reports, the project team has also chosen a level of contingency consistent with them.

While the level of contingency provided for the HTGR capability is not identified as a line item, the cost data provided to the NGNP Process Integration team was identified as including an appropriate allocation for contingency. No additional contingency has been added to this element.

A. **Threats:** *Uncertain events that are potentially negative or reduce the probability that the desired outcome will happen.*

1. The singularly largest threat to this estimate surrounds the lump sum cost included for the HTGR reactor(s). This is followed by the HTSE process, where applicable. While the overriding assumption is that these elements will be NOAK, currently, a complete HTGR has not been commissioned and the HTSE has been successfully developed in an integrated laboratory-scale model, but has not been completed in either pilot plant or production scales.
2. The level of project definition/development that was available at the time the estimate was prepared represents a substantial risk to the project and is likely to occur. The high level at which elements were considered and included has the potential to include additional elements that are within the work scope but not sufficiently provided for or addressed at this level.
3. The estimate methodology employed is one of a stochastic parametrically evaluated process. This process used publicly available published costs that were related to the process required, costs were normalized using price indices, and the cost was scaled to provide the required capacity. The cost-estimating relationships that were used represent typical costs for BOP allowances, but source cost data from which the initial island costs were derived were not completely descriptive of the elements included, not included, or simply referred to with different nomenclature or combined with other elements. While every effort has been made to correctly normalize and factor the costs for use in this effort, the risk exists that not all of these were correctly captured due to the varied information available.
4. This project is heavily dependent on metals, concrete, petroleum, and petroleum products. Competition for these commodities in today's environment due to global expansion, uncertainty, and product shortages affects the basic concepts of the supply and demand theories, thus increasing costs.
5. Impacts due to large quantities of materials, special alloy materials, fabrication capability, and labor availability could all represent conditions that may increase the total cost of the project.

COST ESTIMATE SUPPORT DATA RECAPITULATION

– Continued –

Project Title: NGNP Process Integration – HTSE Ammonia with ASU
File: MA36-P

Page 9 of 9

B. **Opportunities:** *Uncertain events that could improve the results or improve the probability that the desired outcome will happen.*

1. Additional research and work performed with both vendors and potential owner/operators for a specific process or refinery may identify efficiencies and production means that have not been available for use in this analysis.
2. Recent historical data may identify and include technological advancements and efficiencies not included or reflected in the publicly available source data used in this effort.

Note: Contingency does not increase the overall accuracy of the estimate; it does, however, reduce the level of risk associated with the estimate. Contingency is intended to cover the inadequacies in the complete project scope definition, estimating methods, and estimating data. Contingency specifically excludes changes in project scope, unexpected work stoppages (e.g., strikes, disasters, and earthquakes) and excessive or unexpected inflation or currency fluctuations.

VIII. **OTHER COMMENTS/CONCERNS SPECIFIC TO THE ESTIMATE:**

None.

Client: M. Patterson
Prepared By: B. Wallace, R. Honsinger, J. Martin
Estimate Type: Class 5

[illegible]

Source	Reported Capacity	Reported Trains	Report Cost Year	Reported Cost	Reporting Year Cost Per Train	Normalized Cost Per Train using CEPCI Index	Capacity Required	Trains Req'd.	Capacity per Train	Factored Cost per Train from Normalized Cost	Total Current Cost for Required Trains
(INL Internal Cost Data (INL 2009)	1	MWth	2009	\$ 1,708,333	\$ 1,708,333	\$ 1,708,333	2,146 MWt/h			\$ 3,666,008,904	\$ 3,666,008,904

[illegible]

Single source cost point. This cost has been provided by the subcontracted subject matter expert L. Demick to the INL NGNP Process Integration team. This cost represents a complete turnkey cost. The cost of an HTGR reactor, as provided by L. Demick, is \$2,000,000 per MWe required. This cost used has been reduced to \$1,708,333 per MWe to exclude the cost of power cycles.

Client: M. Patterson
Prepared By: B. Wallace, R. Honsinger, J. Martin
Estimate Type: Class 5

[illegible][illegible][illegible]

Single source cost. The reported costs are from the INL project team expert. The reported cost represents a Rankine power cycle, excluding the steam generator. The cost is based on information found in NETL 2007b, which has been adjusted and customized for this project by the INL project team expert. The allowances listed under 'Balance of Plant' are based on NETL 2000. These allowance values are comparable to additional published estimating guides, such as Page 1996. The allowances have been adjusted and customized for this project based on estimator judgment. The reduced civil/structural/buildings allowance accounts for the buildings that are included in the Rankine power cycle cost. Water and electrical systems BOP allowances are included in the reported cost for the Rankine power cycle.

Detail Item Report - High Temperature Steam Electrolysis (HTSE)

Project Name: NGNP Process Integration
Process: HTSE Ammonia with ASU
Estimate Number: MA36-P

Client: M. Patterson
Prepared By: B. Wallace, R. Honsinger, J. Martin
Estimate Type: Class 5

Sources Considered:

Source	Reported Capacity	Reported Trains	Report Cost Year	Reported Cost	Reporting Year Cost Per Train	Normalized Cost Per Train using CEPCI Index	Capacity Required	Trains Req'd.	Capacity per Train	Factored Cost per Train from Normalized Cost	Total Current Cost for Required Trains
INL Internal Cost Data (INL 2009)	1.00	kg/s	2009	\$ 36,120,156	\$ 36,120,156	\$ 36,120,156	6.36	kg/s		\$ 229,865,058	\$ 229,865,058

Source Selected:

Source	Reported Capacity	Reported Trains	Report Cost Year	Reported Cost	Reporting Year Cost Per Train	Normalized Cost Per Train using CEPCI Index	Capacity Required	Trains Req'd.	Capacity per Train	Factored Cost per Train from Normalized Cost	Total Current Cost for Required Trains
INL Internal Cost Data (INL 2009)	1.00	kg/s	2009	\$ 36,120,156	\$ 36,120,156	\$ 36,120,156	6.36	kg/s		\$ 229,865,058	\$ 229,865,058

Balance of Plant:

Description	% of Total Cost	Cost Per Train	Total Cost
Water Systems		\$ 16,320,419	\$ 16,320,419
Civil/Structural/Buildings	7.10%	\$ 21,147,585	\$ 21,147,585
Piping	9.20%	\$ 16,320,419	\$ 16,320,419
Control and Instrumentation	7.10%	\$ 5,976,492	\$ 5,976,492
Electrical Systems	2.60%	\$ 18,389,205	\$ 18,389,205
	8.00%	\$ 78,154,120	\$ 78,154,120
		Total Balance of Plant	
		Total Balance of Plant Plus the Selected Source	\$ 308,019,178

Basis of Estimate Notes:

Single source cost. The reported costs are from the INL project team expert. The cost is based on information from Harvego 2008, Solid State Energy Conversion Alliance, and discussions between INL engineers and Ceramater and Proton Energy. The allowances listed under 'Balance of Plant' are based on NETL 2000. These allowance values are comparable to additional published estimating guides, such as Page 1996.

Detail Item Report - Air Separation Unit (ASU)

Project Name: NGNP Process Integration
Process: HTSE Ammonia with ASU
Estimate Number: MA36-P

Client: M. Patterson
Prepared By: B. Wallace, R. Honsinger, J. Martin
Estimate Type: Class 5

Sources Considered:

Source	Reported Capacity	Reported Trains	Report Cost Year	Reported Cost	Reporting Year Cost Per Train	Normalized Cost Per Train using CEPCI Index	Capacity Required	Trains Req'd.	Capacity per Train	Factored Cost per Train from Normalized Cost	Total Current Cost for Required Trains
Shell IGCC Base Case (NETL 2000)	213,207 lb/hr	1	1999	\$ 51,204,000	\$ 51,204,000	\$ 67,118,402	65,715 lb/hr	1	65,715 lb/hr	\$ 33,125,271	\$ 39,836,648
NETL Baseline Report (NETL 2007a)	1,728,789 lb/hr	2	2006	\$ 287,187,000	\$ 143,593,500	\$ 147,157,470	65,715 lb/hr	1	65,715 lb/hr	\$ 31,358,395	\$ 37,711,792
Princeton Report (Kreutz 2008)	201,264 lb/hr	1	2007	\$ 105,000,000	\$ 105,000,000	\$ 102,322,040	65,715 lb/hr	1	65,715 lb/hr	\$ 52,276,709	\$ 62,868,281
Hydrogen Report (Gray 2004)	296,583 lb/hr	1	2004	\$ 76,000,000	\$ 76,000,000	\$ 87,600,180	65,715 lb/hr	1	65,715 lb/hr	\$ 35,466,315	\$ 35,466,315
Shell GTC Report (Shell 2004)	385,259 lb/hr	1	2004	\$ 53,760,000	\$ 53,760,000	\$ 61,965,601	65,715 lb/hr	1	65,715 lb/hr	\$ 21,443,600	\$ 25,788,201
Shell IGCC Power Plant with CO2 Capture (NETL 2007b)	373,498 lb/hr	2	2006	\$ 144,337,000	\$ 72,168,500	\$ 73,959,712	65,715 lb/hr	1	65,715 lb/hr	\$ 39,522,003	\$ 47,529,396

Source Selected:

Source	Reported Capacity	Reported Trains	Report Cost Year	Reported Cost	Reporting Year Cost Per Train	Normalized Cost Per Train using CEPCI Index	Capacity Required	Trains Req'd.	Capacity per Train	Factored Cost per Train from Normalized Cost	Total Current Cost for Required Trains
Average of normalized and factored costs from NETL 2007a and Gray 2004											
										\$ 33,412,355	\$ 36,589,053

Balance of Plant:

Description	% of Total Cost	Cost Per Train	Total Cost
Water Systems	7.10%	\$ 2,372,277	\$ 2,597,823
Civil/Structural/Buildings	9.20%	\$ 3,073,937	\$ 3,366,193
Piping	7.10%	\$ 2,372,277	\$ 2,597,823
Control and Instrumentation	2.60%	\$ 868,721	\$ 951,315
Electrical Systems	8.00%	\$ 2,672,988	\$ 2,927,124
		\$ 11,360,201	\$ 12,440,278
		\$ 44,772,555	\$ 49,029,331
Total Balance of Plant			
Total Balance of Plant Plus the Selected Source			

Rationale for Selection:

NETL Baseline Report (NETL 2007a) and Hydrogen Report (Gray 2004) have been selected. An average cost of the two has been selected in order to not represent an overly aggressive or conservative cost. The allowances listed under 'Balance of Plant' are based on NETL 2000. These allowance values are comparable to additional published estimating guides, such as Page 1996.

Note: The base ASU cost was multiplied by "1.36*0.6" to account for the increase in oxygen output purity from 95% to 99.5%. The adjustment is based on INL simulations calculating the increase in capacity that would be needed have the required purity output. The Gray 2004 report uses an oxygen purity of 99% and was not adjusted by the "1.36*0.6."

Detail Item Report - CO2 Generation

Project Name: NGNP Process Integration
Process: HTSE Ammonia with ASU
Estimate Number: MA36-P

Client: M. Patterson
Prepared By: B. Wallace, R. Honsinger, J. Martin
Estimate Type: Class 5

Sources Considered:

Source	Reported Capacity	Reported Trains	Report Cost Year	Reported Cost	Reporting Year Cost Per Train	Normalized Cost Per Train using CEPCI Index	Capacity Required	Trains Req'd.	Capacity per Train	Factored Cost per Train from Normalized Cost	Total Current Cost for Required Trains
CO2 Compression - Subcritical Princeton Report (Kreutz 2008)	10	1	2007	\$ 6,310,000	\$ 6,310,000	\$ 6,149,067	2	MW	2	MW \$ 2,329,179	\$ 2,329,179
CO2 Compression - Supercritical Princeton Report (Kreutz 2008)	13	1	2007	\$ 9,520,000	\$ 9,520,000	\$ 9,277,198	0.3	MW	0.3	MW \$ 987,887	\$ 987,887
CO2 Generation CO2 Generator (Wood 2009)	184,095	1	2007	\$ 8,102,200	\$ 8,102,200	\$ 7,895,558	184,017	lb/hr	184,017	lb/hr \$ 7,893,551	\$ 7,893,551

Source Selected:

Source	Reported Capacity	Reported Trains	Report Cost Year	Reported Cost	Reporting Year Cost Per Train	Normalized Cost Per Train using CEPCI Index	Capacity Required	Trains Req'd.	Capacity per Train	Factored Cost per Train from Normalized Cost	Total Current Cost for Required Trains
Kreutz 2008: Combined Subcritical and Supercritical Processes										\$ 11,210,617	\$ 11,210,617

Balance of Plant:

Description	% of Total Cost	Cost Per Train	Total Cost
Water Systems	7.10%	\$ 795,954	\$ 795,954
Civil/Structural/Buildings	9.20%	\$ 1,031,377	\$ 1,031,377
Piping	7.10%	\$ 795,954	\$ 795,954
Control and Instrumentation	2.60%	\$ 291,476	\$ 291,476
Electrical Systems	8.00%	\$ 896,849	\$ 896,849
		Total Balance of Plant	\$ 3,811,610
		Total Balance of Plant Plus the Selected Source	\$ 15,022,226

Rationale for Selection:

Single source cost point. The only CO2 generation source considered was Wood 2009. This cost was supplemented with CO2 compression costs from Kreutz 2008 to represent a full island cost. Both subcritical and supercritical process costs were included under the CO2 Compression heading. The allowances listed under 'Balance of Plant' are based on NETL 2000. These allowance values are comparable to additional published estimating guides, such as Page 1996.

Detail Item Report - Methanation

Project Name: NGNP Process Integration Process: HTSE Ammonia with ASU Estimate Number: MA36-P	Client: M. Patterson Prepared By: B. Wallace, R. Honsinger, J. Martin Estimate Type: Class 5	
--	---	--

Sources Considered:

Source	Reported Capacity	Reported Trains	Report Cost Year	Reported Cost	Reporting Year Cost Per Train	Normalized Cost Per Train using CEPCI Index	Capacity Required	Trains Req'd.	Capacity per Train	Factored Cost per Train from Normalized Cost	Total Current Cost for Required Trains
DOE FE Report (DOE 1978)	1,000 tpd	1	1978	\$ 1,467,000	\$ 1,467,000	\$ 3,432,834	3,360	1	3,360 tpd	\$ 7,103,237	\$ 7,103,237

Source Selected:

Source	Reported Capacity	Reported Trains	Report Cost Year	Reported Cost	Reporting Year Cost Per Train	Normalized Cost Per Train using CEPCI Index	Capacity Required	Trains Req'd.	Capacity per Train	Factored Cost per Train from Normalized Cost	Total Current Cost for Required Trains
DOE FE Report (DOE 1978)	1,000 tpd	1	1978	\$ 1,467,000	\$ 1,467,000	\$ 3,432,834	3,360	1	3,360 tpd	\$ 7,103,237	\$ 7,103,237

Balance of Plant:

Description	% of Total Cost	Cost Per Train	Total Cost
Water Systems			
Civil/Structural/Buildings	7.10%	\$ 504,330	\$ 504,330
Piping	9.20%	\$ 653,498	\$ 653,498
Control and Instrumentation	7.10%	\$ 504,330	\$ 504,330
Electrical Systems	2.60%	\$ 184,684	\$ 184,684
	8.00%	\$ 568,259	\$ 568,259
		Total Balance of Plant	2,415,101
		Total Balance of Plant Plus the Selected Source	\$ 9,518,338

Rationale for Selection:

Single source island cost identified by the project technical lead. The allowances listed under 'Balance of Plant' are based on NETL 2000. These allowance values are comparable to additional published estimating guides, such as Page 1996.

Detail Item Report - Ammonia Synthesis

Project Name: NGNP Process Integration
Process: HTSE Ammonia with ASU
Estimate Number: MA36-P

Client: M. Patterson
Prepared By: B. Wallace, R. Honsinger, J. Martin
Estimate Type: Class 5

Sources Considered:

Source	Reported Capacity	Reported Trains	Report Cost Year	Reported Cost	Reporting Year Cost Per Train	Normalized Cost Per Train using CEPCI Index	Capacity Required	Trains Req'd.	Capacity per Train	Factored Cost per Train from Normalized Cost	Total Current Cost for Required Trains
Vendor - Verbal 2009	360	1	2009	\$ 44,000,000	\$ 44,000,000	\$ 44,000,000	3,360	2	1,680	\$ 110,880,901	\$ 221,761,801
Economics Ammonia Coal Gasification (Morel 1977)	1,000	1	1977	\$ 50,748,000	\$ 50,748,000	\$ 80,243,904	3,360	2	1,680	\$ 109,546,276	\$ 219,092,551
Stamcarbon, Middle East Fertilizer Symposium, March 2009	4,297	1	2008	\$ 800,000,000	\$ 800,000,000	\$ 779,596,498	3,360	2	1,680	\$ 443,768,260	\$ 887,536,519
Ammonia, Chem Systems, 1998	1,653	1	1998	\$ 160,000,000	\$ 160,000,000	\$ 210,320,924	3,360	2	1,680	\$ 212,375,463	\$ 424,750,926

Source Selected:

Source	Reported Capacity	Reported Trains	Report Cost Year	Reported Cost	Reporting Year Cost Per Train	Normalized Cost Per Train using CEPCI Index	Capacity Required	Trains Req'd.	Capacity per Train	Factored Cost per Train from Normalized Cost	Total Current Cost for Required Trains
Vendor - Verbal 2009	360	1	2009	\$ 44,000,000	\$ 44,000,000	\$ 44,000,000	3,360	2	1,680	\$ 110,880,901	\$ 221,761,801

Balance of Plant:

Description	% of Total Cost	Cost Per Train	Total Cost
Water Systems		\$ 7,872,544	\$ 15,745,088
Civil/Structural/Buildings	7.10%	\$ 10,201,043	\$ 20,402,086
Piping	9.20%	\$ 7,872,544	\$ 15,745,088
Control and Instrumentation	7.10%	\$ 2,882,903	\$ 5,765,807
Electrical Systems	2.60%	\$ 8,870,472	\$ 17,740,944
	8.00%	\$ 37,699,506	\$ 75,399,012
		Total Balance of Plant	
		Total Balance of Plant Plus the Selected Source	\$ 148,580,407 \$ 297,160,814

Rationale for Selection:

The verbal cost was selected as recommended by the project team expert. The Stamcarbon information shows a roughly 350% increase in prices between 2003 and 2008 emphasizing the importance of using the most recent information available. The allowances listed under 'Balance of Plant' are based on NETL 2000. These allowance values are comparable to additional published estimating guides, such as Page 1996.

Detail Item Report - Urea Synthesis

Project Name: NGNP Process Integration
 Process: HTSE Ammonia with ASU
 Estimate Number: MA36-P

Client: M. Patterson
 Prepared By: B. Wallace, R. Honsinger, J. Martin
 Estimate Type: Class 5

Sources Considered:

Source	Reported Capacity	Reported Trains	Report Cost Year	Reported Cost	Reporting Year Cost Per Train	Normalized Cost Per Train using CEPCI Index	Capacity Required	Trains Req'd.	Capacity per Train	Factored Cost per Train from Normalized Cost	Total Current Cost for Required Trains
Vendor - Verbal 2009	625	1	2009	\$ 85,000,000	\$ 85,000,000	\$ 85,000,000	2,939	1	2,939	\$ 215,184,342	\$ 215,184,342
Perry's Chemical Engineering Handbook, 7th Edition	200	1	1994	\$ 8,800,000	\$ 8,800,000	\$ 12,240,152	2,939	1	2,939	\$ 61,388,719	\$ 61,388,719
PNL	4681	1	2009	\$ 182,000,000	\$ 182,000,000	\$ 182,000,000	2,939	1	2,939	\$ 137,653,721	\$ 137,653,721
Stamcarbon, Middle East Fertilizer Symposium, March 2009	3,582	1	2008	\$ 550,000,000	\$ 550,000,000	\$ 535,972,592	2,939	1	2,939	\$ 475,978,115	\$ 475,978,115

Source Selected:

Source	Reported Capacity	Reported Trains	Report Cost Year	Reported Cost	Reporting Year Cost Per Train	Normalized Cost Per Train using CEPCI Index	Capacity Required	Trains Req'd.	Capacity per Train	Factored Cost per Train from Normalized Cost	Total Current Cost for Required Trains
Vendor - Verbal 2009	625	1	2009	\$ 85,000,000	\$ 85,000,000	\$ 85,000,000	2,939	1	2,939	\$ 215,184,342	\$ 215,184,342

Balance of Plant:

Description	% of Total Cost	Cost Per Train	Total Cost
Water Systems	7.10%	\$ 15,278,088	\$ 15,278,088
Civil/Structural/Buildings	9.20%	\$ 19,796,959	\$ 19,796,959
Piping	7.10%	\$ 15,278,088	\$ 15,278,088
Control and Instrumentation	2.60%	\$ 5,594,793	\$ 5,594,793
Electrical Systems	8.00%	\$ 17,214,747	\$ 17,214,747
		\$ 73,162,676	\$ 73,162,676
		\$ 288,347,019	\$ 288,347,019

Rationale for Selection:

The verbal cost was selected as recommended by the project team expert. The Stamcarbon information shows a roughly 350% increase in prices between 2003 and 2008 emphasizing the importance of using the most recent information available. The allowances listed under 'Balance of Plant' are based on NETL 2000. These allowance values are comparable to additional published estimating guides, such as Page 1996.

Detail Item Report - Nitric Acid Synthesis

Project Name: NGNP Process Integration
Process: HTSE Ammonia with ASU
Estimate Number: MA36-P

Client: M. Patterson
Prepared By: B. Wallace, R. Honsinger, J. Martin
Estimate Type: Class 5

Sources Considered:

Source	Reported Capacity	Reported Trains	Report Cost Year	Reported Cost	Reporting Year Cost Per Train	Normalized Cost Per Train using CEPCI Index	Capacity Required	Trains Req'd.	Capacity per Train	Factored Cost per Train from Normalized Cost	Total Current Cost for Required Trains
Perry's Chemical Engineering Handbook, 7th Edition	334 tpd	1	1994	\$ 6,600,000	\$ 6,600,000	\$ 9,180,114	5,192 tpd	6	865	\$ 16,251,244	\$ 97,507,466
Fertilizer Manual	359 tpd	1	1998	\$ 15,200,000	\$ 15,200,000	\$ 19,980,488	5,192 tpd	6	865	\$ 33,851,959	\$ 203,111,753

Source Selected:

Source	Reported Capacity	Reported Trains	Report Cost Year	Reported Cost	Reporting Year Cost Per Train	Normalized Cost Per Train using CEPCI Index	Capacity Required	Trains Req'd.	Capacity per Train	Factored Cost per Train from Normalized Cost	Total Current Cost for Required Trains
Fertilizer Manual	359 tpd	1	1998	\$ 15,200,000	\$ 15,200,000	\$ 19,980,488	5,192 tpd	6	865	\$ 33,851,959	\$ 203,111,753

Balance of Plant:

Description	% of Total Cost	Cost Per Train	Total Cost
Water Systems	7.10%	\$ 2,403,489	\$ 14,420,934
Civil/Structural/Buildings	9.20%	\$ 3,114,380	\$ 18,686,281
Piping	7.10%	\$ 2,403,489	\$ 14,420,934
Control and Instrumentation	2.60%	\$ 880,151	\$ 5,280,906
Electrical Systems	8.00%	\$ 2,708,157	\$ 16,248,940
		\$ 11,509,666	\$ 69,057,996
		\$ 45,361,625	\$ 272,169,749

Rationale for Selection:

The Fertilizer Manual was selected for being both the newest cost point and the most conservative. The data from Perry's Chemical Engineering Handbook is based on earlier data from Peters and Timmerhaus, making it even less desirable. The allowances listed under 'Balance of Plant' are based on NETL 2000. These allowance values are comparable to additional published estimating guides, such as Page 1996.

Detail Item Report - Ammonium Nitrate Synthesis

Project Name: NGNP Process Integration Process: HTSE Ammonia with ASU Estimate Number: MA36-P	Client: M. Patterson Prepared By: B. Wallace, R. Honsinger, J. Martin Estimate Type: Class 5	
--	---	--

Sources Considered:

Source	Reported Capacity	Reported Trains	Report Cost Year	Reported Cost	Reporting Year Cost Per Train	Normalized Cost Per Train using CEPCI Index	Capacity Required	Trains Req'd.	Capacity per Train	Factored Cost per Train from Normalized Cost	Total Current Cost for Required Trains
Perry's Chemical Engineering Handbook, 7th Edition	334 tpd	1	1994	\$ 6,000,000	\$ 6,000,000	\$ 8,345,558	3,779 tpd	3	1,260 tpd	\$ 18,507,052	\$ 55,521,157
Fertilizer Manual	1,395 tpd	1	1998	\$ 35,000,000	\$ 35,000,000	\$ 46,007,702	3,779 tpd	3	1,260 tpd	\$ 43,270,765	\$ 129,812,295
EPA Report	1,200 tpd	1	1981	\$ 9,480,000	\$ 9,480,000	\$ 13,434,154	3,779 tpd	3	1,260 tpd	\$ 13,831,044	\$ 41,493,133

Source Selected:

Source	Reported Capacity	Reported Trains	Report Cost Year	Reported Cost	Reporting Year Cost Per Train	Normalized Cost Per Train using CEPCI Index	Capacity Required	Trains Req'd.	Capacity per Train	Factored Cost per Train from Normalized Cost	Total Current Cost for Required Trains
Fertilizer Manual	1,395 tpd	1	1998	\$ 35,000,000	\$ 35,000,000	\$ 46,007,702	3,779 tpd	3	1,260 tpd	\$ 43,270,765	\$ 129,812,295

Balance of Plant:

Description	% of Total Cost	Cost Per Train	Total Cost
Water Systems	7.10%	\$ 3,072,224	\$ 9,216,673
Civil/Structural/Buildings	9.20%	\$ 3,980,910	\$ 11,942,731
Piping	7.10%	\$ 3,072,224	\$ 9,216,673
Control and Instrumentation	2.60%	\$ 1,125,040	\$ 3,375,120
Electrical Systems	8.00%	\$ 3,461,661	\$ 10,384,984
		Total Balance of Plant	\$ 14,712,060
		Total Balance of Plant Plus the Selected Source	\$ 57,982,825
			\$ 173,948,476

Rationale for Selection:

The Fertilizer Manual was selected for being both the newest cost point and the most conservative. The data from Perry's Chemical Engineering Handbook is based on earlier data from Peters and Timmerhaus, making it even less desirable. The allowances listed under 'Balance of Plant' are based on NETL 2000. These allowance values are comparable to additional published estimating guides, such as Page 1996.

Detail Item Report - Steam Turbines

Project Name: NGNP Process Integration
Process: HTSE Ammonia with ASU
Estimate Number: MA36-P

Client: M. Patterson
Prepared By: B. Wallace, R. Honsinger, J. Martin
Estimate Type: Class 5

Sources Considered:

Source	Reported Capacity	Reported Trains	Report Cost Year	Reported Cost	Reporting Year Cost Per Train	Normalized Cost Per Train using CEPCI Index	Capacity Required	Trains Req'd.	Capacity per Train	Factored Cost per Train from Normalized Cost	Total Current Cost for Required Trains
Steam Turbine and HRSG											
Shell IGCC Base Cases (NETL 2000)	189	MW	1	1999	\$ 50,671,000	\$ 66,419,744	131	MW	1	MW \$ 53,340,709	\$ 53,340,709
Steam Turbine											
NETL Baseline Report (NETL 2007a)	401	MW	4	2006	\$ 74,651,000	\$ 18,662,750	131	MW	1	\$ 22,456,151	\$ 22,456,151
Princeton Report (Kreutz 2008)	275	MW	1	2007	\$ 66,700,000	\$ 64,998,858	131	MW	1	\$ 41,855,168	\$ 41,855,168
Shell IGCC Power Plant with CO2 Capture (NETL 2007b)	230	MW	1	2006	\$ 44,515,000	\$ 45,619,856	131	MW	1	\$ 32,550,623	\$ 32,550,623

Source Selected:

Source	Reported Capacity	Reported Trains	Report Cost Year	Reported Cost	Reporting Year Cost Per Train	Normalized Cost Per Train using CEPCI Index	Capacity Required	Trains Req'd.	Capacity per Train	Factored Cost per Train from Normalized Cost	Total Current Cost for Required Trains
Shell IGCC Power Plant with CO2 Capture (NETL 2007b)	230	MW	1	2006	\$ 44,515,000	\$ 45,619,856	131	MW	1	MW \$ 32,550,623	\$ 32,550,623

Balance of Plant:

Description	% of Total Cost	Cost Per Train	Total Cost
Water Systems	7.10%	\$ 2,311,094	\$ 2,311,094
Civil/Structural/Buildings	9.20%	\$ 2,994,657	\$ 2,994,657
Piping	7.10%	\$ 2,311,094	\$ 2,311,094
Control and Instrumentation	2.60%	\$ 846,316	\$ 846,316
Electrical Systems	8.00%	\$ 2,604,050	\$ 2,604,050
		\$ 11,067,212	\$ 11,067,212
		\$ 43,617,835	\$ 43,617,835

Rationale for Selection:

Shell IGCC PowerPlant with CO2 Capture (NETL 2007b) is a recently reported cost point that closely reflects this project's requirements. The Princeton Report (Kreutz 2008) source for the steam turbine cost point is the NETL 2007b report. The allowances listed under 'Balance of Plant' are based on NETL 2000. These allowance values are comparable to additional published estimating guides, such as Page 1996.

Client: M. Patterson
Prepared By: B. Wallace, R. Honsinger, J. Martin
Estimate Type: Class 5

[illegible]

Source	Reported Capacity	Reported Trains	Report Cost Year	Reported Cost	Reporting Year Cost Per Train	Normalized Cost Per Train using CEPCI Index	Capacity Required	Trains Req'd.	Capacity per Train	Factored Cost per Train from Normalized Cost	Total Current Cost for Required Trains
Cooling Tower Depol	156,524 gpm	5	2009	\$ 4,611,840	\$ 922,368	\$ 922,368	146,019 gpm	5	29,204 gpm	\$ 884,712	\$ 4,423,559

[illegible]

Single source cost. Publicly available current data. Calculated capital costs based on publicly available cost data from a vendor regularly engaged in the building of cooling towers. The allowances listed under "Balance of Plant" are based on NETL 2000. These allowance values are comparable to additional published estimating guides, such as Page 1996.