INL/EXT-09-16080

NGNP with Hydrogen Production Preconceptual Design Study, HTGR Component Test Facility (CTF) Feasibility and Recommendations

Prepared by Westinghouse Electric Company, LLC for the Next Generation Nuclear Plant Project

Jacques Holtzhausen

February 2008



The INL is a U.S. Department of Energy National Laboratory operated by Battelle Energy Alliance.



DISCLAIMER

This information was prepared as an account of work sponsored by Westinghouse Electric Company, LLC for an agency of the U.S. Government. Neither the U.S. Government nor any agency thereof, nor any of their employees, makes any warranty, expressed or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness, of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. References herein to any specific commercial product, process, or service by trade name, trade mark, manufacturer, or otherwise, does not necessarily constitute or imply its endorsement, recommendation, or favoring by the U.S. Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the U.S. Government or any agency thereof.

NGNP and Hydrogen Production Preconceptual Design Study

HTGR Component Test Facility (CTF) Feasibility and Recommendations

APPROVALS

Function	Printed Name and Signature	Date
Author	Jacques Holtzhausen	
	M-Tech Industrial, Ltd	February 14, 2008
Reviewer	Jan van Ravenswaay	
	arusa	February 14, 2008
	M-Tech Industrial, Ltd 🦻 🦯	
Approval	Edward Brabazon Edward Bul	February 14, 2008
	Shaw Environmental & Infrastructure, Inc.	

Westinghouse Electric Company LLC Nuclear Power Plants Post Office Box 355 Pittsburgh, PA 15230-0355

©2008 Westinghouse Electric Company LLC All Rights Reserved

LIST OF CONTRIBUTORS

Name and Organization	Date
Edward Brabazon: Shaw Stone and Webster	February 2008
Peter Wells: Shaw Stone and Webster	February 2008
Andries Haasbroek : Westinghouse South Africa	February 2008
Marius Fox : Westinghouse South Africa	February 2008
Marius Janse van Vuuren: PBMR	February 2008
Heinz Mittermaaier: PBMR	February 2008
Riaan du Bruyn: M-Tech Industrial	February 2008
Jaco van der Merwe: M-Tech Industrial	February 2008
Kobus Olivier: M-Tech Industrial	February 2008
Jannie Potgieter: M-Tech Industrial	February 2008
Peet Venter: M-Tech Industrial	February 2008
Schalk Prinsloo: M-Tech Industrial	February 2008
Dan Mears: Technology Insights	February 2008
Scott Penfield: Technology Insights	February 2008
Fred Silady: Technology Insights	February 2008

BACKGROUND INTELLECTUAL PROPERTY

Section	Title	Description
NONE		NONE

REVISION HISTORY

RECORD OF CHANGES

Revision No.	Revision Made by	Description	Date
А	Jacques Holtzhausen M-Tech Industrial (Pty) Ltd	Final Draft	14 February 2008
0	S.A. Caspersson, Westinghouse	Final Report	29 April 2008

APPLICABLE DOCUMENTS AND DATA

The following documents and data are applicable:

TITLE	REFERENCE NUMBER
[1] "High Temperature Fluid Flows Test Facility White Paper," NGNP Engineering, INL, September 2007	INL/EXT-07-13146

DOCUMENT TRACEABILITY

Created to support the following Document(s)	Document Number	Revision
NONE	NONE	

TABLE OF CONTENTS

LIS	T OF CO	NTRIBUT	FORS
BAC	CKGROU	JND INTE	LLECTUAL PROPERTY
REV	ISION H	HISTORY	
LIS	T OF TA	BLES	
LIS	T OF FIG	GURES	
ACI	RONYMS	5	
SUN	IMARY	AND CON	VCLUSIONS 11
INT	RODUC	ГІОЛ	
1.	CTF M	ISSION N	EED
2.	CTF JU	STIFICA	TION
3.	CTF FU	INCTION	AL AND OPERATIONAL REQUIREMENTS
3.1	MAIN	CATEGO	RIES OF UNITS UNDER TEST27
	3.1.1	ІНХ СОМ	IPONENT TESTS
		3.1.1.1 3.1.1.2 3.1.1.3	CTF IHX Operational Requirements: Westinghouse Vendor Team
	3.1.2	MIXING	CHAMBER TEST
		3.1.2.1	CTF Mixing Chamber Operational Requirements: Westinghouse Vendor Team
	3.1.3	HIGH TE	MPERATURE DUCT & INSULATION TESTING
		3.1.3.1 3.1.3.2	CTF HTD&I Operational Requirements: Westinghouse Vendor Team 30 CTF HTD&I Operational Requirements: AREVA Vendor Team
	3.1.4	STEAM C	GENERATOR TESTING
		3.1.4.1 3.1.4.2	CTF SG Operational Requirements: Westinghouse Vendor Team
	3.1.5	HELIUM	CIRCULATOR
		3.1.5.1 3.1.5.2	CTF Circulator Operational Requirements: Westinghouse Vendor Team 33 CTF Circulator Operational Requirements: General Atomics Vendor Team
		3.1.5.3	CTF Circulator Operational Requirements: AREVA Vendor Team
	3.1.6	VALVES	TESTING
		3.1.6.1	CTF Valves Operational Requirements: General Atomics Vendor Team 34
	3.1.7	AUXILIA	RY SYSTEMS
	3.1.8	CONTRO 3.1.8.1	L & INSTRUMENTATION
	3.1.9	OTHER H 3.1.9.1	IELIUM HEAT EXCHANGER TESTING REQUIREMENTS

3.2 SOUTH AFRICAN TEST FACILITIES		3.1.10	GENERA	L FUNCTIONS	35
3.2.1 THE HELIUM TEST FACILITY. 36 3.2.1.1 Capabilities. 37 3.2.1.2 Test Schechule 39 3.2.1.3 Possible Modifications 39 3.2.1.4 Current Configuration 40 3.2.1.5 Ability To Address CTF Mission Need 41 3.2.2.1 Capabilities 41 3.2.2.2 THE PEBBLE BED MICRO MODEL 41 3.2.2.3 Possible Modifications And Current Configuration 41 3.2.2.3 Possible Modifications And Current Configuration 41 3.2.2.4 Ability To Address CTF Mission Need 42 3.2.3 THE HEAT TRANSFER TEST FACILITY. 42 3.2.3.1 High Temperature Test Unit 42 3.2.3.1 High Temperature Test Unit 42 MITTU Capabilities 42 HTTU Capabilities 44 HPTU Capabilities 44 HPTU Capabilities 44 HPTU Tost schedule 45 HPTU Possible Modifications and Current Configuration 45 HPTU Ability to Address CTF Mission Need 45 ALT FOONFIGURATION RE	3.2	SOUT	H AFRICA	N TEST FACILITIES	
3.2.2 THE PEBBLE BED MICRO MODEL 41 3.2.2.1 Capabilities 41 3.2.2.2 Test Schedule 41 3.2.2.2 Test Schedule 41 3.2.2.4 Ability To Address CTF Mission Need 42 3.2.3 THE HEAT TRANSFER TEST FACILITY. 42 3.2.3.1 High Temperature Test Unit 42 HTTU Capabilities 42 HTTU Test Schedule 43 HTTU Test Schedule 43 HTTU Dossible Modifications And Current Configuration 43 HTTU Ability To Address CTF Mission Need 44 HPTU Capabilities 44 HPTU Possible Modifications and Current Configuration 45 3.2.3.2 High Pressure Test Unit 44 HPTU Capabilities 44 HPTU Possible Modifications and Current Configuration 45 3.2.4 JUSTIFICATION CONCLUSION 45 3.2.4 JUSTIFICATION CONCLUSION 46 4.1 CONCEPT 1. 48 4.1.1 FACILITY LAYOUT 49 4.1.2 PROS AND CONS 52 4.2		3.2.1	THE HEL 3.2.1.1 3.2.1.2 3.2.1.3 3.2.1.4 3.2.1.5	IUM TEST FACILITY. Capabilities. Test Schedule Possible Modifications Current Configuration Ability To Address CTF Mission Need	36 37 39 40 40
3.2.2.1 Capabilities 41 3.2.2.2 Test Schedule 41 3.2.2.3 Possible Modifications And Current Configuration 41 3.2.3 THE HEAT TRANSFER TEST FACILITY 42 3.2.3 THE HEAT TRANSFER TEST FACILITY 42 3.2.3 THE HEAT TRANSFER TEST FACILITY 42 3.2.3.1 High Temperature Test Unit 42 MITTU Test Schedule 43 HTTU Tots Schedule 43 HTTU Possible Modifications And Current Configuration 43 3.2.3.2 High Pressure Test Unit 44 HPTU Possible Modifications and Current Configuration 43 3.2.3.2 High Pressure Test Unit 44 HPTU Possible Modifications and Current Configuration 45 HPTU Possible Modifications and Current Configuration 45 HPTU Ability to Address CTF Mission Need 45 3.2.4 JUSTIFICATION CONCLUSION 45 4. CTF CONFIGURATION RECOMMENDATIONS 46 4.1 CONCEPT 1 48 4.1.1 FACILITY LAYOUT 55 4.2 PROS AND CONS 52		3.2.2	THE PEB	BLE BED MICRO MODEL	41
3.2.3 THE HEAT TRANSFER TEST FACILITY. 42 3.2.3.1 High Temperature Test Unit 42 HTTU Capabilities 42 HTTU Possible Modifications And Current Configuration 43 HTTU Ability To Address CTF Mission Need. 43 3.2.3.2 High Pressure Test Unit 44 HPTU Capabilities 44 HPTU Test schedule 45 HPTU Possible Modifications and Current Configuration 45 HPTU Ability to Address CTF Mission Need 45 3.2.4 JUSTIFICATION CONCLUSION 45 4.1 CONCEPT 1 48 4.1.1 FACILITY LAYOUT 49 4.1.2 PROS AND CONS 52 4.2 CONCEPT 2 54 4.2.1 FACILITY LAYOUT 55 4.2.2 PROS AND CONS 57 4.3 CONCEPT 3 58 4.3.1 PROS AND CONS 59			3.2.2.1 3.2.2.2 3.2.2.3 3.2.2.4	Capabilities Test Schedule Possible Modifications And Current Configuration Ability To Address CTF Mission Need	41 41 41 42
3.2.3.1 High Temperature Test Unit 42 HTTU Capabilities 42 HTTU Test Schedule 43 HTTU Possible Modifications And Current Configuration 43 HTTU Ability To Address CTF Mission Need 43 HTTU Capabilities 44 HPTU Possible Modifications and Current Configuration 43 HPTU Capabilities 44 HPTU Possible Modifications and Current Configuration 45 HPTU Possible Modifications and Current Configuration 45 HPTU Possible Modifications and Current Configuration 45 HPTU Ability to Address CTF Mission Need 45 HPTU Ability to Address CTF Mission Need 45 3.2.4 JUSTIFICATION CONCLUSION 45 4.1 CONCEPT 1 48 4.1.1 FACILITY LAYOUT 49 4.1.2 PROS AND CONS 52 4.2 CONCEPT 2 54 4.3.1 FACILITY LAYOUT 55 4.2.2 PROS AND CONS 57 4.3 CONCEPT 3 58 4.3.1 PROS AND CONS 59 4.4 CONCEPT 3 <td< td=""><td></td><td>3.2.3</td><td>THE HEA</td><td>T TRANSFER TEST FACILITY</td><td></td></td<>		3.2.3	THE HEA	T TRANSFER TEST FACILITY	
H1TU Ability To Address CTF Mission Need. 43 3.2.3.2 High Pressure Test Unit 44 HPTU Capabilities. 44 HPTU Test schedule 45 HPTU Possible Modifications and Current Configuration 45 HPTU Ability to Address CTF Mission Need. 45 3.2.4 JUSTIFICATION CONCLUSION 45 3.2.4 JUSTIFICATION RECOMMENDATIONS. 46 4.1 CONCEPT 1 48 4.1.1 FACILITY LAYOUT 49 4.1.2 PROS AND CONS 52 4.2 CONCEPT 2 54 4.2.1 FACILITY LAYOUT 55 4.2 PROS AND CONS 57 4.3 CONCEPT 3 58 4.3.1 PROS AND CONS 57 4.3 CONCEPT 3 58 4.3.1 PROS AND CONS 57 4.4 CONCEPT RECOMMENDATION 60 5. CTF COST ESTIMATE AND SCHEDULE 62 5.1 CONCEPT 1 - COST SUMMARY 64 5.1.2 CONCEPT 2 - COST SUMMARY 65			3.2.3.1	High Temperature Test Unit HTTU Capabilities HTTU Test Schedule HTTU Possible Modifications And Current Configuration	42 42 43 43
HPTU Capabilities44HPTU Test schedule45HPTU Possible Modifications and Current Configuration45HPTU Ability to Address CTF Mission Need453.2.4 JUSTIFICATION CONCLUSION454. CTF CONFIGURATION RECOMMENDATIONS464.1 CONCEPT 1484.1.1 FACILITY LAYOUT494.1.2 PROS AND CONS524.2 CONCEPT 2544.2.1 FACILITY LAYOUT554.2 PROS AND CONS574.3 CONCEPT 3584.3.1 PROS AND CONS594.4 CONCEPT 3594.4 CONCEPT RECOMMENDATION605. CTF COST ESTIMATE AND SCHEDULE625.1 COST ESTIMATE635.1.1 CONCEPT 1 - COST SUMMARY645.1.2 CONCEPT 2 - COST SUMMARY65			3.2.3.2	HTTU Ability To Address CTF Mission Need High Pressure Test Unit	
HPTU Test schedule45HPTU Possible Modifications and Current Configuration45HPTU Ability to Address CTF Mission Need453.2.4 JUSTIFICATION CONCLUSION454. CTF CONFIGURATION RECOMMENDATIONS464.1 CONCEPT 1484.1.1 FACILITY LAYOUT494.1.2 PROS AND CONS524.2 CONCEPT 2544.2.1 FACILITY LAYOUT554.2 PROS AND CONS574.3 CONCEPT 3584.3.1 PROS AND CONS594.4 CONCEPT RECOMMENDATION605. CTF COST ESTIMATE AND SCHEDULE625.1 CONCEPT 1 - COST SUMMARY645.1.2 CONCEPT 2 - COST SUMMARY65			0121012	HPTU Capabilities	
HIT TO FOSSIBLE MOUNTCAINES and Current Comparison Meet 45 HPTU Ability to Address CTF Mission Need 45 3.2.4 JUSTIFICATION CONCLUSION 45 4. CTF CONFIGURATION RECOMMENDATIONS 46 4.1 CONCEPT 1 48 4.1.1 FACILITY LAYOUT 49 4.1.2 PROS AND CONS 52 4.2 CONCEPT 2 54 4.2.1 FACILITY LAYOUT 55 4.2.2 PROS AND CONS 57 4.3 CONCEPT 3 58 4.3.1 PROS AND CONS 59 4.4 CONCEPT RECOMMENDATION 60 5. CTF COST ESTIMATE AND SCHEDULE 62 5.1 CONCEPT 1 - COST SUMMARY 64 5.1.2 CONCEPT 2 - COST SUMMARY 65				HPTU Test schedule	
3.2.4JUSTIFICATION CONCLUSION454.CTF CONFIGURATION RECOMMENDATIONS464.1CONCEPT 1484.1.1FACILITY LAYOUT494.1.2PROS AND CONS524.2CONCEPT 2544.2.1FACILITY LAYOUT554.2.2PROS AND CONS574.3CONCEPT 3584.3.1PROS AND CONS594.4CONCEPT RECOMMENDATION605.CTF COST ESTIMATE AND SCHEDULE625.1CONCEPT 1 - COST SUMMARY645.1.2CONCEPT 2 - COST SUMMARY65				HPTU Ability to Address CTF Mission Need	
4. CTF CONFIGURATION RECOMMENDATIONS		3.2.4	JUSTIFIC	CATION CONCLUSION	45
4.1 CONCEPT 1	4.	CTF CO	ONFIGUR	ATION RECOMMENDATIONS	
4.1.1 FACILITY LAYOUT	4.1	CONC	ЕРТ 1		48
4.1.2 PROS AND CONS 52 4.2 CONCEPT 2 54 4.2.1 FACILITY LAYOUT 55 4.2.2 PROS AND CONS 57 4.3 CONCEPT 3 58 4.3.1 PROS AND CONS 59 4.4 CONCEPT RECOMMENDATION 60 5. CTF COST ESTIMATE AND SCHEDULE 62 5.1 CONCEPT 1 - COST SUMMARY 63 5.1.2 CONCEPT 2 - COST SUMMARY 65		4.1.1	FACILITY	Y LAYOUT	
4.2 CONCEPT 2		4.1.2	PROS AN	D CONS	
4.2.1 FACILITY LAYOUT	4.2	CONC	ЕРТ 2		54
4.2.2 PROS AND CONS 57 4.3 CONCEPT 3 58 4.3.1 PROS AND CONS 59 4.4 CONCEPT RECOMMENDATION 60 5. CTF COST ESTIMATE AND SCHEDULE 62 5.1 CONCEPT 1 - COST SUMMARY 63 5.1.2 CONCEPT 2 - COST SUMMARY 65		4.2.1	FACILITY	Y LAYOUT	
4.3 CONCEPT 3		4.2.2	PROS AN	D CONS	57
4.3.1PROS AND CONS594.4CONCEPT RECOMMENDATION605.CTF COST ESTIMATE AND SCHEDULE625.1COST ESTIMATE635.1.1CONCEPT 1 - COST SUMMARY645.1.2CONCEPT 2 - COST SUMMARY65	4.3	CONC	ЕРТ 3		
 4.4 CONCEPT RECOMMENDATION		4.3.1	PROS AN	D CONS	
 5. CTF COST ESTIMATE AND SCHEDULE	4.4	CONC	EPT RECO	OMMENDATION	60
5.1 COST ESTIMATE	5.	CTF CO)ST ESTI	MATE AND SCHEDULE	
5.1.1 CONCEPT 1 - COST SUMMARY	5.1	COST	ESTIMAT	F	63
5.1.2 CONCEPT 2 - COST SUMMARY 65	~,1	5.1.1	CONCEP	Г 1 - COST SUMMARY	
		5.1.2	CONCEP	Γ 2 - COST SUMMARY	
5.2 SCHEDULE	5.2	SCHE	DULE		

5.2.1 S	SCHEDULE - CONCEPT 1	67
5.2.2 S	SCHEDULE - CONCEPT 2	
APPENDIX A:	DESIGN DATA NEEDS MATRIX	A-1
APPENDIX B:	SOUTH AFRICAN PBMR TEST FACILITIES	B-1
APPENDIX C:	LITERATURE STUDY ON OTHER FACILITIES	C-1
APPENDIX D:	CONCEPT 1 DETAILS	D-1
APPENDIX E:	CONCEPT 2 DETAILS	E-1
APPENDIX F:	DDNS TEST CONFIGURATIONS	F-1
APPENDIX G:	IHX TEST SPECIFICATION	G-1
APPENDIX H:	NGNP CTF COSTING	H-1

LIST OF TABLES

Table 1: Helium Test Facility (HTF) Operational Conditions	. 38
Table 2: Pebble Bed Micro Model Operational Conditions	. 41
Table 3: High Temperature Test Unit (HTTU) Operational Conditions	. 42
Table 4: High Pressure Test Unit (HPTU) Operational Conditions	. 44
Table 5: Concept 1 Cost Summary	. 64
Table 6: Concept 2 Cost Summary.	. 65

LIST OF FIGURES

Figure 1:	Component Test Facility Feasibility Study Work Plan Outline 17
Figure 2:	Component Test Facility Justification Philosophy
Figure 3:	Work flow diagram of the process that was followed to attain the Functional & Operational Requirements resulting in the Configuration Recommendation
Figure 4:	High level process flow diagram of the Helium Test Facility Main Loop
Figure 5:	Helium Test Facility (HTF) operational envelope (dark blue area) compared against a facility that will typically address the CTF F&ORs (grey area)
Figure 6:	High level process flow diagram of the possible modifications to the HTF Laboratory
Figure 7:	High Temperature Test Unit (HTTU) operational envelope (dark blue area) compared against a facility that will typically adress the CTF F&ORs (grey area)
Figure 8:	High Pressure Test Unit (HPTU) operational envelop (dark blue area) compared against a facility that will typically adress the CTF F&ORs (grey area)
Figure 9:	Work flow diagram of the process that was followed to recommend configurations of the CTF that will address all Mission Needs
Figure 10:	High level Process Flow Diagram of Concept 1 indicating all Technology Development Loops, Component Qualification Loop & Full Scale Circulator Loop 48
Figure 11:	Conceptual physical layout of Technology Development Loop 1 indicating major components as found in the Process Flow diagram
Figure 12:	Conceptual layout side view of Technology Development Loop 1 50
Figure 13:	Conceptual floor plan view of Technology Development Loop 1 50
Figure 14:	Physical layout of Concept 1 showing the TDL, interconnecting Hot Header, CQL, CLT, allocated floor space and lay down areas
Figure 15:	Perspective view of the physical layout of Concept 1
Figure 16:	High level Process Flow Diagram of Concept 2 indicating Primary Loop, Secondary Loop, Steam Generator Loop & Full Scale Circulator Loop
Figure 17:	Physical layout of Concept 2 (CQL 2)

Figure 18:	Floor plan layout of Concept 2(CQL 2) indicating major components as can be found in the Process Flow diagram
Figure 19:	Side view layout of Concept 2 (CQL 2)
Figure 20:	High level process flow diagram of Concept 3 indicating the Primary Loop, Secondary and Tertiary Loops as well as the Full Scale Circulator Test Loop
Figure 21:	Schedule for Concept 1 indicating key dates and dependants
Figure 22:	Schedule for Concept 2 indicating key dates and dependants

ACRONYMS

ASME	American Society of Mechanical Engineers	
BEA	Battelle Energy Alliance	
COTS	Commercial Off the Shelf	
CTF	Component Test Facility	
CTL	Circulator Test Loop	
CQL	Component Qualification Loop (as incorporated in Concept 1)	
CQL 2	Large Scale Component Qualification Loop (Concept 2)	
СТР	Component Testing Program	
DDN	Design Data Need	
DOE	Department of Energy	
DRL	Design Readiness Level	
FHS	Fuel Handling System	
FOAKE	First-Of-A-Kind-Engineering	
F&OR	Functional and Operational Requirements	
HTF	Helium Test Facility	
HTTF	High Temperature Test Facility	
HTTU	High Temperature Test Unit	
HPS	Helium Purification System	
HPTU	High Pressure Test Unit	
IET	Integrated Effects Tests	
IHX	Intermediate Heat Exchanger	
INL	Idaho National Laboratory	
ISI	In-Service Inspection	
LWR	Light Water Reactor	
MSS	Main Support System	
NHS	Nuclear Heat Source	
NGNP	Next Generation Nuclear Plant	
PHTS	Primary Heat Transport System	
PCDR	Pre-Conceptual Design Report	
PCS	Power Conversion system	
PBMR DPP	Pebble Bed Modular Reactor, Demonstration Power Plant	
PBMM	Pebble Bed Micro Model	
RCS	Reactivity Control System	
RFC	Ready For Commissioning	
SET	Separate Effect Tests	
SG	Steam Generator	
SHTS	Secondary Heat Transport System	
TBD	To be defined	
TDL	Technology Development Loop (as incorporated in Concept 1)	
TQC	Testing, Qualification and Commissioning	
TRL	Technology Readiness Level	
UUT	Unit Under Test	
V&V	Verification & Validation	

SUMMARY AND CONCLUSIONS

The Next Generation Nuclear Plant (NGNP) project is a US-based initiative to demonstrate the viability of using High Temperature Gas-Cooled Reactors (HTGR) in the production of heat for usage in a wide range of energy producing technologies. These technologies typically include electricity production, hydrogen production, salt water desalination and the like. This forms part of DOE's long term vision of acknowledging the potential of using nuclear energy as opposed to burning fossil fuels to meet the growing demand for energy. This task was authorized by EPAct 2005 and charged Idaho National Laboratories (INL) with the responsibility of investigating and selecting the appropriate technology for supplying process heat at high temperatures (~950°C) using a nuclear heat source.

As part of this responsibility, INL initiated three pre-conceptual designs for the NGNP by different vendor teams. These designs included proposals for the complete system as well as related technology development and testing requirements. The vendor teams identified the major elements of developmental testing and the vendor reports focused mainly on the different heat transport systems and their associated components. In order to support the development of some of the high risk components that were identified in the reports, a dedicated component test facility (CTF) was proposed. Such a facility would be supportive of the NGNP with regard to technology development and risk mitigation in terms of schedule requirements and equipment qualification. Typical applications include primary and secondary heat transport systems testing, demonstration and developmental testing of NGNP specific control, maintenance and inspection philosophies.

The purpose of this study was to evaluate the feasibility of this envisioned CTF with regards to the following key areas:

- CTF Mission Need
- CTF Justification
- CTF Functional and Operational Requirements (F&ORs)
- CTF Configuration Recommendations
- CTF Cost Estimate and Schedule

The study was conducted by means of a work plan as illustrated in the figure below. The Design Data Needs, Technology Readiness Levels as well as Design Readiness Levels (DDNs, TRLs, DRLs) of all three vendor groups and the NGNP lifecycle requirements were used as inputs to establish the CTF Enveloping Philosophy.



Component Test Facility Feasibility Study Work Plan Outline

The CTF Enveloping Philosophy was defined as:

The CTF is a technology development platform for components and systems in support of the NGNP program. In order for these technologies to be integrated into the NGNP, it will be required that full scale, representative size component tests be conducted on certain items or assemblies. These tests need to be done at NGNP representative conditions, with regards to pressure, flow rate and temperature.

The justification process for the CTF basically consisted of an in depth review of the mission need with specific reference to the Functional and Operational Requirements (F&ORs) that were developed as part of this task. The South African PBMR test facilities were used as basis for the analysis against the F&ORs and Mission Need. The analysis was performed in terms of the technical capability, timeframe utilization and possible modifications to these facilities to meet the CTF requirements. The nine main categories into which the Units Under Test (UUTs) resorted were also defined as part of the analysis. The result of the analysis indicated that none of the RSA test facilities that were evaluated sufficed as a CTF candidate and it was proposed that different concepts be developed that will in fact address all CTF Mission Need requirements. The figure below provides a flow diagram of this process.



Work flow diagram of the process that was followed to attain the Functional & Operational Requirements resulting in the Configuration Recommendation

A concept deriving philosophy was formulated with the Mission Needs, DDNs, NGNP lifecycle requirements as well as anticipated time schedules as basis. Three concepts were developed accordingly and a high level trade-off analysis was performed to determine the most feasible concept. The trade-off analysis comprised aspects such as minimizing risk through maximum utilization of commercially available components to improve reliability, minimizing the simultaneous use of two or more units under test, etc.

The first concept (Concept 1) consists of three small, completely independent test facilities which are referred to as Technology Development Loops (TDLs). These individual loops are interconnectable to a common manifold/header. This interconnected facility can then provide high temperature (950°C), high pressure (9MPa) helium to a single large Component Qualification Loop (CQL) at the combined operational envelopes of all the individual smaller TDLs and can then be used for larger scale component qualification. In addition to the TDLs and CQL, this concept also includes a completely independent and separate, full scale (in terms of the NGNP) Circulator Test Loop (CTL). The two figures below illustrate a 3D layout of a single TDL (on the left) and a plausible footprint size of a complete Concept 1 facility (with all three TDLs and CTL on the right).



Concept 1 Layout

Concept 2 differs from Concept 1 and comprises mainly one large facility plus a separate full-scale CTL, instead of multiple smaller facilities. This large facility's sizing is driven by a mass flow rate recommendation of approximately 15 percent of the maximum NGNP circulating mass flow which relates to roughly 25 kg/s for the concept. A preliminary 3D layout of such a facility is provided in the figures below.



Concept 2 Layout

Lastly, a third concept (Concept 3) was proposed which consists of one large primary loop $(20 - 50 \text{ MW}_t)$ with numerous secondary loops connected to it as well as a separate CTL. The connection of the primary and secondary loops is established by means of heat transfer testing

UUTs. It is anticipated that the secondary loops are in turn connected to tertiary loops for testing and evaluating of commercial high temperature application items for example hydrogen production systems. This concept was, however, not recommended due to several risks, which could be detrimental when imposed on the NGNP lifecycle requirements, in terms of the Mission Need that was mentioned earlier.

Both Concepts 1 and 2 are feasible options to consider as being CTF candidates; however Concept 1 was recommended. This is mainly due to the fact that it complies with the Mission Need, addresses almost all of the DDNs and F&ORs and aligns better with the NGNP lifecycle requirements in terms of cost and schedule. One of the typical advantages associated with this concept is the higher level of reliability by using commercial-off-the-shelf (COTS) components as opposed to first-of-a-kind engineering (FOAKE) components used in Concept 2 (such as the circulators that still need to be developed). Other advantages include the ability to facilitate a large development audience due to the concurrent, parallel testing capabilities and separate CTL. Another advantage of Concept 1 is the utilization of the manifold/header that enables large scale testing; however this component in itself could provide some design challenges that will be investigated in future studies. Opposed to Concept 1, Concept 2 has the ability to test even larger scale components up to 15 percent of the NGNP scale.

The cost and schedule of both Concepts 1 and 2 were prepared at a feasibility level. Each of the cost estimates were determined as baseline models and a techno-economic trade-off study between Concept 1 and 2 still needs to be performed in the pre-conceptual design phase. Cost estimates were based on applicable South African quotes and experience gained from the PBMR test facilities as well as US-based inputs regarding civil works and the like. Some assumptions were made where not enough information could be gathered and are listed in more detail in the relevant section of this document.

The total cost for Concept 1 amounts to approximately US\$ 243 million while that of Concept 2 amounts to approximately US\$ 250 million. Both these cost models include expenditure for civil work, hardware components, vessels, structures, utilities, construction management (i.e. distributables) and engineering design costs. The confidence level of the cost estimates that are presented herein is expressed as a 50:50-confidence level which implies a balanced probability of being over or under budget. A contingency amount was also included and ranged between 10 percent and 20 percent for Concept 1 and 2 respectively. A preliminary schedule was prepared for both concepts where construction commenced in the 4th quarter of 2009 and an envisaged duration of 20 to 24 months for Concept 1 and 2 respectively.

It is the conclusion of this feasibility study that a Component Test Facility is definitely required. More specifically, the approach of Concept 1 addresses the NGNP lifecycle requirements best and it is therefore recommended. However, it is proposed that an optimization of the recommended layout be performed during the pre-conceptual design phase to determine whether Concept 1 is most suited or possibly even a combination of the Concepts 1 and 2.

INTRODUCTION

The Next Generation Nuclear Plant (NGNP) project is a US-based initiative to demonstrate the technical, licensing, operational, and commercial viability of High Temperature Gas-Cooled Reactor (HTGR) technology for the production of high temperature (up to 950°C) heat for any combination of process heat, process steam and cogeneration applications, including utilization of the low temperature waste heat for applications such as water desalination. The HTGR can be used as a substitute for the burning of fossil fuels for a wide range of industrial process applications. Substitution of the HTGR for burning fossil fuels conserves these hydrocarbon resources for other uses, reduces uncertainty in the cost and supply of natural gas and oil, and eliminates the emissions of greenhouse gases attendant with the burning of these fuels. The HTGR also provides enhanced safety features that permit substantially reduced emergency planning requirements and improved siting flexibility compared to current and advanced light water reactors (LWRs).

During FY07, pre-conceptual designs were developed for the NGNP by three competing vendor teams, along with related technology development and testing requirements and associated plans. Major elements of the development-related testing identified by the teams are focused on the main heat transport systems and their associated components. To support these needs, a test facility is envisioned, which is herein referred to as the High Temperature Gas-Cooled Reactor (HTGR) – Component Test Facility or "CTF". The purpose of this facility is to support the development of high temperature gas thermal-hydraulic technologies (e.g., helium, helium-nitrogen, CO_2) as applied in heat transport and heat transfer applications. Such applications include but are not limited to, primary coolant, secondary coolant, direct cycle power conversion, intermediate, secondary and tertiary heat transfer, and demonstration of processes requiring high temperatures (e.g., hydrogen production).

The initial focus of the CTF will be in support of the NGNP project. However, it is envisioned that the CTF will be open for use by the full range of suppliers, end-users, facilitators, government laboratories and others in the domestic and international community supporting the development and application of HTGR technology. Currently, it is envisioned that the CTF will be a DOE-owned facility sited at the Idaho National Laboratory (INL).

The purpose of this special study is to evaluate the feasibility of the envisioned CTF concept and covers five key areas, as identified in [1], namely:

- CTF Mission Need
- CTF Justification
- CTF Functional and Operational Requirements (F&ORs)
- CTF Configuration Recommendations
- CTF Cost Estimate and Schedule

The work plan outline is presented in Figure 1 where the Design Data Needs, Technology Readiness Levels and Design Readiness Levels (DDNs, TRLs and DRLs) were used to formulate the CTF envelope philosophy. The five key areas were then addressed within this philosophy as well as the NGNP life cycle requirements to finally result in this report.



Figure 1: Component Test Facility Feasibility Study Work Plan Outline

1. CTF MISSION NEED

During various life cycle stages of the NGNP project, a number of systems, sub-systems, assemblies, and components need to be developed. Concurrently with this development, verifications and validations need to be performed via tests as a risk mitigation strategy. Active testing of complete NGNP systems at full scale is not achievable in all cases due to several practical and physical constraints. Rather, a more practical approach would be to test certain identified engineering scale components/assemblies that exemplify a representative sample of the actual items to be used in the NGNP. These components are typically found in the Primary and Secondary Heat Transport Systems (PHTS and SHTS) and some tertiary loops that may include the Hydrogen Production System and Power Conversion System (PCS). Items to be tested are typically heat exchangers, circulators, valves and gas piping.

The earlier mentioned pre-conceptual design reports (PCDRs) were performed under leadership of three vendor teams, namely AREVA, General Atomics and Westinghouse Electrical Company. Special studies that were performed by the vendor teams during the pre-conceptual design resulted in the identification of several design data needs (DDNs). In addition, an initial effort was made to establish the technology readiness levels and design readiness levels (TRLs and DRLs) of key systems and components. These DDNs, TRLs and DRLs essentially stated the requirements and needs during the complete lifecycle of the NGNP. They addressed aspects ranging from materials engineering, material qualification and laboratory scale component testing up to and including full scale components. These DDNs were used as the basis for the development of the mission needs of the CTF.

A total of nearly 400 DDNs, using the PCDRs of the three vendor teams as basis, were identified and are listed in Appendix A as part of the input matrix to this study. After closer evaluation of the DDNs, it was found that it will not be feasible to address all the DDNs with the CTF and the complete spectrum of DDNs will rather be addressed within a larger Component Test Program (CTP). The DDNs within the CTP were classified ("binned") into three different types: Task Groups, Specialized Laboratories and the CTF.

- 1. Task Groups will develop and establish the procedures and work plans that are not normally associated with Specialized Laboratory work and will include compilation of code cases, etc. The Task Groups will typically be made up of expert consultants.
- 2. Specialized Laboratories will be utilized to address certain DDNs in their fields of expertise and these will typically include material certification, validation and testing. These are envisaged to be accredited to relevant standards and can be on-site or off-site from INL, or even abroad.
- 3. The CTF will be used to test the components that were constructed/developed from the work done by the Task Groups and Specialized Laboratories.

The DDNs, TRLs and DRLs served as input to address the complete lifecycle requirements of the NGNP, which will include the CTP and the CTF. The NGNP lifecycle is defined as:

- 1. Research, development and design
- 2. NRC licensing
- 3. Long lead procurements
- 4. Construction
- 5. Commissioning, initial operations and testing
- 6. Operation, training and verification
- 7. Certification and commercial deployment application

With all the DDNs, TRLs, DRLs and NGNP lifecycle requirements taken into account, the CTF Envelope Philosophy can be given as:

The CTF is a technology development platform for components and systems in support of the NGNP program. In order for these technologies to be integrated into the NGNP, it will be required that full scale, representative size component tests be conducted on certain items or assemblies. These tests need to be done at NGNP representative conditions, with regards to pressure, flow rate and temperature.

By employing this philosophy, the risks in the NGNP life cycle, which can be addressed in the CTF, can be mitigated in a structured, value adding and timely manner. In defining the Mission Statement of the CTF, cognizance must be taken of the Envelope Philosophy to ensure that a comprehensive needs requirement is formulated.

The Mission Statement of the CTF is defined as being a facility that:

- Must support the complete NGNP lifecycle as outlined above.
- Must be available to the entire nuclear community that contributes to the NGNP.
- Must provide the required test conditions including secondary loop conditions to support process heat application testing and hydrogen production using various technologies.
- Must facilitate testing of laboratory and engineering scale components.
- Must facilitate testing of representative size components that are to be used in the NGNP.
- Must facilitate testing for component characterization and qualification including primary fluids.
- Must have the capability to do Verification and Validation (V&V) of computer codes and must, therefore, have the required traceability in terms of data capturing, storing and presenting for all of its main systems, including ancillary systems where necessary. The CTF instrumentation selection and quantity must also facilitate this need.
- Must have to ability to do simultaneous testing in support of the NGNP milestone and key dates.
- Must have the ability to do both steady-state and transient tests in support of the previously mentioned points.

- Most provide for the testing, qualification and calibration of instrumentation under comparable conditions to that of the envisaged NGNP operating conditions.
- Must provide for the testing of control philosophies.
- Must provide for inventory control and testing under certain contamination conditions including loop-to-loop leak detection.
- Must provide for control room human factors.
- Must be able to facilitate and support the NGNP maintenance and support program with regards to development of installation and maintenance procedures.
- Must provide the opportunity to test and develop control room simulators.
- Must enable the sourcing and evaluation of different suppliers to the NGNP with regards to their component quality, customer service, etc.
- Must support code cases (new and updating of existing ones)
- Must support V&V of heat transfer correlations
- Must support development of ISI (In Service Inspection) requirements and methodologies of IHX and other components
- Must support NGNP commercial and operational phases
- Must support investigations into other heat transport fluids (i.e., molten salts, etc.)

As part of the Work Description, it was indicated that in addition to the NGNP project phases, the CTF Mission Need will also be evaluated to address the following items:

- Development, ownership and operation by DOE
- Location at the Idaho National Laboratory (INL)
- Potential interface with NGNP for interactive testing with the nuclear heat source (e.g., to evaluate radionuclide contamination transmission, cleanup and control).

While it is recommended that the first two items be addressed by BEA, the Westinghouse team supports the location of a DOE owned CTF at the Idaho National Laboratory (INL). With regards to the potential interface with the NGNP for interactive testing with a nuclear heat source, the Westinghouse team does not see any reason why the CTF cannot be located close to the NGNP (if also located at INL) and will evaluate the location of the CTF and the possible interface with the NGNP as part of the project. The integration aspects and issues, such as licensing, will need to be evaluated in more detail as part of the conceptual design of both the CTF and NGNP to ensure optimum integration and to minimize risks.

2. CTF JUSTIFICATION

Justification of the CTF will be discussed in this section. The philosophy (presented in Figure 2) that was followed during the justification of the CTF mainly revolved around the following points:

- Determine what is actually required of the CTF (Mission Need).
- Evaluate existing facilities' capabilities to meet CTF requirements.
- Suggest possible modifications to these facilities if the complete Mission Need is not addressed.
- Re-evaluate the feasibility after modifications.
- Propose utilization.



Figure 2: Component Test Facility Justification Philosophy

A fundamental understanding of the CTF Mission Need is crucial. If this is not unambiguously presented, the possibility of motivating an under-specified, too small, non-value adding test facility is evident. It is specifically for this reason that the Mission Need was derived from *ALL* the needs as discussed in Section 1.

The motivation for evaluating existing test facilities was to determine whether it would be possible to reduce the cost and time for meeting the CTF Mission Need. It could be much more economical to use existing facilities or modifications of them, instead of building a complete new facility. Furthermore, it can be assumed that existing facilities have already established a broad knowledge base of operations in high pressure and temperature helium which is an advantage for the NGNP program. However, it can be assumed that modifications to existing facilities generally do not

deliver the required performance in terms of the Mission Need of the conceptualized facility. This is purely because existing facilities were typically designed and developed for another purpose and scope and more often than not experience has shown that the modification costs vs. outcome are not always justifiable. Therefore, the justification philosophy includes the re-evaluation of a facility's capabilities after a proposed modification and how this addresses the CTF Mission Need. It is only hereafter that a proposal can be made to whether the CTF is justifiable in the greater NGNP life cycle need.

The CTF Mission Need from Section 1 can be elaborated further, and areas where such a facility will be applicable include:

- Qualification and testing of large scale components in a high temperature, high pressure environment such as the
 - Intermediate heat exchanger (IHX)
 - Ducting and insulation
 - Mixing chambers
 - Steam generator (SG)
 - High temperature valves
 - Specific application high temperature instrumentation
 - Industrial hydrogen components and
 - Helium circulators.
- Design code development Verification & Validation collaboration.
- Materials development and qualification.
- Manufacturer and supplier evaluation and development.

Other less tangible aspects¹ justify the CTF due to the fact that:

- It will facilitate the role of Idaho National Laboratory (INL) in the coordination, consolidation and leading of the development of heat transfer and transport technologies to establish and advance the application of HTGR technology.
- It will ensure the availability of a facility to serve the development phases of the NGNP and beyond. The possible limited capacity and availability of other facilities (most of which are outside of the USA and supporting other projects) could adversely affect the NGNP schedule.
- It will improve the efficiency of technology development for the NGNP and follow-on technology upgrades.
- It provides a means for off-line trouble shooting of component and system problems and for the development of programs and processes to ultimately support a growing commercial HTGR fleet.

¹ Some of these areas that are mentioned served as motivation for the CTF and can be found in [1]

- It provides a long-term US-based facility for continued development of advanced technologies to increase the capabilities and broaden the applications of the HTGR.
- It serves in the development of human capital and skills for the HTGR NGNP environment.
- It provides insights in the identification of shortfalls in the CTF design that can be taken into account in the NGNP design.
- It provides an environment where Quality Assurance, safety and procurement systems can be tested and verified and where shortfalls/enhancements can be identified.
- It provides a means for the testing and evaluation of manufacturing technologies for large scale manufacturing of First-of-a-Kind Engineering (FOAKE) systems and long lead time components.
- It will provide the opportunity to understand and test phenomena that prevail in transients of critical hot components at a CTF scale for both experimental results and V&V of codes.
- It will provide vast amounts of test data that will be beneficial for operation of the NGNP.

Before an evaluation of any facility could be done, it was important to define a measuring unit to which the facilities will be evaluated to. To define this measuring unit, the Functional and Operational Requirements (F&ORs) for the CTF needed to be laid down.

The process that was followed to determine F&ORs is discussed in the next section, after which the justification process continues with the evaluation of existing (or modified) facilities.

3. CTF FUNCTIONAL AND OPERATIONAL REQUIREMENTS

Figure 3 illustrates the method that was followed in determining the F&ORs from the DDNs, TRLs and DRLs as presented in the DDNs Matrix in Appendix A. The sorted DDNs were further binned into main categories of components/systems to be tested. These are:

- Intermediate heat exchanger (IHX)
- Mixing chambers
- High temperature ducting and insulation
- Steam generator (SG)
- Helium circulator
- Isolation valves
- Auxiliary systems
- Control and Instrumentation
- Other heat exchanger (HX) equipment
- General functions

The requirements from all three vendor groups' DDNs were distilled into process parameters such as pressure, temperature, mass flow, energy required, etc. Some of the DDNs process parameter requirements were well defined in terms of units and magnitudes while others were very vague and mentioned needs in general and in very broad terms. These process parameters were sorted in matrix format with the aim to result in a Functional and Operational Requirements list that indicated the maximum values of the operational envelope of the CTF. These maximum values were useful to determine a first order sizing and conceptual layout of the CTF. This first order layout implied a facility that could possibly be equivalent in size to the NGNP itself due to requirements of full scale testing of some of the components. Also, at this stage in the process, it was not clear whether to provide for single component testing or assemblies of these components (such as the IHX). For obvious schedule and financial reasons, a facility of this scale is not feasible and a process of optimization was followed during which the categorized components/systems' individual F&ORs were combined in such a fashion to define the tests that need to be performed in the CTF.



Figure 3: Work flow diagram of the process that was followed to attain the Functional & Operational Requirements resulting in the Configuration Recommendation

The F&ORs for the tests in terms of energy balances, layouts and configurations were determined in the context of the *Facility Philosophy* (explained in Section 4) and resulted in three possible concepts. Concept 1 (which consists of three *Technology Development Loops (TDLs) as well as a Component Qualification Loop (CQL) and* full scale *Circulator Test Loop (CTL)*) was configured into fourteen (14) different setups to enable testing of all the required DDNs. Energy balances were performed on all the setups to determine the operational envelope of the system components. This resulted in a first order specification and sizing of the system elements. The same process was followed for Concept 2 where a total of three different setups, including energy balances were defined. The same process was not performed in as much detail for Concept 3 for reasons that will be discussed later in this section. The Main categories into which the Units Under Test (UUTs), as listed in the DDNs, were divided are discussed in the next points with their individual F&ORs. A summary of a typical UUT, such as the IHX, together with Test Modes and a Test Specification is provided in Appendix G.

3.1 MAIN CATEGORIES OF UNITS UNDER TEST

3.1.1 IHX Component Tests

The CTF should have the flexibility to test a range of IHX designs, configurations, operating conditions and heat transport fluids. The heat transport fluids might have controlled levels of impurities in some tests. In the absence of a specific NGNP design, the options proposed by the three vendor teams were used as the basis for evaluating the potential range of development requirements.

Mockups or scaled representative IHX concepts are required to be tested in operating conditions comparable to anticipated NGNP conditions. The functionality for large scale testing at representative conditions should not be excluded.

The main tests to be conducted include:

- IHX performance verification testing, which could serve as empirical validation for thermal-hydraulic design methods and analysis.
- Life prediction and durability testing to evaluate design and fabrication methods, as well as data generated by material laboratories. Thermal-mechanical aspects of concepts should be evaluated during these tests, which typically include interface development.
- Seals tests on various sealing interfaces, as well as the influence on leak rates due to various process parameters.
- Flow induced vibration tests and tests on IHX configurations and its associated piping, together with frequency spectra and sound pressure levels caused by different flow velocities.

3.1.1.1 CTF IHX Operational Requirements: Westinghouse Vendor Team

The following provides a list of operational requirements for the CTF as imposed by IHX development and testing requirements from the Westinghouse Vendor Team.

- Primary helium inlet temperature of 950°C (nominal)
- Primary outlet temperature of 337°C (nominal)
- Secondary helium inlet temperature of 290°C (nominal)
- Secondary outlet temperature of 900°C (nominal)
- The CTF should provide for long-term testing, sufficient to provide confidence in the operating life of the IHX components
- IHX-A Primary Heat Transport System (PHTS) inlet pressure shall be 8,750 kPa
- PHTS to Secondary Heat Transport System (SHTS) ΔP and interior to exterior ΔP near zero (essentially pressure balanced at <200 kPa)
- IHX-B SHTS inlet pressure shall be 9,100 kPa.
- The working fluid in both the PHTS and the SHTS shall be helium, with controlled impurity levels which are still To Be Defined (TBD).

- Pressure drop across primary side and also across secondary side of IHX shall be smaller than 1.23 percent of its respective inlet pressure (e.g. [Primary IHX-A inlet Primary IHX-B outlet] < 108 kPa)
- A summary of the representative cores to be tested for both IHX A and B are provided in the following tables:

IHX-A (1 x Test Core) Requirements			
	PRIMARY	SECONDARY	
m	1.15 [kg/s] (138 total cores)	1.15 [kg/s] (138 total cores)	
T_in	950 [°C]	710 [°C]	
T_out	760 [°C]	900 [°C]	
Pressure_in	8.750 [MPa]	9.011 [MPa]	
Delta T	190 [°C]		
Q	1.134 [MW]		
Dimensions:	1000 x 56 x 275 [mm]		

IHX-B (1 x Test Core) Requirements			
	PRIMARY	SECONDARY	
m	0.938 [kg/s] (170 total cores)	0.938 [kg/s] (170 total cores)	
T_in	760 [°C]	287 [°C]	
T_out	337 [°C]	710 [°C]	
Pressure_in	8.683 [MPa]	9.10 [MPa]	
Delta T	423 [°C]		
Q	2.058 [MW]		
Dimensions:	1000 x 56 x 420 [mm]		

- The IHX test cores would need to be subjected to the transient testing to be defined
- Cooling helium should be provided to the IHX test vessel if required by the unit under test [TBD].

3.1.1.2 CTF IHX Operational Requirements: General Atomics Vendor Team

The following is a list of operational requirements for the CTF as imposed by IHX development and testing requirements from the General Atomics Vendor Team.

- It is necessary to confirm by experiment the flow distribution throughout the IHX (both primary and secondary inlets and outlets) accompanied by analytical evaluation.
- Data are needed to produce frequency spectra and sound pressure levels that may be generated by the IHX as a function of flow velocities.
- Physical and operational characteristics of insulation are required relative to thermal cycling, mechanical and acoustic vibrations, and effects of flow and thermal gradients.
- The CTF should be able to measure leak rates under operating conditions and should be configured in such a way to investigate the influence of various parameters in the leak rates.

• The flow induced excitation mechanisms of concern are turbulent buffeting, vortex shedding and fluid elastic instability.

3.1.1.3 CTF IHX Operational Requirements: AREVA Vendor Team

The following is a list of operational requirements for the CTF as imposed by tubular IHX development and testing requirements from the AREVA Vendor Team. These values represent the anticipated values for the full-scale heat exchanger and only representative parameters would need to be provided in the CTF.

Primary side (shell Side)

- IHX inlet temperature: 900°C
- IHX outlet temperature: 489.5°C
- Primary side inlet pressure: 5 MPa
- Pressure drop: 11.33 kPa
- Fluid: Helium

Secondary side (tube side)

- IHX inlet temperature: 449.1°C
- IHX outlet temperature: 850°C
- Secondary side inlet pressure: 5.46 MPa
- Pressure drop: 260 kPa
- Fluid: Helium Nitrogen (He-N₂)
- The IHX test modules would need to be subjected to the following transients
 - Cool-down transients of 300°C in 5 sec.
 - Heat-up transients of 300°C in 120 sec
- Representative geometry [TBD]
- Testing of IHX concepts is proposed to be conducted in the following steps:
 - Mock-up scaled versions to be tested in ~1 MW loop facility
 - Qualification tests of full-scale mock-up in ~10 MW loop facility
- All tests should be conducted with sufficient flow for representative flow distribution in headers, as well as providing all the representative conditions at the same time.

3.1.2 Mixing Chamber Test

The CTF should be capable of performing various predefined tests on representative helium mixing chamber designs and configurations.

The main tests to be conducted are:

- Performance verification test on a prototype mixing chamber.
- Thermal cycling effects testing.
- Nominal operating life of the mixing chamber [equivalent to NGNP plant life].
- Working fluid shall be helium.
- Different size fixed orifice testing for mixing of gas.

3.1.2.1 CTF Mixing Chamber Operational Requirements: Westinghouse Vendor Team

The following is a list of operational requirements for the CTF as imposed by helium-mixing chamber development and testing requirements from the Westinghouse Vendor Team.

- Inlet pressure of 8.5 MPa for SHTS
- Helium inlet temperature of 900°C
- Process Coupling Heat Exchanger (PCHX)
 - T-outlet: 660°C (Hydrogen Production System in operation)
 - T-outlet: 900°C (Hydrogen Production System not in operation)
- Mixing chamber outlet: 840°C
- Total HTS flow: 159.6 kg/s
 - Flow to PCHX: 39.9 kg/s
 - Flow to SG: 119.7 kg/s (NGNP required flow)
- Split of 75 percent hot gas (900°C) and 25 percent cold gas(660°C)

3.1.3 High Temperature Duct & Insulation Testing

The CTF should provide the capabilities to verify and experimentally validate the designs for high temperature ducts and insulation (HTD&I) which are to be used for fluid transport in both primary and secondary heat transfer loops. Experimental testing and validation will need to be performed on prototype samples and emphasis needs to be placed on long-term validations.

3.1.3.1 CTF HTD&I Operational Requirements: Westinghouse Vendor Team

The following is a list of operational requirements for high temperature duct and insulation design validation as required by the Westinghouse Vendor Team.

- PHTS ducts and insulation up to 950°C
- SHTS ducts and insulation up to 900°C
- Fluid: Helium
- Piping prototypes need to be tested at full temperature and pressure (Pressures equal to the requirements of the WEC IHX requirements need to be provided).
- Flow rates: It is suggested to provide the same boundary velocity by means of an annulus design. Final size and velocity TBD
- Prototype tests include:
 - Mechanical properties evaluation
 - Investigation of environmental effects on proposed designs
 - Long-term tests [TBD] for the validation of acceptability and continued effectiveness (performance) of proposed designs under normal operating conditions.

3.1.3.2 CTF HTD&I Operational Requirements: AREVA Vendor Team

The following is a list of operational requirements for high temperature duct and insulation design validation as required by the AREVA Vendor Team.

- PHTS ducts and insulation up to 900°C
- SHTS ducts and insulation up to 850°C
- In order to address the risk of the high temperature ducts and insulation AREVA proposed a qualifications process constituting of the following CTF related steps:
 - Subscale mock-up tests in helium of about 1 MW for validation purposes
 - Full scale mock-up test in ~10 MW test facilities.
- The tests should include:
 - Depressurization tests
 - Pressure drop, heat loss
 - Leak tightness of connections
 - Temperature measurement needs to be taken at various locations during operating conditions.

3.1.4 Steam Generator Testing

The CTF should provide the capabilities to perform various tests on steam generator (SG) designs which include:

- Acoustic response testing under different flow conditions as well as flow induced vibrations due to various excitation mechanisms.
- Thermal and mechanical performance of steam generator related insulation.
- Demonstration tests of certain design aspects in steam generators such as tube retention and wear protection devices, and the non-helical transition tubes. These tests would typically be used for determining adequacy of existing designs, as well as evaluating new proposals.
- Seal-related tests in order to evaluate designs and validate performance-related criteria with varying parameters.
- Feed water related tests which include aspects such as orifice performance verifications, as well as design and manufacturing configurations.
- Steam generator instrumentation related mock-up tests need to be conducted.
- Steam generator performance tests need to be conducted in order to evaluate the heat transfer characteristics of certain regions.

3.1.4.1 CTF SG Operational Requirements: Westinghouse Vendor Team

The following is a list of operational requirements for the steam generator tests as required by the Westinghouse Vendor Team.

• Hot Side:

- Fluid: Helium
- Inlet pressure: 8.2 MPa
- Pressure drop: ~ 0.1 MPa (NGNP requirement)
- Inlet temperature: 900°C
- Helium flow: 159.6 kg/s (NGNP requirement)
- Outlet temperature: 272°C

- Design pressure: > 13.2 MPa
- Cold Side:
 - Fluid: water / steam
 - Feed water / steam flow: 206.3 kg/s
 - Feed water temperature: 219°C
 - Feed water pressure: 18.9 MPa
 - Steam pressure: 12.78 MPa
- Empirical data is needed to investigate the noise on large steam generator surfaces as a function of varying frequencies. Acoustical response of the tube bundle and cavity also need to be measured as a result of primary flow. Data to be generated include representative frequency spectra and sound pressure levels generated by the steam generator bundle as a function of velocities and geometry variations.
- Physical and operational characteristics of the insulation are to be verified as a result of:
 - Thermal cycling [cycles TBD]
 - Mechanical and acoustic vibrations
 - Flow and thermal gradients
- Accelerated wear tests to demonstrate existing tube-retention device designs.
- Operating requirements that influence the seal test are:
 - Performance verification and leak rates measurements under prototypical conditions.
 - Influence of leak rates under differential pressures.
- Testing of non-helical portions of the tube bundle is needed to determine:
 - Spatial envelope
 - Characteristics of thermal movement
 - Interactions of tubes and supports to evaluate adequacy of clearances.
- Test should be conducted to accurately determine flow induced vibration characteristics of the helical tube bundle, lead-in/out tubes and transition tubes.
- Test data is needed to design and size orifices to be used in the individual tube circuits. Performance verification regarding erosion/corrosion resistances to be evaluated as well as fabrication and assembly performances. Data requirements include:
 - Pressure drop measurement
 - All data measurements in accordance with validation requirements
- Testing of steam generator mock-ups to confirm the design and assembly techniques of critical instrumentation. Ease of removal and replacement must be in accordance with requirements for experimental data and validation for non-safety related components.

3.1.4.2 CTF SG Operational Requirements: General Atomics Vendor Team

Data required once the design has developed further and materials have been selected.

3.1.5 Helium Circulator

The CTF should provide for full scale integrated tests of various circulator configurations which could assist in the verification of circulator component designs and adequacy of support systems. Typical tests will include:

- Circulator design verification tests
- Circulator performance empirical verification
- Circulator control system testing.

3.1.5.1 CTF Circulator Operational Requirements: Westinghouse Vendor Team

The following is a list of operational requirements for the CTF as imposed by helium circulator development and testing requirements from the Westinghouse Vendor Team:

- Primary helium loop pressure of 9MPa
- Primary inlet temperature of 350°C exit conditions
- Secondary helium loop pressure of 9MPa
- NGNP Design: 10.8 MW Circulator

3.1.5.2 CTF Circulator Operational Requirements: General Atomics Vendor Team

The following is a list of operational requirements for the CTF as imposed by helium circulator development and testing requirements from the General Atomics Vendor Team.

- Primary helium circulator
- Secondary helium circulator (Secondary circulator DDNs are covered by primary helium circulator DDNs due to design similarity)
- Shutdown cooling circulator
- Primary and secondary 5 MPa.

3.1.5.3 CTF Circulator Operational Requirements: AREVA Vendor Team

The following is a list of operational requirements for the CTF as imposed by helium circulator development and testing requirements from the AREVA Vendor Team.

- Scale: Full scale recommended
- NGNP proposal
 - 3 x 5 MW circulators & 1 x 1.5 MW circulator
 - At full power required, the circulator should run at maximum of 90 percent
- Primary and secondary pressure of 5MPa.

3.1.6 Valves Testing

The CTF should provide the capabilities to do performance and structural verification on high temperature valves for maintenance and/or isolation, albeit design requirements are still TBD.

3.1.6.1 CTF Valves Operational Requirements: General Atomics Vendor Team

The following is a list of operational requirements as obtained from the General Atomics PCDR:

- CTF should provide large scale facilities for valve testing at 950°C in representative primary loop environment.
- Tests to be used for component qualification

3.1.7 Auxiliary Systems

The CTF should provide a complete array of auxiliary systems in support of the tests to be conducted. These auxiliary systems should include, but are not limited to the following:

- Helium purification system
- Helium inventory control system
- Heat rejection systems (typically air cooled condensers instrumented to enable full energy balances)
- Control instrumentation air system

3.1.8 Control & Instrumentation

The CTF must be used for instrumentation and control philosophy development as well as adequacy verification for certain applications.

3.1.8.1 CTF C&I Operational Requirements: General Atomics Vendor Team

Typical requirements for the CTF regarding instrumentation include the following:

- Capabilities to measure and verify helium mass flow measurements
- Verify conduction cool down temperature monitoring instrumentation
- All instrumentation to be used for verification and validation purposes

3.1.9 Other Helium Heat Exchanger Testing Requirements

The CTF should be capable of performing various predefined tests on representative supporting component designs and configurations, including the shutdown heat exchanger. The main tests to be conducted in support of the shutdown heat exchanger are:

- Insulation verification tests
- Vibrational fretting wear and sliding wear of tube restraint
- Devices for bare tubes
- Instrumentation attachment test
- Bare tubes inspection methods and equipment
- Shroud seal test
- Acoustical response of the helical bare tube bundle
- Inlet flow and temperature distribution test
- Tube bundle local heat transfer and flow resistance characteristics

3.1.9.1 CTF Operational Requirements: General Atomics Vendor Team

All other heat exchanger test requirements relate to DDNs as determined by the General Atomics Vendor Team. Detailed requirements are TBD once the design is further developed.

3.1.10 General Functions

The following is a list of general functions that should be addressed by the CTF.

- The CTF should provide data and measurements that could be utilized for verification and validation purposes of thermal-fluid related software.
- The CTF should also be used for qualifications control as well associated program requirements development.
- Control room human factors are also envisaged to be tested and developed using the CTF.
- Specific hydrogen production testing is not defined yet but should be included in the future.

The F&ORs for the CTF have been determined in this section and provide a set of requirements that existing facilities can be measured against. The next section describes the South African facilities and their ability to meet the requirements of the CTF.

3.2 SOUTH AFRICAN TEST FACILITIES

The PBMR facilities were identified and used in the justification of the CTF primarily because they have the ability to test under high temperature and pressure helium conditions. Other facilities located or planned elsewhere in the world which are listed in [1] were excluded in this evaluation due to time and resource constraints. However, a literature study on some German facilities (Appendix C) was conducted to determine what was done on other typical test facilities with similar mission needs. The literature study also served as guidance to establish the Envelope Philosophy (e.g., full scale testing vs. laboratory scale testing, etc.) that was followed in the justification of the CTF.

The South African PBMR test facilities were designed, built and operated specifically for the technology development of the PBMR Demonstration Power Plant (PBMR DPP). The following facilities were reviewed:

- The Helium Test Facility (HTF)
- The Heat Transfer Test Facility (HTTF), which consists of two units:
 - The High Pressure Test Unit (HPTU) and
 - The High Temperature Test Unit (HTTU)
- The Pebble Bed Micro Model (PBMM).

(Refer to Appendix B for detailed descriptions of these facilities.)

The assessment of the facilities concurred with the justification philosophy (presented in Section 2) in terms of the evaluation with regard to their capabilities, test schedule, possible modifications, current configuration and ability to address the CTF Mission Need. The outcome of the assessment is briefly presented in the following sections.

3.2.1 The Helium Test Facility

The Helium Test Facility (HTF) was mandated to do design/development/functional/integrated and performance testing on the PBMR Main Support Systems (MSS) up to delivery of the MSS to the first demonstration plant. The main focus of the HTF hereafter is full scale, non nuclear tests on the Fuel Handling System (FHS), Reactivity Control System (RCS) and Reserve Shutdown System (RSS). These systems are termed Units Under Test (UUTs).



Figure 4: High level process flow diagram of the Helium Test Facility Main Loop

3.2.1.1 Capabilities

The HTF supports the development, verification and non-nuclear testing of critical prototype components of the PBMR MSS. It provides the capability to test components and sub-assemblies in a high-temperature and high-pressure helium environment that is similar to the operating conditions expected for the PBMR DPP. The operational envelope of the HTF is provided in Table 1 and Figure 5. From this table, it is evident that the maximum usable flow rate and temperature are on the order of 1kg/s and 900°C respectively. (NOTE: These conditions cannot be attained simultaneously; see Appendix B for more details.)

NGNP-CTF 20-CTF

9	. Description	I.	11							Man	ifold									
		əsey	อระเ	əsei	Pressure	•				'		1		ш		Line	9 6	Lab	Availibilt	y
		d	ld	łd	[MPa]	[kg/s]	[°C]	[kg/s]	[c]	[kg/s]	[°C]	[kg/s]	[°c]	[kg/s]	[°c]	[kg/s]	[°C]	kg/s	[°c]	Date
-	FHSS @ 1 MPa Line D, T = 280°C (via FHS system)		×		۲	•		0.051	280			•						0.051	280 [TBD]
2	FHSS @ 1 MPa Line G, T = 200 - 250°C (via equalisation line)	×			1	-	-	-	-		-	-		-		0.03	250	0.03	250 [TBD]
9	FHSS @ 1 MPa Line G, T = 280°C (via FHS system)		×		٢	•		•				•				0.13	280	0.13	280 [TBD]
4	RSS @ 2.2 MPa & T_max ≤ 250 °C	×			2.2	0.05	250	0.05	60	0.05	60	0.15	100	0.05	50			0.05	250 [[TBD]
5	RSS @ 6.5 MPa & T_max <u>≤</u> 300°C	×			6.5	0.05	300	0.05	100	0.05	100	0.03	100	0.05	50		•	0.05	300	[TBD]
9	RSS @ 6.5 MPa & T_max ≤ 600°C		×		6.5	0.05	500	0.05	100	0.05	100	0.03	100	0.05	50			0.05	500	[TBD]
~	RSS @ 9.0 MPa & T_max ≤ 300°C (SAS transport)	×			6	0.05	300	0.05	280	0.05	280	0.4	150	0.05	50	,		0.05	300	[TBD]
∞	RSS @ 9.0 Mpa & T_max ≤ 600°C (SAS transport)		×		6	0.05	580	0.05	280	0.05	280	0.4	150	0.05	50			0.05	580	TBD]
6	RSS @ 9.0 Mpa & T_max ≤ 900°C (SAS transport)			×	6	0.05	750	0.05	280	0.05	280	0.4	150	0.05	50			0.05	750 [TBD]
5	RSS @ 9.0 Mpa & T_max ≤ 600°C (Manifold D for lower RSS vessel conditioning at 350°C)		×		6	0.05	580	0.1	350	0		0		0.05	50			0.05	580 [[TBD]
7	RSS @ 9.0 Mpa & T_max < 900°C (Manifold D for lower RSS vessel conditioning at 350°C)			×	6	0.05	750	0.1	350	0	•	0		0.05	50		•	0.05	750 [[TBD]
12	: RCS @ 9.0 MPa & T_max ≤ 300°C	×			6	0.2	300	90.0	280	0.05	280	0.05	120	0.05	50		-	0.2	300 [TBD]
13	RCS @ 9.0 MPa & T_max ≤ 600°C		×		6	0.2	580	90'0	280	0.05	280	0.05	200	0.05	50	-	-	0.2	580 [[TBD]
4	. RCS @ 9.0 MPa & T_max ≤ 600°C			×	6	0.05	006	0.05	280	0.05	280	0.4	150	0.05	50			0.05	006	TBD]
15	r RCS @ 9.0 MPa & T_max ≤ 300°C (No manifold C flow)	×			6	0		0.06	280	0.05	180	0.05	120	0.05	50			0.06	280	TBD]
16	RCS @ 9.0 MPa & T_max 600°C (No manifold C flow)		×		6	0	-	90.0	350	0.05	180	0.05	120	0.05	50		-	0.06	350 [[TBD]
17	rcs @ 9.0 MPa & T_max ≤ 600°C (No manifold A & E flow)		×		6	0.22	580	90.0	350	0	-	0	-	0.05	50	-	-	0.22	580 I	[TBD]
18	RCS @ 9.0 MPa & T_max ≤ 900°C (No manifold A & E flow)			×	6	0.22	006	90.0	350	0	-	0		0.05	50		-	0.22	006	TBD]
19	- Combined RCS & RSS @ 9.0 MPa & T_max ≤ 300°C	×			6	0.25	300	0.11	0.1	0.9	280	0.35	120	6.0	50			0.25	300	TBD]
20	Combined RCS & RSS @ 9.0 MPa & T_max ≤ 600°C		×		6	0.25	580	0.11	280	0.9	280	0.35	120	0.1	50			0.25	580	TBD]
21	FHSS @ 9.0 MPa, T=280°C (via equalisation line)	×			6	-	-	-	-		-	-		-	-	0.6	280	•	0	
22	FHSS @ 9.0 MPa, T=280°C (via FHS system)		×		6	-		-	-	-		-		-		0.58	280		0	-
	Maximum Conditions				6	0.25	006	0.11	350	0.9	280	0.4	200	0.9	50	0.6	280			

Table 1: Helium Test Facility (HTF) Operational Conditions

Motes 1 Tempeature measured at manifold C 2 Tempeature measured at manifold C 2 Tempeature at mozzle of RSS test-up, wessel (NB) 4 Tempeature at mozzle of RSS test-up, wessel (NB) 5 Tempeature at mozzle of RSS test-up, wessel (NB) 6 Tempeature at mozzle of RSS test-up, wessel (NB) 6 Tempeature at mozzle of RSS test-up, wessel (NB) 8 Tempeature at mozzle of RSS test-up, wessel (NB) 8 Dempeature at mozzle of RSS test-up, we



Figure 5: Helium Test Facility (HTF) operational envelope (dark blue area) compared against a facility that will typically address the CTF F&ORs (grey area)

3.2.1.2 Test Schedule

Currently, the HTF team works closely with PBMR Testing, Qualification and Commissioning (TQC) to develop and implement test and qualification strategies for the development and testing of the previously mentioned systems. On this basis, a total of 275 tests were defined and need to be completed on a priority basis in support of these systems. Based on what is contained in the qualification strategies, the HTF management estimated the number of tests that need to be completed per annum to allow designers to deliver these PBMR DPP systems on time. Currently 25 critical design/development tests have been scheduled for completion during 2008, with the rest of the 275 scheduled for the following year and in the future. The latest forecast indicated that the HTF will be committed to PBMR DPP MSS tests until at least 2012. This schedule takes into account the current availability of resources and plant capability.

3.2.1.3 **Possible Modifications**

In essence, it must be understood that the HTF is actually a "cold" system with locally heated hot spots for testing the three UUTs. Essentially the HTF consists of a main loop with heaters, a helium circulator, coolers, etc. and three UUTs coupled thereto (refer to Figure 4). It is therefore not a facility that can easily be modified to suit the CTF Mission Need. However, a HTF Laboratory is being designed where some lab-scale tests can be conducted on components such as valves. A proposal for a secondary loop in the laboratory area with an operating envelope of ± 1 kg/s at 9 MPa and localized heating to ~950 °C can be found in Appendix B and is depicted in Figure 6.



Figure 6: High level process flow diagram of the possible modifications to the HTF Laboratory

3.2.1.4 Current Configuration

The HTF, as a complete facility, is currently not configured to support major changes. The only foreseeable changes are the addition of the HTF Laboratory and possible increases in temperature in the localized heating in the UUTs to represent the NGNP conditions.

3.2.1.5 Ability To Address CTF Mission Need

When the HTF capability envelope is compared to the CTF Envelope Philosophy and F&ORs, it is found the HTF cannot address the requirements due to capability constraints on components, current and future test schedules and physical space constraints. Due to established test schedules, this facility will not be available for use within the required timeframe to achieve the 2018 NGNP startup.

The HTF cannot accommodate full scale testing of HTS components, but rather specialized testing of materials or scaled components at diluted requirements when compared with the NGNP F&ORs.

An important aspect that also came out of the investigation is the fact that nowhere in the DDNs were the PBMR DPP related tests that are currently underway at the HTF mentioned. It is evident that the assumption was made that these tests do not need further investigation by the WEC NGNP team due to the fact that PBMR was already committed to obtaining the results for PBMR DPP purposes. These results could, in the future, be offered in kind, but will require further investigation and negotiations among the relevant parties.

It must also be noted that the PBMR DPP and NGNP have slightly different operating conditions in terms of inlet and outlet temperatures. The PBMR DPP has a core outlet temperature of 900°C compared to the 950°C of the NGNP. This would imply that the HTF test conditions are only set up to reach NGNP requirements that fall within the range of the PBMR DPP. It is proposed that a separate study be done on exactly what modifications need to be made, if any, to the HTF to test and verify that the MSS components that are under test will suffice for the NGNP reactor as well.

3.2.2 The Pebble Bed Micro Model

The purpose of the Pebble Bed Micro Model (PBMM) was to demonstrate the concept and controllability of the PBMR three-shaft recuperated closed Brayton Cycle. The PBMM was also utilized to demonstrate the Flownex computer code's ability to accurately predict the dynamic behavior of the system. The operational envelope of the PBMM is found in Table 2. From this table it is evident that the maximum usable flow rate and temperature is in the order of 2kg/s and 700°C, respectively, with Nitrogen as the working fluid. (NOTE: These conditions cannot be attained simultaneously; see Appendix B for more details.)

3.2.2.1 Capabilities

Variable	Unit	Min	Мах
	MPa		
System Pressure	(abs)	0	0.9
System Mass Flow Rate	kg/s	0	2
System Heater Power	kW	0	350
Heater Temperature	°C	0	700
Fluid		Nitrogen	Nitrogen

Table 2: Pebble Bed Micro Model Operational Conditions

3.2.2.2 Test Schedule

The PBMM is currently not in use.

3.2.2.3 Possible Modifications And Current Configuration

Extensive modifications are needed to change the current facility for use as a component test facility or laboratory. The major changes will include a blower, pipe work, a new control system and instrumentation. The use of helium in the facility must be investigated further as sealing of the vessel will be of concern.

3.2.2.4 Ability To Address CTF Mission Need

When the PBMM capability envelope is compared to the CTF Envelope Philosophy and F&ORs, it is found the PBMM cannot address the requirements. It is not foreseen that the PBMM will suffice for use as a CTF in terms of the CTF Envelope Philosophy.

3.2.3 The Heat Transfer Test Facility

The Heat Transfer Test Facility (HTTF) consists of two clearly distinguishable test units, namely the High Temperature Test Unit (HTTU) and the High Pressure Test Unit (HPTU). The purpose of the facility is twofold namely:

- To validate the correlations that are currently used to model the relevant heat transfer and fluid flow phenomena required for the integrated simulation of the pebble bed core, via a comprehensive set of separate effects tests.
- To generate results that may be used to validate the different simulation methodologies applied in the integrated models that represent the entire pebble bed core, via a comprehensive set of integrated effects tests.

3.2.3.1 High Temperature Test Unit

HTTU Capabilities

The HTTU is an integrated effects test facility that represents a section of the pebble bed reactor. The HTTU pebble annulus is the same width and geometrically similar to the actual PBMR reactor core and it will be used to measure the heat transfer characteristics of the pebble bed as a whole. Some of the tests that will be conducted with the HTTU will be used to validate correlations currently employed by PBMR for the determination of the pebble-to-pebble effective conductivity, pebble-to-reflector conductivity and temperature profiles through the core for different gas flow rates. These tests include steady-state and transient experiments with nitrogen and helium under different conditions. The high temperature pebble bed core or test section forms the heart of the HTTU plant. The test section contains about 28,000 graphite spheres of size similar to that of the PBMR fuel spheres. The operational envelope of the HTTU is found in Table 3 and Figure 7. From this table it is evident that the maximum usable flow rate and temperature are on the order of 4kg/s and 1200°C in the flow configuration and 1600°C in the near vacuum and natural convection configurations. The fluids that can be used in the HTTU are Helium (Natural Convection) and Nitrogen (Natural and Forced Convection) at pressures ranging from 10-100kPa (abs).

NOTE: These conditions cannot be attained simultaneously (see Appendix B for more details).

Variable	Unit	Min	Max
System Pressure	kPa (abs)	10	100
System Mass Flow Rate - Nitrogen	kg/s	0	0.5
System Heater Power	kW	0	500
Heater Temperature	°C	Ambient	1600
Heat Exchanger Power	kW	0	157

Table 3: High Temperature Test Unit (HTTU) Operational Conditions





Figure 7: High Temperature Test Unit (HTTU) operational envelope (dark blue area) compared against a facility that will typically adress the CTF F&ORs (grey area)

HTTU Test Schedule

The HTTU is currently utilized for PBMR tests and it is foreseen that it will be available in 2010 for other work.

HTTU Possible Modifications And Current Configuration

It is not foreseen that modification to the HTTU configuration can be made to further address the CTF Mission Need. However, the results obtained from the HTTU will be relevant to the NGNP as it forms the basis for the PBMR design and will be used to V&V the correlation used in the simulation of the PBMR reactor.

HTTU Ability To Address CTF Mission Need

When the HTTU capability envelope is compared to the CTF Envelope Philosophy and F&ORs, it is found the HTTU cannot address the requirements due to its inability to meet operational requirements. The tests that are currently being conducted could possibly be presented in-kind from PBMR to contribute to the NGNP's success and vice-versa.

3.2.3.2 High Pressure Test Unit

HPTU Capabilities

The HPTU operates at a system pressure of 5.0 MPa and a temperature of 75°C, using nitrogen as the working fluid. The HPTU consists of a number of test sections, each evaluating different parameters and reactor phenomena.

The aim of the HPTU is to validate the correlations that are used for different heat transfer and fluid flow phenomena through comprehensive Separate Effects Tests (SET), and to validate the different simulation methodologies used in the integrated models through comprehensive Integrated Effects Tests (IET). It should be noted that the HPTU is not an exact scale model of the actual reactor core or any other reactor structures. It is merely an assortment of representative sections of a pebble bed core, suitable for conducting SET and IET.

The operational envelope of the HPTU is found in Table 4 and Figure 8. From Table 4, it is evident that the maximum usable flow rate is on the order of 2.9kg/s. The fluid that is used in the HPTU is Nitrogen at pressures ranging from 100 to 5,000kPa (abs).

Variable	Unit	Min	Max	Completion date
System Pressure	kPa	100	5000	Jan '08
System Mass Flow Rate	kg/s	0.01117	2.888	Jan '08
Braiding Mass Flow Rate	kg/s	0.001532	0.12480	Jan '08
System Heater Power	kW	0.03491	9.668	Jan '08
Braiding Heater Power	kW	0.127	5.481	Jan '08
Heat Exchanger Power	kW	0.04507	0.04507	Jan '08

Table 4 [.] High Pressure	Test Unit (HPTU) C	Derational	Conditions
	1031 01111 (111 10/0	perational	00110110113



Figure 8: High Pressure Test Unit (HPTU) operational envelope (dark blue area) compared against a facility that will typically adress the CTF F&ORs (grey area).

HPTU Test schedule

The HPTU is fully operational and at the end of its testing phase. The tests for the PBMR were completed at the end of February 2008.

HPTU Possible Modifications and Current Configuration

Extensive modifications (localized heating and cooling) are required to reach high temperatures (T>900 °C) and that at only 5.0 MPa. It is therefore not foreseen that modification to the HTTU configuration can be made to further address the CTF Mission Need. However, the results obtained from the HPTU will be relevant to the NGNP.

HPTU Ability to Address CTF Mission Need

When the HPTU capability envelope is compared to the CTF Envelope Philosophy and F&ORs, it is found the HPTU cannot address the requirements due to the fact that it was designed to be a high pressure, low temperature and flow rate, Nitrogen operated facility. The tests that are currently being conducted could possibly be presented in-kind from PBMR to contribute to the NGNP's success and vice-versa.

3.2.4 Justification Conclusion

In conclusion, it can be said that after employing the Justification Philosophy to evaluate the South Africa test installations, these facilities do not meet the Mission Statement, Functional and Operational Requirements or Envelope Philosophy and will, therefore, not be suitable as Component Test Facility candidates.

This implies that a completely new facility must be designed and constructed to serve the life cycle requirements of the NGNP. The new facility must be specified in terms of what the F&ORs dictate to result in a solution that will meet the imposed CTF Mission.

The following section presents the recommendations for three concepts of the CTF that should meet the requirements listed in the preceding sections.

4. CTF CONFIGURATION RECOMMENDATIONS

Using the DDNs, together with additional requirements, a *Functional and Operational Requirements List* was created, which basically dictated a number of different test configurations (refer to Figure 9 for the process that was followed). The different concepts were evaluated and will be discussed in this section. Detail descriptions on all the concepts can be found in Appendix F.



Figure 9: Work flow diagram of the process that was followed to recommend configurations of the CTF that will address all Mission Needs.

From the different F&ORs in the previous section, it is clear that the capability to test a vast array of components and configurations needs to be provided for in the recommended facility concepts. In addition to these verification tests, it is also required to perform long-term life prediction and durability tests on either representative mock-up models or larger scaled components. Keeping this in mind, a *Facility Philosophy* was derived to enable the proposal for such a facility with different concepts.

The Facility Philosophy dictates that recommended concepts of the facility:

- Should have the capability of performing numerous tests at the same time. This is needed to address the various long-term testing requirements from different vendors.
- Need to accommodate further development work in terms of coupling commercial process demonstrations via high temperature heat exchangers.
- Should provide test capability for mock-up / scaled versions of certain components under test, while also allowing for full scale testing on circulators.
- Need to provide the capability to investigate different fluids (gases) in secondary loops.
- Should provide sufficient auxiliary systems to perform tests and become familiar with the working of these systems.
- Need to provide an environment where control philosophies can be tested.
- Need to provide an environment where development work can be performed on certain instrumentation.
- Should strive to utilize components that are one order more reliable than the components under test, typically commercial-off-the-shelf (COTS) items.
- An additional requirement is that the complete facility should be constructed and instrumented with Verification and Validation (V&V) in mind.
- Endeavor to possibly facilitate connection to a Nuclear Heat Source (NHS). If the connection to a NHS is required, the facility would need to be designed and built according to ASME III which will lead to a steep increase in cost.

Three different concepts are proposed in this report, based on the *Facility Philosophy*, above. Each of these concepts will be described with reference to its layout, the enveloping values as determined from the different test configurations and some additional considerations.

4.1 CONCEPT 1

Concept 1 consists of three small, completely independent test facilities which can be referred to as Technology Development Loops (TDLs). Each of these three loops could be connected to a common header in order to provide high temperature helium to a single large Component Qualification Loop (CQL). The large loop could then be used for larger scale component qualification by using the combined mass flows and heat energies from the TDLs. In addition to the TDLs and CQL, this concept also includes a completely independent and separate full scale Circulator Testing Loop (CTL).

A process flow diagram of the complete facility for Concept 1, which includes the three different TDLs, CQL and a full scale circulator loop, is provided in Figure 10. Please refer to Appendix D for a more detailed description of Concept 1.



Figure 10: High level Process Flow Diagram of Concept 1 indicating all Technology Development Loops, Component Qualification Loop & Full Scale Circulator Loop

4.1.1 Facility Layout

A preliminary facility layout of TDL 1 is presented in Figure 11, Figure 12 and Figure 13. This layout does not represent an optimized facility and was only created to obtain a feel for possible sizes of a single facility and related equipment. Although the complete facility is portrayed outside a building, it is recommended that it be housed inside a large building, utilizing overhead cranes with sufficient space for future development and lay down areas.



Figure 11: Conceptual physical layout of Technology Development Loop 1 indicating major components as found in the Process Flow diagram



Figure 12: Conceptual layout side view of Technology Development Loop 1



Figure 13: Conceptual floor plan view of Technology Development Loop 1

An envisaged layout of the entire Concept 1 is illustrated in Figure 14. Specific consideration was given to the following:

- The facility layout should have large open / undeveloped areas in the vicinity of the test vessels. This is to accommodate later development work with regards to either liquid salt secondary loops, or process coupling for commercial applications.
- The facility layout should be such that the heaters from the three smaller loops are in close proximity to each other, in order to reduce the common hot header for a possible large loop.
- Auxiliary systems should be located to the rear of each facility in order to ease access.
- Dedicated laydown areas should be provided.



Figure 14: Physical layout of Concept 1 showing the TDL, interconnecting Hot Header, CQL, CLT, allocated floor space and lay down areas



Figure 15: Perspective view of the physical layout of Concept 1

4.1.2 Pros And Cons

A few additional considerations that are regarded as advantages for this concept include:

- Three small test loops provide independent testing capability of various components from different vendors at the same time.
- Smaller, less complex facilities tend to utilize standard off-the-shelf components, as is or with minor modifications.
- The TDLs can be built in succession and lessons learned from one could be transferred to another, without impairing the NGNP time schedule.
- Risks are mitigated in terms of complexity and manufacturing lead times, while allowing an overall footprint that is quite compact.
- Utilizing the smaller loops for larger scale testing is accommodated by means of the common header configuration.
- Smaller loops provide independent connectivity for potential commercial application testing utilizing hot helium heat exchangers.
- Smaller facilities tend to favor transients in terms of lower thermal inertia and smaller gas volumes for depressurization.

• Multiple independent loops spread the risk in terms of availability and redundancy of the test facility as a whole.

The disadvantages or aspects that need further investigation include:

- Limited mass flow and heating capacity of the smaller facilities.
- This concept includes complex inlet and outlet headers which need to operate at high temperatures. The complexity of the outlet header might, however, be decreased by means of defining test configurations which always include a heat transfer testing component while also testing non-heat transfer components.
- Possibility of long lengths of hot pipes. Could be addressed by optimized routing.

4.2 CONCEPT 2

Concept 2 differs from Concept 1 in that it comprises of one large facility instead of multiple smaller facilities and is used as a large scale Component Qualification Loop (CQL 2). This large facility is driven by a mass flow recommendation of ~15 percent of the maximum NGNP circulating mass flow which relates to ~25 kg/s. This recommendation came as a result of various discussions with the engineering team of the HTF and component specialists. The process layout is similar to that of the Concept 1, in that it also utilizes a primary, secondary and dedicated steam generating loop. In addition to these, it is again proposed to have a separate full scale circulator testing circuit (as in Concept 1).

A process flow diagram of the complete facility for Concept 2, which includes the primary, secondary and steam generator loop is indicated in Figure 16. This also illustrates the separate full scale CTL. Please refer to Appendix E for a more detailed description of Concept 2.



Figure 16: High level Process Flow Diagram of Concept 2 indicating Primary Loop, Secondary Loop, Steam Generator Loop & Full Scale Circulator Loop

4.2.1 Facility Layout

A preliminary facility layout of Concept 2 is presented in Figure 17. This layout does not necessarily indicate all minor details of the proposed concept, but merely provides an idea of expected sizes. The circulator loop is not included in this illustration and is expected to accommodate a footprint size of approximately 50m x 25m.



Figure 17: Physical layout of Concept 2 (CQL 2)



Figure 18: Floor plan layout of Concept 2(CQL 2) indicating major components as can be found in the Process Flow diagram



Figure 19: Side view layout of Concept 2 (CQL 2)

4.2.2 Pros And Cons

Additional considerations that are regarded as advantages are:

- The capability to perform large scale testing (maximum sizes are provided in the loop descriptions in Appendix E).
- Provision should be made for future development in terms of coupling of commercial high temperature processes.
- A large test facility could provide conditions closer to that of the NGNP with regards to fault finding, program development, safety programs, maintenance programs and inservice inspections.
- The lesson learned from a facility such as this could be more easily transferred to the NGNP design and construction phases.
- Quality assurance programs (such as NQA-1) on a large facility could be of more relevance to NGNP related programs than from smaller facilities.

With these added benefits, the following disadvantages are also to be mentioned:

- The complexity associated with a large facility immediately increases the risk in terms of non standard components and long manufacturing lead times.
- Some major components, such as the circulator, need to be developed. This implies that a unit under test is supplied by certain process conditions by another unit under test which is contrary to the *Facility philosophy*.
- A large facility makes complete independent testing from various parties quite difficult, which translates back to possible time scheduling risks. Testing of numerous components at the same time can be obtained but with a high level of complex control.
- The facility would be less amenable to scaled testing or module testing, which may be more cost effective than large-scale testing, when otherwise technically acceptable.

4.3 CONCEPT 3

Concept 3 is an alternative for Concept 2 and will only be discussed via a high level process flow diagram. This concept basically consists of one large primary loop $(20 - 50 \text{ MW}_t)$ with numerous secondary loops connected to it, plus the separate CTL. The connection of the primary and secondary loops is established by means of heat transfer testing components. It is further anticipated that the secondary loops are in turn connected to tertiary loops for testing and evaluating of commercial high temperature applications items. A representative process flow diagram of such a facility is provided in Figure 20, while a list of associated advantages and disadvantages is presented thereafter.



Figure 20: High level process flow diagram of Concept 3 indicating the Primary Loop, Secondary and Tertiary Loops as well as the Full Scale Circulator Test Loop

4.3.1 Pros And Cons

Advantages associated with this concept include:

- The flexibility to perform numerous tests at the same time by means of various connectivity possibilities in both secondary and tertiary loops.
- Large capacity in terms of mass flow and heating capability which provides for large scale component testing.
- Large scale facilities will provide more relevant information with regard to program development, fault finding and in-service training.
- The lessons learned from such a facility could be more easily transferred to the NGNP design and construction phases.
- Quality assurance programs (such as NQA-1) on a large facility could be of more relevance to NGNP related programs than from smaller facilities.

Apart from these advantages, this concept is not highly recommended due to the following aspects:

- The complexity associated with a large facility immediately increases the risk in terms of non-standard components and long manufacturing lead times.
- Some major components such as the circulator need to be developed. This developed component is now utilized in testing components under development which increases the risk of potential non-operating conditions.
- A large facility makes complete independent testing from various parties quite difficult, which translates back to possible time scheduling risks. Testing of numerous components at the same time can be obtained, but with high level of complex control.
- Due to the fact that this facility is also quite large and that several secondary loops need to be supplied by hot gas, it could increase the price of primary loop hot pipes dramatically.

4.4 CONCEPT RECOMMENDATION

Three different concepts were discussed in the previous section and a recommendation regarding the most desirable concept that addresses the CTF Mission Need and F&ORs is presented below.

Concept 1 consists of three independent small test facilities which are specifically sized to address explicit DDNs as obtained from the PCDR of the three vendor teams. These three smaller facilities can in general be considered as Technology Development Loops (TDL) (for smaller components), while they are capable of being integrated via a common header. The common header allows for large mass flows and heating capability which could be used as a Component Qualification Loop (CQL) (up to ~10 MW_t) as per specific design needs. The advantage of the separate, but interconnecting loops lies in the manner in which different components can be tested at the same time using different loops. Also, the smaller loops require less engineering challenges during design and a staged technology growth path can be followed, where lessons learned from the first loop can be applied in the succeeding loops. It can also be advantageous that, when the first loop has been constructed and commissioned, testing can already commence while the other loops in the facility are being built. This is in favor of the NGNP schedule and is one of the primary reasons why Concept 1 is recommended as the concept of choice.

Concept 2 consists of a large loop used for component qualification (CQL 2) with the basic sizing being driven by a ~15 percent NGNP mass flow recommendation. This facility will be able to address almost all DDNs but has the limitation of performing a singular, long term durability test which entirely commits the plant to one specific test that could negatively impact on the greater NGNP schedule. Together with this disadvantage are the added risk, due to complexity, the higher operating costs of a single large plant and, specifically, the research and development (R&D) that is required for most of the loop components. The required R&D work on the loop components might affect the target completion date of 2011. Concept 2 is the second choice in recommending a test loop configuration for the CTF.

Concept 3 utilizes a singular primary hot loop with numerous secondary and tertiary loops connecting to it. Although the flexibility might seem to be an advantage, it is foreseen that the complexity in control philosophies with various independent experiments might be problematic. If the functionality of testing different UUT simultaneously is encumbered, it is foreseen that the Mission Need will not be satisfied. More specifically, it is required that the CTF be available to a huge community of contributors that has a large number of envisaged tests (as per DDNs) which will probably entail a comparable waiting list if the facility cannot accommodate parallel testing. This would put the NGNP schedule at risk and is one of the reasons why Concept 3 is not recommended to be a feasible concept for the CTF.

Despite its disadvantages, the ability to have a larger test loop such as that of Concept 2 (excluding the CTL) later on in the component qualification stages of the NGNP lifecycle does make sense. It is possible that the common header proposal of Concept 1 could prove to be more complex or costly than can be anticipated now. It might turn out that construction of the loop configuration of Concept 2 should follow after construction of TDL2 or TDL3 of Concept 1.

This is also why Concept 1 is attractive; it provides flexibility in testing as well as a staged approach in financial expenditure.

5.2 SCHEDULE

The schedule for the CTF was done in line with the cost estimate and the following assumptions were used:

- The final mile-stone is RFC in FY2011
- Schedules are provided for Concepts to stand as singular independent units that do not share utilities.
- Manpower will not be a constraint during any phase of the project.
- Based on construction and design time of PBMR facilities such as HTF and HTTF.
- *Force Majeure* was not catered for in these estimates.

The two envisaged schedules are presented in the next paragraphs.

5.2.1 Schedule - Concept 1

Figure 21 below depicts the schedule of Concept 1 and illustrates that in light of meeting the FY2011 deadline, the concept design phase must start in December 2008. After approval of the concept design, the preliminary design will follow thereafter, but must be completed no later than December 2009 to start support of the civil work. This provides a 20 month period during which to complete Concept 1.

2	Tool Manaa	Duction	Ctort	Cinich	
			lipic		Ort 2009 Ort 2009 Ort 0rt 0rt 0rt 0rt 0rt 0rt 0rt 0rt 0rt 0
2	Component Test Facility (CTF) - Concept 1	660 days	Mon 08/12/01	Fri 11/06/10	
e	Civils	240 days	Mon 09/12/28	Fri 10/11/26	
4	Site preperation	2 mons	Mon 09/12/28	Fri 10/02/19	
2	Road work	1 mon	Mon 10/02/22	Fri 10/03/19	
9	Buildings & Cranes	8 mons	Mon 10/03/22	Fri 10/10/29	
7	Paving	1 mon	Mon 10/11/01	Fri 10/11/26	
æ	Utilities	340 days	Mon 09/12/28	Fri 11/04/15	
6	Water treatment	6 mons	Mon 10/03/22	Fri 10/09/03	
10	Electrical	6 mons	Mon 09/12/28	Fri 10/06/11	
11	HPS	6 mons	Mon 10/11/01	Fri 11/04/15	
12	HICS	6 mons	Mon 10/11/01	Fri 11/04/15	
13	Compressed air	1 mon	Mon 10/11/01	Fri 10/11/26	
4	Fire protection	1 mon	Mon 10/11/01	Fri 10/11/26	
15	Technology Development Loop 1 (TDL 1)	660 days	Mon 08/12/01	Fri 11/06/10	
16	Concept Design	6 mons	Mon 08/12/01	Fri 09/05/15	
17	Preliminary Design	8 mons	Mon 09/05/18	Fri 09/12/25	
18	Procure Long lead Items	18 mons	Mon 09/08/03	Fri 10/12/17	
19	Final Design	12 mons	Mon 09/12/28	Fri 10/11/26	
20	Construction	8 mons	Mon 10/11/01	Fri 11/06/10	
21	Technology Development Loop 2 (TDL 2)	500 days	Mon 09/05/18	Fri 11/04/15	
22	Concept Design	4 mons	Mon 09/05/18	Fri 09/09/04	
23	Preliminary Design	5 mons	Mon 09/09/07	Fri 10/01/22	
24	Procure Long lead Items	18 mons	Mon 09/08/03	Fri 10/12/17	
25	Final Design	6 mons	Mon 10/01/25	Fri 10/07/09	
26	Construction	6 mons	Mon 10/11/01	Fri 11/04/15	
27	Technology Development Loop 3 (TDL 3)	500 days	Mon 09/05/18	Fri 11/04/15	
28	Concept Design	4 mons	Mon 09/05/18	Fri 09/09/04	
67	Preliminary Design	suom c	10/60/60 uow	Fri 10/01/22	
30	Procure Long lead Items	18 mons	Mon 09/08/03	Fri 10/12/17	
3	Final Design	6 mons	Mon 10/01/25	Fri 10/07/09	→ →
32	Construction	6 mons	Mon 10/11/01	Fri 11/04/15	
33	Circulator Test Loop (CTL)	460 days	Mon 09/05/18	Fri 11/02/18	
34 1	Concept Design	2 mons	Mon 09/05/18	Fri 09/07/10	
35	Preliminary Design	2 mons	Mon 09/07/13	Fri 09/09/04	
36	Procure Long lead Items	18 mons	Mon 09/08/03	Fri 10/12/17	
37	Final Design	4 mons	Mon 09/09/07	Fri 09/12/25	
38	Construction	4 mons	Mon 10/11/01	Fri 11/02/18	
39	Component Qualification Loop (CQL)	520 days	Mon 09/05/18	Fri 11/05/13	
40	Concept Design	4 mons	Mon 09/05/18	Fri 09/09/04	
41	Preliminary Design	6 mons	Mon 09/09/07	Fri 10/02/19	
42	Procure Long lead Items	18 mons	Mon 09/08/03	Fri 10/12/17	
43	Final Design	6 mons	Mon 10/02/22	Fri 10/08/06	
44	Construction	7 mons	Mon 10/11/01	Fri 11/05/13	

Figure 21: Schedule for Concept 1 indicating key dates and dependants

5.2.2 Schedule - Concept 2

concept phase to RFC. The fact that R&D is required in developing some of the components is clear from the long design and construction time. The circulator loop will be built in parallel with the large CQL 2. Figure 22 presents the schedule for Concept 2 and dictates that it will take an estimated 720 days, i.e. two years, to complete, i.e. from

₽		Task Name	Duration	Start	Finish		000				010				100			
	(600			N	010				L LOZ			
	0					Qtr 4	Qtr 1	Qtr 2	Qtr 3	Qtr 4	atr 1	Qtr 2	Qtr 3	Qtr 4	atr 1	Qtr 2	Qtr 3	Qtr 4
7		Component Test Facility (CTF) - Concept 2 (CQL2)	720 days	Mon 08/12/01	Fri 11/09/02			I		I								
e		Civils	240 days	Mon 09/02/02	Fri 10/01/01		\geq			ľ								
4		Site preperation	2 mons	Mon 09/02/02	Fri 09/03/27													
2		Road work	1 mon	Mon 09/03/30	Fri 09/04/24						Γ							
9		Buildings & Cranes	8 mons	Mon 09/04/27	Fri 09/12/04					ľ								
2		Paving	1 mon	Mon 09/12/07	Fri 10/01/01													
œ		Utilities	249 days	Tue 09/09/01	Fri 10/08/13						ľ		P					
6		Water treatment	6 mons	Mon 10/03/01	Fri 10/08/13													
10		Electrical	6 mons	Tue 09/09/01	Mon 10/02/15													
5		SdH	6 mons	Mon 09/12/07	Fri 10/05/21													
12		HICS	6 mons	Mon 09/12/07	Fri 10/05/21													
13		Compressed air	1 mon	Mon 09/12/07	Fri 10/01/01													
4		Fire protection	1 mon	Mon 09/12/07	Fri 10/01/01													
15		Circulator Test Loop (CTL)	340 days	Mon 09/02/02	Fri 10/05/21		>											
16		Concept Design	2 mons	Mon 09/02/02	Fri 09/03/27													
17		Preliminary Design	2 mons	Mon 09/03/30	Fri 09/05/22													
18		Final Design	4 mons	Wed 09/07/01	Tue 09/10/20													
19		Construction	6 mons	Mon 09/12/07	Fri 10/05/21													
20		Component Qualification Loop 2 (CQL 2)	720 days	Mon 08/12/01	Fri 11/09/02		l			I	l	l	I	I	l	l	\geq	
21		Concept Design	6 mons	Mon 08/12/01	Fri 09/05/15			ſ										
22		Preliminary Design	9 mons	Mon 09/05/1E	Fri 10/01/22													
23		Procure long lead items	18 mons	Wed 09/07/01	Tue 10/11/16													
24		Final Design	20 mons	Thu 09/10/01	Wed 11/04/13													
25	i.	Construction	12 mons	Mon 10/10/04	Fri 11/09/02													



APPENDIX A: DESIGN DATA NEEDS MATRIX

Π	#20)	0	tT, CAR	100 100	8	, 606, 20	61,03	6,043	19(1)	69(3)	69(3)	6 H) H	00,00	6973	61/M3	10,028	M, 000	M, 020	=	2	x
D ig	78.	L	°¢	88	Ŕ	00	÷	\$	*	÷	÷	*	*	÷	\$		ĉ	ñ	8	8	8
=	Tak yak	٥ ٧	-	-	-					"		"	"		"		-	-		"	
Н	n ottenado la ionemmo:	0 P.	-	-	-	-								-							
H	NORRE THE OF	- - -																		_	
ę.	peen Buo		-	-	-	-															
UP C	Duje La Duj Duje La Duj	•	-	-	-	-	-		-	-	-	-	-	-							
6.0	09	8 I																		_	
	100-316	POMN		3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3
Π	900-0W	MPTU	2		,		2	g	,	2	9	,		9		9	2	9	9	2	2
	800-374	, LLI	3	2		145, 568	4	3		2	9		2	2	-	3	9	9	9	3	\$
3.2) Facilit	100-DW	HIF I	40°, 400	40°, 600	a a	401 'NA	ar, se	a ka	a k	đa je	ta interest	40' H	a x a	i i i i i i i i i i i i i i i i i i i	i i i i i i i i i i i i i i i i i i i	100, 100 00, 100	10, 100 00	141, 500 Chi	100,100	100 X	10 X
Ĩ	110-100	(other)	HCC Withomason V Without Sector	MC Without Street	1	5	Prediction edition regionsy regionsy regions	Teener Internet 1.2 March	5	1		1		5		74	78	74	~ 6	~ 6	~ 4
	010-80	Other)	- Annalise of	- California		2	*****	BLOCK IN INC.		to hold a		*	-		turde Network Pethodis Pethodis Pethodis Pethol						
Н	210-300	() Her	teres Teres	Media 1900	\$	2	10	tot wor Bhe sett entr	\$	0 CT 0101	101	111	2	2	Private Contract of Contract o						
H		- <u>6</u>	NC IN	PC IN	1	YN	YEN	Enclosed and a second	1	A 100	VIN	No.	1 1 1	VIN	Arrest Arrest arrest control c	no miler	98	98	98	9	8
H	110-80	(Oh	Costrated Input/type	Costrated	Nonice Description Provided Description Description	20 A	100	o d Thermal o of Manual	Themator	to Integrate h	100	1	Critica press, market performant	N.N.	Heating contrast contrast contrast contrast for contra trast for contra trast for contrast for c	champer by a	P.Calebrane Mr. 7.	P.Calebrate Mr. 7.	T NO OR DRIVEN	T NO OR DRIVEN	1 Monte and a
	010-80	(Other)	unginged earlies	understand with loss	Periferanse verhoet ed on a protoke name deather	Notice operating the two for and and and operating op	The design service Mr s 40 equivalent full- come's years.	Thermal and momental partment momental partment of the active free option (i.e., thermal re- proversit and scien- proversit and scien- proversit and scien- proversit of the active provessit of the a	demonstrate the Decision	Test of Incologies of cents deciges to validat magin thefares.	Thema movement December 100	Providencial control of the communication of the communication of the communication of the broader, jean out the source of communication broad.	Brason / Camestan Matterio Mat for oth	2	Rectanty And and the adde of the state responses to be responsed to adde	Determine specific reg	Arrest specifications in	Arrest speaked in the	Arrest specifications in	Arrest specifications ()	Were specifications in
Π	600-800	Fluid	100	100	1	- HOM	Hint.	Heren I	a la	- HOM	- HOM	Him.	NUN.	NO.	1	- HUM	100	10.0	100	100	100
	800-80	eσ	160	94	5	5	MM.	WW	ww	WW	ww	ww	WW	WW	01	101	180	110	160	180	160
Π	200-80	a 6	9	9	Maria Talance Maria Talance December 1997 Maria Stating A. Maria Stating A.	8	8		8	5	œ	8	8	8	8	œ	9	0	9	9	9
Ħ	900-80	(other)	н 1	F	-1227		WT_JOHE DC Ream		WT JOH DC Rean OAC OAC	WT JOH DC Rean OAC	WT JOK DC Rean JOHC T	WT JOH WT JOH OW MAR	ء د	WT JOH 202 Rean John	WT JOH DC Photo DARC T	۲. ۲	2	2 0	2 0	2	2
5	500-WQ	(ucceg)	C 200C N	C 260C N	T. Committee	outlet topPC N	4 400C	c eaec at 2000	4 2000 4 2000	1000	4 2000 4 2000	A 2000	ž	6 200C	C DBCC	×	F	F	F	F	-
quiremen		۔ ت	ac Cen	ac Cen	ACC NOR	, outline Host	53	53	53	53	53	53	A PL	53	53	99	8	90	99	2	8
ational re	900-80	0 1 0	T_JOHE R	T_JOHE U	LTATU CTATU	Record Merci	WW.	N.W.	WN	WN	WN	NN N	PWINE	WN	YAN N	91	91	91	91	91	91
and Open	500-WO	P (Debta	< 200 HP4	P-10010-2	NW	10W	NON NON	YOW	VOW	NW	NW	VIII	WW	YOM AND	10W	08	08	08	090	98	98
nctional a	200-800	P (Secon)	1410	1	1961	11100	1001	Part 1	1.1MP4	1 JMP4	1 3MP4	Purct 1	VON	1300	1 CMP4	160	160	100	180	160	91
(3.3) Fu	100-80	P (Prim)	a Npo	o dec	YN	11100	VIN	Vev	VIN	WW	WW	Y	ALK	YIN		190	160	180	190	160	180
(3.1) Mission Need			Metallic: IHX Performance Verficetion	Cenamic: IHX Performance Verfication	Mining Chamber Performance Test	Evaluation of High Temperature Ducts and Insulation Systems	Acoustic Response of Helical Bundle	trsulation Verification Test	Freiting & Skiding Wear Protection Tests	Shroud Seal Test	Lead-inLead- out TransfordExpans on Loop Mockups *	Flow Induced Vibration Testing of Helical Bundle	Orfice Qualification	Instrumentation Machment Test	Helical Burdle and Transforn Region - Heat Transfor Teat	- Circulators	. Tube type IHX	Plate type IHX	 Isolation valves High temperature) 	- Helum purfication /	- Het Gas Duct
			HT8-01-	HTS-02- 04	HTS-08-	HT8-04-	80-01- 04	-10-08	80-01- 08	80-01- 10	80-01- 11	80-01- 12	80-01- 13	80-01- 14	80-91- 10-01-	AREVA- 023	AREVA- 024	AREVA- 025	AREVA- 026	AREVA- 027	AREVA- 033
diroso 1			CTF	CTF	H.	CIF	CTF	GF	CTF C	CIF	CTF	EL C	CTF	CIE	GTF	CTF	CTF	CTF	CTF	CTF	GTF
Vendo			WEC	WEC	WEC	WEC	WEC	WEC	WEC	WEC	WEC	WEC	WEC	WEC	WEC	ARE	ARE	ARE	ARE	ARE	ARE

Die TOUX	in Buiwo	UN8 are	Specific to a Lin														ľ		$\left \right $	$\left \right $			ł	ţ	$\left \right $	ľ	┟	Г
Vendor	Group	# NOO	(3.1) Mission Need	(3.3)	Functional	and Operation	onal require	ments				Ţ			T		Ĩ	1.2) Facility	+	+	6	S) LIN Cy	82	1	-	5	-	Т
				100-804	200-903	500-80 4	P00-804	900-WOJ	900-804	200-1804	800-WO4	600-¥QJ	010-804	110-804	210-804	C10-BOJ	910-BOI	100-DVJ	80-344	\$0-244	800-204	Dupupy Dig Dig Dig Dig Dig Dig Dig Dig Dig Dig	BURNER BURN Description	ous un o	Operation Commercial Aced.	180		
				P (Pris	m) P (Secon)	P (Delta)	T (Prim)	T (Secon)	T (Other)		σ	Fluid	(Other)	(Other)	(other)	(Dther)	(other)	HTF	HITU N	PL PL	- MNID	•	1	٨	۳. ۲		H	П
W.	CTF 00	NHEVA-	- Instrumentation	100	180	080	180	08	081	160	160	100	Arres specifications rise,	OR NUMBER				NL, 440	9	2						-	1901	
A	CTF N	113.01	Primary Hellum Circulator (PHC)	5 750	91	090	160	90	081	180	160	100						nt, teet	2	â	Tig	8	180 181	080	0 180			
4	2 M	413.01.0	Crostator Magnetic and Catober Bearings Design Verification	<u>p</u>	P	9	91	9	g	04	2		critic and operation and the of operation, of the st operation, of the st operation, operating the effice operating the effice operating	ecoding of conditing of conditing of condition	Alter dynamic Negociae la Negociae di Negociae N	contribut conter beenings		2 8 7 8	2	2	at a	g	at Oat	98	0 8			
4	N N	413.01.0	Circulator Prototype Design Verfostion	2	9	9	9	9	9	9	2		Compare the Andrewa Compare of the Andrewa expectable of the with a standard optime and an and a standard optime down and and a standard	erodoranto performanto performanto of more, loso enhanto norve, cinculato attener de citiano	vites (Statut Statut Statut Statut	activations activation https://www.inter- transmin. https://www.inter- https://wwww.inter- https://www.inter- https://www.inter	2 8 7 8	2	2	ž	8	20 A	94				
4	OTF A	4.13.02.0	Confirmation of PCHE Cone Temperature Distribution	a 160	91	9	P	9	98	P	91	-	15 X04 wit is beinge ein 15 X04 wit is beinge ein 16 X04 wit is beinge eine	t recession of card	tin ty separitie	of the temperature		40 H	2	ž	ž	8	041 241	980	94 9			
4	CTF 5	4.13.02.0	Continuation of IHX Thermal Hydrautic Characteristics	1 190	94	g	ž	9	081	91	01	-	R is recessary to contain the optimation through primary and operintary is accompanied by an addition	Lip experiment the aut the INC (public links and cublic) it evaluation.				1, 18 10 10	2	2	18	8	180 X	90	91 92			
4	CTF 0	4.13.02.0	HDX Acoustic Test	91	941	95	01	9	GR	91	94		Over the resolution of press, spectra and sound press, the periodical by the PCI.	und investi that may use investi that may as a function of ferr				ni, teo 10	2	2	ž	8	16 24	98	9 9			
4	CTF 7	N.13.02.0	HK Insulation Varification Tests	1 160	991	09	041	98	081	091	160	HOLD I	restance are represented in sound the method of the	ACCURATION DESCRIPTION				ni. tee	2	9	196	8	180.18	080	081.09			
4	OTF 8	4.13.02.0	HX Seal Tests	911	94	04	011	9	9	160	041	1.104	Variaus shorty-sects, soperator jornel, and other sects jornel, and submittee sects particle in the sect weap for protection in particular.	Citra die needed 1 conten the despe- sites ander compti- menum the infra- tionature the infra-	Second Second	such tapk and activity and	~ *	4, tee 10, 100	2	4	20	8	SEC OFF	000	040			
4	OTF 9	4.13.02.0	H-X Flow Induced Vibration Test	1 160	044	08	011	9	081	091	091	100	Calculate revealed to account of the second to the second of the second the second second the second second the second second second	The Revictions exclusion motion are consistent formed	tan of some time of some time.	the grad		A. 100	9	2	196	8	81 081	080	9			
4	CTF C	2:14.01	Shutdown Circulator	5 T6D	160	090	180	08	180	160	160	Philippe	No kith eveletion					HL, 1400 160 161 161	9	940	196	8	380 UBL	080 0	081 09			
4	CTF 1	0.14.01.0	SCS Circulator Magnetic and Catcher Bearings Design Verfication	5 T80	091	98	9	9	9	91	91	-	ancientes cue con					10 10 10 10 10 10 10 10 10 10 10 10 10 1	9	ž	194	8	81 081	080	91.09			
4	OTF 2	214.01.0	SCS Circulator Prototype Impeliar Aerodynamic and Acoustic Test Data	s 160	091	98	91	9	081	91	140	100	acception of the other					K, 180 N	9	2	194	8	80.081	080 0	91.09			
4	CTF 3	0.14.01.0	SCS Circulator Prototype Test in High Pressure Test Facility (HPTF)	s 780	091	98	9	9	98	91	91	1.00	anciente cue con					10 A	9	ž	116	8	81 081	090 0	91.0			
4	OTF 4	214.01.0	Shufdown Circulator Loop Shuf-off Valve (SLSV) Life Cycle Test Data	a 190	091	08	91	00	981	91	01		exception of the off				~ ~ ~	N, 100	9	2	196	8	81 081	98	91			
×	CTF C	2.14.04	Shufdown Heat Exchanger (SHE)	a 1960	180	080	160	00	081	180	160	1000	No arth evaluation					NL, 440	2	Ŷ	THE	8	180 18	080	0 100			
4	OTF 1	C.14.04.0	SHE Insulation Verfication Tests	8 190	944	094	160	98	081	160	180	100	No arth evaluation				~ *	10, 100 10	2	â	Tie	8	180 18	- 08 0	081.00			
<	CTF 2	0.14.04.0	SHE Viterational Fredting Wear and Siding Wear of TRDs for Bare Tubes	8 190	044	06	91	9	9	95	911	100	NO KID AN MAKING					4, 800 M	9	2	901	8	at Oit	080	041 09			

A-3 of A-17

Appendix A – DDNs Matrix-FINAL.doc

April 2008

Image: constrained by the co	Т	#20g	Π	Τ																		
1 1	2	181	H	+						-		\vdash						\vdash				-
1 1	12	Dist Water	Ħ							F		F										\vdash
1 1	+	Commercial Commercial	*	081 09	040	081 08	041 00	081 08	9	081.00	0% 0	041 04	0100	04. 0	040 04	081.00	9	081 09	91.0	081 00	050	-
1 1	1	internation	٨	1080	1080	1091	98	1091	9	080	98	95	98	9	- Ge	8	1 080	L CBL	04	1091	08	
M M		anamine d	~	081 08	081	081 08	9 9	08t 08	9	081 08	9 9	9 0	9 9	9	8	041 041	081 08	081 08	041 04	081 08	081 02	
No. No. <td>- 20</td> <td>Dup up on</td> <td>•</td> <td>8</td> <td>8</td> <td>8</td> <td>9</td> <td>8</td> <td>9</td> <td>9</td> <td>2</td> <td>8</td> <td>2</td> <td>9</td> <td>9</td> <td>8</td> <td>9</td> <td>8</td> <td>9</td> <td>8</td> <td>8</td> <td></td>	- 20	Dup up on	•	8	8	8	9	8	9	9	2	8	2	9	9	8	9	8	9	8	8	
Matrix Matrix<	1001	098		8	ş	8	8		9	9	8	- 9	8	9	9	8	9	8	9	8	8	
N N		100-374	POMM	3	3	4	-	3												*		
No. No. <td>T</td> <td>00-0W</td> <td>UT 9H</td> <td></td> <td></td> <td>,</td> <td></td> <td>,</td> <td></td> <td></td> <td></td> <td></td>	T	00-0W	UT 9H			,												,				
Main Main <th< td=""><td></td><td>50-344</td><td>PEH</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></th<>		50-344	PEH																			
No. Control Co	1000407	100-5743	НЦ	2 2 2 2 2 2 2	10 10 10 10 10 10 10 10 10 10 10 10 10 1	et, teo		40 100 100	10 10 10 10 10 10 10 10 10 10 10 10 10 1	100		100 X		100 Y		1	1 1 1 1 1	10, 100 21, 100	1 1 1 1	10 10 10 10 10 10 10 10 10 10 10 10 10 1	100 100 100 100 100 100 100 100 100 100	
mm mm<	2	P10-804	(other)	53	58	58	5 8	58	53	58	5 8	53	5.8	53	58	53	5.8	53		58	5.8	Ľ
Main Main <th< td=""><td>t</td><td>610-804</td><td>Other)</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></th<>	t	610-804	Other)																			
Model Anno Anno </td <td>╞</td> <td>210-1004</td> <td>ther) (</td> <td>+</td> <td></td> <td>\vdash</td>	╞	210-1004	ther) (+																		\vdash
Mon Anno Annon Anno Anno <th< td=""><td>╞</td><td></td><td>6</td><td>+</td><td></td><td>\square</td><td></td><td></td><td></td><td>\vdash</td><td></td><td>\vdash</td><td></td><td></td><td></td><td></td><td></td><td></td><td>nom of unifold</td><td></td><td></td><td>\vdash</td></th<>	╞		6	+		\square				\vdash		\vdash							nom of unifold			\vdash
No. Control Co	╡	110-804	(01-																annénete performe L'viène performe			
Main Control C		010-804	(Other)	o into evaluate	o intra evaluation	o into eventione	anti-available	ective entropy	and a second	o into evaluation	anti-evention	out waters	anti- evention	anti-weighter	outo eventese	a management	and an and the		Ma are concluding and or interaction and of performance and o	and welling	C efer onlighted	
Anno. Annonno. Anno. Anno.	t	600-804	Fluid	No.	-	1000	-			-	1	-	1	-	1	1			078	1	ļ	T
Answer Local and the second matrix Description of the second matrix <thdescription matrix<="" of="" second="" th="" the=""> Descr</thdescription>	T	800-904	σ	2	2	9		g		9		9	2 2		9	9	g	94		9	9	
Monte Control Exception Control Control <t< td=""><td>t</td><td>200-804</td><td>e</td><td>-</td><td></td><td>-</td><td>-</td><td></td><td></td><td></td><td>-</td><td></td><td></td><td></td><td></td><td>-</td><td></td><td>-</td><td>-</td><td></td><td></td><td></td></t<>	t	200-804	e	-		-	-				-					-		-	-			
Access Acces Acces Acces <td>╡</td> <td></td> <td>(Jac)</td> <td>991</td> <td>91</td> <td>8</td> <td>ŝ</td> <td>91</td> <td>95</td> <td>91</td> <td>8</td> <td>951</td> <td>ę</td> <td>gt</td> <td>ę</td> <td>8</td> <td>951</td> <td>991</td> <td>9E</td> <td>95</td> <td>ĝ</td> <td></td>	╡		(Jac)	991	91	8	ŝ	91	95	91	8	951	ę	gt	ę	8	951	991	9E	95	ĝ	
Num Control Data Num Control Data Num Control Data Num Dat	╡	900-804	107	08L	GR	Q#	91	081	of the second se	981	98	OR C	91	G	ĝ	98	ĝ	180	g	081	91	
Number Construction Participation Participation <td>CT IN COLUMN</td> <td>500-WOU</td> <td>T (Secon)</td> <td>9</td> <td>9</td> <td>8</td> <td>9</td> <td>8</td> <td>9</td> <td></td>	CT IN COLUMN	500-WOU	T (Secon)	9	9	8	9	9	9	9	9	9	9	9	9	9	9	9	9	8	9	
Accurate Control Description Description <thdescription< th=""> <thde< td=""><td>in the line is</td><td>100-80J</td><td>(Prim)</td><td>-</td><td>e</td><td>e</td><td></td><td></td><td></td><td></td><td>ŕ</td><td></td><td></td><td></td><td></td><td></td><td></td><td>ľ</td><td>ŕ</td><td>e</td><td>-</td><td>[</td></thde<></thdescription<>	in the line is	100-80J	(Prim)	-	e	e					ŕ							ľ	ŕ	e	-	[
Account Account <t< td=""><td>NUMBER</td><td></td><td>etta) T</td><td>91</td><td>ž</td><td>91</td><td>91</td><td>9ž</td><td>91</td><td>91</td><td>91</td><td>91</td><td>2 g</td><td>91</td><td>ĝ.</td><td>91</td><td>9£</td><td>081</td><td>ŝ</td><td>081</td><td>ž</td><td></td></t<>	NUMBER		etta) T	91	ž	91	91	9ž	91	91	91	91	2 g	91	ĝ.	91	9£	081	ŝ	081	ž	
Norm Circle Description Description <thdescription< th=""> <thdescription< th=""> <thdescript< td=""><td>in nue le</td><td>-00-808</td><td>on) P (0</td><td>92</td><td>98</td><td>8</td><td>g</td><td>92</td><td>9</td><td>92</td><td>8</td><td>98</td><td>g</td><td>9</td><td>2</td><td>9</td><td>g</td><td>98</td><td>9</td><td>98</td><td>8</td><td></td></thdescript<></thdescription<></thdescription<>	in nue le	-00-808	on) P (0	92	98	8	g	92	9	92	8	98	g	9	2	9	g	98	9	98	8	
Norm Classes Set Information Profession A CFF 3 C44040 Set Information Profession A CFF 3 C44040 Set Information Profession A CFF 3 C44040 Set Environment Profession A CFF 5 C14040 Rest Environment Profession A CFF 1 C14040 Rest Environment Profession A CFF 1 C14040 Rest Environment Profession A CFF 1 C14040 Rest Environment Profession A CFF C14040 Rest Environment <	Lunctoo	200-903	m) P (Sec.	91	91	91	91	91	94	94	94	951	ę	94	92	94	92	981	91	094	91	
Access CC4.00.00 SRE Instrumentation Access 3. CC14.00.00 SRE Instrumentation Access 3. CC14.00.00 SRE Instrumentation Access 3. CC14.00.00 SRE Instrumentation Access 5. CC	10.01	100-804	P (Pri)	a 160	a 190	8 160	911	a 190	94	a 196	a 160	91.0	× 180	94	91	a 160	001.8	a 190	911	a 160	94	
Matrix CFF CFF<	OUT MEASURE FOR		E estermentation	dachment Test	PHE Bare Tubes repection Methods and Equipment	HE Shroud Seal est	countical Response fithe SHE Helical are Tube Bundle	SHE Intet Flow and emperature listitution Test	3-E Tube Bundle coal Heat Transfer nd Flow Resistance Interdetatics	SHE Tube Helical Voli Program	SHE Lead-InLead- ut Expansion Loop "ube Design and "brication	Valiety Protection and retrumentation	Arrify Helium Mass Now Measurement softumentation	Arrfly Conduction Cooldown Iomporature formboring satrumentation	Auctear Island Control and Strumentation	Arthy Core Inlet and Dutiet Heltum Temperature Seasurement situmentation	SHTS Circulator Secondary Circulator DNIs are covered by Vitmary Helium Troustor DONS due I design similarity)	olation Valves	Phote of Primary Sociant Helium and Importune on HTS Piping and Wee Materials	figh Temperature solation Valve Votokype Design virfication	ITE Plant Supporting Quipment	HTE Steam enerator/Superheat
A A			2 0 2 0 2 5	-	14.04.0	14.04.0	14.04.0 0	14.04.0	14.04.0	14.04.0	04.04.1 T	210	31.01.0	31010	3404	34.010	102	42.02	42.020	42.02.0	45.04	45.04.0
	dhose			OTF 0	CTF 4	CTF 50	OTF 0	CTF 10	STE C	0 E	OTF 0	OTF C	CIF 10	C C	CTF C	10	N N	OTF	Z-	N 2TF 2	CTF	Z
	Version			×	×	M	×	5	4	5	×			4	1	4	4	4	4	×	4	

A-4 of A-17

Appendix A – DDNs Matrix-FINAL.doc

April 2008

followIn	g DDN's a	re specific to a CTF			_																				
dor Qro	#NOO dn	(3.1) Mission Need	(3.3) F	unctional a	nd Operatio	nal requires	nents	H	Π				Π	ľ	H	09.0	0 Facility	H	H	1020	Ufe Cycle		H	rating	
			100-804	008-005	600-804	100-804	500-WOU	900-909	700-804	800-804	600-¥04	010-902	110-804	510-903	C10-80J	P10-BOJ	100-DW	80-3%	\$00-044	098	Dep 10 uon Trospeput Dige uon Dige uon	otionutiue o	Openation Commonial	Tel Tel Tel	8000
L			P-(Prim	(D (Gecon)	P (Detta)	T (Prim)	T (Secon)	T (Other)	e	σ	Fluid	(Other)	(Other)	(other)	(Other) (Other()	HLL H	III III	PTU PBE	- N	•	~	5	F	
CTF	AddTone	Full Scale Testing/Qualification of systems and components	061.01	gi	96	9	9	9	9	9		Complete completeration	5	1	2	1	00 000 000	3	2	QL	8	0 180	040 040		
CIF	Addiona	Control & Instrumentation development / qualification	1 160	2	8	2	9	9	9	2		Contra Sinabumanadon di	and Colonia Colonia	The register	g	141. Tel	2	2	4	81	*	040	040 040		
CTF	Additiona	CTF to be used for V&V of methods / I software	VIN LL	ww	-	1	5		5	ş		A DESCRIPTION AND A DESCRIPTION OF	eta Rir CTF Scill	VBV W Deep e		14. No.	1	3	2	95	8	0 180	041 091 0		
CTF	Additions	Fluid inventory I systems testing	051.5	011	98	9	9	C C C C C C C C C C C C C C C C C C C	9	94	100	Card Interfactory specialization	14 180			Yint	100 Ho	2	2	91	8	0 teo ne	01100		
OTF	Additiona	Quality control 1 systems testing	ALC: NO	WW	NUN	-	10	1	w	WW	-	Calify control cyclien reach	NUMBER OF DEC			21	11			091	8	D 180 TR	01100		
CTF	Additions	Control room human	And DT	ww	NON NON	AN N	va.	N.N.	×.	WW	-	Novelly until other here	1 months months			140.0		2	2	91	# 91	D 180 TK	011001100		
CTF	Additiona	I Operational	Yes	WW	NW		10	R N	5	WW	-	Procedures development resultance	the design of the second se	100 / District Group	2	100 A		2	ž	91	2	0 teo	040 041 0		
CTF	Additions	I Programs	ALM NO	WW	MIN I	-	10	1.1	w	ww	-	Manterian and repair program / process	CHICKLER CONTRACTOR	1 moderal person	Discensi derrefageen	4	000 000	2	ź	190	2	0 teo	0100		
CTF	Addione	High temperature instrumentation (Flow 4 control)	8 190	091	091	9	9	180	9	10		Constitue questions	water for high line	repeating from one	WM (MM	1042	400	2	2	180	# 91	0 teo Teo	0 160 180		
CTF	Write Paper	Main need from High Temp Elstrolysis (HTE) for CTF: Super heaters / Steam generators	Vite a	Part 1	NW		Lines donc work 2000	FWTJOHE PWTJOHE TOME: TOME:	g	W	- HELM	CODE DEVICES IN DRAFT	Pi on chean gu	United	Wild.	2007 2007	2	2	ž	011	#L 08	an out o	0 160		
CIF	White Paper	Materials	odec 11	No.	*J1000C>	T_Jose stat	Const 2000		8	to a	UNUR	Machine Luni Soldsmith Soldsmith Hapter 20 Price College Price College P	Manufacture Zingo Abigua Zingo Abigua Kotakon Kotakon Kotakon Katako	Specific reprints	and industry both	A look Vinc	1	2	ź	06L	8	041	0110		
CIF	White	Plate HX	Rection Long-lense Rectored Rectored	The formation of the fo	4. Mills, instanting and instanting many on manufacture states contaction and account of the states of the states of the states of the stat	ang-Kijus Oli. Agadalor. Masu kupatolor		Structured acceleration two two transmission	The development of the the composed much as the the development of the the the development of the the development of the the settle result con the the settle result con the the settle result con the	Vision Annual Sector Annual Se	ooto (marine) alaa maarine alaa qabaala alaa qabaala 1 maga taanu 1 marine alaa 1 marine	data hase to be completed in representative excitors in representative excitors in the properties of the properties of the properties and the state of the set of the state of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the	ert sett society, bestrig sokeng port on the set of a ch	Approximation of the second se	in provide second second	cite tage of o	models to a	1							

A-5 of A-17

Appendix A – DDNs Matrix-FINAL.doc

April 2008

	All DDN'6																		$\left \right $				ļ		
centerfixers Referance	*H00	beak noise (6.1)	(1.1) Functional and Operational requirement													Allord (L.C)			250	S • 1			Datum		
			N0+10 4	80+80 s	a)-80 i	200-KD 4	90-10 J	80°-10-8	a) 10 s	80-KD 4	60-10-1 50-10-1	#0-8D3	20-801	60-10 J	H-0-3D-3	100-29/8	8 96-005	600-D4 J	100-201	080 080 080 080 080 080 080 080 080 080	Construction Construction Construction	Commercial Commercial	197		
			P (Prisc)	P (Secon)	P (Della)	T (Prim)	(lacon)	T (Office)	8		And TED (Oh	wr) 1100 (0	ther) TED (0	ther) TED (Off	ee) (Office)	щĸ	Ĕ	4 UT 9	MMG	•	A 41	44 44			
	Nuclear Hask Supply System 1(tential)																								
	Fuel imatuden				ĮĮ		Ħ	$\left \right $	Ħ	╢			H	H	H		Д	H		Ħ	H	╘	⋕		
C TASKUAD	N165-01-00	r um ensenten met te conta operational constitues Fuel heating bets for accident conditions					╈			+		+	+	_					+	* *	+	+			
0 ASIULAD	N105-01-02	Fuel Gruphie Insulation tests			Ц		╢			╢								╢	╫	*	⋕	╢	-		
	Graphie						╞			$\ $								$\left \right $	H	Ħ			Ħ		
C TASKUAD	NICESCH	Europed Properties of Insultance Grophies at Low Temperatures								_									_	*			8		
C TASKUAD	NHGS-02-02	Exampled Properties of Intelliged Grophies of High Temperatures																		*			8		
	2 Nis of Transport Southern 6073	5																							
	Architemediate Heat Exchange Minister	per .					F		t	╞								\vdash	╞	F	Þ	F	╞		
		Enterthin Reference Specifications for Allay					t		t	╞		╞						$\left \right $	╞	,	╞	╞	ŀ		
	LINE ALL DO	Thereal Physical and Michaelan Properties			ſ		\uparrow		t	╀								+	┢	-	╞	╞			
TASIOLAD	HT5-01-02	of Aley 517 Redding and An Weided Processes of			ſ		\dagger			+		+	+	+				+	\dagger	*	+	+	Ŧ		
TASKOLAD	112-01-00	Watership of Alloy 6179x Compact Next Eacheroner																		•	-		-		
ASIOLAD	HT5-01-04	Aging Effects of Alloy 617			Į		Ħ			╢								╞	╫	4		╢	Ŧ		
D TASKUAD	HT5-01-05	Alloy 017																		1 1	_		÷		
D TASKUAD	102-01-08	Influence of Grain Star on Materials Properties on May 917					\square													1			÷		
TASKUAD	HTS-01-07	Establish Reference Specifications for Allay 250																		*			-		
TASKUAD	HTS-01-00	Therrol Physical and Michaelal Properties of Alex 220																		*			-		
TASKIAN	62-10-5114	Weiding and Al-Vielded Properties of Materials of Alloy 2000s: Compact Heat Exchanges					\square			\vdash									\vdash		-		-		
ASIOIAN C	MT5-01-10	Aging Dilects of Alley 200			Ű		╢			╢								$\left \right $	╢	- w:		╢	Ŧ		
TASKUAD	HTS-01-11	Environmental Effects of Imparts Helaum on Alloy 200								_			_						-	1 1	_	_	-		
D TASKUAD	MT5-01-12	Influence of Grain Stars on Materials Properties on Misy 200																		5			-		
TASKUAD	112-01-12	Vetos for Thereafture Modeling of Flate Type Compact Heat Exchanges								_										1			÷		
TASICLAD	MTS-01-54	Methode for StreedStrain Modeling of Plate- Type Compact Next Exchanges																		1	1		+		
TASKULAD	HTS-01-15	Otherts for Sectional Advances of Patis-Type Operand Heat Exchangem at Very High Temperatures																		*	-		-		
D TASKUAD	HT5-01-15	Methods for Pertomance Modeling of Plate- Type Compact Next Exchanges																		*	-		-		
cur	102-01-12	Veitals: PUX Performance Verfaction	e Was	5	* 200 10°a	1,000 9500 11,00545	N 2005 2005	*	00L	D Hellow	att UA a / TEO predetion	Control Impoundly Meetic	No ICK Netal Techog	LIX Durbility Tetting	INX Performano e terding	Yes, see note	g	Ao No		*	-	*	-		
TASKUAD TASKUAD	HT5-01-10 HT5-01-10	Data Supporting Materiale Code Case Data Supporting Design Code Case								\parallel										97 97		** **			
	Drevvedue Meat Exchange						+												+	Ŧ	╞	╞	╞		
0 ASIME	Creating MTS-02-66	Review Editing Technology			\prod		\parallel			\parallel		\parallel	\parallel					\parallel	╢	-	╢	╢	F		
	N15-02-05	Management Property Decades Design Mechanics					\parallel		t	$\ $		╢	╢					╉	Η	-	-	5			
0	MUDION	Cerante: IKK Performance Verfication	st No	t data	80.4	1_000	200	×	001	0. Malei	NUM NTIO preference	Central Impurity Invote	No. 10X	Dumbiny Testing	INX Performance e landing	Vec, tee cole	an an	No No		*	-		÷		
C TASKUAD	MT5-02-65	Varuhsteing Technology								\vdash	Interace development	_								1 5	-	5	÷		
C TASKUMD	HT5-02-68	Docks and Standards					\parallel			\mathbb{H}								$\left \right $		1 1	1	1 1	+		
	Office Internation Records																			_					
		AIL UUN &																							I
------------	--------------------	--------------------------------------	--	---	-----------	-----------	---	--	-----------	--	---	--	--	--------------	---------------	--------------	--------------	--------------	---------	--------	---------------	-------------------------------------	-----------	--------------	-------
Centerhim	Balintanca	# HOO	(1.4) Mile size: News	(1.1) Functional and Operational requirement c													Alley CO			830	5.48			5	Ű.S
				NO-100-	89° 80 s	©0+80 ±	199-16D /	201 -10	жэ- ю -	ar 10	80-10 s	960-16D /	#0-8D-	30-8D s	80-10 J	H0-8D (100-544	6 MC -005	600-047	100-04	085	uo pontrauo ; para para fue ;	noticned	ber juliy	Ler (
				P (Prim)	P (Secon)	P (Delta)	T (Prim) (3	(uoce	T (Other)	6	0 FM	d TBD (Other)	TED (Other	() TED (01)	ter) TED (DRv	r) (Oher)	щ×	Ē	HPTU	FONIM	•	~ =	, și 1		
000	ar	19-00-5114	Mundo Charles Performants Ten	YON	14051	- H 8	1000 000 000 000 000 000	- 280 KK - 280 KK - 280 KK - 280 KK		ter Bar Bar Bar Bar Bar Bar Bar Bar Bar Ba	and	Performance verification sector to prototype multi- citation	Northed Sectors A generation for the main sectors of generation for the main for th	1 N S	WW	WW.	40 H X	2	2	9	*	*	*	-	64
		our scott actuades a utility					+	+															Ŧ	╈	
	J.	10-0-0	Creaters of the Terperiture Dutt and Reading System	00 Kps	04 Mps	- F 8	Reaction Control March Barrier Barier Barrier Barrier Barrier Barrier Barrier Barrier	2%~		p	1	Newson Sectors (New Sectors) (NN NN	NN NN	5		44 (14)			-	-			•
	c .	Nydrugen Production System (1993)																							Ш
		Back Date	Owith Themodynamic Data for the Hyd				\dagger	+			╞			╞				\downarrow		╞	+		t	+	Τ,
		07-12-54H 27-12-54H	Process Gather Reaction Monifold Data Analyse Cata and Improve struction				\parallel	╫			\parallel			\parallel		\parallel		\parallel		╢	ur ur ur		#		
		Supplementary Mondain					╟	╟											Π			\square	⋕	╟	Π
NDC MDC	TASKUAD TASKUAD	20-02-54H	Develop Gateki Historiak and Design Develop Seal Materiak and Design	08L			ŝ	$\left \right \right $													* *				C4 C4
No.	TASKUAD	N0-02-54H	Density Choice a state the				╢	╢			$\left \right $										- 41				909
MDC	TASKULAD	\$0-00-S4H	Develop Pipelog Moterials and Design Methods				+	+										\downarrow		1	*	-	~	-	64
		Feed Purification					╢	╢						\prod		\prod				Ħ			Ħ	╢	Π
MDO	TASKUAD	10-03-54H	Leasting in a compose interaction to impaction flatington Tolerance for				+	+			+									+	*		+	-	-
	TASKUAD	00-00-04H	Interfield Test Saffark Add Decomposition Methods					+															÷		
WD0	TASKUAD	10-02-04	Test Feed Water Publication Methods																		9 7		~		-
and	TASKILAD	Uncomposed NES-24-01	Develop a Commercial Sulfato Aud Decomposition Catalont				\uparrow	+													*		-	-	
MDC	TASIOLAD	1175-64-02	Test Silvon Carbie and ofter Centric Materia in Decomposition Service				\vdash	\vdash														-	-		-
MEC.	TASKUAD	NP5-04-03	Test Moy 230 and Moy 617 in a High Temperature Softwic Ack, Sulfar Doodde and Orogen Atmosphere				\square	\square													*	-	*		~
NDC	TASKUAD	NPG444	Develop a Methodis Bond Alloy 230 or Alloy 017 or Similar Materials is Silicon Carbitia and other Centralian																		97	-	*		~
MDC	TASKUAD	90*10*5dH	Develop Waterie to Seal the Joint behaven Ceramic Decomposer Derects and the Weiter Tubertaet or Versel																		97	-	*		-
MDC MDC	TASKUAD	20102541	Tett a Piti-tosie Decorpoter Data Seporting Decign Docie Cate				\parallel	\parallel													9 - 9-	-	97 97		04 O4
		Sufficie Acid Concentrator						+																+	
MEC	TASKUAD	HPS-65-01	Vestors the Height Explorient to a Theoretical Parke (HETP) for the Concentrator																		8				
		502 Absorbers																						+	
MDC	TASKUAD	HP66501	Vesture the Height Equivalent to a Theoretical Plate (HETP) for the 502 Absorbert																		*		*	-	*
		Electrolyters					╢	\parallel												╢	╢		⋕	╢	Π
MDC	TASKUAD	10-02-SHH	Optimize Catalyst Loading in the Electrodes																		*	-	**	-	•
WICO WICO	TASNUM ASNUM	00-03-54H	Develop a UN MANDORM Develop a Cell Configuration and Nativitation				Ħ	╢	T	Ħ	╢		╢	\parallel	╢	\parallel		\parallel		Ħ		∄	#	\mathbf{H}	•
MIC	TADALAD	22-02-54H	Date and the set a reaction was for			Ī	+	+	Γ	Ť	+	+	+	\downarrow	\downarrow	\downarrow	\downarrow	╡	Ī	t		Ŧ	-	+	• •

	ff 2	74.1		*	ТП			П	11		1	1		49	1	0	•	• •	~	•		-
	Lrait	ายอ		Ŧ				Ħ	Ш		- 24		24	**	1	8	~	9 O	~	~		~
		Commercial Appl.	84					[]						l								
	F	notisnedO	şA	*	П	*	4.					,		П	Ţ							
		o pongeno g	A A1	+	╂╋	\mathbb{H}	\vdash	⊢┤		+-	H	+	-	╞	+		-			-		-
	Ē	Page 1			Ħ	Ш		Ħ		Ħ	Ħ			Ħ	t							
	F	Dilensia Licensia	•	**	-	-	97	-	-		-	-		ļļ	ſ	-	-					-
	Cycle Cycle	G 89	۰		Ш			Ш			Ц			Ц	ļ							
		100-344	POMM										Ŷ			3	SN S	4	SN SN	8	ş	ŝ
		600-04 J	HPTU										ŝ			2	ž	2	2	8	£	ŝ
		8 WC-005	Ш¥										ŝ			2	2	8	2	g	g	g
	1.2 Facility	100-54 4	жШе										ite, can nois				64, 100 Tá		64, 100 TOD	41 H	1	ies, san nobe
		H-0-3D J	(oper)									Prediction	Vanish of the second se		Ī	Themal conducted at 0.2 Mar. 7	NUN	and a second sec	NUN	NUM, NUM	1	NIN
		80-10 J	TILD (Driver)										MN			Diffects of ficew and ficew and	WN	vintea proj Bujneg	WW	WW	WW	WW
		20-80 J	TED (Other)										MN N	ļĮ	ſ	Effects of mechanical and sources	NN	Hours Frence of	NN	ММ	WW	WW
		#0-80-4	TED (Other)										YON			Thereal cycling of features	Theoreal cycling might to a requirement	Vestore kut	NA	NUN	Critica Critica pressured rop preferences validation	NN
		040-16D-3	TBD (Other)									and and a second se	tentos Ibaix 60 equivalent Mi-		Thereal and	mechanism mechanism for ituation for ituation for the four mechanism mechanism for the form for the form form for the form for the form for the form for the form for the form form form for the form form form form form form form form	demonstratie End Die soliciteg TRD design	Tett of two types of useds designs to validate design	Therrol movement	Fice defaced whendion characteristics of the therm prevention table burchs, Jeas with the start currention start.	Ersulos / Cerrodian maisteren bet far orfica	NIN
		a)- 80 J	Fhuid										-	Ш	ĺ		ange	and the	100m	Helen	Water	and a
	ļ	80-10 d	a		Ш	Щ		\square			\square	<u> </u>	WN	Щ	1	5	WN	SN N	WW	WN	NN N	WN
	Ļ	ar 10 d	8	\downarrow	Ш	Щ		\square			\square		0ET	Щ		Ê	đ	10	et.	ĝ	ĝ	Ń
		809-30-4	T (00km)										FWT_Jake 2200 Sham T_ordet 5400			3	FWT_bliet 2200 Sissen T_outhet 5400	FWT Joint 2200 Sham	FWT_pliet 2000 Steam T_orbit 5400	PWT Jake 2000 Sham T_outlet SHDD	2	FWT Jane 2200 Sham T_adht 5400
		200-3D J	(gecon)									3		Ľ	ſ	T_inite 600 200	1000 1000 1000	1 2000 1 2000 1 2000	1 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2	T_NK 000 17 of 12	WW	
		1997-RD 4	T (Prim)										NN N	ſ		1	WW	S N	MM	MM	FW New Warpwat ure of nominally 22000	NN
		80-80 J	P (Della)		\prod			\prod					MM	Ц		5	MM	SH SH	MM	WN	SH N	WN N
		ar 10 f	P (Secon)										0.2 MPa			2020	0.2WPa	CANCO	COUP.	c4020	11	62M20
(1.1) Functional	Operational requirement s	N9-10-1	P (Prim)										NUN	Ш	ſ	1	NN N	10	NN	NA	NN N	NN
	(0.4) Mitcalar Need			Build and Test a Stack of Cells in a Pilot Plant	Mercily Product Inguraties	Test Protect Purification Methods	Test Second in the Flict Plant	Develop valves for High-Temperature Acid Service		Secondary site Constition Characteristics appendix 1, 5, 1007–1014, 1014, 1014, 1014, 1014	Heliun Environment Effects on 2-14 Cr-14io		Acoutic Response of Helizal Bundle	Large Helical Col Polytoxico Methods 2014 Inter Internation		to and the Andrewson Tax.	Frefrig & Siding Wear Protection Tests	factor a sector processory transfer	Leadin Lead-cultion dis Allagaerish Loop Vedage	Flew Metsoel Vitration Testing of Heital Basels	Onfice Guardination Test	Instrumentation Affantiment Text
All DDN's	\$ NOC			NPS-07-00	Product Purification HPS-08-01	201025211	behavestellon and Coebuly HPS-63-01	00-00-00H	Power Convertion System PCSI	Steam Generator co.ne.co	20-10-00	-	10-10-00	20-10-02		47 in 1995	80-61-68	01-10-05 Abrone	11-10-05	20-51-13	(1-12-05 (1-12-05	11-10-05
	Reinnance			ASIOLAD	1 SOLAD	ASIONS	VENDAR	ANDAD			ASION		F	A SOLAD			F	1	-	F	÷	F
	Controlium			8	8	8	8	8	-		8		8	8		8	8		8	8	8	8

A-8 of A-17

Appendix A – DDNs Matrix-FINAL.doc

April 2008

		All DDN's																						ł	ľ
northen Raires	1.00C	* HOD	(3.1) Mit ution Need	(1.1) Functional and Operational regulatement s												0.275	Alla			(1.5) Cycl				Dat	f P
				N9-10-4	50+30 d	an-so a	100-KD 4	99-10 J	809-KD-4	201003	80+30-3	940-14D d	H9-80-3	34 - ¥0 J	80-10 J	H0-80 J	100-5W A	6 VC-005	6 MC-003	100-201	reading and a second	Construction Construction	notanego Operation Intonen ero 2	our Voly	78.4
				P (Prisc)	P (Secon)	P (Della)	(Prim) (S	(uose	(CENIC)	8	Q FMd	TED (Other)	TED (Oher)	TED (Office) TE	D (Dfiler)	(Jank)	ATTR	a Line	e ura	MM		^	9A		
							⊢s,	and	j,			Realizative confidence on th controls of tables to impact on the controls of tables in the control table from the control tables from the control tables	lissitureler confident or fororferet i l'ortetto i l'ortetto tale at tale at the ettoria	Average T Average T Average T coefficients to coefficients to subtrate of with tubes for the fra settures to without to the form	the transfer fam for alone for a bundles to a bundles to										
CIT	a M	00-01-10	Tracks Test Tracks Test	NUN	0.200%	MM	162 W	100 100	34: 5400	at on	D Heller	chaight tabes.	tunda.	tube bundle. plt	D. NO	Yes, n	N 400 40	ž	0 No	-	5			C1 C1	-
TASKUA	e av	10-10-XX	Review and re-assessive existing 50 development data.																						
	AR	REVA DONIs summary storiote																		+	F	þ	þ	#	Т
	╢		Metalitica Vector instantish (NG) temperatura chell		$\left \right $	Ħ	╢	╢	Ħ	╢			\prod		╢		Ħ	╢	╫	╢	⋕	⋕	⋕	Ħ	Π
TASKUA	AN AN	10/1/01	 Testing and codification of modified SQn-186 					$\left \right $		\vdash								\vdash	\vdash		F			F	
		000 100	Reader reserves - Testing and coeffication of careficials core				-	\parallel		╟								╞	+		+				Π
			and managements 10.00 - Tetho and coeffection of it paral 017			Ĭ	\parallel	╢	╢	╫					╫		\parallel	╫	╫	╫	⋕	⋕	⋕	⋕	Π
TASIOLA	AD AS	007/9-003	and/or Haynes 200				+	+	\uparrow	+	\downarrow				+	+	\dagger	+	+	+	+	+	+	+	—
ASIDIA		10.00 EDA	Civareiza Bisadar Internate		$\left \right $		╟	╟		╟								╟	╟		Ħ	╞┼	╞	Ħ	П
TASNUS TASNUS		1014-035	Testing and codification of maximitals Controls and sheaths		$\left[\right]$		╟	╟		╟								╟	╟		⋕	╞	╞	\square	Π
TASKUA	an An	10/10/02	Testing and colfication of Cartan-Cartan composites				\square	$\left \right $	Ħ	$\left \right $					\parallel			\square			H			\square	
			Graphite (initial)																+					+	
TASIOLA	AN AN	12/14-030	Guilffeaten at isve dess, limited temperature		T		+	+		+								+	+		+			-	
	\parallel		Graphtie (subsement)				╢	+		+								\parallel	╢	╢	╢		╢	╢	Π
TASKUA	W UV	10/14-039	Gudffesten st high den, high temperature				┥	+	┤	+					+	+	+	+	+	+	+			7	
	\parallel		Core internal structure		$\left[\right]$	Ĭ	╢	╢		╢					╢		\parallel	╢	╢	╢	Ħ	⋕	⋕	∏	Π
TASKULA	UN UN	10/10/00	Cualification of high does, high temperature				+	+		+					+	+	+	+	+	+	+	+	+	+	
	5.8	tenpater Codes and effects					\parallel	\parallel		H								\parallel	\vdash		\square			\square	
TASKULA	ev v	10/W/Dit	Cook development - Ingenerational Speed of Authorita coder (a., NOVP, NONTERURNS, MEDITYS)																						
TASIOLA	AD AR	510 M/101	 Inprovement/Availagenet/of Itemating/control/automating Inprovement/Availagenet/of of Aver codes 					+ +		$\left \right $															
		100.004	Flat performance models and codes - Develop that performance models haved				╢	╢		╢					╫			╢	╫	╢	⋕	⋕	⋕	⋕	П
			False value available available available		$\left[\right]$	Ĭ	╢	$\left \right $	╢	╢								╢	╢		Ħ	⋕	⋕	Π	Π
TASKUA	W N	100 M (100	Code qualification of existing codes - ATLAS		\prod		╫	╢	\parallel	╫					╫	\parallel	\parallel	╫	╫	╫	⋕	⋕	⋕	╫	Т
AUNSAT AUNSAT		10000	- ISOMTREUTHS				╢	╢	╢	╢					╫		\parallel	\parallel	╫	╢	Ħ	⋕	⋕	∏	Т
A SMUL		ALL AVERAGE	- MUTT I -		$\left[\right]$	Ĭ	╢	\parallel		╢								╢	╢		Ħ	⋕	╢	∏	Π
TASIOLA		100,400	- CALINENET - CALINENET		$\left \right $		\parallel	╢	\parallel	╫					╫	\parallel	\parallel	\ddagger	╫	╫	⋕	⋕	⋕	⋕	Т
		And POStar Diff. Concerts					╟	╟		╟					$\left \right $		Ħ	╞┼	╢	╟	Ħ	╞┼	╞	Ħ	П
	582	der sich noch in heit nie- der sich noch in heit filte Viewing carpoorentie					\vdash	+		+					╞		T	\uparrow	+	+	F		╞	F	Т
LU LU	W	10.4.00	- Citedaten	10,00	10,00	8,28		R R R R		de.	lister a	Deterrine speci Incuirements for circuitator	NN.	88	NUN N	Yes, p	4004	#	*					~	~
CLL	W	NEW-DA	- Tube type BLX	Q.	01	01	at 01	er er	F	000	1 March	Area specifications / requirements TD	NIN D	NN NN	A NUM									÷	**
																									1

All DDN's	All DDN's															ŀ				┟				ļ
Carlinol Tracional Continue Brinnes DOH# (3.1) Minim Need a carlinear	Carlinea Reactional Constraint Co	(1.1) Exercisent and Operational Registrennt (3.1) Mitution Nand	(1.1) Functional and Operational requirement					ł		ł						0	2) Facility			0.5) Cycle				DRLT Lradir
2 + C4 + 64	2 + C4 + 66	нанец нанец	104 (G	ar 10 4		80-80.4	207-3D-1		80° KD 4	80-104 (60-¥D 4	80-10-1 1	H0-80-4	50-10-1	60-10-1	но-козе	100-2014	k wc-005	500-24 a	100-201	04100017	uoteminos ~	ind Manual Commercial	100
CT AND CONTRACT TO CONTRACT.	11 011 011 100 100 100 100 100 100 100	The scenario of the scenario o				011	91	GEL	i i		-	Atena Atena Atena Atena Atena Atena	D NUA	NN.	WW NW	1	t	2			-	+		-
CTF ATE/A-009 - Indicion valves (ingle longworkaw) TBD TDD TDD TDD TDD TDD TDD TDD TDD TDD	MATC/ALOS - Laskies uskus (ligh kequentary) TEO	. Issies sike (righ kenjesten) TEO TEO TEO	001 011	TIC		E C	8	ę	F	0 10	u đi	Area up existations / regularments TD	WN D	мм	ми	N.N.								~
(1) (Michaeling presents	At the fully seeds	. Helden sufferetion solven TTDO TTDO	100 TED	00	8	Ē	g	Ê	P	0 0	5	Area specifications / presidenter TD	YN D	WW	MM	1								-
Tristancia Metrovacio - Structura collog apriara Metroscata Metrovacio - Fantanto estato Metroscata Metrovacio - Metroscata conte diversi Metrovarian	MATE/A (20) - Relations colling system AND/A (20) - Frait Andrey Gostem AND/A (20) - HALEGO Control System Differ MACADEAN	 Statistican conflig system Fault strateging system Mark strateging system Mark strateging 				\mathbb{H}																		
TASTALAD ATOVA-001 - ECCS - Entry Posteria Investment Providen, and DAMPA Posteria	MIGVA-021 - EXCS - Variat Costroll, lowersheet Protection, and ScaleNy Protection	 Rocds Plant Desire(Investment Protection, and Safety Protection 				4																		
ctr AtEnvet3 - M4 Gau Daci T10 T10 T10	ALEC/4-033	- Not Get Deci TED TED	T00 T00 T10	700 710	g	011	9	GEL	Ê	0 10	Net	Area specifications / regimenteris TD	D NUA	ми	NN	NN								~
CEF ARD/A/C/A - FEDERARIARIAN - TEO TEO TEO	ALE/A-CM - McDamentation TED TED -	- katowa kateka TBD TBD TBD	TED TED	001	g	E	ĝ	ĝ	Ĕ	0	Netur	Area specifications / regimenents TD	D NUA	NN	NN	NN								-
PCS ACCARDED - Erzylan Cysle autog	PCS AREALEDS - Ergen Optic setting	- Erzylan Cycle setting				11				+														
100 - 100 - 1000	Amerikan Contraction of the contract of the co	 Terteo-restingary testing Generating and electrical estimated testing 			\uparrow	1	╀	+	+	╀	\downarrow								+	┢	F	╞	╞	+
PERSALESS Fillen off-correct & duality series REEVALSS Fillen off-correct and series and powers were and powers were and powers	MERCH-200 I.Hum opti scene 4 Auto Sales MERCH-200 I.Hum Reserve (Hand Sales) MERCH-200 I.Hum Spik werd) MERCH-200 I.Hum Spik werd)	- Helium pole scenaria dialta) webp - Helium pole scenaria webp - Helium spice webp																						
generat. ATOMCS	GENERAL ATOMICS																				-	1		
RestRiction Products C.07.00	Paw/Piteton Products Cost.00				Η		H	H	Η	Η	μ					Π			Η	Η	Ħ	Ħ	H	Ħ
REPORTED COTO LA DESERVE MARANA COTO DE VIOLANCE DEVENSIONEL MARANA COTO DE VIOLANCE DEVENSIONEL	COT 01 Lot partness COT 01 Distribution COT 01 01 UCO Kerral Fixease	Tuel parente Tuel Parente UCO Attraf Posses Development			\parallel		+			+									╫	╫	+			⋕
TAGNOJAD C.07.01.00 F.uk Partisk Caning Prosens Development TAGNOJAD C.07.01.00 F.uk Caning Prosens Development	0.07.01.02 Fuel Particle Conding Proteins Development COD 07.03 Fuel Compare Faderaters Preses	Faul Pariste Casiting Process Development Faul Compact Solverson Version			\square	i I	$\left \right $			\vdash									\square		\square	Ħ		
TARDARI C.O. 01.04 Outly Corto Test Testingue Device way 10000040 C.O. 01.04 District Sectors Exercic Conference	0.07 01.04 Datily Control Test Testingues Development 0.07 01 05 Development Sections Sections Development	Gually Cortos Testingues Development Dial Drotas Decembric Benkonent				i I.	$\left \right $	$\left \right $		$\left \right $														
TASKAME MAD OILO FRANCISCOM ATTREE DANSY UND FRED	N OT OT AS Production of High Guardy UDO TREDO	Value Predication of High County UCO TRECO			t	1	+			+									+	+	F	+		F
An environment of the second o	An enterclass and Southy of LDU UCC (MF) solecies to an applicable of LDU UCC (MF)	As exercises and Quality of LEU UCC (API solveded barrup Sue)			\square	ı I				H									$\left \right $	$\left \right $	H	H		
TABADAR C. O. CO. Faul Performance	C.O. O. Fail Performance	Fuel Performance			╢		╢	╢		╢									╫	╢	\parallel	⋕	╢	⋕
INSUMMENT 2.07.02.01 COMPLAN 2.07.02.02 INSUMMENT 2.07.02 INSUMMENT 2.07.02 IN	C 07 02 0F C 07 02 05 C 07 05 C 05 C 05 C 05 C 05 C 05 C 05 C 05 C	Costro Manual Projecti Data Defective Particle Performance Data Themrocine Performance Data Ser Exe			╫		╢	╢	\parallel	╢	\parallel								╫	╫	╫	⋕	╫	#
PASPAGAR C.07.03.04 Fael Compact Thermophysical Properties Normal Compacts Fael Section Section 201	C.07.02.04 Fast Compact Thermophysical Properties Normal Compact Teamline Fast Performance	Fuel Compact Thermophysical Properties Normal Compacts Faul References			╟				╞	H											Ħ	Ħ	╞	╞
TABINAR C.07.02.66 Valence of the contract of	C 07 02 06 Validation Devices and the procession of the contract of the contra	Valenties (measure on reconstruction) Valenties (New York Structure Valenties (State			╉		+	+	+	+	\downarrow								+	+	+	+	+	+
TARKAGE C.O. 00.00 Fail Part Tark Data	C.O. 00.07 Fail Proof Team Data Development of Team Data	Faid Proof Test Data Involution Southern and Bill 1000 MP			╢	11	╢	╢	╢	╢									╫	╫	⋕	⋕	⋕	⋕
TASIMARI N.07.02.00 Ketebertura tukit Academi Performance of Libu UCO 0411	N 07 02.00 toted 6 tare a facto Academic Performances of LDD UCOC (MFI	external turnup tartis Accident Partments of UDU UCC (NF)			+		+	+	+	+	\downarrow								+	+	╀	+	\pm	+
TASPOJAD N.07.02.09 solve ded turnup turkij	N.07.02.09 solve ded turnup tue()	solve ded turrup tuells			T		+	+	+	+	+								+	+	+	+	╡	+
TARKAR C.07.00 Radioacké Tanget Tarkar C.07.00 Radioacké Tanget	C.07.03 Endersolde Transport C.07.03 Endersolde Transport	Radionacidia Transport Pieros das Balanas trans dan Mandala			Ħ	11	╢	╢	╫	╢	\parallel								╫	╫	⋕	⋕	⋕	⋕
Interest of the second se	C. D. A.D.M. Frances date presents that the second state of the se	Frances was remeater than the manual Frances Media (Marcine Chinardes in Tael Kambia			Г		+	-	\mid	+									+	+	+	+		t
TABAGLAD C.O. 00.00 Preside Product Diversion Devices International International Product Product Devices International Produc	C 07 03.03 Photos Photos Chinade An Education In Praticipa C and An Education Control Photos	Plaster Product Diverse Diversities in Puscies County Protoco County			Π	11	H	$\left \right $	H	\mathbb{H}	\square								H	H	Ħ	Ħ	╞	Ħ
TABADAB C.07.00.64 Guideline	0.07.03.04 Graphik	Gupples	+	+			+	+	+	+	\downarrow	_				+			+	+	+	+	\pm	+
TARRAGE C.00.00.06 Tetam Permetan ia Heat Deducer Table NARADE C.00.00.06 Tetam Pergeocity Con Nalvesa	C. 07 03.06 Trittern Permetisci in Heat Exchanges Tubes C. 07 03.06 Trittern Transportin Core Materiale	Titlen Fernesion is Heat Endarge Tubes Titlen Torrpools Con Manual			\uparrow		+	+	+	+						\parallel		\parallel	+	+	╢	#	╢	

A-10 of A-17

Appendix A – DDNs Matrix-FINAL.doc

	Ű Z	761.1			Τ	Т	Т			Π	Π	Т	Π	Т	Т	Π	Т	П	Π	Т	Π	П	Т	Т	Т	Г		Π		Т	Π	Т	Т	Г	Г	Г	Г	Г	Г			Τ	
1	L rai	DBL VDN	H	_	7	7	-	F			Π		П	1	_	F	Ŧ	Ħ	\prod	7	Π		+	Ŧ	+		\square	\square		F	\prod	-	+			F	F	F		F		Ŧ	
		vi Operation Intrammo 2 I/v					+	\vdash		╢	╢	+	॑			╢	+	╢	╢		╢	+	+	+	+	\vdash	\vdash	╟	\square	+	╢			\vdash	\vdash	+	+	\vdash	\vdash	\vdash	\vdash	+	
			Ħ			4	\vdash	F		\parallel	\parallel	+	Ħ	4		Ħ	Ŧ	Ħ	Ħ	7	Ħ	\parallel	Ŧ	Ŧ	+	F		Ħ		\vdash	Ħ	\downarrow	1	F	F	F	F	F	F	\square	\square	⋣	Н
	l	Piterio Al				\pm		\square		\parallel	⋕	\pm	⋕			\ddagger	\ddagger	⋕	⋕	\pm	⋕	\parallel		\pm		E	E	╓		\perp	⋕		\pm	E	E	t	t	t	E			╈	
	_	Direction 1	+	-	+	+	+	Н		+	╢	+	H	-	-	\mathbb{H}	╀	\mathbb{H}	╢	+	╢	+	+	+	+	+	\vdash	\parallel	\vdash	+	╢	+	+	\vdash	\vdash	+	\vdash	\vdash	\vdash	\mathbb{H}	\vdash	┦	Н
	(3.5) Life Cycle	989 1	\square	_		\downarrow				Ц	Щ	\perp	Ш		_	Ц	1	Щ	Щ	4	Ц			\downarrow	4			\parallel			Щ	\downarrow	\downarrow									Ц	
		100-2914	Luna 1																																								
		600-24 a B	2			1	\square	Π		Π	Ħ	\top	Ħ	1		Π	t	Ħ	Ħ	1	Ħ	Π		T	T	\square		IT			Ħ	1	T	Γ	Γ	T	Γ	\square	Γ			Ħ	
		200-2014 E				+	+	Η		H	╫	+	Ħ	┥		Η	$^{+}$	Ħ	Ħ	┥	╢	╢	+	$^{+}$	+	\vdash	\vdash	╟		+	Ħ	┥	┥	┢	┢	┢	┢	+	┢	\square		╢	
	-		2	_	-	+	+	\vdash		+	╢	+	╢	+	-	+	+	₩	╢	+	╢	╢	+	+	+	┢	\vdash	╟		+	╢	+	+	┝	┝	┝	┝	┢	┝	\vdash		╢	
	(1.2) Facility	100-297.8	ŧ																																								
		но-ко не G	04000																																								
		80-10 a	(MILLI) CARL																$\left[\right]$																								
		20-10 a	(100 COLOR)														Í																										
		#0.05 eff	Castro (castro								Π						T			T					T																		
		1			\uparrow	\uparrow	\top	Η		\parallel	\dagger	\uparrow	Ħ	+	┥	Ħ	t	Ħ	Ħ	\uparrow	Ħ	\parallel	T	╈	\dagger	t		\parallel		t	Ħ	\uparrow	╡	t	t	t	t	t	t	Π		Ħ	
		80-80-4 60	ni oni																																								
		60-80 J	1992																																								
		80-10 d	,							Π			Π			Γ	Γ	ſ	I		П	Π									Π												
		8974D 4	*		\square	\square				П	Д		Ш]		П	Ţ	Ц	Į	\square	Ţ			Ţ	Ţ			\prod			ĮĮ		\square									\square	
		89-10-4 100-11	(Jean) I																																								
	ļ	20-10-1- 00-10-10-00	(uccast) (Ţ		║					Ţ							#												
		10-10-1 10-10-1	an.c.																																								
	Ī	80-80 a 3	(centrol)		T	T				Π	Π		Π	T		Π	Γ	Π	Π	T	Π	Π	T	Τ	T			Π			Π		T			Γ	Γ	Γ				Π	
		90-80-465 100-66	r (aecord			1										T	Ť			1				T						T	Ħ											T	
	0.3) Functional Operational requirement	10-10-1 10-10-1 10-10-1	04440								\parallel						T			1						T																	
	26 40 5 8	I	tits of	ire Nige	cheritotes		ut cu	ad Love	ours Relief							Ħ		Duts	Passad.			c	thrafforn .	(note)	(Healer)		000		Graphite	T	-		1 million	wet Design	a de la	letign	f Leak	u Decign	and		fion Test		
	Need		Parador	de ll'an	et Chart		ada ar D	in a Vient	y of Pres	dation Da	Son Day	THE OT IS	Sector of				ta selon Da	add5m			(10) 14	and N	Derron	441 (Gro	in (Drou	Pates	as foo	d Graphi M Graph	ins From		1	D and a state	orbel Au	Cquipt1	(neu)	(neu)	Flow an	Vibratio	purbusit and later	Selectio	Outilities	in the	
	Mission		o têben C	Preiseole	interest of the		of the DN uport	Tento of	Chickney	NUMBER OF STREET	Number of the second se	Tical For	VLPC S			2	Man Da	A short V	100		Tion For	later (M	buett P	celon Ra	taken Rati	omotica	ching Ra	ALTER AN	thing Rat		704m		uitan C	n Contra	and date	and the	Aguers.	Proteo lo	Themote To	(quete	risembly.	and Hat	non Dat
	(11)		Material Material	Instant P	pressue de la comparación de la comparación de la comparación de l	fastion .	feation of Mon Train	Contract The	fination in	ALL PAR	Aurbon Martine	Ind Chee	10 10 10			totion Do	el Name	Totion M	N Dispos	aline	in Odd	phile C	Votion	ing Com	ng Carro Tadon R	aphile C	ice Leas	Inputts	Me Less		S Married S		the of N	Triblew	No Mapp	Contraction of the local division of the loc	Solid A	Ma Pleas	tion of New	isned A	Index A	Demails of	port day
			adionaci nucleural	Monthann 4	r Dry De	Pretture	Manufacture	Incion Pr	Montan Tites	stion 6	MODE NO.	Tytical a	N Supp	STATISTICS.	8	one Com	See Mark	on Car	ant hu	NISO CO	C Contra	ASI ON	i selitet	yO Coat	O Costs	PERIODI	adional Prime	-14 Cont	Monut		Mahon C	effection of the second se	a local	C SALAR	-Con P	Con P	Marcel C	100	Amonda and a second	when C	Mitron C	autor le	See and
e,			e 6	6	e: \$16	í Ó	02	e E	οř	22		e al d		14	- 5	ő	00	0		1		3 (1)	a	6	63	# 8	22	00	æ	87	20	220	100	123	s d	143	e zi č	105	63	20	ź	8	á
NOO I																		$\ $												and of the second													
Ā	80				2	9	-								5		59	2	$\ $	2		z 19	8	8			-			5 or here		F	90						9		-		F
			0.00.00.0	0.00.00.0	0.00.00.0	00.001	100.00	100.001	1.00.00.1	10.00	10.00	- 10 M	100.00	107.00.2	107 03.2	10.00	10.01	10.04	20.00	100.00.0	120.02	100.001	1.00.05.1	1.00.05.1	100.001	1.00.00.1	1.00.00.1	100.02	1.00.00.1	fraction 2	11.01	110.110	101101	0.00.00	11.01.0	0.00.00	0.00.00	11.01.0	0.10.11	11.01.1	111.01.1	11.02	THE DOLL
	82		Ő	0	0	0	Ő	0	0			T	Ĩ	Ĩ	ž	Ĩ	Ĩ	Ĩ	Í	Ĩ	Ī	Ĩ		Ĩ	Ĩ	Ĩ	Ĩ	Ĩ	ž		Ĩ	2	26	ľ		ľ	ľ			0	-	Ĩ	
	Reinne		SKAAR	ALC: NO	VSKAAD	NAMA!	SKAAE	NAMAR	NSKAAR	NAME A	N N N N		NUMBER OF	NSKAAL	ALC: NO	INCOMES N	No.	NOVEN IN	TAXA2	ALANA A		ASKANAL	A 2K/AA	ASKAA	IN LANSING	SKAAD	SKAAR	TAXABLE VALUES	ALC: NO		NUMBER OF	VENAA	ALANA A		DALAR.			ALAR A	SKAAR	SKAAR	NSKA.A	NVV5	TELEVISION OF
	5		F	E	Ē	F		F	Ē			T		F	F	f		F	f	F		ĒĒ		F	F		F		Ē	\top	Ħ	F	F	ľ	f	٢	۲	ſ	F	F	F	f	Ē
	(Lensed)																																										
	3		1.5	a	a	- 31	91 A	1.5	- 3	ată b	atāt	81 â	181	3	- 31	15	ată	ES	15	_≴b	atsi i	atā	15	3	≾B	a 🛪	1.5	ផង	1.5	1	15	3	- S B	1 3	1.5	1.3	a 3	a a	1.5	1.5	15	- 65	¢.

April 2008

IAL.doc

A-11 of A-17

Appendix A – DDNs Matrix-FINAL.doc

CTF	
20-	
CTF	
NGNP-	

ļ	DRLTR	161 061						\prod	∏	\prod	\parallel	∏	H		╢	∏			\square	T	F	F			F	∏						E				∏	\square		F
		Commercial MpH.				Ш		\parallel	Щ	\parallel		\parallel	Ц	\downarrow	Щ	\parallel							\parallel			\parallel										\prod			
		v Operation	+	+	+	₩	+	╢	╢	╢	╢	╢	╢	+	╢	+			╟	+	+	╀	+	+	+	╢	-	\vdash	\parallel	\vdash	\vdash	┝	\vdash	\vdash		╢	+		┞
		notourtimo3 vi	$\downarrow \downarrow$	\downarrow		Ш		#	#	Ħ	Ħ	Ħ	Ħ	\downarrow	⋕	Ħ			Ħ	t	t	t	⋣	t	\Box	Ħ			Ħ							Ħ	Ħ		t
		DUPLY DATE T	+	+	+	H	+	╢	╢	╂╂	╢	╢	╢	+	╢	+			\mathbb{H}	+	+	╀	╢	+	+	╢	-	\vdash	\mathbb{H}	\vdash	\vdash	\vdash	\vdash	\vdash		╢	+		┞
	9 a 9	059 ($\uparrow \uparrow$	╡	\square	$\parallel \parallel$	\uparrow	\parallel	Ħ	\parallel	Ħ	Ħ	Ħ	1	\parallel	Π			\parallel	T	T	t	\parallel	T	T	Ħ			\parallel			\square				Ħ	\parallel		ſ
ŀ	820	10-34 A		1	\uparrow			\parallel	\parallel	\parallel	\parallel	₶	╞		\parallel	\parallel			\parallel	t	\uparrow	t		\uparrow	T	₶						t				Ħ	\parallel		t
		600-24 J	2													t						T		1								t							F
		200-2914 Ĕ	2			\square																																	
	L2) Facility	100-244 È	ł																																				
	c.	H0-30-10 (19)	(march)	1	T			\parallel	╢	\parallel	╢	₶	╞			Ħ				T	\uparrow	t		\uparrow	T							F				Ħ			t
		06-60 (06%)	(March 1	1	T			╢		╢						T				T	T	t		t								F				Ħ			t
		20-10 (0fter)		1	\square			\parallel	Ħ	Ħ	\parallel	₶				\parallel			\parallel	T	T	t										ſ				Ħ	T		ſ
		#0.04 10 (Offer) 11	Lineary) was	╡	T			\parallel						┤								t			T							F				Ħ			t
		#0-52 4 Fig0 (Ober)	luncion and																																				t
	İ	89-30-1 M		1												Π						T																	Γ
		жны а	,	+	\square	III		††	Ħ	Ħ	††	Ħ	Ħ	1	\dagger	Π			\parallel	T	\top	t	\parallel	\top	\top	Ħ						Γ				Ħ	Ħ		F
		80-80-4 S		+	\vdash	$\parallel \parallel$	+	╢	Ħ	\ddagger	╢	₶	Ħ	+	\parallel	+			╟	\dagger	+	\dagger	\parallel	+	+	Ħ		\square	\parallel	\vdash	\vdash	\vdash	\vdash	\vdash		Ħ	\parallel		t
		1 (0 e ki)	(augo) -	+				Ħ								Ħ					T	t		t															ſ
	ł	90-10-1- 80-00-1-	Decree	+	\vdash		+	╢	╢	\parallel	╢	╢	╞	+	╢	╢			╟	\dagger	+	\dagger	\parallel		+	Ħ			\parallel			\vdash				╢	\parallel		t
		10-40 10-40	Čast.	╡	T		+	╢	╢	\parallel	₶	Ħ	╞	╡	\parallel	\parallel			\parallel	t	\uparrow	t	\parallel		┢	Ħ			\parallel			t				Ħ	Ħ		t
	t	8 5 0 (0	L (DEIR)									Ħ	Ħ													Ħ										Ħ			ſ
		9 (Becon)	r (aecord						Π		\prod	$\left[\right]$			Π	Π						Γ																	Γ
	().1) Functional Descriptional Viguinement	P (Priss)	0000					T							\parallel	T						T		T															Γ
	(3,4) Minuter Need		Effects of Primary He and Temperature on Metallo Reactor internals Materials	internals latents on wear a reacter Internals Maritan	Effects of Primary its and Temperature on His Data Waterial	Pitrous Insulation Material Properties Hard Ceramic Insulation Properties Data	Erricoluty of Neutro Vanishin Reactor Internale (MRI)	Reader Own Des Pelsen Viberice Pais	Control Red Vioration Control Red Vioration	Core Dennet Falses Mode Data Dove Dennet Falses Mode Data	Control find Structured Integraty Data Graphics Wattandal Streegh Data	Graphia Patron Data	Graphie Mechanical Properties Data	Graphia Insidiation Induced Demonstrate Change Data	draphile Themai Properties Data	Graphite Competition Data	Graphic Concettan Data for Methods Validation	Graphics Destructive and Nondestructive Ensembled Data	Graphite Cole Searce Qualification Reserve Strationan Pellet Process	Development Data Gruppite Coldation Data for Postalated	Properties of High Temperature Control Red	10,400	Verfication of Neutran Delastare and Oabling Fael Denset Channel Flow Data	Control Red Chartell How Data Bolton ReflectantCons Support Pressure Drop	and Flow Misrog 2010 Westlike Planum Element and Top Reflector Pressam Deno and Plow Distribution	Dore Coordian Test Data Dore Technology Test Data	Pringer Nacional Data Menument at Temperature for GT-MHR Physics Methods Validation	Critical Experimental Data for GE-MHR Physics Methods Visitation	Reador Service Equipment	Reader Equipment Service Pacificy Tools Design Verfication	Reserve Straktion Vacuum Tool Dediga Verfication	Neutron Detector Service Equipment Design Verfication	Metallo Reactor Internate (MRI) 151 and Surveibros Equipment Cetign VerStation	Metallo Con Support El and Survellance Equipment Design Verfantian	Gruphite Reactor Internate (GPI) and Oore Support ISI and Surveillance Design Verfication		Vecels	Imidation Data the Reaction Versial Materials (modified BCINIMs, Sek-317 Grade SH, Clans 2 Pate and Sk-338 Grade FSH Pergend)	Properties of Heary Sector Vessel Materials
	*100		011.02.10	N.11.02.11	N.11.02.13	K.11.02.14 0.11.02.15	81.100.16	0.11.03	0.11.03.02	0.11.03.04	0.11.00.00	0.11.03.12	0.11.00.13	0.11.03.14	0.11.00.15	01100110	0.11.00.19	0.11.03.20	0.11.03.21	0.11.03.22	0.11.03.23	0.11.00.24	0.11.00.21	0.11.03.42	C.11.02.44	211.00.45	0.11.01.51	0.11.01.52	0.11.04	0.11.04.01	0.11.04.02	0.11.04.03	0.11.04.04	0110100	0.11.04.06	Manual Stations (MS) (1 45 A)	C-12.01	N-12-01-01	
	Reinnen		TASKAAD	TASKAAD	TASKAAD	ASKAAD ASKAAD	TASKAAD	ASKAAD Aska AD	ASKAND -	DAMAR I	ASKANA ASKANA	ASKAN	BACKAR	TASKAAD	DAMAR I	DADARA D	TASKAAD	TASKAAD	BAAND	TASKAAD	TASKAAD	TASKAAD	TASKAAD	TASKAAD	TASKAAD	ALC: NO ALC: N	ASKAAD	TASKAAD	DAXABA	TASKAAD	TASKAAD	TASKAAD	TASKAND	TASKAAD	TASKAND		BAAAA	ASKAAD	
	northin							Ĩ										-				T																	Γ

		f 2	34.4									1			П		П	—	П		П	Π		Т			<u> </u>				Т	Π	-	T	\square		П
		Datr	ายอ			t		Ħ		\pm					Ħ				Ħ	t	Ħ	Ħ		t		t				\pm	t	╢		F	F	F	Ħ
$\ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \ $			Commercial Apple.	114																		Ш															
			operation	54						\square					П				\Box			П								\Box		П					П
Allocation Allocat			UO NA RU RUO 2	^		+	⊢	\vdash	+	+					₩	+	+	+	\vdash	+		Н	+	╀	\vdash	+	+	-		+	+	╢	+	┢	⊢	⊢	₽
MICION MICION MICION International Internati			DEAL DAY			+	\vdash	\vdash	+	+					H		+	+	H			Η	+	+	\vdash	+				Н	+	╢	+	+	⊢	\vdash	H
MICON Number of the second secon			Dilevening Dilevening	•				\Box		\square					П				\Box			П				\square				\Box	\Box	П			\Box	\square	Π
International problem Internaterase International problem In		(J.S) Cycle	Q 98	•																		Ш															
Antional			100-54	FONM										Pol netac																							
ALTORY ALTORY ALTORY Invoto Bart Invoto			600-04 <i>1</i>	HPTU								ļ		r, viteritien Mitteen and	Ц						8.	Ц															
Allocut Descent state Descent state<			6 WC-003	Ē								antig.		Name of the second	Ц				Ц		Chinedad												\downarrow		L		Ш
MIDION MIDION International Description Intenal Description		Appegleti	100-5973	жШЕ								ti Bh a' calabhr		the level with a for the level of the local states							C Data	1															
All CONF. All CONF. <t< td=""><td></td><td></td><td>H0-801</td><td>(Other)</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td>1</td><td></td><td>characteric</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td>Π</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></t<>			H0-801	(Other)								1		characteric								Π															
			610-18D J	ID (DRHr)								Ī		natural agrity of alling parts d susceris					Π																		Π
AllONA AllONA AllONA Invite Device			30-8D J	D (Other) T		T						or nami boraty Accel telenos	sier thrat aing dherance	and in the second s		T		\uparrow		T		H		t		╈				T	t	Ħ	1	\uparrow	F		H
ALTON ALTON International production of the			#0-3D-1	D (Other) TI		T						Chily of the contract of the c	STURE O	Arris -	Ħ	T		T				H		t		T				T	t		╡	T	F		H
ALLONA ALLONA International Province P				we) TE		┢	\vdash	\mid	+	+		ener Alect Cont Cont Cont Cont Cont Cont Cont Con	1163		Ч	\vdash	+		H		╟	Ч	_	1 1	4	1	1			410	a :	11	44	1 1	1	4	4
ALTORY ALTORY ALTORY Invest 044 1			60-10-	TED (OF								-			4			_				-		No lefts work	No info avail	No lefts work	No info avail			No info avail	No krite svali	No info avail	No left avail	No info and	No info and	No info and	No info avait
All DONE Control Contro Control Control <t< td=""><td></td><td></td><td>60-1D J</td><td>Fhuid</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td>_</td><td></td><td></td><td></td><td></td><td></td><td>uperior of the</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></t<>			60-1D J	Fhuid								_						uperior of the																			
All DOVE All DOVE All DOVE Notices Distant Distant Distant Notices Distant Distant Distant Notices Distant Distant Distant Notices Distant Distant Distant Notices Notices Distant Distant Notices Distant Distant Distant Notices Distant Distant Distant Distant Distant Distant Distant Distant Distant Distant Distant Distant <td></td> <td> .</td> <td>80-10-f</td> <td>0</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td>\downarrow</td> <td></td> <td>- 58</td> <td></td> <td>S</td> <td>\downarrow</td> <td></td> <td></td> <td>-</td> <td>÷.,</td> <td>10</td> <td>24</td> <td>+</td> <td></td> <td>\downarrow</td> <td>\square</td> <td>\perp</td> <td></td> <td></td> <td></td> <td>\downarrow</td> <td>\downarrow</td> <td>Ц</td> <td>\downarrow</td> <td>\downarrow</td> <td>L</td> <td>L</td> <td>Щ</td>		.	80-10-f	0						\downarrow		- 58		S	\downarrow			-	÷.,	10	24	+		\downarrow	\square	\perp				\downarrow	\downarrow	Ц	\downarrow	\downarrow	L	L	Щ
All DONG All DONG Increase DONG PERIOD DONG PERIOD DONG PERIOD DONG PERIOD DONG PERIOD DONG PERIOD			an-10-	8		+			_	_	<u> </u>	- the second		y of the ex- theorem is a	4			ty experim Ateal evel	perment i	Prepared a	in jointe, a	4	_	+	\square	+				+	+	\parallel	+	+	┝	┝	μ
All DONA All DONA Increase Contract Co			909-16D /	T (Deter)								rinto and mat load capac fittionin of radi		diseal capability on including me				any to confirm (conject by analy	to confirm by ac	Cedito produce persiónal chan	tests, suparait																
All DONG All DONG Control Contro Control Control <			90-8D J	((Secon)								- min solution amplitude of the end of the		oo ite tux date qeb date qeb				R is neces	ACTINGUES	nia are nee rical and o	SUL COMP											Ш	\downarrow		L		Ш
All DOME All DOME All DOME Nonumer Nonumer Nonumer Nonumer Nonumer Nonumer Nonumer Nonumer Nonumer Nonumer Nonumer Nonumer Nonumer Nonumer Nonumer Nonumer Nonumer Nonumer Nonumer Nonumer Nonumer Nonumer Nonumer Nonumer Nonumer Nonumer Nonumer Nonumer Nonumer Nonumer Nonumer Nonumer Nonumer Nonumer Nonumer Nonumer Nonumer Nonumer Nonumer Nonumer Nonumer Nonumer			999-362 é	0 T (Prim								dyne and d		88,	1			0000	n la M	8 6	AND COLOR	1										Ш	\downarrow		L		Ш
All DONG Annone Denemica Denemica Denemica Denemica Recent and			©0+3D ±	P (Della								,			⊥			applied to															\downarrow		L		Ш
All DONG			899-¥D 4	P (Secon)											l			*																			
All DON's Chill Brunnes Chill Brunnes Rennes Chill Brunnes Chill Brunnes Chill Brunnes Branch Brunnes Brunnes Chill Brunnes Brunnes Brunnes Brunnes Chill Brunnes Brunnes Brunnes Brunnes Chill Brunnes Brunnes Brunnes Brunnes Brunnes <td>г</td> <td>(1.1) Functional and Operational regulatenen</td> <td>N0-10-</td> <td>P (Prim)</td> <td></td>	г	(1.1) Functional and Operational regulatenen	N0-10-	P (Prim)																																	
All DOINe Renneces Renne		(3.4) Minution News			Reader Vessel Emission's (Medike SO-NA) ABB-OE SA307 Grade St, Olass 2 Plate and ABB-OE SA307 Grade St, Olass 2 Plate and	Heart card bate for the behall cleares	Imdiation Data for Reactor Vennel Maintal. 2K Cr - 1Mai	Keadar Pressure Vessel Enisoity (25.01 – 1941)		Vitrary Hellom Citulator (PHC)	Effects of Primary Costart Helium and Temperature on Primary Heat Transport System Choulder Hastefals	Creater Magnets and Cascher Tearings Melloy Welfstreet		Desister Preisten Design Verfication	Manual New York Profession (1971)	Effects of Helium and Temperature on 140. Valentis	Continuation of POHE Core Cone Cone of	Continuation of POHE Core Temperature Natification	Continuation of IROC Thermal Hydraulic Characteristics	MX Apputit Test MX Insulation Verfication Tests	MCC Seal Tests MCC Files independ Vibration Test			arenden urbeiten 2005 Ornalder Nagredo and Ostoher Teatron Dester Verlitation	SCS Christian Projektion Impeller Aerodynamics and Accustic Test Data	000 Circulator Protogoe Text in High Presson Text Profession HIGTE	Shutdewn Circulator Loop Shut of Valve SLSV) Life Cycle Test Sata	Indution Effects on SOS Circulator Mainrich	Effects of Printary Conduct Helium and Emperature on SCS Circulator Materials	Shubdram Hast Exchanger (SHE)	SHE Inuideer Verficultur Tetts SHE Vitrational Prefix g Wear and Siding	CHE Inducedation Adaptment Test	SHE Bark Tapes Inspection Methods and Coupored	ann annae ann ma Acamtical Neponte of the SHE Heltal Ban Tube Bande	2010 Mile Now and Temperature Destruction Test	SHE Tube Bunde Look Heat Transfer and You Residence Characteristics	2010 Tube Histori Col Program 1111 Auto-Mando and Domainin Jose Tabe
Refrances Refraction Refract	All DDN's	# HOD			1000	0.12.01.04	N12.01.05	112.01.06	DOMARY NEAT TRANSPORT	SYSTEM (PWTS) M 13.00	1010ELN	2 2 2 2 2 2 2 2 3 2 3 2 3 2 3 2 3 2 3 3 2 3		N 13.01.00		N.13.02.01	N.13.02.02	K12.02.04	1110205	N.13.02.06	N.13.02.08		SVSTEM (SOS) 0 14.00	0.44.01.01	0.14.01.02	014101	0.14.01.04	1 11100	114.01.06	0.14.04	0.14.64.01	014164.00	0.14.04.04	0.14.04.06	0.14.04.07	0.14.04.00	0.14.04.09
		Reinnance				DAMAR A	ASKAAD	ASKAAD			av.max	F		F	ALC: N	ASKAAD	ASKAAD	-	E	-					E		E	ASKAAD	ASKAAD				-				
		neofikes								-				0	Ĭ			0	0						0									- 11			2

A-13 of A-17

Appendix A – DDNs Matrix-FINAL.doc

April 2008

E S	161	Т	_	Π		П	—	Π	Т		Π	Т	Т	Т	Т	Г		Г		Т	Π		Т		Т	Π	Г	Π	Π		Π			П	T	Γ
DRU	ายอ			Π				Ħ	\downarrow		Ħ	1	1	1	1						\parallel	\neg			1	Ħ		I						Ш		
	Commercial Apple.	114		Ш				Ш			Ш															Ш										
	nottenedO i	şh	_	Ш	-		+	₩	+		₩	+	+	+	+	╞	⊢	-		+	Н	\rightarrow	+	$\left \right $	+	₩	╞	_	+		+		+	Ш	_	
	no tes in mo 2	^ ^!	-	╢		+	+	╢	+	-	╢	+	+	+	+	\vdash	⊢	\vdash	\vdash	+	+	+	+	+	+	╢	\vdash	╟	╢	\vdash	╢		+	H	+	+
	Condication of			Ħ				Ħ	\pm		Ħ	+	\pm	\pm	1	Þ	F	F			Ħ		\downarrow		\pm	Ħ	Þ	Ħ					\downarrow	Ш		
	299	•	_	╢	_	+	+	╢	+	-	╢	+	+	+	+	\vdash	⊢	\vdash	\vdash	+	╢	+	+	+	+	╢	\vdash	╟	╢	\vdash	╢	\vdash	+	H	+	\vdash
(J.S) Life Cycle	059	'		Щ	_		+	⋕	+		⋕	\downarrow	4	\downarrow	_	╞	\vdash	╞			\parallel	\downarrow	\downarrow		+	\parallel	╞	_	+		\parallel		\downarrow	Ш	_	\vdash
	100-34 4	PDVB		Ш				Ш	\downarrow		Ш	\downarrow		\downarrow							Ц		\downarrow			Ш								Ш		
	600-D4 J	UT 9H		Ш				Ш	\downarrow		Ш	\downarrow	\downarrow	\downarrow							Ц		\downarrow			Ш							\downarrow	Ш		
	6 WC-003	Ĕ		\parallel				Ш			Ш	\downarrow		\downarrow							Ц		\downarrow			Щ								Ш		
All Facility	100-5918	HTF.																																		
	но-за 🛔	(Other)																																		
	80-10 J	(TED (DRH)																																		
	30-10 J	r) TED (Ohe							\downarrow			\downarrow																			\parallel					
	H0-8D-4	TEO (Ohe																																		
	60-10 A	TBD (Other)																			Vo info available	Vo info available	No info available		No info available No info available											
	s>-xD-1	Fhuid																			Í	_	Ĩ													
	80-1D 4	ø		\prod				\prod			\prod				\downarrow							\downarrow	\downarrow			\prod							\square	Щ		
	-08-404	8		\parallel		\parallel	\downarrow	\parallel	\downarrow		\parallel	\downarrow		\downarrow		\vdash		\downarrow			\parallel	\downarrow	\downarrow		\downarrow	\parallel	\vdash	\parallel		\square			\downarrow	\prod		\downarrow
	909-34D 4	T (00%)																																		
	700-30 J	(Becon)																																		
	100-KD 4	T (Prim)						\prod																		Π										
	60-80 a	P (Della)																																		
	an 10 1	P (Secon)																																		
(1.1) Functional and Operational requirement s	N0-10-4	P (Prisc)																																		-
(CA1) Mills stime Named		molection (Perts on Stationer Condico	System Hau Exchange Marchis Effects of Primary Coded Helican and Terryperture of Stations Cooling System Heart Exchanges Material			Entering of ROCS Panel Medi Sertaes Med Transi Test of ROCS VO Stuckers	Integrated ROCS Performance ROCS Cooling Parel Heat Transfer Development and Friction Easter	Effective Conductivity of Care Blocks Respansy induced Fluid Mailes in a High	Aspect Radio Cavity		Core Refielts Foil Handley Nachtenfield Medianian	Dedign Verfication Feel Transfer Casts Consocrant Design	Verfication Thereat Rolet and Grands Assembly Dobot	Decigo Vertication Vertir fred Handleo Secters Jectermentation	and Control Methoday Configuration Southern Taxa Data	Ford Handley Existence Footbook Dedige	Fiel Handleg Equipment Support Structure Design Verfloation	Fiel Sealing and Impedion Equipment Design Verfication	Initiative Seal and SM ISouthorities Tools Design Verfication		Salety Protection and Instrumentation	Verfy Hellum Mass Flow Massimered Instrumentation	Verlooks heteroetalish		Nuclear Idané Contrai and Instrumentation Netty USA Intel 202 CODACTANDER Terresoltan Manusersani Instrumentation	Verity Plateout Probe Operation		Tuttorrative Service Lifetime of Unabled Turbine Statist	at 960 oC Verfication of Black Cooking Design	Thermal Barrier Condings for Tarbles Biodes	Пернайг	Creep Data for Candidate Recuperator Metal	Recuperant support system, peugn Verfication	Duck and Seals PCS Duct Design Verficulan & Support		20115 Oradater (Secondary Oradater DOM) are covered by Petracy Hellum Oradater
* NOD			0.14.04.11		REACTOR CANTY COOLING SYSTEM (RCCS) C.18.80	0.16.00.01	0.16.00.00	0.16.00.05	0.16.00.06	PUEL RANDLING AND STORAGE SYSTEM (FMLSS) 0 34 00	0120	0.21.01.01	0.21.01.02	0210100	021004	021010	0.101.00	0.21.01.00	0.01.01.00	MORE FOR PROVIDE TOWN	0.31.01	0.10.10.1	0.31.01.02	PLANT CONTROL, DATA AND MSTRUMENTATION SYSTEM (PCDAUS) C 34.00	0.40	2010102	PUMBE CONVERSION	NALOI 10	NALOLOI NALOLOI NALOLOI NALOI NAL	NAL0103	1 AV 02	NALOCOL	NA1.02.02	N.AT.04 N.AT.04.01	SECOMDARY NEAT TRANSPORT SYSTEM TRANSPORT SYSTEM	
Reinnance			TASKAAD ASKAAD			A SKALAD	ASKAAD	ASKAN	ASKAAD		ASKAAD.	LASKAAD	LASKAAD	ASKAAD	ASKAAD	ASKAAD	ASKAAD	ASKAAD	ASKAND			E	ħ			ASKAND			ASKAAD ASKAAD	UKUNSK.	ASKAAD	ASKAAD	UMANAN I	ASKAND		
Controlium									~				_	_								-	_									_				

A-14 of A-17

Appendix A – DDNs Matrix-FINAL.doc

	DRL/TR L rating	187 061															\prod													
		Letonemental Apple	114																											
		Operation	**		\square		H	+	╢	╢	H	╢	╢		H		╢													
		no fourtieno 3	-1		Ħ		Ħ		#	Щ	Ħ	#	#	F	⋕	\perp	#	F	F											
		Burn Burn T			\square		\mathbb{H}		╂	⊞	╢	╂	╂		╢		╂													
	(3.5) Life Cycle	089	•																											
		900-5W	FONIM							Ш												ŝ	ow.	en en		ş	ş	ş	5	
		600-D4 A	UT 9H						\parallel	Ш	\parallel	\parallel	\parallel		\parallel	\downarrow	Ш			4	ł	ź	÷	£		£	÷	÷	4	
		6 WC-005	Ĕ						\parallel	Ш	\parallel	\parallel	\parallel		\parallel	╞	\parallel				2	g	g	g		g	g	g	4	ŧ
	(11) Facility	100-24 8	жШн																			Yes, see note	Yes, see note	Yes, see oote	Postičia, sea osta	Yes, see note	Yes, can ada	No. can polo		
		H-0-30 J	(Other)				\prod		\prod		Π	$\left \right $	\prod		Π		Π				£	ALM.	ji.	ALC: NO	N.	No.	N.	5	5	£
		80-10 J	ab (bher)								\parallel	\parallel	\parallel		\parallel						6	N N		4 W		1		1		6
		a•-vo.	D (Office) T			\uparrow			╢		╢	\dagger	╢		╢	t	╢		\vdash			z 5		*		2				
		#0-8D-3	(Other) TB			+			╫		╢	╢	╫	$\left \right $	╢	t	Ħ	\uparrow	\vdash			2	z	z	z	2	afteral erra / ho	xxext connet wn / wn / to annet N		
			6 6 6		\$	+	$\left \right $	+	╢	$\left \right \right $	\parallel	╢	╢	-	\parallel	+	╢	+	\vdash			NN	NN NN NN	, NUA	A NUA	NN N	Open proble trust	A Carl	1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1	100
		040-10 A	TED (Other		No info availat													TRD ater decigned	TBD atter deciment	Complete companies int	Contrast & Instrumentation development /	qualification requirements	Specifications in gainements CTT to be use for VIIV	Pluid Invention opecia/Bordion	Casily control tytism regimensets	Specify canifo human factor receivements	Procedures development pus Bradion	Maintenace a repair program prosess development	Deterrite up regimentati Ngh temporal francostrol	Advented by
		so-a⊃a	Fhuid																	4		(Mar	ului.	(ietum	(idea	anitati anitati	nutre i	ş	1	
		80+10 d	•		Ц		Ш		\parallel	Ш	Щ	\parallel	\parallel		Щ		Щ			1		đ	NN N	01L	NN N	N N	MN N	ž	F	
		ar 10 s	8	formance of set materia					\parallel	\prod	\prod	\parallel	\parallel	\vdash	\prod		\parallel			l f	2	ĝ	NN N	00L	NIN	NUN	Ň	5	F	
		909-160 d	T (Officer)	d to assess per utation, value to the and structure																1		Dat	Ń	TED	NN NN	NN N	NN	2	ci.	FWT_Jellet 2200 Sham
		90-8D J	(Becon)	internal internation			Щ										Щ			5	2	ŝ	NN	91	NN	MM	WW	KA KA	ş	
		200-KD 4	() T (Prim)	Color Value	Ц		Щ		\parallel	Щ	\prod	\parallel	\parallel		\prod		\parallel					gt	WN	DIT	WN	NN N	WN	SN N	f	
		©0+30 J	P (Della		Ц		\prod		\parallel	Ш	\prod	\parallel	\parallel		\prod		\parallel			1		đ	WN	01L	NN N	NN N	WN	SN N	F	
		30° 40 d	P (Secon)		Ц						\prod				\prod					ļ		00L	NN	001	NN	NUN	NN.	N,	F	
	(3.1) Functional and Operational regulational	N0-10-3	P (Prim)																	1		00L	NN N	100	NN.	NUM	Y N	50		
	(1.1) Minution News			Effects of Primary Control Helium and Temperature on SHITS Pipeling and Valve Materials	Nigh Temperatus Insisten Value Prototype Design Vertication		Suiture Acid Decomposition Catalyst Performance	Burtan Rescion	Served Thermodynamic Bode	Nythogen kodide Discompatifica NAVO Membrane Separation	Uquid HI Decomposition	Materia Compatibility Domotics conferences	Colpres Murubanbly		SCC Vestion	son reneate excenterate SOE Englewing Soale Module Decomption	WORP SCE Muis-Module Demonstration	HTE Plant Supporting Eculement	ITTE Steam Generatoritizzerheater	ntill framtucktegen Feil State Testeg/Statification of systems		Control & Instrumentation development / guaritation	OTF to be wred for VEV of methods / software	Platel Investory systems leading	Guality control systems testing	Detroi reen tuman facion	Operational	Program	Nigh temperature instrumentation (Flow	With read from High Terry Eldragolo (HTE)
All DDN's	*N00			N 42.02.01	N.42.02.02	SHERED IS PRODUCTION	NAM OF	NA4.02	N 44 02 02	NAM (D) NAM (D) (C) NAM (D) (C)	N 44 03 03	N AA DA	N 44 04 02	MTE-BASED NO PRODUCTION SYSTEM (NTE)	NA5.03	1440.00	145.03.03	NASA	145.04.01	Later of		Addines	Additional	Additional	AND AN AREA AND AN	Addined	and the second	the second s		
	Reinnance			t,	t.		A SPOARD	DAMAR I	ASKANA B	ASKAAD ASKAAD	BACKAR	ASKAAD	ASKAND I		ASKAND .	TASKAAD	BACASA	ħ	t.			-	ħ	11	ŀ	E	ŧ	Þ	;	
	Contection			5	1					5 5 5		55	4		5		4			4										

A-15 of A-17

Appendix A – DDNs Matrix-FINAL.doc

April 2008

NGNP-CTF 20-CTF

					_		_					_						_	_					_				
	DRL/TR L raing	181 061	\neg		+	\prod	\prod	H	\prod	∏	Π	Ŧ	\square	Н	+	Н	+	Н	+	Η		Н	Ŧ	Η	Ŧ	Η		
		Commercial Apple.	HV.		T	IT	Π	T	Π	Ħ	Π	T	Π	Π		Π	T	Π		Π		Π	T	Π	T	Π	1	
		notisnedO	5A		Ŧ	Ħ	Ħ	Ħ	Π	Ħ	П	Ŧ	Ħ	Ħ	Ŧ	П	+	П		Π		П	Ŧ	Π	Ŧ	Π	0000	
		Construction Construction	41		t	⋕	Ħ	⋕	Ħ	⋕	⋕	t	Ħ	Ħ		Ħ	+	Ħ	1	Ħ		Ħ	t	Ħ	1	Ħ	De com	<u></u>
		Para Buo 2 Dijevenja Niko			\pm	⊞	⊞	⊞	⊞	⊞	╢	\pm		H		H	\pm	Η		H		Η	\pm	╢	\pm	H	0000-0	
	6	ass	ı.			Π				Π	Π	Ι								\prod			Ι				etal deb	
		100-2014	DIMM		T	Ħ	IT	Ħ	Ħ	Ħ	Ħ	t	Π	Π		Π	T	Π	T	Π		Π	T	Π	T	Π	del Imp	
		000-7W 4	5	ş	+	╫	╟	╫	H	╫	╢	╀	╟	Н	+	Η	+	Н	+	ℍ		Η	+	╢	+	॑	bull: mo	
			5	£	+	╢	╟	╫	╟	╢	╢	╀	╟	Н	+	Н	+	Н	+	ℍ		Н	╀	╢	╀	╟	f NED-F	
		P. MC -003	Ĕ	g	\downarrow	\parallel	Щ	Ш	Щ	Щ	Щ	\downarrow	Щ	Ц		Ц		Ц		Ц		Ц	╀	Ц	+	Ц	gran c	
	2.2) Facility	140-54 4	щ	40 AN 10																							- for darely	o operations of the second sec
		H-9-30-3	(Other)	NIN																								A constraint of the second sec
		60-1D-1	TED (DRev)	W																								the second secon
		80-80 J	TED (Other	special tregaliterin tregaliterin TBD. Double Double Double Double DON																								interest and a second s
		#0-8D-3	TDD (Other)	Muterial Lin. Creep Adige Creep Adige Creation / Consider High Tang																								for the card
		80-10-1	TBD (Other)	MARCHART LITE DAGENETS Scott 617 Scott 617 Scott 618 VOST 030 VOST 180 VOST																								1 and Latenerity. To and Latenerity. Lotset and displaying the second se
	İ	60-¥D.4	Fluid									T	22				T		T				t		T			R. 1870. R. 1870. R. 1880. R. 1980. R. 1980.
		89° KD 4	σ	WW	T	Ħ	IT	Ħ	Ħ	Ħ	Ħ	t	n anter 1	Π		11	ſ	Π	T	Π		Π	t	Π	t	Π	Que dat	Contraction of the second seco
	t	ar 10 d	8	ĝ	T	Ħ	IT	Ħ	Ħ	Ħ	Ħ	t	141144	Π	T	Į	è	Π	T	Ħ		Ħ	t	Ħ	t	Ħ	Creep-datio	tenso te
		909-160 d	T (Other)	4									o of totion gas			THAT CRAME	dite control of la										data, including	the cross is a constraint of the cross of th
		90-3DJ	(Jacon)	1, MK 2000 1, Julie 800								t	In a monitorial			n berperature	1000Cl po						100000000000				mical property	The second secon
		999-KD 4	T (Prim)	3838									8¢			eni Ng	11 (12) 11 (12)						1000				e mecho	en provincial de la constante
	İ	as+ao a	P (Della)	2 - 40 - 40 - 40 - 40 - 40 - 40 - 40 - 40	T	Ħ	IT	Ħ	Ħ	Ħ	Π	T			T	ferrel may	CONCEPTION OF THE OWNER OWNER OF THE OWNER OF THE OWNER OF THE OWNER OF THE OWNER OF THE OWNER OF THE OWNER OF THE OWNER OF THE OWNER OF THE OWNER OF THE OWNER OWNER OWNER OF THE OWNER		T			Π	THE PART OF		T		Date	CLUMER Second Second S
		99-80-4	P (Secon)	10.00													5						Intelling					Кортинства Вортинства
	(1.1) Functional and Operational requirement s	N0-10-1	P (Prim)	10.00			To test the	fabrication Main	components	Vessenan	georetrical.										Gaptile & composite coltation		FIRE					herts Herts Hertsfeld Hertsfeld Soly feld Hertsfeld Hert
	(3.1) Minuten Need			MSHORI		Fuel Patiention	Laboratory attain \$5%cation - Control controlses	- Compatis - Compatis Industrial pilot live	 Coaled particles Commands 	Characterization Defect inscinition	After Inscition	Feel qualification	insidation Society Antion		Matherials Processions of affairs	In Impure He atmosphere	Acrosofteto preserve Universitation	Constant + criego	Comption + low cycle fatigue Normal operating pressure		to sirin seven charf son		Interager Detadlation	Vistel mitats	Composition Composition	ann an annais a' Dan Annais	Pare Fix	10.0 (American American American Social States of American Ameri Social States of American American Social States of American States Tates American
All DDN'6	* 400			Mikite Paper																								
	Reinnang			ħ		ASKUAD	TASKUAD	ASPULAD	TASKOLAD TASKOLAD	ASSULAT	ASIONE	ASINUAD	TASKULAD A SKULAD	ASIOUAD	A SPOLAD	ASIONS	ASPOLAD	ASIOLAD	TASKUAD	TASKOAD	A SKOLAD	TASKUAD	ASPUAD	ASIONE	TASKUAD		110	
	Controlium					ADDA	ADDA	AND A	ADVA Marka	Will have	ALC: N	NULL NULL	ADD3	SEVA.	Will have	WW.			Ī		N.G.	EVA.	Ī		Ī			

April 2008

Appendix A – DDNs Matrix-FINAL.doc

A-16 of A-17

	~ 7		_	_			_	_	_		1	_	
	Leding	181 180	\vdash	┝			┝	╀	┝			⊢	
		-pddy-	114	ſ			T	T	T			\square	
		notisredO	54	┢			t	H	H			⊢	
		LOUR MILLION	٨										
		Construction	*1	┝			┝	+	\vdash			┝	
		Dujeveni 1 Dujeveni 1	•	E			L	L	Ē				
	(3.5) Cycle	098	١										
		100-34.8	PONDA	L									
		6 00- 24/J	HPTU				L						
		6 VC -003	Ĕ										
	(1.1) Facility	100-29/3	HTF.			No for 1 to 10 MVM text local) Karlenshe) for a FIMA in HFPR, sin			
		H-0-3D-J	(other)		a too a					by TTU (JRC Met Io 1996) INL			
		80-1D I	TED (Office)		Ther dedicates above (400°C) or or during N	ioning.				Undertainen 1 petoke imadia			
		50-¥D-1	TED (Ofher)		cole 1 text 0 cole (text) 0 / large H a fo	commiss.				ptis of hall y high turn-			
		#0-XD-3	TED (Other)		u belagelat 100 100 100					Instead and Instead to way up			
		80-10-1	Tab (Other)			o decign (peoding				sentative officed AUROA.care power anache ansented			an an an an an an an an an an an an an a
		se-so 1	Fhuid	3 19601		is and certain (is decised)				Mity of a report ent in the MAX rin OEA Cast			Nievi operal di tame type P coun (EVC NEA), Nimo TR-13, NITTR.
		80-10-4	a	madin		Den se	Printion	Γ	Γ	Fead aperim mack		18	to white a law whi
		ar 10 d	s	One with		A Design of the second se	wight be a				Rewin 1000 1000 1000 1000 1000	ation in N	y data erd an system coneca as coneca as dary ME-
		90+10-4	T (OBM)	publication that		n, texts chard of Tradien of the fac	As of RAD which			etting an Ion spectram e reflector	Todition heat currents in the master conty and return circuition in the stores	tates infrared	a. 56
		%0+¥D-J	(gecon)	ě		filme design	NOW ALL THE			othilly of g it as trans the graphs	Decry beat beat means friend f	and hence	
		109-KD 4	T (Prim)			t titget of	å			An the poil	Contact on cod- down: validation of	o con fixe	
		a)≁ao i	P (Della)			n the fire				edment v then uped	Variante nut autoria Marina Ma		
		9)-10-1	P (Secon)		te Npr Methodate Methodate	r and calcher bearing				Critical eq Interplatic neu at the interf	Maing of cold and hot consists in corrected		
	(1.1) Functional and Operational requirement	NO-10-4	P (Prim)		Mertweite of Die impedier pie exalie 0.2 to 0.40 Loops productie in	Includes Includes				-	Representation in production in production in production production		Comparison with data on gas loop transfert transfert
	(1.1) Mile silon Nee d			Vict gas duct		Crawleter	Colorentee Colorentee		Computer Code Qualification	in trette	there will be a set of the set of	Vestroeits / Thems-field dynamics coupling	tation and out
All DDN'6	* MOD			đ.		,							
	Reinnere			-									
	notion			6		5	0				5		5
	ວິ			L			L		L			1	

Appendix A – DDNs Matrix-FINAL.doc

APPENDIX B - SOUTH AFRICAN PBMR TEST FACILITIES

1.1 HELIUM TEST FACILITY (HTF)

1.1.1 Background

The Helium Test Facility (HTF) is a facility for the development, verification and non-nuclear testing of critical prototype components of the PBMR and Support System. It provides the capability to test components and sub-assemblies in a high-temperature and high-pressure helium environment that are similar to the operating conditions expected for the PBMR demonstration plant.

The HTF will be used for testing of the following PBMR Demonstration Plant systems, subsystems and components, also defined as Units Under Test (UUT):

- Fuel Handling and Storage System (FHSS)
- Reactivity Control System (RCS)
- Reserve Shutdown System (RSS)
- Helium Inventory Control System (HICS)
- Gas Cycle Valves (GCV)
- Instrumentation
- MPS Recuperator

The HTF is situated on the premises of NECSA, at Pelindaba, near Pretoria. The facility consists of a totally enclosed 40m high (8 levels) test tower with a 10m x 13m footprint and a 20 ton overhead crane with a passenger lift (ground - level 6). The facility is designed to accommodate 5 independent process streams, which are able to operate at up to 9MPa, 50°C - 580°C (1100°C local) and up to 2kg/s. A simplified PFD of the HTF, indicating the maximum temperatures in the different lines is indicated in Figure 1.



B-2 of B-27

Appendix B - SA PBMR Facilities-FINAL.doc

Figure 1: Simplified HTF PFD



Figure 2: Photo of HTF

1.1.2 HTF Envelope

The HTF is subjected to a list of Acceptance Test Procedures (ATPs), in order to demonstrate the required thermal-hydraulic performances as specified in the design and requirement documentation. These ATPs are summed up in Table 1, and will be conducted in three phases. These three phases are distinguished by the maximum temperature limit on the complete facility.

Phase	Maximum Temperature limit	Commissioned date
Phase 1	T _{max} = 300°C (Mainloop)	End 2006
Phase 2	T _{max} <u><</u> 580°C (Mainloop)	Mid 2008
Phase 3	T _{max} <u><</u> 900°C (Local in test set-up)	Mid 2009

A complete summary of the operating envelope in the different sections of the HTF is presented in Table 2. From these specifications it can be concluded that the HTF does have the potential for addressing certain of the CTF needs. This potential would however need to be assessed according to availability of the different conditions.

9	Description	I.	II	111						Mani	fold									
		əsey	əser	อรยเ	Pressure	U				٩		ш		Ľ		Line	9 9	Lab /	vailibilty	
		d	ld	łd	[MPa]	[kg/s]	[°C]	[kg/s]	[2]	[kg/s]	[c]	[kg/s]	[°C]	[kg/s]	[°C]	[kg/s]	[°C]	kg/s	[]	Date
-	FHSS @ 1 MPa Line D, T = 280°C (via FHS system)		×		۲			0.051	280									0.051	280	rbD]
7	FHSS @ 1 MPa Line G, T = 200 - 250°C (via equalisation line)	×			-											0.03	250	0.03	250 [rbD]
3	FHSS @ 1 MPa Line G, T = 280°C (via FHS system)		×		-											0.13	280	0.13	280	rbD]
4	RSS @ 2.2 MPa & T_max ≤ 250°C	×			2.2	0.05	250	0.05	60	0.05	60	0.15	100	0.05	50			0.05	250 [[D]
ŝ	RSS @ 6.5 MPa & T_max ≤300°C	×			6.5	0.05	300	0.05	100	0.05	100	0.03	100	0.05	50			0.05	000	TBD]
9	RSS @ 6.5 MPa & T_max ≤ 600°C		×		6.5	0.05	500	0.05	100	0.05	100	0.03	100	0.05	50			0.05	200	rbD]
~	RSS @ 9.0 MPa & T_max ≤ 300°C (SAS transport)	×			6	0.05	300	0.05	280	0.05	280	0.4	150	0.05	50			0.05	300	[D]
80	RSS @ 9.0 Mpa & T_max ≤ 600°C (SAS transport)		×		6	0.05	580	0.05	280	0.05	280	0.4	150	0.05	50			0.05	580	rbD]
6	RSS @ 9.0 Mpa & T_max ≤ 900°C (SAS transport)			×	6	0.05	750	0.05	280	0.05	280	0.4	150	0.05	50			0.05	750	[D]
10	RSS @ 9.0 Mpa & T_max ≤ 600°C (Manifold D for lower RSS vessel conditioning at 350°C)		×		6	0.05	580	0.1	350	0		0		0.05	50	,	-	0.05	580	[DBD]
7	RSS @ 9.0 Mpa & T_max < 900°C (Manifold D for lower RSS vessel conditioning at 350°C)			×	6	0.05	750	0.1	350	0		0		0.05	50			0.05	750	TBD]
12	RCS @ 9.0 MPa & T_max ≤ 300°C	×			6	0.2	300	0.06	280	0.05	280	0.05	120	0.05	50		-	0.2	300	rbD]
13	RCS @ 9.0 MPa & T_max ≤ 600°C		×		6	0.2	580	0.06	280	0.05	280	0.05	200	0.05	50			0.2	580	[D]
4	RCS @ 9.0 MPa & T_max ≤ 600°C			×	6	0.05	006	0.05	280	0.05	280	0.4	150	0.05	50			0.05	006	rbD]
15	RCS @ 9.0 MPa & T_max ≤ 300°C (No manifold C flow)	×			6	0		0.06	280	0.05	180	0.05	120	0.05	50			0.06	280	rbD]
16	RCS @ 9.0 MPa & T_max 600°C (No manifold C flow)		×		6	0		0.06	350	0.05	180	0.05	120	0.05	50			0.06	350	rbD]
17	RCS @ 9.0 MPa & T_max ≤ 600°C (No manifold A & E flow)		×		6	0.22	580	0.06	350	0		0		0.05	50	-	-	0.22	580	rbD]
18	RCS @ 9.0 MPa & T_max ≤ 900°C (No manifold A & E flow)			×	6	0.22	006	0.06	350	0		0		0.05	50			0.22	006	rbD]
19	Combined RCS & RSS @ 9.0 MPa & T_max ≤ 300°C	×			6	0.25	300	0.11	0.1	6.0	280	0.35	120	0.9	50	-	-	0.25	300	rbD]
20	Combined RCS & RSS @ 9.0 MPa & T_max ≤ 600°C		×		6	0.25	580	0.11	280	6.0	280	0.35	120	0.1	50			0.25	580	rbD]
21	FHSS @ 9.0 MPa, T=280°C (via equalisation line)	×			6			,								0.6	280	•	0	
22	FHSS @ 9.0 MPa, T=280°C (via FHS system)		×		6											0.58	280	•	0	
	Maximum Conditions				6	0.25	006	0.11	350	6.0	280	0.4	200	0.0	50	0.6	280			

Table 2: HTF Thermal-fluid conditions and availability

 Motes

 1
 Temperature massured at manifold C

 1
 Temperature massured at manifold C

 2
 Temperature at mozel or RSS issue-up wessel (NB)

 3
 Manifold D used for conditioning of RSS wessel bution

 4
 Temperature at mozel or RSS issue-up wessel (NB)

 5
 Temperature at mozel or RSS issue-up wessel (NB)

 6
 Temperature at mozel or RSS issue-up wessel (NB)

 6
 Temperature at mozel or RSS issue-up wessel (NB)

 7
 Temperature at mozel or RSS issue-up wessel (NB)

 8
 Bring perpendure at oncore RSS (Is be achiveed with header H1, H2 and H5 or Repring perpendure above 550 (Is be achiveed with HE)

1.1.3 Proposed Modification to HTF

The HTF currently has an empty laboratory with development potential. This laboratory is intended to be a versatile facility for testing of PBMR components in a high pressure high-temperature helium environment. The provided conditions in the laboratory are determined from the main loop capabilities. The conditions that could be available from the main loop consist of three lines (A, C and F) as indicated in Figure 3. The same laboratory could also be utilized for a complete separate CTF loop, which uses the existing auxiliaries (HICBS & HPS) as well as added benefits from existing know-how. A typical arrangement of these two loops is indicated in Figure 3.



Figure 3: Proposed HTF lab configuration

The auxiliaries (HICBS & HPS) would be available for a new CTF loop. The proposed loop will consist of a blower with ± 1 kg/s capability at 9 MPa. A similar blower is currently used by the HTF and can be ordered from HOWDEN. The loop will be able to test a number of the DDNs under the requirement achievable with this blower capacity.

Appendix B - SA PBMR Facilities-FINAL.doc

1.1.4 HTF Summary

Although Figure 1 shows the HTF as being available, this must not be misunderstood as being available for the CTF testing. This merely indicates availability for PBMR DPP testing. The HTF was purpose-built to address specific needs for the PBMR Demonstration Power Plant (DPP), as can be seen from the design and complex PFD of the HTF. The plant, as it is functioning currently, could not be used as the CTF and modifications/extensions of the existing facility would be needed.

The HTF infrastructure, human capital and knowledge make this a very attractive facility to use for component testing. The support systems like the HICBS & HPS are already built and functional. The time schedule, however, indicates that it will not be feasible as an option for component testing due to the primary commitments of the facility to the DPP. A timeframe of FY12 is indicated by the HTF team as a possibility, making it too late for the CTF time schedule requirements.

1.2 PEBBLE BED MICRO MODEL (PBMM)

1.2.1 Background

The purpose of the Pebble Bed Micro Model (PBMM) was to demonstrate the concept and controllability of the PBMR three-shaft recuperated closed Brayton Cycle. The PBMM was also utilized to demonstrate the Flownex computer code's ability to accurately predict the dynamic behavior of the system.

The first phase of the PBMM project was to prove the feasibility of a three-shaft recuperative Brayton cycle. The next phase in the PBMM project was to gather experimental data for the verification and validation (V&V) of Flownex. During this phase, all instrumentation was calibrated to traceable standards to ensure reliable experimental data.

The Pebble Bed Micro Model (PBMM) is a fully functional model of the earlier three-shaft Power Conversion Unit (PCU) of the Pebble Bed Modular Reactor (PBMR), a predecessor of that currently under development in South Africa. Flownex was used extensively in the design of the PBMM and the prediction of its performance.

The PBMM is based on the Brayton power cycle (as used in aircraft engines) but with the following distinguishing features:

- It uses nitrogen as the working fluid.
- The gas moves around in a closed circuit, which implies that no nitrogen is consumed in the power generation process it merely acts as an energy carrier.
- The PBMM uses single stage centrifugal compressors and turbines. It makes use of three separate shafts, one for the high-pressure (HP) compressor/turbine pair, one for the low pressure (LP) compressor/turbine pair and one for the power turbine (PT) and generator. This allows the HP and LP compressor/turbine pairs to run at high speeds thereby reducing the size and therefore also the cost of the machines.
- It makes use of a recuperator to recover heat that would otherwise have been rejected to atmosphere. The recovered heat is transferred elsewhere in the system thereby reducing the heat required from the heat source and ultimately increasing the thermal efficiency of the plant.
- The generator is emulated by a load compressor connected to a power dissipation loop consisting of a flow control valve and a heat exchanger. Variations in load are effected by increasing or decreasing the pressure level in the load rejection loop.



Figure 4 : Solid model of PBMM



Figure 5 : Photo of PBMM

1.2.2 PBMM Envelope

Variable	Unit	Min	Max
	MPa		
System Pressure	(abs)	0	0.9
System Mass Flow			
Rate	kg/s	0	2
System Heater Power	kW	0	350
Heater Temperature	С	0	700
Fluid			Nitrogen

Table 3 : PBMM Envelope

1.2.3 Proposed Modifications to PBMM

Extensive modifications are needed to change the current facility for use as a component test facility or laboratory. The major changes will include a blower, pipe work, new control systems and instrumentation. The use of Helium in the facility has to be further investigated as sealing of the vessel will be of concern.

1.2.4 PBMM Summary

The PBMM successfully completed all the tests specified, and the facility is still fully operational and immediately available. Localized temperatures of 700 degree C at a pressure of 0.9 MPa at a maximum flow rate of 2 kg/s can be achieved. The system was design with Nitrogen as the working fluid. The PBMM is not an ASME accredited facility and extensive changes/modification are needed to address the DDN requirements. The PBMM is not well suited for addressing the CTF mission needs.

1.3 HEAT TRANSFER TEST FACILITY (HTTF)

The Heat Transfer Test Facility (HTTF) consists of two clearly distinguishable test units, namely the High Temperature Test Unit (HTTU) and the High Pressure Test Unit (HPTU). The purpose of the facility is twofold namely:

- To validate the correlations that are currently used to model the relevant heat transfer and fluid flow phenomena required for the integrated simulation of the pebble bed core, via a comprehensive set of separate effects tests.
- To generate results that may be used to validate the different simulation methodologies applied in the integrated models that represent the entire pebble bed core, via a comprehensive set of integrated effects tests.

1.3.1 High Temperature Test Unit (HTTU)

The HTTU is an integrated effects test facility that represents a section of the pebble bed reactor. The HTTU pebble annulus is the same width and geometrically similar to the actual PBMR and it will be used to measure the heat transfer characteristics of the pebble bed as a whole. Some of the tests that will be conducted with the HTTU will be used to validate correlations currently employed by PBMR for the determination of the pebble-to-pebble effective conductivity, pebble-to-reflector conductivity and temperature profiles through the core for different gas flow rates. These tests include steady-state and transient experiments with nitrogen and helium under different conditions. The high temperature pebble bed core or test section forms the heart of the HTTU plant. The test section contains about 28,000 graphite spheres of similar size to those of the PBMR fuel spheres.

1.3.1.1 Background

The HTTU will contribute to both of the objectives listed above since it will be used for the following:

- Steady-state separate effects tests under near-vacuum conditions to validate the correlations used for the pebble-to-pebble effective conductivity, as well as the pebble-to-reflector effective conductivity.
- Steady-state integrated effects tests under natural convection conditions at elevated temperatures to determine the temperature profiles through the core.
- Steady-state integrated effects tests under forced convection isothermal conditions to determine the velocity profiles through the core for different flow rates.
- Steady-state integrated effects tests under forced convection conditions at elevated temperatures to determine the temperature profiles and pressure drops through the core for different flow rates.
- Transient integrated effects tests under near-vacuum conditions at elevated temperatures in order to determine the temperature profiles and the thermal energy storage characteristics of the core.

- Transient integrated effects tests under natural convection conditions at elevated temperatures in order to determine the temperature profiles and the thermal energy storage characteristics of the core.
- Transient integrated effects tests under forced convection conditions at elevated temperatures in order to determine the temperature profiles and the thermal energy storage characteristics of the core for different flow rates.



Figure 6 : High Temperature Test Unit (HTTU) process flow diagram (PFD)



Figure 7: View of the HTTU near the end of construction



Figure 8 : View of the HTTU after construction (one of four blower vessels in the foreground)

The HTTU plant consists of one main vessel section with an adjoining gas pipe network that can be configured to obtain different test results. These configurations are the Vacuum/Natural Convection-, Forced Convection- and Velocity profile measurement configuration. Figure 9 below illustrates two of the three configurations.



Figure 9: The HTTU in Vacuum/Natural Convection configuration (Left) and Forced Flow configuration (Right).



Figure 10: Gas flow path during the Forced Flow configuration

1.3.1.2 HTTU Steady-State Tests

Steady-State Tests Natural Convection High Temperature

Experiment 1: Nitrogen at 1200°C

This experiment will be a steady-state integrated effects test with Nitrogen under natural convection conditions at elevated temperatures.

The test pressure will be 100kPa with the inner wall temperature maintained at 1200°C. The inlet water temperature of the water jacket will be maintained at 25° C and the outlet 35° C. The top and bottom boundaries will be insulated.

Experiment 2: Helium at 1200°C

This experiment will be a steady-state integrated effects test with Helium under natural convection conditions at elevated temperatures.

The test pressure will be 100kPa with the inner wall temperature maintained at 1200°C. The inlet water temperature of the water jacket will be maintained at 25°C and the outlet 35°C. The top and bottom boundaries will be insulated.

Steady-State Tests Forced Convection Isothermal

Experiment 3: Nitrogen 0.5 kg/s isothermal

This experiment will be a steady-state integrated effects test with Nitrogen forced convection isothermal conditions to determine the velocity profile through the core.

The gas pressure at the inlet of the core will be maintained at 100kPa and the inlet temperature at 40° C. The flow rate will be 0.5 kg/s.

Experiment 4: Nitrogen 1 kg/s isothermal

This experiment will be a steady-state integrated effects test with Nitrogen forced convection isothermal conditions to determine the velocity profile through the core.

The gas pressure at the inlet of the core will be maintained at 100kPa and the inlet temperature at 40°C. The flow rate will be 1 kg/s.

Experiment 5: Nitrogen 2 kg/s isothermal

This experiment will be a steady-state integrated effects test with Nitrogen forced convection isothermal conditions to determine the velocity profile through the core.

The gas pressure at the inlet of the core will be maintained at 100kPa and the inlet temperature at 40° C. The flow rate will be 2 kg/s.

Experiment 6: Nitrogen 3 kg/s isothermal

This experiment will be a steady-state integrated effects test with Nitrogen forced convection isothermal conditions to determine the velocity profile through the core.

The gas pressure at the inlet of the core will be maintained at 100kPa and the inlet temperature at 40° C. The flow rate will be 3 kg/s.

Experiment 7: Nitrogen 4 kg/s isothermal

This experiment will be a steady-state integrated effects test with Nitrogen forced convection isothermal conditions to determine the velocity profile through the core.

The gas pressure at the inlet of the core will be maintained at 100kPa and the inlet temperature at 40° C. The flow rate will be 4 kg/s.

Appendix B - SA PBMR Facilities-FINAL.doc

Steady-State Tests Forced Convection High Temperature

Experiment 8: Nitrogen 0.5 kg/s at 1200°C

This experiment will be a steady-state effects test with Nitrogen under forced convection conditions at elevated temperatures to determine the temperature profile and pressure drop through the core.

The gas pressure at the inlet of the core will be maintained at 100kPa and the inlet temperature at 40°C. The flow rate will be 0.5 kg/s. The inner wall temperature will be maintained at 1200°C. The inlet water temperature of the water jacket will be maintained at 25°C and the outlet temperature at 35° C.

Experiment 9: Nitrogen 1kg/s at 1200°C

This experiment will be a steady-state effects test with Nitrogen under forced convection conditions at elevated temperatures to determine the temperature profile and pressure drop through the core.

The gas pressure at the inlet of the core will be maintained at 100kPa and the inlet temperature at 40°C. The flow rate will be1 kg/s. The inner wall temperature will be maintained at 1200°C. The inlet water temperature of the water jacket will be maintained at 25°C and the outlet temperature at 35° C.

Experiment 10: Nitrogen 2 kg/s at 1200°C

This experiment will be a steady-state effects test with Nitrogen under forced convection conditions at elevated temperatures to determine the temperature profile and pressure drop through the core.

The gas pressure at the inlet of the core will be maintained at 100kPa and the inlet temperature at 40°C. The flow rate will be 2 kg/s. The inner wall temperature will be maintained at 1200°C. The inlet water temperature of the water jacket will be maintained at 25°C and the outlet temperature at 35° C.

Experiment 11: Nitrogen 3 kg/s at 1200°C

This experiment will be a steady-state effects test with Nitrogen under forced convection conditions at elevated temperatures to determine the temperature profile and pressure drop through the core.

The gas pressure at the inlet of the core will be maintained at 100kPa and the inlet temperature at 40°C. The flow rate will be 3 kg/s. The inner wall temperature will be maintained at 1200°C. The inlet water temperature of the water jacket will be maintained at 25°C and the outlet temperature at 35° C.

Experiment 12: Nitrogen 4 kg/s at 1200°C

This experiment will be a steady-state effects test with Nitrogen under forced convection conditions at elevated temperatures to determine the temperature profile and pressure drop through the core.

The gas pressure at the inlet of the core will be maintained at 100kPa and the inlet temperature at 40°C. The flow rate will be 4 kg/s. The inner wall temperature will be maintained at 1200°C. The inlet water temperature of the water jacket will be maintained at 25°C and the outlet temperature at 35° C.

1.3.1.3 HTTU Envelope

The following table indicates the test plans for the HTTU for the next two years. The current planning indicates that the tests specified for the HTTU will be completed by the end of 2009.

Experiment	Pressure [kPa (abs)]	Mass Flow Rate [kɑ/s]	Temperature [°C]	Fluid []	Completion date
Steady-state test - near vacuum - high temperature	10	0	1600	Nitrogen	Nov '09
Steady-state test – natural convection - high temperature	100	0	1200	Nitrogen	Nov '09
Steady-state Test – Forced convection – isothermal	100	0.5	40	Nitrogen	Nov '09
Steady-state Test – Forced Convection – high temperature	100	0.5	1200	Nitrogen	Nov '09
Transient Test – near vacuum – high temperature	10	0	1200 to 1600	Nitrogen	Nov '09
Transient test – natural convection – high temperature	100	0	1000 to 1600	Helium	Nov '09
Transient test – forced convection – high temperature	100	0.5	1200	Nitrogen	Nov '09

Tahle	4 · F		Fyn	erime	ntal	Test	Plan
able	4.1	1110	LAP	CINIC	inai	rest	гап

Table 5 : HTTU Envelope

Variable	Unit	Min	Max
	kPa		
System Pressure	(abs)	10	100
System Mass Flow Rate - Nitrogen	kg/s	0	0.5
System Heater Power	kW	0	500
Heater Temperature	°C	0	1600
Heat Exchanger Power	kW	0	157
Fluid		Helium &	& Nitrogen

1.3.1.4 **Proposed Modifications to HTTU**

The HTTU has both helium and nitrogen inventory systems, but no control and purification of these systems. High temperatures can be reached but extensive modifications are needed to address the requirement for component testing. The HTTU can for example be used as a specialized laboratory for material testing but the current test schedule makes this only possible in 2010.

1.3.1.5 HTTU Summary

The HTTU is fully commissioned and operational. The proposed test schedule indicates that the plant will be available in 2010 for other work. The HTTU heater consists of a graphite core structure and has been designed to deliver 1600°C helium and nitrogen that can be used as a fluid within the main heater chamber. The system can be operated under 10 kPa (abs) vacuum conditioning. A forced flow of 0.5 kg/s can be reached at a core temperature of 1200°C. The HTTU is not an ASME accredited facility, but was designed to ASME specifications.

1.3.2 High Pressure Test Unit (HPTU)

The HPTU operates at a system pressure of 50 bar and a temperature of 75°C, using nitrogen as the working fluid. As mentioned earlier, the HPTU consists of a number of test sections, each evaluating different parameters and reactor phenomena.

The aim of the HPTU is to validate the correlations that are used for different heat transfer and fluid flow phenomena through comprehensive Separate Effects Tests (SET), and to validate the different simulation methodologies used in the integrated models through comprehensive Integrated Effects Tests (IET). It should be noted that the HPTU is not an exact scale model of the actual reactor core or any other reactor structures. It is merely an assortment of representative sections of a pebble bed core, suitable for conducting SET and IET.

Construction on the HPTU started in September 2005 and operation commenced a year later, in September 2006.

Due to the shape, distribution and material properties of the pebbles, various thermal fluid phenomena exist inside the reactor. The HPTU attempts to validate correlations that are used in the modeling of the following phenomena:



Figure 11: The thermal-fluid phenomena that the HPTU attempts to validate: A) Average porosity distribution, B) Pebble-to-pebble effective conductivity, C) Pebbleto-reflector effective conductivity, D) Velocity distribution, E) Fluid effective conductivity (braiding effect), F) Pebble-to-fluid convective heat transfer and G) Reflector-to-fluid convective heat transfer

1.3.2.1 Background

The HPTU will contribute to both of the objectives listed above since it will be used for the following:

- Steady-state separate effects tests to validate the correlations used for the pebble-to-fluid heat transfer coefficient at different porosities.
- Steady-state separate effects tests to validate the correlations used for the reflector surface-to-fluid heat transfer coefficient.
- Steady-state separate effects tests to determine the total pressure drop through a homogeneous packed bed at different porosities.
- Steady-state separate effects tests to determine the effective fluid heat conduction due to turbulent mixing at different porosities.
- Steady-state integrated effects tests to determine the total pressure drop through an annular packed bed.
- Steady-state integrated effects tests to determine the effective fluid heat conduction due to turbulent mixing in an annular packed bed.
- Steady-state integrated effects tests to determine the velocity profile at the outlet of the annular packed bed.
- Steady-state integrated effects tests to determine the total pressure drop through a cylindrical packed bed.
- Steady-state integrated effects tests to determine the effective fluid heat conduction due to turbulent mixing in a cylindrical packed bed.
- Steady-state integrated effects tests to determine the velocity profile at the outlet of the cylindrical packed bed.



Figure 12 : HPTU PFD



Figure 13 : Photo of HPTU

1.3.2.2 HPTU Tests

Pressure Drop Test Section (PDTS)

The PDTS will be used to evaluate steady-state separate effects tests to validate the correlations used for the pressure drop at different porosities. There will be 3 different PDTSs to provide for the 3 different porosities required. The geometry of the PDTS has a square cross section with the basic dimensions of 300mm x 300mm x 720mm. This test section will consist of spheres with a diameter of 28.575mm. The pressure drop will be measured by means of an array of differential pressure transducers on the outside of the pressure vessel. The pressure drop will then be determined by means of measurements positioned at the inlet and outlet of the packed bed.



Figure 14: A) A closer look at the pebble bed, which will be used for pressure drop measurements. B) A detail look inside the test section, showing the pebbles, C) Indication of the PDTS layout.

Convection Coefficient Test Section (CCTS)

The CCTS will be used to investigate steady-state separate effects to validate the correlations used for the pebble-to-fluid heat transfer coefficient at different porosities. There will be three different CCTS inserts to provide for three different porosities. The CCTSs have a square cross sectional area of 300mm x 300mm and are 720mm long. The length of the porous bed region varies and is dictated by the different porosities.



Figure 15: A) An illustration of the poisoning of the Ball Heater inside pebble bed. B) An exploded view of the Ball Heater and thermocouple, C) Indication of the CCTS layout.

Near Wall Test Section (NWTS)

The NWTS will be used to evaluate steady-state separate effects tests to validate the correlations used for the wall-to-fluid heat transfer coefficient at an average (not homogeneous) porosity. There will be one NWTS to provide for the one porosity required. The NWTS has a rectangular cross section of 300mm x 112 mm and it is 720 mm long. There will only be two rows of spheres to simulate the two walls of the packed bed. The geometry presents a bilaterally symmetric control volume with average porosity of 0.45 in the near wall region. This test section consists of 60 mm diameter spheres. The measurement requirements of the NWTS consist only of the surface temperature of the heated strip. All sides of the rectangular heated strip are isolated, except for the heated surface.



Figure 16: A) Indication of the NWTS layout, B) An indication of the location of heated strip, C) A closer view of the heated strip.

Braiding Effect Test Section (BETS)

The BETS will be used to investigate steady-state separate effects tests to validate the correlation used for the braiding effect at different porosities. There will be 3 different BETS inserts to provide the 3 different porosities. The BETS has a square cross section of 300 mm x 300 mm and is 720 mm long. This section will consist of spheres with diameters of 28.575 mm.



Figure 17: A) Indication of the BETS layout, B) A closer view of the test section, indicating the pebbles

The BETS will be used to measure the temperature distribution in the radial direction at two different axial positions, which will result from the diffusion of the hot gas that is injected into the test section at a specific point.
Small Annular and Small Cylindrical Packed Beds (SAPB and SCPB)

The SAPB and SCPB test sections will be used to evaluate certain integrated effects on a complete scaled model of the PBMR core. The geometry of the SAPB represents a radially scaled model of the PBMR core with a length of 30 sphere diameter, while the SCPB has the same outer diameter as the SAPB but with no central column. Both the SAPB and SCPB will make use of 6 mm diameter spheres. The total number of spheres needed is determined by the SCPB and amounts to approximately 110,000. The measurements that will be taken consist of the temperature and velocity profile at the exit of the test section as well as the pressure drop over the test section.



Figure 18: A) Indication of the BETS layout, B) A closer view of the test section, indicating the pebbles

1.3.2.3 HPTU Envelope

				Completion
Variable	Unit	Min	Max	date
System Pressure	kPa	100	5000	Jan '08
System Mass Flow Rate	kg/s	0.01117	2.888	Jan '08
Braiding Mass Flow Rate	kg/s	0.001532	0.12480	Jan '08
System Heater Power	kW	0.03491	9.668	Jan '08
Braiding Heater Power	kW	0.127	5.481	Jan '08
Heat Exchanger Power	kW	0.04507	0.04507	Jan '08

Table 6 : HPTU Envelope

1.3.2.4 Proposed Modifications to HPTU

Extensive modifications (localized heating and cooling) are required to reach high temperatures (T>900 °C) and that at only 50 bar.

1.3.2.5 HPTU Summary

The HPTU is fully operational and at the end of its testing phase. The test for the PBMR will be completed at the end of Jan 2008. The plant was designed to function at a pressure of 5 MPa (50 Bar) at a temperature of 35 °C. A maximum mass flow rate of 2.8 kg/s can be reached with the orbital blowers. The HPTU is not an ASME accredited facility, but was designed according to it. It will not be feasible to use this facility for component testing.

APPENDIX C - LITERATURE STUDY ON OTHER FACILITIES

1. INTRODUCTION

A hydrogen economy is proposed to solve the ill effects of using hydrocarbon fuels in transportation, and other so-called, stationary end-use applications where the carbon is released to the atmosphere. Some references propose a closed synthetic hydrocarbon-CO₂ cycle instead of the hydrogen-water cycle to eliminate difficulties related to the production, transport and use of hydrogen [Bossel 2003].

In the current hydrocarbon economy, the transportation of people and goods (so-called *mobile applications*) is fueled primarily by petroleum, refined into gasoline and diesel, and natural gas. However, the burning of these hydrocarbon fuels causes the emission of greenhouse gases and other pollutants. Furthermore, the supply of hydrocarbon resources in the world is limited, and the demand for hydrocarbon fuels is increasing, particularly in China, India and other developing countries.

2. NGNP PROJECT

Since 2005 South Africa has been actively involved with the pre-conceptual design of the DOE funded Next Generation Nuclear Power Plant (NGNP) Project. This project is considered to form part of the GENERATION IV initiative aimed at identifying a reactor system for producing electricity and hydrogen, which excelled at meeting the GENERATION IV goals related to safety, sustainability, proliferation resistance, physical security, and economics.

3. COMPONENT TEST FACILITY

All methods of hydrogen production, apart from the photolytic methods of synthesis, can in principle be coupled to a nuclear reactor to provide electricity and process heat. Conventional light-water reactors (LWR) can be employed for example, to deliver electricity for the low temperature electrolysis process; electricity and hydrogen production are separated effectively and could even be deployed at different locations. Different reactor types with higher coolant outlet temperatures would allow the direct utilization of the hot medium which transfers heat to a chemical process. In such cases, the H₂ production site must be in close proximity of the nuclear site. Mutual utilization of the basic reactor design for electricity and process heat generation was a fundamental requirement in the former German HTGR industrial development programs. This applied specifically to the past projects on direct gas turbine cycles (HHT), steam cycles (THTR-300, HTR-500) and the various nuclear process heat projects, PNP (Prototype nuclear process heat) and NFE (Nuclear long distance energy).

A fundamental difference between the electricity and the process heat market is the power size distribution of the energy supply system. Large plants have been favoured for dedicated electricity generation, whereas the non-electric energy market favours small and medium-sized Combined Heat and Power (CHP) plants due to the limited size of heat distribution networks and

due to very high availability requirements requiring redundant, modular power supply systems. Different CHP applications clearly indicate that the power size of a 200-300 MWt modular design would well fit the needs of industrial heat consumers whereas the 600 MWt GT-MHR already represents an upper limit. A modular arrangement (2-6 units) will be necessary for redundancy, reliability and reserve capacity, which again requires a smaller power size per module. However, smaller power size allows for simplicity and robustness by higher safety margins even at higher operational temperatures if necessary at all.

Nuclear reactor and hydrogen plant will be physically separated from each other by employing an intermediate heat exchanger (IHX) between the primary helium circuit of the reactor and the steam reformer/steam generator system. All applications with IHX require helium outlet temperatures from the reactor to be 900°C or higher to realize a compact IHX component with a larger temperature difference across the IHX. The design of a plant with 850°C coolant outlet temperature and IHX is also feasible, but at the expense of a much larger heat transfer surface.

As part of the ongoing NGNP work MTECH is tasked to perform a first order cost estimation of a component loop test facility. Based on the specifications provided by INEL of the various participants the loop facility at hand is conceptually designed for purposes of the costing. Due to past experience of especially the Germans in the field of high temperature reactor technology it is deemed sensible to summarize the component and loop test facilities operated in Germany. Facilities of note constructed and operated elsewhere are also listed in what follows.

4. LIST OF COMPONENT AND LOOP TEST FACILITIES

4.1 DEVELOPMENT AND TESTING OF AN IHX IN GERMANY

In Germany the concept was investigated of a combination of the HTR-Modul with an IHX. In Figure 1 the layout is represented of the German reference design for a process heat HTR-Modul in a side by side arrangement of nuclear reactor and IHX vessel for each modular unit. The thermal power rating of the nuclear reactor and the IHX are 170 MW. The power limit is determined by the requirement of inherent decay heat removal capability in a depressurized loss of forced cooling (DLOFC) event. If larger thermal powers were needed, an annular core would be required. The limit in that case is caused by the dimensions and type of reactor pressure vessel. Details of the IHX with helical tube bundle are shown in Figure 2.

The employment of an IHX was also suggested within the PNP project with regard to the steam gasification of hard coal, for which the main characteristic data are also given in the table for comparison.



Figure 1: Arrangement of HTR-Module (a) with Helix-IHX (b) or U-tube-IHX (c) [IA 1983]



Figure 2: Intermediate heat exchanger for nuclear applications [Kugeler 2005] - helical tube bundle (left), details of hot gas collector tube and support structures (right).

The Helical coil IHX (see Figure 2) consists of a bundle of helical tubes arranged around a central return gas duct for the hot secondary helium. The support system for the tubes consists of support cylinders with star-shaped, welded-on support plates designed to carry the weight of the bundle. A segmental design of the support structure limits the relative axial expansion caused by the operation temperature. In the upper cold area, the mechanical loads are carried by the vessel cover. This ensures access to the secondary system for in-service inspection and repairs without the necessity to open the primary circuit.



Figure 3: Flow sheet of 10 MW KVK facility for testing nuclear process heat components

A facility for large component testing (KVK) was constructed and successfully operated by INTERATOM as part of the PNP project [Harth 1990]. In a heating system consisting of a heater with steam, a natural gas burner, and an electrical heater with a total thermal power of 10 MW, helium was heated up to 950°C at 4.0 MPa (Figure 3 and Figure 4). This plant also allowed for testing of the hot gas ducts with large diameter, of a steam generator, valves for hot helium and other components like hot headers or auxiliary plants, such as gas purification.



Figure 4: 10 MW KVK facility for testing nuclear process heat components.

Two IHX components were constructed and tested in the KVK loop, one with a helical tube bundle and another one with U-tubes. In Figure 5 the schematics are shown of both components. In Figure 6 and Figure 7 the IHX components are depicted still under construction.



Figure 5: Two IHX components tested in KVK - Helical tube bundle by Steinmüller company (left), U-tube bundle by Balcke-Dürr company (right)



Figure 6: IHX component with helical tube bundle tested in KVK (Steinmüller)



Figure 7: INX Component with U-tube bundle tested in KVK (Balcke-Dűrr)

4.2 TESTING OF THE JAPANESE IHX IN THE HTTR

The IHX used in the HTTR is a vertical, helically coiled counter flow type heat exchanger as shown in Figure 8. The primary helium enters the IHX through the inner pipe of the primary concentric hot gas duct attached to the bottom of the IHX. It flows upwards outside the tubes transferring the nuclear heat of 10 MW to the secondary helium cooling system and flows back through the annular space between the inner and outer shells. The secondary helium flows downwards inside the heat transfer tubes and flows upwards in the central hot gas pipe through the hot header.



Figure 8: Schematic and photograph of the He-He intermediate heat exchanger in the HTTR.

A double-walled shell with a thermal insulation attached on the inside surface of the inner shell provides reliable separation of heat resisting and pressure retaining functions. Cold helium flowing through the annulus brings uniform temperature distribution throughout the outer shell, which has a pressure-retaining function.

Insulation inside and outside the central hot gas pipe keeps the heat transfer low to obtain a high efficiency.

4.3 IHX DESIGN CONCEPT FOR THE US H2-MHR

In the United States, the reference design for a next generation HTGR is the 600 MWt Modular Helium Reactor (MHR). For the purpose of hydrogen generation, the concept of an H2-MHR has been developed which is to be coupled to a H2 production technology based on either S-I thermo-chemical cycle or high temperature electrolysis. The intermediate heat exchanger for this facility is based on a design of so-called "Printed Circuit Heat Exchangers", PCHE, developed by the Heatric company (see Figure 9) [NERI 2003, HEATRIC].



Figure 9: Printed Circuit Heat Exchanger, PCHE (source: HEATRIC) A heat exchanger module is composed of metal plate layers containing alternately coolant channels for the primary and for the secondary fluid flowing (e.g.) counter to each other (top right).

The flow channels with a semi-circular profile (top left) are chemically etched into the plates using a technique similar to that for printing electrical circuits. This manufacturing technique makes complex streams possible. The metal plates are stacked (top right) and then diffusionbonded, where the metal surfaces are pressed together promoting a grain growth between the plates, thus becoming a solid all-metal core (bottom left). PCHE designs have been developed which are highly compact, highly robust (bottom right) and which have high thermal efficiencies, allowing pressures of 50 MPa and temperatures of 900°C.

4.4 GERMAN CONCEPTS OF HELIUM-HEATED STEAM REFORMING

In comparison to a conventional steam reformer, the employment of a nuclear steam reformer requires certain changes, since operational conditions of a nuclear reactor are not that flexible as a fossil-fueled furnace. Also safety requirements are much more stringent than for a fossil-fueled system. It is therefore desired to achieve highest effectiveness in utilizing the nuclear process heat in the whole production process system. A large H2 production rate is achieved, if the process feed gas rate and the conversion rate are high. The feed gas rate depends on the amount of heat input into process gas and the temperature of process gas. The conversion rate depends on temperature and pressure of the process gas.

A principle flow sheet of an HTGR with steam reformer, where all heat for the reforming process, the steam production, gas purification, and gas compression can be gained from the helium circuit, is shown in Figure 10. The stages of gas purification include the shift conversion, CO₂ scrubber, H₂ separation, and a methanation reaction to remove traces of carbon oxides from the process gas. The typical temperature profiles along a splitting tube are shown in Figure 11.



Figure 10: Principal flow sheet of HTGR with SR [Kugeler 2005] Legend: 1 - HTGR, 2 - steam reformer, 3 - steam generator, 4 - He blower, 5 - preheater gas, 6 - preheater gas, 7 - shift conversion, 8 - CH4 preheater, 9 - CO2 washer, 10 - H2/CH4 separation, 11 - me



Figure 11: T-diagram for use of heat in HTGR with SR [Kugeler 2005].

Nuclear steam reforming of methane was the subject of extensive R&D activities in Germany in the 1970-1980s. Within the NFE (Nuclear Long-Distance Energy Transportation) project, large test facilities were constructed and successfully operated at FZJ to study the steam reforming process and also the reverse process of methanation under nuclear conditions.

Steam reforming was investigated in the EVA single splitting tube test facility, later in EVA-II [Verfondern 2007] representing bundles of reformer tubes. The latter used an electrical heater with a power of 10 MW to heat up helium gas to a temperature of 950°C at 4.0 MPa (see Figure 12, top). In the connected steam reformer, the heat between 950°C and 650°C was used to run the steam reforming process. In the connected steam generator (helical tubes, power 4 MW), the helium heat was used up to 350°C.

Via a helium circulator, the cold helium was routed back to the electrical heater. The circuit was operated under nuclear conditions at a lower power level, but with a full-scale SR component. Also the process gas handling system was the same as in a nuclear plant.

In a methanation plant, ADAM, the product gas was reconverted to methane and steam, thus completing a closed cycle without any CO2 emissions (see Figure 12, bottom). With regard to the power input of 10 MWe, the heat release rate achieved in the ADAM plant was 5.3 MWt. The so-called ADAM & EVA [Verfondern 2007] system represents a long-distance chemical heat transportation system based on hydrogen as the energy carrier.



Figure 12: Flow sheet of steam reforming test facility EVA-II (top) and of combined test facilities EVA-II and ADAM-II (bottom) (source: FZJ).

Two reformer bundles have been tested in the EVA-II facility: a bundle with guiding tubes (annulus design) for each reformer tube (5 MW, 18 tubes) and a bundle with baffle structures (disks and doughnuts) on the helium side (6 MW, 30 tubes). The tubes and catalytic system were 1:1 scale compared to components planned for nuclear applications. Also the loads imposed on the supporting structures were characteristic to the nuclear case. Both have operated without any difficulties for more than 6000 h.

Figure 13 shows the component with guiding tubes tested in EVA-II. Both designs of a steam reformer bundle are shown in Figure 14. The specific data of reformer tubes investigated were very similar to the respective design for nuclear applications.



Figure 13: Steam reformer bundles tested in EVA-II (source: FZJ). (a) Schematic of annulus (left), baffle design (right). (b) Photo of baffle design steam reformer bundle.



Figure 14: Steam reformer bundle of baffle design (top) and annulus design (bottom)

4.5 EVO AND HHV

Oberhausen II [IAEA 1984], operated by the German utility EVO (Energie Versorgung Oberhausen AG), is a 50 MW(e) direct-cycle Helium turbine plant (Figure 15). The power source is a gas burner rather than a nuclear reactor core, but the power conversion system resembles those of the GFR (Gas-cooled Fast Reactor) and other high-temperature reactor concepts. *Oberhausen II* was operated for more than 25 000 hours between 1974 and 1988. Design specifications, drawings and experimental data have been obtained through the European HTR-E project, offering a unique opportunity to validate codes on a large-scale Brayton cycle. Available measurements of temperature, pressure and mass flow rate throughout the circuit have allowed a very comprehensive thermohydraulic description of the plant, in steady-state conditions for design data and operating data as well as during transients.

The HHV has an electrically-driven turbo machinery consisting of a 2-stage turbine and an 8-stage compressor on a single-shaft arrangement with a synchronous rotational speed of 3,000 rpm. Figure 16 shows a picture of the HHV turbine. The compressor requires 90 MW power, the turbine power produces about 46 MW, and the electric motor supplies 45 MW. The mass flow rate is about 200 kg/s.

During the initial operation, oil ingress and excessive helium leakage occurred. After the problems were corrected, the HHV [IAEA 1984] test plant was successfully operated for about 1,100 hours, and the measured results showed that the helium gas turbine had a higher efficiency than the design value. They found that creep and fatigue crack growth at high temperature with impurities such as carbon in the helium coolant comprises the main mechanism limiting the lifetime of the turbine blades and disks. Also, it was estimated that the lifetimes of uncooled turbine components are around 50,000-60,000 hours and that the maximum temperature with uncooled metallic blades and disks is 850°C.



Figure 15: High-pressure Turbine Rotor from EVO in Germany.



Figure 16: Rotor from HHV in Germany

References

- 1. Bossel U., Eliasson B., Energy and the Hydrogen Economy, 8 January 2003.
- 2. IA, Nukleare Prozesswärmeanlagen mit Hochtemperaturreaktor-Modul zur Kohleveredlung, Technical Report ITB 78.10122.8, Kraftwerk Union AG, INTERATOM/GHT (1983).
- 3. Kugeler K., et.al., Technical and Safety Aspects of Processes of Hydrogen Production Using Nuclear Energy, Int. Congress on Advances in Nuclear Power Plants ICAPP 05, May 15-19, 2005, Seoul, Korea, Paper 5729.
- 4. B Harth R., et.al., Experience Gained from the EVA II and KVK Operation, Nucl. Eng. Des. 121 (1990) 173-182.
- 5. NERI, Nuclear Energy Research Initiative, Annual Report, General Atomics, San Diego, USA (2003).
- 6. IAEA Specialists Meeting on Heat Exchanging Components of Gas-Cooled Reactors, R. Harth, H. F. Niessen, V. Vau & R. Merken, Düsseldorf, 16 19 April 1984.
- 7. Nuclear Energy for Hydrogen Production, Karl Verfondern (Ed), FZJ Report, 2007.
- 8. PBMR, (http://www.pbmr.co.za).
- 9. JJ van der Merwe, R Bollen, JP van Ravenswaay, VALIDATION AND VERIFICATION OF FLOWNEX NUCLEAR, Proceedings HTR2006: 3rd International Topical Meeting on High Temperature Reactor Technology October 1-4, 2006, Johannesburg, South Africa.
- 10. HEATRIC, (http://www.heatric.com/compact_heat_exchangers.html).

APPENDIX D CONCEPT 1 DETAILS

1.1 TEST CONFIGURATIONS

In order to provide a recommendation with regards to facility enveloping sizes, a number of different test configurations were imposed on Concept 1. These test configurations are summarized in Table 1, and were each evaluated in terms of energy balances. A complete summary of these energy balances, together with general considerations per test configuration can be found in at the end of this appendix. The "TEST#" column in Table 1 corresponds with the "DOCUMENT NUMBER" on the energy balance sheet.

Test #	Main Test Configuration	Sub Test	TDL #
IHX-W_1	IHX Performance verification tests: WEC	Steady state	TDL 1
	Core A		
	 Test core size of 1.34 MW 		
	 Prescribed mass flow 		
	Defined inlet and outlet temperatures		
IHX-W_2	IHX Performance verification tests: WEC	Steady state	TDL 1
	Core B		
	Test core size of 2 MW		
	Prescribed mass flow		
	Defined inlet and outlet temperatures		
IHX-W_3	IHX Performance verification tests: WEC	Loss of	TDL 1
	Core A	secondary	
	No heat transfer to secondary loop	side pressure	
	Primary side to accommodate high	& IIOW	
	lemperature in recuperator		
	Resulting in large duty recuperator	1	
IHX-W_4	Core P	LOSS Of	TULT
	No heat transfer to secondary loop	side pressure	
	Romeat transfer to secondary toop Primary side to accommodate high	& flow	
	temperature in recuperator		
	Resulting in large duty recuperator		
IHX-G 1	IHX Performance verification tests: GA	Steady state	
	(Maximum test core size)	oloudy blato	
	Determining possible test core size		
	(small) from known conditions		
	 Mass flow (same as for WEC) 		
	 Test core temperatures from PCDR 		
	 Resulting test core: 2.14 MW 		
	Test core size to evaluated for		
	feasibility		
	 Large duty on recuperator 		
IHX-G_2	IHX Performance verification tests: GA	Steady state	CQL
	(Maximum qualification core size)		
	Determining possible qualification		
	core size (large) from known		

Table 1: Summary of Test Configurations in Concept 1 as Dictated by the DDNs

conditions

Test #	Main Test Configuration	Sub Test	TDL #
	 Mass flow (High value per TDL) Qualification core temperatures from PCDR Resulting qualification core: ~10 MW Qualification core size to evaluated for feasibility 		
IHX-A_1	 IHX Performance verification tests: AREVA (Maximum test core size) Determining possible test core size (small) from known conditions. Secondary side to be tested with He-N₂. Calculation based on He only. Mass flow (same as for WEC) Test core temperatures from PCDR Resulting test core: ~2.45 MW Test core size to be evaluated for feasibility 	Steady state	TDL 2
IHX-A_2	 IHX Performance verification tests: AREVA (Maximum qualification core size) Use all three TDL mass flow & duty capabilities Three TDLs determine maximum representative core size which can be tested Resulting test core: ~11 MW Maximum required Recuperator size: : ~7 8 MW 	Steady state	CQL
MIX-W_1	 Mixing chamber performance verification: WEC Prescribed Mixing Chamber test temperatures Prescribed mass flow Minimum heater flow rate 	Steady state	TDL 1
DIV-W_1	 High temperature ducts & insulation performance verification test: WEC (small scale) Prescribed test temperature: 950°C Determine maximum heater outlet temperature TDL to accommodate high temperature in recuperator 	Steady state	TDL 3
DIV-W_2	 High temperature ducts & insulation performance verification test: WEC (large scale) Use all three TDL mass flow & duty capabilities Three TDLs determine maximum representative mass flow and duty available Maximum return header temperature 	Steady state	CQL
SG-W_1	Steam generator performance verification test: WEC	Steady state	CQL

Test #	Main Test Configuration	Sub Test	TDL #
CIR-W	 Circulator performance: WEC Circulator requirements from WEC Determine maximum flow rate in loop Determine pipe size & flow velocity 	Steady state	Circulator loop
CIR-G	 Circulator performance: GA Circulator requirements from GA Determine maximum temperature in loop Determine maximum cooler temperature Determine minimum operating envelope for mass flow and heat duty of cooler Determine loop materials & insulation requirements 	Steady state	Circulator loop
CIR-A	 Circulator performance: AREVA Circulator requirements from WEC Determine maximum flow rate in loop Determine pipe size & flow velocity 	Steady state	Circulator loop

The enveloping values for each TDL will be presented in the following sections from these test configurations and the energy balances.

1.2 TECHNOLOGY DEVELOPMENT LOOP 1

This loop consists of both a primary and a secondary loop, and its main sizing requirements are based on the IHX test core requirements as from the Westinghouse consortium. Both the primary and secondary loops are sized with only helium. In addition to IHX testing, this small loop also provides for testing of various components in dedicated fully instrumented test vessels in both the primary and secondary loop for temperatures up to 950°C. It is also envisaged that TDL1 will provide connection flanges for future testing of varying secondary loop contents such as liquid salt configurations for hydrogen production. This capability is provided in the form of extra connection points to the primary circuit test vessel. Additional capabilities of this loop also include testing of mixing chambers, by means of additional piping to the test station vessel in the primary circuit.



1.2.1 Technology Development Loop 1 – Primary Side

The primary side of TDL 1 consists of a heat source (H1.1), connected in such a way to either provide the hot helium to a test station vessel (TS1.1) or the dedicated IHX testing vessels. It is anticipated that the line to the IHX test vessel (IHX1.1) will have some kind of dust generator (DG1.1) for performance testing under controlled impurities levels followed by a filtration unit (FS1.1) after the IHX. From here on the hot helium is recuperated (RX1.1) in order to provide a more energy efficient configuration. At the outlet of the recuperator, the gas is cooled (CL1.1) by an appropriate cooler (depending in the temperature) to a conservative low temperature at the circulator (C1.1) inlet. The recuperator outlet is again connected to the heater inlet, while an additional line to the test station vessel is provided for mixing chamber testing. The secondary side is connected via the IHX test core inside the IHX testing vessel. Figure 1 illustrates this layout while the enveloping values are displayed in Table 2.



Figure 1: Technology Development Loop 1: Primary Side

	TDL 1 – Primary side							
No.	Components	Power [MW]	Mass flow rate [kg/s] - MAX	T_in [°C]	T_out [°C]	Pressure	Fluid	
C 1.1	Circulator (ΔP: 500 kPa @ 5 MPa)	0.2 [max]	2	80 ⁻ [min]	-			
RX 1.1	Recuperator (Hot side)	6 3 [max]	1.75	950 [max]	260 [max]			
RX 1.1	Recuperator (Cold side)	0.5 [max]	1.75	~ 85 [max]	776 [max]			
H 1.1	Heater	4.0	1.75	776 [max]	950 [max]		_	
TS 1.1	Vessel - Test Station	N/A	1.75	950 [min]	950 [max]	5 – 9 MPa	Pure Helium	
DG 1.1	Dust Generator	N/A	1.15	760	950			
IHX 1.1	Heat exchanger Vessel (primary)	N/A	1.15	950 [max]	950 [max]			
CL 1.1	Cooler	1.6	1.75	260 [max]	80 [nom]			
FS 1.1	Filtration station	N/A	1.15	950 [max]]		
PD 1.1	Pipe & Ducting	N/A	1.75	950 [max]			

T-1.1. 0.	D	V - 1		D_{1}
Table 7	Enveloning	values of the Primar	ν Νίαε ότι εςπηριοσγ	Development Loop L
1 4010 2.	Linveroping	values of the filling	y blue of reenholdsy	Development Loop 1

1.2.2 Technology Development Loop 1 – Secondary Side

The secondary side of TDL 1 is connected to the primary side by means of the IHX test core and is also sized for helium alone. This loop is also envisaged to have a test station vessel for possible expansion while the rest of the loop is very similar to the primary side. The only difference is a mixing valve at the circulator (C1.2) outlet for controlling the IHX inlet temperature. Figure 2 illustrates the layout while the enveloping values are presented thereafter in Table 3.



Figure 2: Technology Development Loop 1: Secondary Side

	TDL 1 – Secondary side							
No.	Components	Power [MW]	Mass flow rate [kg/s] - MAX	T_in [°C]	T_out [°C]	Pressure	Fluid	
C 1.2	Circulator (ΔP: 500 kPa @ 5 MPa)	0.2 [max]	2	80 [min]	-			
RX 1.2	Recuperator (Hot side)	3.7 [max]	1.15	900 [max]	464 [max]			
RX 1.2	Recuperator (Cold side)	5.7 [max]	1.15	~ 85 [max]	756 [max]	5 – 9 MPa	Pure	
TS 1.2	Vessel - Test Station	N/A	1.15	900 [min]	900 [max]		Hellulli	
CL 1.2	Cooler	2.0 [max]	1.15	464 [max]	80 [nom]			
PD 1.2	Pipe & Ducting	N/A	1.15	900 [max]			

 Table 3: Enveloping Values of the Secondary Side of Technology Development Loop 1

1.3 TECHNOLOGY DEVELOPMENT LOOP 2

Technology Development Loop 2 (TDL2) has a similar configuration to that of TDL1, but differs in the fact that it does not provide a number of test station vessels. This loop is mainly proposed for investigation purposes of different fluids (such as He/N_2 mixtures) in the secondary loop, while also allowing for concurrent IHX testing by various vendors. The secondary loop is currently sized with helium, and further investigation is necessary to determine the suitability of one circulator for both helium and He-N₂ mixtures. It is however anticipated that a different circulator would be required for different fluids being tested.

1.3.1 Technology Development Loop 2 – Primary Side

The primary side of TDL 2 is similar to that of TDL 1, except that it does not have an additional test station vessel. Figure 3 illustrates the layout while the enveloping values are presented in Table 4.



Figure 3: Technology Development Loop 2: Primary Side

	TDL 2 – Primary side							
No.	Components	Power [MW]	Mass flow rate [kg/s] - MAX	T_in [°C]	T_out [°C]	Pressure	Fluid	
C 2.1	Circulator (ΔP: 500 kPa @ 5 MPa)	0.2 [max]	2	80 [min]	-			
RX 2.1	Recuperator (Hot side)	6 3 [mov]	1.75	950 [max]	257 [max]			
RX 2.1	Recuperator (Cold side)	0.5 [max]	1.75	~ 85 [max]	776 [max]		Duro	
H 2.1	Heater	4.0	1.75	776 [max]	950 [max]	5 – 9 MPa	Helium	
IHX 2.1	Heat exchanger Vessel (primary)	N/A	1.15	900 [max]	900 [max]			
CL 2.1	Cooler	1.6	1.75	257 [max]	80 [nom]			
PD 2.1	Pipe & Ducting	N/A	1.75	900 [max]			

Table 4:	Enveloping	Values of the	Primarv	Side of ⁻	Technoloav	Development	Loop 2
10010 11	Enteroping			0140 01	i eennelegy	Borolopinone	-00p -

1.3.2 Technology Development Loop # 2 – Secondary Side

It is anticipated that the secondary side of TDL2 will be used with either helium or other fluids under testing, such as $\text{He-N}_2 / \text{CO}_2$ mixtures. Current sizing has been done using helium and further investigation still needs to be performed regarding the suitability of a single circulator. It is however anticipated that different circulators will be utilized with different fluids when tested. Figure 4 illustrates the process while the enveloping values are presented in Table 5.



Figure 4: Technology Development Loop 2: Secondary Side

	TDL 2 – Secondary side							
		_	Mass flow		_			
No.	Components	Power [MW]	rate [kg/s] - MAX	T_in [°C]	T_out	Pressure	Fluid	
C 2.2	Circulator (ΔP: 500 kPa @ 5 MPa)	0.2 [max]	2	80 [min]	-		Sizing	
RX 2.2	Recuperator (Hot side)	2.2 [mov]	1.15	850 [max]	455 [max]		on	
RX 2.2	Recuperator (Cold side)	2.5 [max]	1.15	~ 85 [max]	~ 700 [max]	5 – 9 MPa	Other	
CL 2.2	Cooler	2.2 [max]	1.15	455 [max]	80 [nom]		be	
PD 2.2	Pipe & Ducting	N/A	1.15	850 [max]		lesleu	

Table 5: Enveloping Values of the Secondary Side of Technology Development Loop 2

1.4 TECHNOLOGY DEVELOPMENT LOOP 3

Technology Development Loop 3 (TDL3) again uses the basic building blocks as proposed in TDL 1, but with the sole purpose of providing a test station for non heat transfer components, such as valves, ducting, insulation etc. It also serves the purpose for providing the additional energy input when the three loops are used concurrently and connected together in a common header. Technology Development Loop 3 also addresses the need for a separate facility due to long term test requirements and the possibility of time constraint issues.

1.4.1 Technology Development Loop 3 – Primary Side

The primary loop of TDL 3 is again similar to TDL 1 expect for the fact that it does not have separate vessels for IHX and component testing. It is anticipated that this loop will be used for non-heat transfer testing while the possibility exists for future expansion of commercial testing on the secondary side.

Figure 5 Illustrates this loop with its enveloping values presented thereafter in Table 6.



Figure 5: Technology Development Loop 3: Primary Side

	TDL 3 – Primary side							
No.	Components	Power [MW]	Mass flow rate [kg/s] - MAX	T_in [°C]	T_out [°C]	Pressure	Fluid	
C 3.1	Circulator (ΔP: 500 kPa @ 5 MPa)	0.2 [max]	2	80 [min]	-			
RX 3.1	Recuperator (Hot side)	6 3 [max]	1.75	950 [max]	257 [max]			
RX 3.1	Recuperator (Cold side)	0.5 [max]	1.75	~ 85 [max]	776 [max]		Duro	
H 3.1	Heater	4.0	1.75	776 [max]	950 [max]	5 – 9 MPa	Helium	
TS 3.1	Vessel - Test Station	N/A	1.75	950 [min]	950 [max]			
CL 3.1	Cooler	1.6	1.75	257 [max]	80 [nom]			
PD 3.1	Pipe & Ducting	N/A	1.75	950 [max]			

Table 6: Enveloping Values of the Primary Side of Technology Development Loop 3

1.5 COMPONENT QUALIFICATION LOOP (CQL)

A component qualification loop (CQL) is also proposed as part of Concept 1. This component qualification loop is a larger facility which is required for larger scale component qualification of up to 10 MW, as dictated by certain design data needs. It is anticipated that the primary circuit of the CQL could utilize the heating, cooling and mass flow producing capabilities of the three smaller facilities, while a dedicated secondary loop is added.

Typical tests on this facility include large scale IHX cores of up to 10 MW, duct & insulation testing and fully representative size steam generators.

1.5.1 Component Qualification Loop – Primary Side

The primary side of the CQL is shown in Figure 6, and consists of common inlet and outlet headers, steam generator testing connections (SG 4.1) as well a testing vessel for heat transfer and non heat transfer components (in IHX 4.1). A dedicated steam loop is also provided for complete representative testing of steam generator components. The primary side also incorporates a recuperator (RX 4.1) to reduce the capacity of each heater in the TDLs. A summary of the components and values for the primary side is provided in Table 7.



Figure 6: Large Loop: Primary Side

	CQL – Primary side							
No.	Components	Power [MW]	Mass flow rate [kg/s] - MAX	T_in [°C]	T_out [°C]	Pressure	Fluid	
RX 4.1	Recuperator (Hot side)	7.9 [mov]	5.25	950 [max]	657 [max]			
RX 4.1	Recuperator (Cold side)	7.o [max]	5.25	590 [max]	858 [max]			
IHX 4.1	Heat exchanger Vessel (primary)	N/A	5.25	950 [max]	590 [max]	5 – 9 MPa	Helium	
SG 4.1	Steam generator (testing capability)	11.2 [max]	5.25	900 [max]	272 [nom]			
PD 4.1	Pipe & Ducting	N/A	5.25	950 [max]			

Table 7: Enveloping Values of the Primary Side of CQL

1.5.2 Component Qualification Loop – Secondary Side

The secondary side of the CQL is connected to the primary side by means of the IHX test core (in IHX 4.1) as well the recuperator (RX 4.1). The loop further consists of an additional recuperator (RX 4.2) as well as the normal cooler and circulator arrangement. Figure 7 illustrates the proposed layout with the enveloping values presented thereafter.





CQL – Secondary side							
No.	Components	Power [MW]	Mass flow rate [kg/s] - MAX	T_in [°C]	T_out [°C]	Pressure	Fluid
C 4.2	Circulator (ΔP: 500 kPa @ 5 MPa)	0.6 [max]	6	80 [min]	-		
RX 4.2	Recuperator (Hot side)	12.1 [mov]	5.25	657 [max]	184 [max]		
RX 4.2	Recuperator (Cold side)	13.1 [max]	5.25	~ 85 [max]	565 [max]	5 – 9 MPa	Helium.
CL 4.2	Cooler	2.8 [max]	5.25	184 [max]	80 [nom]		
PD 4.2	Pipe & Ducting	N/A	5.25	925 [max]			

Table 8: Enveloping Values of the Secondary Side of CQL

1.5.3 Full Scale Circulator Loop

A full scale circulator testing loop is also proposed to address full scale testing requirements of different circulator designs. This separate loop is mainly proposed as part of the philosophy of not having 2 or more components under test in a single test configuration. A typical arrangement is shown in Figure 8, with a summary of the main components in Table 9.



Figure 8: Circulator Test Loop
Circulator test loop – Secondary side									
No.	Components	Power [MW]	Mass flow rate [kg/s] - MAX	T_in [°C]	T_out [°C]	Pressure	Fluid		
C 5.1	Circulator: Unit under test	12.4 MWt [max]	159.6 [max]	590 [max]	-				
CL 5.1	Cooler	12.4 [max]	159.6 [max]	590 [max]	272 [min]	5 – 9 MPa	Helium.		
PD 5.1	Pipe & Ducting	N/A	159.6 [max]	590 [max]					

Table 9: Enveloping	Values of the	Circulator	Test Loop

1.6 COMPONENT DESCRIPTIONS

This section provides a general description and recommendations for future work on the different components and sub systems of Concept 1.

1.6.1 Circulators

Circulator – TDL Primary & Secondary side

The circulator unit is used as the primary fluid mover in the process loop. The circulator should therefore be able to overcome the differential pressure demand at the required flow rate set by the individual process components, subsystems and units under test. The main requirement in terms of circulator capacity is usually driven by the units under test. Various options are available in terms of circulator type and design. However, aspects such as Helium leakage to atmosphere and contaminant into the process loop, drive the choice of design and will be discussed in the specific sections below.

• Circulator Process Requirements

The maximum flow rate required for the specified tests in the three TDLs is estimated at 1.75 kg/s. Provision is made for increased flow up to 2.0 kg/s which might be required for surge control by means of a bypass loop across the circulator. The required flow rate is easily obtained by a single stage high speed centrifugal design. A maximum pressure rise of 500 kPa is expected which results in a Pressure Ratio (PR) of 1.056 at an inlet pressure of 9000 kPa. The theoretical temperature rise across the compressor is calculated at 9.8°C with an inlet temperature of 80°C and isentropic efficiency of 80%. The required pumping power is calculated as approximately 200 kW.

• Circulator Drive

To simplify the design of the circulator system and to ensure that the facility's design integrity is one level higher than the units under test, it is recommended that the compressor uses a variable speed 2 pole electric motor and step up gearbox that is not submerged in the working fluid. This also eliminates the use of Active Magnetic Bearings (AMB) and the associated control systems. However, the circulator system should be designed in such a way to allow for later modifications in the event of a requirement for specifically testing AMB.

• Dry Gas Seal System

The compressor impeller is situated within the pressure boundary, with only a shaft penetration though the pressure boundary. The proposed sealing mechanism at this interface would be a dry gas seal. The dry gas seal would cause some leak to atmosphere but is assumed to be acceptable. If calculation shows that the leak is unacceptable, it is still possible to make use of the submerged type drive system.

• Circulator Drive Lubrication

Provision should be made to lubricate the gearbox and associated bearings in the drive system of the compressor. The details of the lubrication system will be addressed at a later stage in the design. It is of utmost importance to specify the allowable concentration of lubricant (if any) in the gas stream during the next phases of design.

• Circulator Vessel

The compressor is housed in its own pressure boundary assembly, with only a shaft penetration. An inlet and outlet nozzle flange is attached to the pressure boundary. The vessel design should allow for future modification of the drive system to a submerged drive system with AMB.

Circulator – CQL Secondary side

The CQL secondary side circulator would follow the same design approach as followed for the TDL circulators. However, the CQL secondary side circulator is required to circulate 5.25 kg/s through the process. Provision is made for increased flow up to 6.0 kg/s which might be required for surge control by means of a bypass loop across the circulator. The required flow rate is obtained by a single stage high speed centrifugal design. A maximum pressure rise of 500 kPa is expected which results in a Pressure Ratio (PR) of 1.056 at an inlet pressure of 9000 kPa. The theoretical temperature rise across the compressor is calculated at 9.8°C with an inlet temperature of 80°C and isentropic efficiency of 80%. The required pumping power is calculated as approximately 600 kW.

1.6.2 Heater Unit – TDL Primary Side

The heater assembly used in the three TDLs is similar in design and constitutes a number of electric resistance heaters that are installed in series. The heater configuration was determined by examining a number of different test configurations which had several requirements. Heating is done by means of electric resistance elements to ease controllability of the power level for different test configurations. The suggested heater should supply a nominal duty of approximately 4MW. The maximum flow rate through the heater is 1.75 kg/s and the maximum outlet temperature is limited to approximately 950°C. The heat loss in the piping to the test vessels and/or hot headers might require that the heater outlet temperature be raised above 1000°C. The effect of thermal losses in the hot pipes should therefore be investigated and a requirement for the maximum heat loss to atmosphere should be specified for the hot pipes.

Heating Elements

Literature suggests that a low heat flux is required to efficiently heat Helium in a high pressure environment. A typical value heat flux of 2.4 W/cm^2 is required which translates to a lower element surface temperature but requires a large equivalent heat transfer surface area. To reduce the temperature rise over the successive heater units placed in series, it is suggested that smaller independent heater units be placed in series in a single pressure vessel. The heating elements located at the inlet of the unit could typically be a lower cost heating element using sheath materials of Incoloy 800, and the heaters at the outlet of the heater unit could be a higher quality

heating element such as the products manufactured by Kanthal. It is recommended that the radiation heat produced by the heating elements be utilized to heat a larger surface area which is in contact with the primary fluid. Provision should also be made to account for thermal expansion between the heating elements placed in series.

Heater Vessel

A vertical vessel is suggested with sufficient room and access openings. It is suggested that the flow be from the bottom to the top to prevent the negative effects of natural convection streams in the heater; however, from a physical layout point of view it is better to have the flow from the top to the bottom. This should be investigated to see whether it would be advantageous to orient the flow from bottom to the top. It is suggested that the vessel is passively cooled by means of internal insulation.

Care should be taken to avoid heat radiation to the pressure boundary and it is advised to install all heaters in radiation shield / boxes, either of high temperature metals or appropriate ceramics. Pressure boundaries should be designed according to standard ASME practices with surface temperatures within acceptable code limits.

Insulation

The insulation material for the heaters will ultimately be determined by the design of the heater unit internals. It is suggested that insulation blanket material be used which can easily be wrapped around the specific geometry of the heater, instead of custom engineered insulation material sections fitted to the inside of the heater. The choice of insulation will therefore be determined at a later stage.

1.6.3 Pressure Boundary

Hot Pipes – (Helium > 550°C)

The suggested method of construction of the hot pipe is a coaxial designed pipe with an exotic high temperature material flow tube liner, incorporating various insulation materials up to the larger diameter pipe pressure boundary. The use of an actively cooled pressure boundary in conjunction with insulation material should still be investigated.

The flow tube sizing was done with the lowest anticipated loop pressure, along with the maximum specified velocity. This should therefore result in lower velocities at elevated pressures. A maximum flow tube diameter of 0.2 m is calculated at a nominal flow rate of 1.75 kg/s and a flow velocity of 30 m/s at 950°C, 5 MPa. If the flow diameter is reduced to 0.16m, using the same process conditions, the flow velocity is increased to approximately 45 m/s.

The pressure boundary dimensions are to be determined once a detail calculation has been done regarding the insulation material. The pressure boundary dimensions are estimated to be approximately 0.6 - 0.8 m if the pressure boundary is not actively cooled. The pressure boundary section should make provision for instrumentation connection points which can be used to monitor the pressure and temperature levels in the hot pipe. The hot pipes should be designed to be pressure balanced across the flow tube and the possibility of isolating these two

sides from each other should be investigated and could assist in the purification processes. A typical section length of 5m is foreseen. The governing philosophy for the hot pipes is to make them as short as possible, have no valves located in them, have no compensators in them but rather compensate in the cold pipes and have minimal bends except when the bends are actually used for compensating purposes.

Cold Pipes – (Helium < 350°C)

The so-called Cold Pipes are the pipes immediately before and after the Circulator units in the three TDLs. Calculations have also shown that the cold pipe temperatures will be well below 350°C. It is recommended that all the cold pipes are manufactured from a type of carbon steel, such as ASME A106 Gr B.

The use of carbon steel would reduce the total cost of the facility but the risk of corrosion of the piping in periods when the facility is open for maintenance, test setups and/or repair is increased. Tradeoff studies need to be performed in the Intermediate design phase to weigh up financial and long term life contamination issues due to rust, etc.

A maximum pipe flow diameter of 0.14 m is calculated at a nominal flow rate of 1.75 kg/s and a flow velocity of 30 m/s at 350°C, 5 MPa. If the flow diameter is reduced to 0.12m, using the same process conditions, the flow velocity is increased to approximately 40 m/s. The effect of erosion of the inner surface of the pipe should be investigated at these high flow velocities.

IHX Test Vessel – TDL Primary Side

The IHX Test Vessel is used to test various IHX functions. The design of the IHX test vessel should allow for Human Factors (HF), seeing that this test vessel will be used extensively for different IHX core setups that require adequate space for maneuverability and internal piping. The test vessel should also employ mechanisms for easy access to internal components and instrumentation without dismantling the entire vessel. It should also provide adequate internal fixture brackets, slides, rails, instrumentation channels, etc. for ease of units under test fitting and inspection. It is estimated that the vessel has an internal diameter of 3.0m and a length of 5m.

It is recommended that the vessel be oriented in a vertical manner, with a girth flange located 2m from the bottom of the vessel and the top section removable in the classic "bell" configuration. The four main inlets to the vessel are located in the "fixed/stationary" bottom section. Instrumentation and other required process equipment is also routed through this section. The top bell-section of the vessel is provided with manholes for inspection, maintenance and other tasks that do not require that the vessel top be removed. Cognizance should be taken in the design of the bell-section sealing surface and the handling of this section to prevent damage seeing that this will be an expensive item and provision should be made for adequate lay-down areas and equipment.

It is foreseen that the vessel must be insulated on the inside. This is required as a safety precaution when a Unit Under Test (UUT) fails and the vessel is exposed to the maximum heater outlet temperature.

Test Station Test Vessel – TDL Primary Side

The IHX Test Station is utilized to test various components and sub systems such as valves, hot ducting, process heat exchangers and the like. The same philosophy used for the IHX Test Vessel is employed here. It is proposed that the test Station vessel has an internal diameter of 3.0m and a length of 5m.

1.6.4 Heat Transfer Components

Recuperator Unit – TDL Primary Side

The recuperator unit in all three TDLs is used to recover the energy input of the Heater units after the UUTs. To ensure that the process loops' design integrity is one level higher than the units under test, requires that conventional type recuperators be used. Since various tests are performed at different flow rates and pressures a detailed investigation is needed to determine whether a single recuperator sized for the worst case requirement would be able to operate at a reasonable effectiveness at off design conditions.

In the event where tests are conducted and little or no heat is rejected by the test components such as valves tests and hot ducts and insulation tests, the inlet temperature of the recuperator can reach 950°C. It is recommended to use a COTS conventional type recuperator to ensure that the reliability of the loop is a level higher than that of the test components.

It should be investigated whether it would be possible to use a Helical Tubular Heat Exchanger. The tubular concept was developed and qualified in Germany for the Coal Gasification process coupled with a HTR, where the inlet temperature was 950°C and the mass flow rate approximately 3 kg/s. The operating pressure was significantly lower at 4000 kPa but this should have a negligible effect on the heat transfer capabilities.

The maximum possible heat transfer is approximately 6.3MW assuming a conservative effectiveness of 80%. The maximum required flow rate in the loop is 1.75 kg/s. A first order estimate of the size of the recuperator is approximately a diameter of 2.5m x 12m length.

Another possibility would be to use a Helical Tubular Exchanger in conjunction with a compact heat exchanger. The Helical Tubular Exchanger is used to recuperate the high temperature portion of energy whilst the compact heat exchanger exchanges the lower temperature heat. This should reduce the overall size of the recuperator section with associated savings on the required pressure vessel as well.

Recuperator Unit – TDL Secondary Side

The secondary side recuperator of the TDL loop will be a similar design to the TDL primary side recuperator. This recuperator is significantly smaller and the required duty is approximately 3.7 MW with an effectiveness (assumed) of 80%. The maximum required flow rate in the loop is 1.75 kg/s. A first order estimate of the size of the recuperator is approximately a diameter of 2.0m x 8m length. A similar approach to that of the TDL Primary Side recuperator can be followed using a Helical Tubular Exchanger in conjunction with a compact heat exchanger.

Recuperator Unit – CQL Primary Side

The primary side recuperator of the CQL loop will be a similar design to the TDL primary side recuperator. The recuperator is slightly bigger and the required duty is approximately 7.8 MW with an effectiveness (assumed) of 80%. The maximum required flow rate in the loop is 5.25 kg/s. A first order estimate of the size of the recuperator is approximately a diameter of 2.0m x 15m length. A similar approach to that of the TDL Primary Side recuperator can be followed using a Helical Tubular Exchanger in conjunction with a compact heat exchanger.

Recuperator Unit – CQL Secondary Side

The secondary side recuperator of the CQL loop will be of similar design to that of the CQL Primary Side recuperator. The recuperator is significantly bigger and the required duty is approximately 13 MW with an effectiveness (assumed) of 80%. The maximum required flow rate in the loop is 5.25 kg/s. A first order estimate of the size of the recuperator is approximately a diameter of 3.0m x 18m length. A similar approach to that of the TDL Primary Side recuperator can be followed using a Helical Tubular Exchanger in conjunction with a compact heat exchanger.

1.6.5 Heat Sink Requirements

Cooler – TDL Primary Side

The cooler is used to cool the helium prior to entering the circulator. The circulator inlet temperature is conservatively limited to 80° C. The maximum helium temperature at the inlet to the cooler (without gas bypass from the surge control valve) is approximately 260°C. The required maximum duty of the cooler at a nominal flow rate of 1.75 kg/s is 1.6 MW. It is suggested that either an air-cooler or shell-and-tube cooler be used for this application. An air cooler requires a variable speed drive to control the outlet temperature. The shell-and-tube heat exchanger performs better when sudden temperature transients are present due to the thermal inertia of cooler and coolant. If a shell-and-tube unit is used, it is recommended that a water and ethylene glycol mixture be used. The use of a mixture of water and ethylene glycol would possibly require a closed circuit cooling tower. A maximum coolant flow rate of 20 – 25 kg/s is required to keep the water temperature below 50°C at the cooler outlet. The outlet temperature of the helium can then be regulated by using a coolant bypass and circulating loop.

Cooler – TDL Secondary Side

The secondary side loop of the TDL requires that the fluid be cooled from 460° C to 80° C. The high inlet temperature requires the use of an Air-cooled Helium cooler. The required maximum duty of the cooler at a nominal flow rate of 1.15 kg/s is 2.5 MW. A first order estimate of the size of the cooler is approximately 4.0m x 4.0m x 0.5m. The cooler uses 4 axial flow fans to supply the required air flow rate of 60 kg/s.

Cooler – CQL Secondary Side

The secondary side circulator inlet temperature is also conservatively limited to 80° C. The maximum helium temperature at the inlet to the cooler (without gas bypass from the surge control valve) is approximately 185°C. The required maximum duty of the cooler at a nominal flow rate of 5.25 kg/s is 2.6 MW. A shell-and-tube cooler is recommended for this application, also with a water and ethylene glycol mixture as secondary coolant. A maximum coolant flow rate of 25 - 30 kg/s is required to keep the water temperature below 50° C at the cooler outlet.

Auxiliary Cooling System

An Auxiliary Cooling System is required for each TDL to supply cooled treated water to the helium coolers (if shell and tube coolers are used). The operation and reliability of the auxiliary cooling system is of utmost importance critical to avoid damage to the helium circulators. The auxiliary cooling system consists of the cooling tower, the water treatment and make up system, the cooling pumps and interconnecting pipe system.

• Cooling Tower

It is suggested that a closed circuit cooling tower be used to cool the fluid. The cooling fluid's temperature before it enters the cooling tower circuit reaches a maximum temperature of approximately 50°C. The cooling tower cools the cooling fluid down to approximately 25°C. The maximum water temperature at the inlet to the heat exchanger is approximately 30°C.

Cooling Pumps

The cooling pumps required in the auxiliary cooling system should supply the coolers with approximately 20 kg/s water. A single stage centrifugal pump is suggested with a 600 kPa pressure rise at the supplied flow rate. An additional pump is suggested for redundancy.

Cooling System Piping

The cooling system piping comprises the piping between the cooling tower and Helium coolers. The minimum required pipe size is a 100 mm NB.

Water Treatment System

The cooling water systems are an integral part of the process. The systems require proper chemical treatment for reliable plant operation. The typical problems associated with the cooling

water systems include corrosion, scale, fouling and microbiological contamination. These problems contribute to other secondary problems with heat transfer abilities of components and ultimately performance degradation of the process.

Air-cooled Condenser

The air-cooled condenser forms part of the Steam Generator Tests. The details for the condenser will only be determined once the detail of the steam generator tests has been defined. The condenser will typically have a capacity of 15MW at 5kg/s.

1.6.6 Helium Inventory and Control System

The Helium Inventory System (HICS) has the main function to supply, extract and maintain Helium inventory within the process loops. The HICS should have the ability to either fill the system from bulk Helium containers or from the storage vessels located onsite. The system should be able to pump helium from the latter at a pressure lower than the process pressure to the process.

Components of the HICS

• Helium Storage Vessels

The helium storage vessels are used to store the process inventory during maintenance or repair periods when the complete inventory is not to be wasted. It is suggested that the storage vessels have the capacity to store the entire inventory of the process – primary and secondary loop. The entire inventory will be stored at an estimated pressure of 14000 kPa to reduce the required storage volume. The volume of the primary side and secondary side of the loop is approximately $200 - 300 \text{ m}^3$. The total calculated volume of the storage tanks are $130 - 190 \text{ m}^3$ at 14000 kPa. The storage vessels' volume is currently limited to approximately 16 m^3 . In total 10 - 12 of these vessels are required to store the entire inventory. The vessels will have an approximate diameter of 1.5m and a length of 10m. Tradeoff studies need to be performed during the Preliminary design to determine the cost implication of investing in hardware such as the Helium Storage Vessels and the cost of loss-of-inventory.

• Inventory Transfer System

The inventory transfer system is utilized to transfer Helium from the bulk Helium containers and the storage tanks to the primary and secondary process loops and back. The system consists of isolation and control valves as well as a positive displacement compressor unit. The compressor unit is used to transfer the fluid when the pressure of the volume to which the fluid is transferred is higher than the system from which it is pumped. The size of the compressor is determined by the maximum pressure of the storage vessels and the time required to fully transport the inventory of the process. The different modes of the inventory transfer system are illustrated in Figure 9 through Figure 13. Figure 9 shows the process flow diagram when the loop is supplied with Helium when the pressure in the loop is higher than the pressure in the storage tanks. Figure 10 shows the process flow diagram when the loop is supplied with Helium when the pressure in the pressure in the storage tanks and the compressor is not

needed. Figure 11 and Figure 12 show the process flow diagram when the Helium is extracted from the loop when the pressure in the loop is 1) higher than the pressure in the storage tanks and the compressor is not needed and 2) lower than the pressure in the storage tanks and the compressor is needed to increase the pressure in the storage tanks.

Figure 13 shows the process flow diagram for the conditioning of the Low Pressure Vent tank, which can be utilized when a pipe break is simulated to suddenly extract the inventory. The pressure in the LP Vent tank is reduced significantly to simulate a postulated pipe break scenario. The LP Vent tank should however be located close to the loop where the pipe break scenario is simulated to reduce the inertia effects of the gas.







Figure 10: Helium Injection into System When the Process Pressure is Lower than the Storage Tank Pressure



Figure 11: Helium Extraction from the System When the Process Pressure is Higher than the Storage Tank Pressure



Figure 12: Helium Extraction from the System When the Process Pressure is Lower than the Storage Tank Pressure



Figure 13: Conditioning of the Low Pressure Vent Tank

Vacuum System

The vacuum system is used to evacuate the process loop before Helium gas is introduced into the loop. The vacuum system is also used to reduce the pressure of the low pressure vent tank that is used for specified tests.

1.6.7 Helium Purification System (HPS)

Purification Requirements

It is envisaged that the general purification requirements for the Component Test Facility would be to remove H_2 and CO from each of the primary and secondary loops to restrict the deposition of carbon on metallic surfaces, particularly ferritic steels at high temperatures (\approx 500°C). The moisture content in the primary loop in particular, must be removed as it will react with the dust from the dust generators to form H_2 and CO₂. Residual oxygen from air after purging will also react with the dust from the dust generators to form CO and CO₂.

Water and carbon dioxide will also be removed and be kept under the allowable limits (to be specified). It is expected that a large amount of impurities would be present after initial evacuation. It is further suggested that the dust from the dust filters be heated and purged separately to reduce the amount of moisture and oxygen present before operation.

Process Description

A Pressure Swing Adsorption (PSA) is used to remove impurities from the helium stream. A molecular sieve membrane or packed bed is used at high pressures and low temperatures to adsorb H_2O and CO_2 . The packed bed or membrane becomes saturated after a period of time, and therefore needs to be regenerated. The regeneration process consists of blowing pure helium at elevated temperatures and low pressures in the reverse direction of the main process, whereby the impurities are removed from the molecular sieve. Since there will be no radioactive isotopes such as ¹⁴C or ³H the regeneration gas can simply be blown to the off-gas. The H₂ and CO must however first be converted for the adsorption process in the molecular sieve.

Components of the HPS

• Dust Filters

Since there will be dust generators, a filter or cyclone will be required to remove dust that enters the HPS. This will be necessary to ensure that the packed beds which remove impurities from the gas stream function as desired. Because of the potentially large amounts of dust generated, it is suggested that the gross amount be filtered with a cyclone or pre-filter followed by fine dust filters. The pre-filter will enhance the efficiency and operable life of the fine dust filters.

• Copper Oxide Catalytic Converter

The copper oxide catalytic converter oxidizes H_2 and CO so that it can be adsorbed in the molecular sieve. The CuO beds require a temperature of approximately 210°C with an oxygen supply to regenerate the bed after a period of oxidizing the CO and H_2 .

• Coolers

After the H_2 has been oxidized to H_2O in the CuO beds, it is recuperated and cooled using the feed from the loop, after which it is further cooled using a chilled water heat exchanger. This will ensure that most of the water is condensed, and also serves as a cooling medium for the gas stream for the adsorption of the impurities in the molecular sieve.

• Water Coalescer

A water coalescer is installed after the coolers to remove the water from the gas stream. This is necessary since water ingress in the molecular sieve will greatly reduce the adsorption capacity.

• Molecular Sieve

The molecular sieve will remove the remaining H_2O and CO_2 from the helium stream. Two, type 13X molecular sieves with an effective pore size of 1nm are suggested in parallel. While one is used to adsorb the impurities, the other is regenerated. The molecular sieve sizing will depend on the amount of impurities remaining in the system after evacuation and purging.

• Circulators

If the HPS is to be used to remove impurities before operation a circulator will be required in parallel with a valve to pre-circulate the helium. During normal operation a control valve will be used to control the amount of flow through the HPS due to the differential pressure.

1.6.8 Control and Instrumentation

The instrumentation requirements of CTF Concept 1 will be provided in a summary of the different types and requirements as per each separate process loop, while general requirements and recommendations for the Control & Instrumentation philosophy will be presented below.

General Requirements

The following is a list of general requirements and/or recommendations for the CTF Instrumentation and Control, and is applicable to the TDLs as well as the CQL.

All instrumentation should be categorized as being part of either *plant protection, controllability* or *performance verification* instrumentation. A clear distinction among these should therefore prevent that performance verification instrumentation be used for controllability or equipment protection purposes and assure that Intellectual Property associated with Technology Development is protected.

Appendix D - Concept1 detail-FINAL.doc

These levels of categorization should then also be used to determine their robustness as well as accuracy and traceability to international standards. It is also suggested to have a dedicated Data Acquisition System (DAQ) for each of these categories, which could assist in plant operability by a single dedicated team while ensuring protection of intellectual property in the form of performance indicators.

Some of the major control items on the CTF loops include, but are not limited to the following:

- Mass flow rate control by varying the circulator drive speed with a VSD
- Circulator surge control by means of a circulator bypass loop
- Heater outlet temperature control with thyristor control on the heating elements
- Operating and position feedback on valves (typically in HICS, HPS...)
- Start-stop on all pumps, compressors, vacuum pumps.
- Helium Inventory Control
- Controllability of gas analyzer (valves, sampling pumps)

Data logging capability should at least have the following characteristics:

- The scan rate should be determined by user requirements and previous test facility experience.
- Designed in such a way to allow for easy addition of data channels
- High temperature system temperature measurements should be performed with at least 3 4 instruments in close vicinity, and should make use of a thermowell with a very low thermal inertia.
- All pressure measurements should use pressure averaging with at least 3 to 4 instruments
- All instrumentation penetrations should be provided through fixed sections of the appropriate vessels and provision should be made for termination of all necessary instrumentation in the inside of the vessels.

Care should be taken to install and position instrumentation (especially for performance verification) in easily accessible places, with easy replacement as a high priority.

Input and Output Channels

Table 10 gives an indication of the minimum required number of output channels. These outputs should serve as the minimum number of required measurements for Plant Protection, Plant Controllability and Performance Verification. Ultimately the entity which uses the facility to test their respective components should give an indication of what their specific needs are. Provision should also be made to have available open channels already routed to field termination points in the event of additional outputs required by the Test Entity.

Description	Т	Р	ΔΡ	Mass flow	σ/ε	Leak Rate	Gas Analyzer	Other
TDL 1				_				
Primary Loop								
Heater	20	-	1	-	-	-	-	-
Piping	12	10	-	5	10	-	-	-
Test station vessel	25	-	3	-	25	5	F	5
IHX test vessel	50	-	3	-	50	5	5	5
Dust generator	-	-	1	-	-	-	-	-
Filtration station	-	-	1	-	-	-	-	-
Recuperator	16	-	2	-	-	-	-	-
Cooler	4	-	1	-	-	-	-	-
Circulator	8	-	2	-	-	-	-	10
Secondary Loop								
Test station vessel	25	-	3	-	25	5	5	5
Recuperator	16	-	2	-	-	-	-	-
Cooler	4	-	1	-	-	-	-	-
Circulator	8	-	2	-	-	-	-	10
TDL 2								
Primary Loop								
Heater	20	-	1	-	-	-	-	-
Piping	12	10	-	5	10	-	-	-
IHX test vessel	50	-	3	-	50	5		5
Recuperator	16	-	2	-	-	-	-	-
Cooler	4	-	1	-	-	-	-	-
Circulator	8	-	2	-	-	-	-	10
Secondary Loop								
Recuperator	16	-	2	-	-	-	-	-
Cooler	4	-	1	-	-	-	-	-
Circulator	8	-	2	-	-	-	-	10
TDL 3								
Primary Loop								
Heater	20	-	1	-	-	-	-	-
Piping	12	10	-	5	10	-	-	-
Test Station Vessel	50	-	3	-	50	5		5

Table 10 [•] Minimum Rec	wired Number of (Jutputs for Concept 1
		Sulpulo for Concept f

Description	Т	Р	ΔP	Mass flow	σ/ε	Leak Rate	Gas Analyzer	Other
Recuperator	16	-	2	-	-	-	-	-
Cooler	4	-	1	-	-	-	-	-
Circulator	8	-	2	-	-	-	-	10
CQL								
Primary Loop								
Hot headers	10	2	-	-	-	-	-	-
Piping	20	5	-	3	-	-	-	-
Steam generator vessel	50	2	2	-	20	-	-	-
IHX Test Vessel	50	-	3	-	50	5	5	5
Recuperator	16	-	2	-	-	-	-	-
Cold headers	10	2	-	-	-	-	-	-
Secondary Loop								
Recuperator	16	-	2	-	-	-	-	-
Cooler	4	-	1	-	-	-	-	-
Circulator	8	-	2	-	-	-	-	10
Circulator Loop								
	20	10	5	1	-	-	-	-
HICS								
	10	10	5	2	-	-	-	10
HPS								
	10	10	5	2	-	-	-	10
TOTAL	660	71	72	23	300	30	15	110

Some general considerations regarding the different instrumentation types are summed up in the following section:

Temperature Measurement

All temperature measurements should make use of proven technology, in terms of standard thermocouples for specific ranges. Care should be taken with regards to installation and guidelines such that those from API or similar are recommended. All instruments should further be subjected to calibration from international recognized laboratories or institutions for traceability and future usage of obtained data. A summary of major aspects that need to be addressed include:

- Detailed selection of correct instruments for measurement range and application
- Calibration requirements and plan
- Installation requirements and guidelines
- Accessibility and re-calibration possibilities

Pressure Measurement

Pressure measurements should again make use of high integrity, proven instrumentation with specific attention to be given to ranges and the application of hot measurements.

Mass flow Measurement

Mass flow measurements are anticipated to be measured at the colder location of the loop, with a maximum temperature of 650°C for the mixing chamber tests. With this high temperature it is anticipated that standard pressure drop measurement installations will be used, with additional care for high temperature differential pressure measurement. A further investigation with regards to different or newly developed technology is still recommended.

Strain Measurement

Apart from the various strain measurements on the units under test, it also envisaged that the plant should have various measurements at critical locations. These should typically be high temperature strain gauges in excess of 1000°C from manufacturers such as *Strainsense* (www.strainsense.co.uk) or HPI (www.hitecprod.com).

Leak Rate Monitoring

Leak rate monitoring should be provided in at least mobile and stationary units. These different systems are needed for both leak rates monitoring on the complete plant as well dedicated installed systems where leak rates are needed to be measured on components under test. Specific means of monitoring still need to be investigated, depending on the anticipated rates and additional constraints. Typical methods include:

- Mechanical effects
- Pressure decrease
- Tracer gas measurement

1.6.9 Circulator

The circulator in this loop will be a UUT. Full scale circulator tests are required to verify their performance at design conditions. The design of the loop makes provision for a circulator up to 15MW_t. The maximum flow rate is limited to 160 kg/s.

The following is a short write-up by one of the leading South African turbo machinery consultants and serves as motivation for employing a full scale circulator loop.

"The characteristics of helium as process gas present a very different set of constraints for the design of Turbo machinery. Firstly the sonic velocity in helium is approximately 3 times higher

than that of conventional fluids used as process fluid. Generally the tip speeds of industrial Turbo machinery is limited to velocities well below the sonic velocity i.e. Mach < 1. With Helium as operating fluid the rotating speed is no longer limited by the mechanical design. The rotating speed is governed by the maximum allowable material stress due to the centrifugal load. Secondly the specified heat capacitance of helium is approximately five times higher than air. Therefore the pressure & temperature rise that can be achieved per stage is very small.

High pressure helium Turbo machinery presents an even more challenging set of design requirements. In order to reduce the weight of the nuclear grade pressure boundary, the rotational speeds are increased to the mechanical limit of the rotating component material allowable stress limit. Even at high rotating speeds and pressure levels only moderate Reynolds numbers can be achieved. Experience has shown that the efficiency of the turbo machine as well as the performance of the individual gas path components is very dependant on the Reynolds number.

Scaled testing of Helium Turbo machinery by making use of geometrical scaling laws is difficult to achieve in practice. Ideally testing should be carried out at similar Reynolds and Mach numbers. Due to the fact that the rotational speed and pressure for the full scale model is set at high levels for the full scale design, half scale testing is not practical for the following reasons:

Doubling the operational rotational speed will require allowable stress limits well above the current state of the art material limits.

An increased density (pressure) to maintain testing similarity requires an even heavier pressure boundary, offsetting the benefit of scaled testing. Increasing the pressure also affects the pressure balancing of the rotating train.

To maintain similarity at part load presents an even bigger challenge due to the fact that the flow will not be fully turbulent.

The objectives of the full scale helium loop test are to verify the predicted compressor performance, stability of operation and reliability at both the design and the part load operations. Therefore the Helium Loop Test should confirm both the steady state and transient characteristics of the turbo compressor.

The material stress intensity due to gas path component vibration is strongly dependant on the inlet pressure. The inlet pressure should be maintained at a constant level during steady state and transient testing to make the evaluation of the test results easier. It is proposed that additional helium gas be supplied to the closed loop by means of an inventory control system, to maintain a constant pressure level at the compressor inlet. This should serve as a design criterion for the inventory control system.

Presently very limited experience exists related to surge protection of helium gas turbo compressors. Ideally the turbo compressor should be relieved from the surge condition as soon as possible. The response of the compressor bypass valve should be confirmed as an adequate surge protection system to ensure long term reliability. The suitability & reliability of surge monitoring instrumentation in a high pressure helium atmosphere should be confirmed. In conclusion it is recommended that a full scale helium blower loop test be considered to verify various characteristics and aspects of the turbo compressor envisaged for the NGNP to ensure long term reliability."

1.6.10 Piping

The piping in the circulator loop is required to handle a maximum temperature of 590° C. The option therefore exists for the use of a single (or multiple) stainless steel pipe(s), or a hot pipe design. To limit the maximum flow velocity in the pipe to 80 m/s, a pipe with a flow diameter of 0.7m is required at 590°C, 9 MPa.

1.6.11 Cooler

The cooler in the circulator loop should be able to extract the heat in the fluid produced by the specific circulator. Since various circulators will be tested, the cooler will be required to operate at various operating points. It should therefore be investigated whether a single unit or 2 and more in parallel is more suited to cover the entire operating range specified for the loop once more information on the circulators is available.

2.1 ENERGY BALANCES





D-37 of D-51

April 2008



D-38 of D-51

Appendix D - Concept1 detail-FINAL.doc

April 2008



D-39 of D-51





D-41 of D-51



D-42 of D-51



D-43 of D-51



D-44 of D-51

NGNP-CTF 20-CTF

HTGR Component Test Facility (CTF) Recommendations



NGNP-CTF 20-CTF

HTGR Component Test Facility (CTF) Recommendations



Appendix D - Concept1 detail-FINAL.doc



D-47 of D-51





D-49 of D-51

NGNP-CTF 20-CTF

HTGR Component Test Facility (CTF) Recommendations



D-50 of D-51

April 2008





Appendix D - Concept1 detail-FINAL.doc

April 2008

Test Configuration: CIR-A

CL 1.1

Primary side : Helium

TeatStation/read House area in a Teatro of Teat Inter-House area in the second of the teat of teat of t

RECUPERTED RX 1.1

ЬŢ TS 1.1

H 1.1

Н 21

IHX 2.1

Ř

Test Ballon retrumentation

FS 1.1

IHX 1.1

Control & Instrumentation (NOTE: Each Test loop will have own set of control & instrumentation systems, shtaring of support systems)

? V & V instrumentation

? Test specific instrumentation

? Process Control

Auxiliary Systems (NOTE: Each Test Loop to have its own set of auxiliary systems, no sharing of support systems)

? Water treatment plant
? Compressed air systems

? HICS ? LP vent vessel ? HPS

Primary side : Helium

C 2.1

RX 2.1

CL 2.1

From CQL

5
APPENDIX E CONCEPT 2 DETAILS

1.1 TEST CONFIGURATIONS

In order to provide a recommendation with regards to facility envelope sizes, a number of different test configurations were imposed on Concept 2. These test configurations are summed up in Table 1, and were evaluated by means of energy balances to determine component sizing. A complete summary of these energy balances, together with general considerations per test configuration can be found in at the end of this appendix. The "TEST#" column in Table 1 corresponds with the "DOCUMENT NUMBER" on the energy balance sheet.

Table 1: Summary	of Test Configurations	s in Concept 2 as Dicta	ated by the DDNs
rabio ni Ganniary	er reet eeningaraderie		

Test #	Main Test Configuration	Sub Test	Loop
IHX- 1	IHX Performance verification tests: WEC Core A & B	Steady state	Primary / Secondary
DIV- 1	Hightemperatureducts&insulationperformanceverification test)	Steady state	Secondary
SG-1	Steam generator performance verification test: WEC	Steady state	Steam generator testing loop
CIR-W	Circulator performance: WEC	Steady state	Circulator loop

The enveloping values for each loop, from these test configurations and the energy balances, will be presented in the following section.

1.1.1 Concept 2 – Primary Side

The primary loop of Concept 2 is very similar to the primary side of the TDLs of Concept 1. Helium is circulated at a maximum rate of 25 kg/s with two 650 kW circulators (C1.1 & 1.2) while the other main components include large scale electrical heaters (H 1.1), double vessel test stations (TS 1.1) as well as the IHX test station vessels (IHX 1.1 & 1.2). Figure 1 illustrates the primary loop, with the maximum component values following thereafter.



Figure 1: High Level Process Flow Diagram of Concept 2 Primary Side

		Concep	t 2 – Primary	y side			
No.	Components	Power [MW]	Mass flow rate [kg/s] - MAX	T_in [°C]	T_out [°C]	Pressure	Fluid
C 1.1 & 1.2	Circulator (ΔP: 500 kPa @ 9 MPa)	1.9	25	250[max]	-		
RX 1.1	Recuperator (Hot side)	69 [mov]	25	925 [max]	394 [max]		
RX 1.1	Recuperator (Cold side)	oo [max]	25	~ 263 [max]	793 [max]	0.00-	
H 1.1	Heater	23	25	793 [max]	950 [max]	(Calculations	Pure
TS 1.1	Vessel - Test Station	N/A	25	950 [min]	950 [max]	on 9 MPa)	Hellum
IHX 1.1	Heat exchanger Vessel (primary)	N/A	25	950 [max]	950 [max]		
CL 1.1	Cooler	19	25	396 [max]	250 [nom]		
PD 1.1	Pipe & Ducting	N/A	25	950 [n	nax]]	

Table 2: Enveloping Values of the Primary Side of Concept 2

1.1.2 Concept 2 – Secondary Side

The secondary side of Concept 2 is again similar to that of the TDL's of Concept 1 and is will be used during IHX testing. This loop also has two test vessels, apart from the IHX test vessels and could be used for concurrent testing of non heat transfer components. A simplified PFD of the secondary loop is illustrated in Figure 2, while the component values follow thereafter.



Figure 2: High Level Process Flow Diagram of Concept 2 Secondary Side

		Concept 2	2 – Seconda	ry side			
No.	Components	Power [MW]	Mass flow rate [kg/s] - MAX	T_in [°C]	T_out [°C]	Pressure	Fluid
C 2.1 & 2.2	Circulator (ΔP: 500 kPa @ 9 MPa)	1.9	25	250[max]	-		
H 2.1	Heater	3.1	25	263 [max]	287 [max]	9 MPa (Calculations	Pure
TS 2.1	Vessel - Test Station	N/A	25	950 [min]	950 [max]	based only on 9 MPa)	Helium
CL 2.1	Cooler	18.2	25	390 [max]	250 [nom]		

	Table 3: Enveloping	Values of th	ne Secondary	Side of	Concept 2
--	---------------------	--------------	--------------	---------	-----------

1.1.3 Concept 2 – Steam Generator Loop

The steam generator loop is a separate loop which extends the primary loop for specific steam generator testing. This separate loop will provide representative steam producing capabilities on the water side of the steam generator with the required condensing capabilities.



Figure 3: High Level Process Flow Diagram of Concept 2 in the Steam Generator Configuration

Table 4: Enveloping Values Maximun	Steam Generator Testing Capability
------------------------------------	------------------------------------

		Concept	2 – Seconda	ry side			
No.	Components	Power [MW]	Mass flow rate [kg/s] - MAX	T_in [°C]	T_out [°C]	Pressure	Fluid
SG	Unit under test	23.2	7.15	900 [max]	272 [max]	9 MPa (Calculations based only on 9 MPa)	Pure Helium
CL 3.1	Cooler	17	6.23 (Water)	54 (vapor) [max]	54 (liquid) [nom]	18 MPa	Water

Details regarding the specific components that are proposed for each of these loops will be provided in the component descriptions.

1.1.4 Full Scale Circulator Loop

A circulator testing loop is purposed again to address full scale testing requirements of different circulator designs as in Concept 1. This separate loop is mainly proposed as part of the philosophy of not having two or more components under test in a single test configuration. A typical arrangement is shown in Figure 4, with a summary of the main components in Table 5.

Full scale Circulator test loop



Figure 4: High Level Process Flow Diagram of the Full Scale Circulator Test Loop

		Circula	ator test loop)			
No.	Components	Power [MW]	Mass flow rate [kg/s] - MAX	T_in [°C]	T_out [°C]	Pressure	Fluid
C 4.1	Circulator: Unit under test	12.4 MWt [max]	159.6 [max]	337 [max]	-		
CL 5.1	Cooler	12.4 [max]	159.6 [max]	350 [max]	337 [min]	9 MPa	Helium.
PD 5.1	Pipe & Ducting	N/A	159.6 [max]	350 [max]		

Table 5: Enveloping	Values of the	Full Scale Circulator	Test Loop
---------------------	---------------	-----------------------	-----------

1.2 COMPONENT DESCRIPTIONS

This section provides a general description and recommendations for future work on the different components and sub systems of Concept 2.

1.2.1 Circulators

The Circulators used for Concept 2 employ the same philosophy as for the TDLs. However, the circulators for Concept 2 require research and development during design and are therefore not COTS items. For the same reason, two full flow circulators are employed, with one used for redundancy. A single stage high-speed circulator is the preferred option with an oil bearing and seal combination as in the case of the TDL circulators. The Circulator must circulate Helium at a process flow rate of 25kg/s. Allowance should be made for a bypass of at least 15% of the process flow to account for Surge Control. It is estimated that a pressure drop of 450 kPa is required, which gives a pressure ratio of 1.05 at an inlet total pressure of 9.0 MPa. It is therefore critical that the piping and associated components have a low pressure drop. If a higher pressure ratio is required, a multi-stage radial or axial circulator will be required. The estimated driver power is 1.6 MW.

The proposed circulator layout is typically a Howden submerged motor circulator with AMBs that is modified to accommodate oil bearing or dry gas seals. The approach is to utilize a highly reliable product for the test loop, but provide flexibility in introducing new developed product such as submerged motor circulators with AMBs.

1.2.2 Heater Unit

The Heater Unit for Concept 2 employs a similar philosophy as for the TDLs. The heater will however, be divided into two units which use various smaller heaters placed in series in the two pressure vessels. The heaters are also electrically powered with thyristor control. The pressure vessel is thermally insulated from the high temperature gas, as well as protected against heating element radiation. The heater unit is installed in a vertical position with the gas flowing in an upwards direction. The heater has a typical inlet temperature of 700°C and an outlet temperature of 950°C. Each heater has a flow rate of 12.5 kg/s.

Each heater vessel has an estimated size of \emptyset of 2.5m, a height of 8m and weighs approximately 120 metric tons.

1.2.3 **Pressure Boundary**

Hot Pipes (T_{Helium}>550°C)

The hot-pipes will be of a similar design and construction as those developed in Germany for the high temperature gas cooled reactor program. It also follows the PBMR approach.

The construction is made up of an inner gas guiding tube, thermally well insulated, with a gap between the actual pressure pipe and this insulated inner pipe (similar to the TDL design). This

Appendix E – Concept 2 Detail-FINAL.doc

gap is thermally conditioned by forced convection of cooling gas provided by an independent circulator system.

A maximum flow tube diameter of 0.35 m is calculated at a nominal flow rate of 25 kg/s and a flow velocity of 80 m/s at 950°C, 9 MPa. The pressure boundary dimensions are to be determined once a detail calculation has been done regarding the insulation material, but is estimated at approximately 1.0 - 1.2 m with active cooling. The pressure boundary section should make provision for instrumentation connection points which can be used to monitor the pressure and temperature levels in the hot pipe. The hot pipes should be designed to be pressure balanced across the flow tube and the possibility of isolating these two sides from each other should be investigated and could assist in the purification processes. A typical section length of 5m is foreseen. As a result of the high cost of this pipe, the physical layout should be done sensitively to keep the total length of this item to a minimum. The governing philosophy for the hot pipes is to make them as short as possible, have no valves located in them, have no compensators in them but rather compensate in the cold pipes and have minimal bends except when the bends are actually used for compensating purposes.

Cold Pipes (T_{Helium}<350°C)

It is recommended that all the cold pipes are manufactured from carbon steel, such as ASME A106 Gr B.

The use of carbon steel would reduce the total cost of the facility but the risk of corrosion of the piping in periods when the facility is open for maintenance, test setups and/or repair is increased. Tradeoff studies need to be performed in the Intermediate design phase to weigh financial and long term life contamination issues due to rust, etc. A maximum pipe flow diameter of 0.25 m is calculated at a nominal flow rate of 25 kg/s and a flow velocity of 80 m/s at 350°C, 9 MPa. The effect of erosion of the inner surface of the pipe should be investigated at these very high flow velocities.

1.2.4 Valves

The layout of the process loop was carefully done to eliminate the need for valves. Valves operating in a high temperature helium environment are not readily available commercially and must be developed for the specific application. Some tests that are done in parallel might require the use of valves for helium flow control. Bellow-sealed valves (bellow on the stem) are the best option for helium applications. Rotational valve stems require a different sealing concept. Multi-stage wet oil/grease seals will successfully seal off the high pressure helium against leaks to atmosphere (10^{-5} mbar.l/ sec per stem can be achieved). The actuation can be by pneumatic or electric actuators.

1.2.5 Test Vessels

The test of specific full size components or representative size components for the NGNP required custom "designed-for" test vessels. The test loop provides space and the necessary interfaces for a few high-pressure test setups. The design of the test vessels should allow for Human Factors (HF), seeing that these vessels will be used extensively for different UUT setups that require adequate space for maneuverability and internal piping. These vessels must be

thermally conditioned by a thermal conditioning system. The temperature of the vessels should preferably be low enough to eliminate any thermal insulation.

Provision is made for three test setups. Two dedicated test vessels are provided, one being vertically oriented and one horizontally oriented. The third setup allows the vendors to connect directly to the process loop via a "test spool piece". The test spool piece is a UUT and can typically be a component such as a hot pipe design, etc.

Even though one can only use a single test vessel at a time, vendors will be able to do three simultaneous setups during plant outage. The selection between different test setups can then be done by minor configuration changes without necessarily shutting down the plant.

The envisaged size of the horizontal test vessel has an inner diameter of approximately of 2.0m and a length of 15m. The vertical test vessel's inner diameter is approximately 2.0m with a height of 5m. A distance of 15m is available between the process connections to connect UUTs via a "test spool piece".

1.2.6 Heat Transfer Components

Recuperator

The recuperator unit in the loop is used to recover the energy input of the Heater units after the UUTs. To ensure that the process loops' design integrity is one level higher than the units under test, requires that conventional type recuperators be used.

In the event where tests are conducted and little or no heat is rejected by the test components such as valve tests and hot ducts and insulation tests, the inlet temperature of the recuperator can reach 900°C. It is recommended to use a COTS conventional type recuperator to ensure that the reliability of the loop is a level higher than that of the test components.

It should be investigated whether it would be possible to use a Helical Tubular Heat Exchanger. The layout will be in such a manner that the pressure retaining sections, e.g., the shell, will be at acceptable temperatures. The sections subjected to the very high temperatures will be of special alloys. The maximum possible heat transfer is approximately 68MW assuming a conservative effectiveness of 80%. The maximum required flow rate in the loop is 25 kg/s. A first order estimate of the size of the recuperator is a vessel with approximate dimensions of a diameter of 3m and a length of 20m. The shell thickness will be in the order of 140 mm, with a total weight of 260 metric tons.

Another possibility would be to use a Helical Tubular Exchanger in conjunction with a compact heat exchanger. The Helical Tubular Exchanger is used to recuperate the high temperature portion of energy whilst the compact heat exchanger exchanges the lower temperature heat. This should reduce the overall size of the recuperator section with associated savings on the required pressure vessel as well.

1.2.7 Heat Sink Requirements

Coolers

The primary loop requires that the fluid be cooled from 400° C to 250° C before entering the circulator. The high inlet temperature requires the use of an air-cooled Helium cooler. The required maximum duty of the cooler at a nominal flow rate of 25 kg/s is 19 MW. A first order estimate of the size of the cooler is approximately $10.0m \times 4.0m \times 0.5m$. The cooler uses 10 axial flow fans to supply the required air flow rate of 150 kg/s. All the fans will be equipped with variable speed drives to control the helium outlet temperature.

1.2.8 Helium Inventory Control System

The helium inventory control system (HICS) of this loop will be similar to the TDL's of Concept 1. The loop allows for the storage of the total inventory of the main and secondary loops of the test facility. Eight vessels of a capacity 125 m³ should be installed inside or outside of the main building. These vessels should be designed according to ASME VIII division 1 and could be manufactured from carbon steel. They have a diameter of 3 meters and a height of 18 meters. Tradeoff studies need to be performed during the Preliminary design to determine the cost implication of investing in hardware such as the Helium Storage Vessels and the cost of loss-of-inventory.

The Helium compressor has a larger flow capacity than that of the TDLs. A single stage positive displacement compressor with a pumping capacity to pump down the test loop to at least 5kPa in less than 24 hours is recommended. This compressor is also used to provide high-pressure helium for pressure control purposes. A typical membrane type compressor is preferred because of low leaking characteristics.

1.2.9 Helium Purification System

The Helium Purification System (HPS) of Concept 2 will be similar in operation to the HPS of the TDL but an order of magnitude larger. The purification take off flow rate will approximately be less than 0.5% of the process flow rate.

1.2.10 Control and Instrumentation

The same Control and Instrumentation (C&I) philosophy is used as in Concept 1, except that the number of I/O's will have an increased number of electrical loads.

1.2.11 Circulator Test Loop

The Circulator Test loop is identical to that of Concept 1.

2.1 ENERGY BALANCES



E-10 of E-14



E-11 of E-14





NGNP-CTF 20-CTF



E-14 of E-14

APPENDIX F - DDNS TEST CONFIGURATIONS

No:	Main Test Configuration	Sub Test	Description
1.	IHX Performance verification tests: (Steady-state tests to verify design, material and thermal fluid performance)	- WEC (Core A & B)	Test core sizes and conditions defined. To be used as direct input for possible test configurations.
		- GA	No test core size defined. Typical conditions from PCDR used.
		- AREVA	Core sizes of ~1 MW and ~10 MW to be tested. Conditions extracted from PCDR
	IHX Performance verification tests: (Transient tests to verify design, material and thermal fluid performance)	- WEC	 Loss of secondary side pressure and flow (Adiabatic conditions). Start-up and shut down cycles (<i>Not specifically addressed. Need to be investigated</i>)
		- GA	Non defined
		- AREVA	Heat-up and cool-down cycles (<i>Not</i> specifically addressed. Need to be investigated)
2.	Mixing chamber performance verification	- WEC	Representative conditions. Mock-up scale TBD.
3.	High temperature ducts & insulation performance verification test:	- WEC	Piping prototype need to be tested at full temperature & pressure.
		- GA	Mockup sizes to be tested in a 1 MW facility and qualification on a 10 MW facility. Conditions extracted from PCDR
4.	Steam generator performance verification test:	- WEC	Numerous tests to be conducted on helium and water side at representative conditions.
		- GA	Need for tests identified but detail to be determined.
5.	Circulator performance / control tests:	- All vendor groups	Full scale at representative conditions.

No:	Main Test Configuration	Sub Test	Description
6.	Isolation valves	- GA	Large scale valve tests at representative conditions
7.	Auxiliary system testing:	Helium purification systems	
		Helium inventory & control systems	Facility should provide capability to be tested
		Heat rejection systems	
8.	Control & instrumentation tests:	- All consortiums	Facility to provide capability of C&I development as well being a V&V compliant
9.	Other HX test:	- GA	Various shutdown heat exchanger (SHE) tests
10.	General functions:	[TBD]	
		[TBD]	

APPENDIX G – IHX TEST SPECIFICATION

1.1 SUMMARY OF TYPICAL COMPONENT UNDER TEST (IHX)

IHX stress and life prediction tests are based on the premise that due to the large size and cost of a full-scale IHX, finite element models will be used extensively in design and life prediction models. These tests are intended to generate steady-state and transient temperatures within the core for precisely controlled temperature, pressure, and flow inlet conditions. Most IHX designs utilize strain relief features to isolate the core from strain introduced by ducting and support structures; thus, life testing requires rigorous consideration and simulation of the IHX boundary conditions and core symmetry. An appropriate test specimen should include the full size core and realistic boundary conditions up to the point of isolation.

The Technology Development Loops (Concept 1) with its 3-meter-diameter test vessel is sized to accommodate very large IHX cores. The data gathered from these tests will be used for the development of a test specification for testing of a representative full scale IHX core in the large loop of Concept 1 or in the proposed Concept 2 vessels. Tests can be conducted up to 2MW capacity in the TDLs and up to 10MW in the large loop, allowing development work and full dimensional scale testing at full temperature and pressure, and reduced mass flow rate (25 kg/s). The imposed transient stresses may be reduced, but quantitative measurements with model validation can be employed to interpret the results.

1.1.1 Test Modes

The following table indicates the general test modes for Units Under Test (UUTs) and more specifically an IHX core.

MODE NR	DESCRIPTION	PURPOSE	OPERATIONAL STATUS	DESCRIPTION
~	Modification/Mainten ance Mode	This mode is used to maintain the Test set-up or to made changes to the equipment that are tested	System is depressurised and may be open to air System Helium has to be cleaned to the correct specification and the IHX pressurised to 0.1 MPa for start-up.	IHX Test set-up is isolated from CTF primary and secondary loops.
2	Off Mode	Default mode after completion of maintenance, shutdown or failure of the Test set-up	Power is supplied, but electrical equipment in the IHX is switched off. Instrumentation is active and all events are monitored.	IHX Test set-up is isolated from CTF primary and secondary loops.
က	Standby Mode	Diagnostics performed on Test set-up to check for readiness of system	Components and support systems initialised and checked for readiness, availability and operation. System equipment and instrumentation are energised and ready for operation	Primary & Secondary loop must be in Standby Mode or Operate Mode
4	Operate Mode	This mode is when the Test set-up is operational, either with conditioning or for the execution of the tests	System is pressurised and thermally conditioned as required for the selected test	CTF primary and secondary loop is in Operate Mode and supply IHX vessel with helium at required temperature, pressure and flow rate
Ð	Conditioning Mode	This mode is used to condition the Test set-up to the required test mode	System is in the process of being pressurised and thermally conditioned as required for the selected test	CTF loops supply helium for the start-up/thermo- hydraulic conditioning of the IHX Test set-up
9	Experimental Modes	These modes are use for the execution of the tests	As per specific experiment	Operations supply (steady state and transients)
7	Shutdown Mode	System is shut down from Standby or Operate Mode	Components in the Test set-up is shut down in an orderly manner C&I monitor all events	RCS Test set-up can be isolated from or connected to the HTF Main loop
ω	Failure Mode	Default Mode after component malfunction	Components are shut down and fault is investigated	CTF loops must be in Standby Mode or Operate Mode

G-2 of G-8

MODE NR	DESCRIPTION	PURPOSE	OPERATIONAL STATUS	DESCRIPTION
			There is an opportunity for the system to recover and progress to Standby Mode	
			Fault is identified and system progresses to Standby Mode, OR	
			Cannot recover from fault and Shutdown is initiated	
თ	Isolation mode low pressure	This mode is use to set the Test set-up to a state that it could be used as a storage vessel for helium	Test set-up is isolated from the main loop System is cooling down (if applicable)	RCS Test set-up is isolated from HTF Main loop
			System is depressurised to the HICBS	
10	Isolation mode high pressure	Helium may be stored in test set-up	Test set-up is isolated from the primary loop System is pressurised	IHX Test set-up is isolated from CTF primary and secondary loops

G-3 of G-8

1.1.2 Example of a Test Specification

1.1.2.1 Description

IHX stress and life prediction model validation tests

1.1.2.2 Purpose

Model Finite Element Analysis (FEA) validation – accurate prediction of thermal profile throughout the core and structure, assures accuracy of the FEA stress maps.

1.1.2.3 Operating Test Conditions

The table below indicates the operating test conditions for the above mentioned test.

		Ø	E	T_in	T_out	T_delta	P_in	P_out	i L
No.	Components		[kg/s]	<u>د</u>	<u>.</u>	<u>C</u>	[Mpa]	[Mpa]	Fluid
	Primary Loop #1								
C1.1	Circulator	0.088	1.15	80	83	3	6	6	Helium
RX1.1	Recuperator (Hot)	3.4	1.15	760	218	542	6	6	Helium
RX1.1	Recuperator (Cold)	3.4	1.15	83	624	541	6	6	Helium
H1.1	Heater	1.7	1.15	624	950	326	6	9	Helium
TS1.1	Vessel - Test Station	0	1.15	950	950	0	6	9	Helium
DG1.1	Dust Generator	TBD	1.15	950	950	0	6	6	Helium
IHX1.1	Heat exchanger Vessel (primary)	1.34	1.15	<mark>950</mark>	<mark>760</mark>	<mark>190</mark>	<mark>6</mark>	<mark>6</mark>	Helium
IHX1.1	Heat exchanger Vessel (secondary)	1.34	1.15	704	<mark>006</mark>	<mark>196</mark>	<mark>6</mark>	<mark>9</mark>	Helium
CL1.1	Cooler	0.8	1.15	218	80	138	ი	6	Helium
	Secondary Loop #1								
TS1.2	Vessel -Test station	0	1.15	900	006	0	6	9	Helium
RX1.2	Recuperator (Hot)	3.7	1.15	900	279	621	6	9	Helium
RX1.2	Recuperator (Cold)	3.7	1.15	83	704	621	6	9	Helium
CL1.2	Cooler	1.2	1.15	279	80	199	6	9	Helium
C1.2	Circulator	0.058	1.15	80	83	3	6	9	Helium
LP1.2	LP Vent tank	0	TBD	TBD	TBD	TBD	6	6	Helium

G-4 of G-8

1.1.2.4 CTF Test Configuration

The configuration below will be the typical setup for above mentioned test.



G-5 of G-8

1.1.2.5 Specific Conditions for Test

- Stable control over inlet set points for temp, pressure, and flow. Uniform inlet temperature profiles, with temperature measurement rakes to confirm pattern factors. Traceable calibration facility provides mass flow, pressure, and temperature measurements.
- The CTF control system regulates a wide range of primary and secondary side delivery temperatures as well as mass flow and pressure to simulate typical NGNP conditions.
- The high temperature gas loop provides independent control over inlet flow rates, temperature and the secondary pressure. The control system provides PID control over 5 degrees-of-freedom.
- Strain gauges to be applied to the secondary inlet side, due to the more moderate temperatures.
- Six-degree-of-freedom control system to simulate equal or faster temperature and pressure transitions than that projected for the NGNP. Data sample rates 200 channels /second
- The rig tolerates repetitive cycles of simultaneous cut of electric power to the heater and primary circulator without damage to the electric elements. The secondary loop utilizes inventory blow-down to simulate the engine spool-down.
- The CTF is equipped with primary and secondary mass flow control, primary and secondary pressure control, and primary and secondary temperature control. An interactive central control and monitor system will be programmed to automate repetitive control of these control variables. This type of testing may result in IHX failure, resulting in the breach of the IHX pressure boundary. The CTF containment boundary is designed to tolerate IHX failures, and execute appropriate safety measures.

1.1.2.6 Quality Assurance Provisions

General Requirements

Quality Assurance shall be responsible to, independently, monitor all test and qualification activities. Quality Assurance shall ensure that the applicable procedures exist and that they are followed correctly during the test and qualification process and shall further verify:

- That the Test set-up conforms to the design requirement
- That all procedures have been followed during the commissioning, and operation of the test set-up.
- That all instruments have been issued with the necessary calibration certificates.
- That all procedures (according to the test instructions) have been followed during the execution of the test in the test set-up.
- The validity of all test results
- The correctness and completeness of the RSS Test report.

Test Roles and Responsibilities

The qualification board has the main responsibility for the test and qualification of systems and components in the CTF. The designated qualification specialist (DQS) will perform all test and qualification work. The following organizational structure shall be applicable for the tests performed in the test set-up.



The CTF operational engineers and the test set-up design engineers will be jointly responsible for the execution of the tests. No test will commence without the approval of these persons. A test register shall be kept at all times, and shall be signed by both parties before a test will commence.

The Designated Qualification specialist shall be responsible for:

- a) The preparation of the test set-up,
- b) The conditioning of the test set-up for a specific test
- c) Execution of the tests
- d) Recording of results
- e) Preparation of test report

The CTF operational personnel shall be responsible for:

- a) The preparation of the CTF primary and secondary loop for the specific test,
- b) The conditioning of the CTF loops for the specific test
- c) Support in conditioning of the test set-up for the specific test
- d) Support in execution of the IHX tests
- e) Monitoring of CTF loops and test set-up condition during the test
- f) Recording of results

g) Supply of results to the Designated Qualification specialist in paper or electronic format.

Safety Requirements and Considerations

The following will be required for test personnel.

- a) All test personnel must use safety clothes
- b) All relevant safety regulations and special conditions must be followed.

Calibration and Measurements

All temperature sensors/gauges, pressure sensors/gauges, flow meters and height measurement equipment shall be issued with a calibration certificate. The calibration certificates shall form part of the test report.

Test Documentation and Data

All test documentation and data for each test shall be available in paper or electronic format.

Test Report

A report will be generated after completion of the tests. The test report will include the results as well as recommendations (if any) to the design.