NGNP-20-RPT-002 Revision 0 January 2007

NGNP and Hydrogen Production Preconceptual Design Report

SPECIAL STUDY 20.2: PROTOTYPE POWER LEVEL

Revision 0

APPROVALS

Function	Printed Name and Signature	Date
Author	Eben Mulder M-Tech-Industrial (Pty) Ltd	29 January 2007
Reviewer	Jan van Ravenswaay M-Tech Industrial (Pty) Ltd	29 January 2007
Approval	Michael Correia Pebble Bed Modular Reactor (Proprietary) Ltd	30 January 2007

Westinghouse Electric Company LLC Nuclear Power Plants Post Office Box 355 Pittsburgh, PA 15230-0355

©2007 Westinghouse Electric Company LLC All Rights Reserved

LIST OF CONTRIBUTORS

Name and Company	Date
Kobus van der Merwe	January 2007
M-Tech Industrial (Pty) Ltd	
Fred Silady	January 2007
Technology Insights	
Dan Mears	January 2007
Technology Insights	
Andrew Kadak	January 2007
KADAK & Associates	

BACKGROUND INTELLECTUAL PROPERTY

Section	Title	Description
None		None

REVISION HISTORY

RECORD OF CHANGES

Revision No.	Revision Made by	Description	Date
0	Eben Mulder	Initial issue	January 30, 2007
	M-Tech-Industrial (Pty) Ltd		

DOCUMENT TRACEABILITY

Created to Support the Following Document(s)	Document Number	Revision
NGNP and Hydrogen Production Preconceptual Design Report	NGNP-01-RPT-001	0

LIST OF TABLES

Table 20.2.1:	Overview of PBMR-DPP Reference and Performance Data	. 35
Table 20.2.2:	PBMR-DPP Fuel Data	. 38
Table 20.2.3:	Cases - Power Level Configuration	. 42
Table 20.2.4:	VSOP-A and Tinte Steady-State Results	. 45
Table 20.2.5:	VSOP-A and Tinte DLOFC Results	. 45
Table 20.2.6:	Discriminating Criteria	. 46
Table 20.2.7:	Neutronics Performance Parameters	. 48
Table 20.2.8:	Thermal-hydraulics Performance Parameters	. 49
Table 20.2.9:	Volume versus Temperature Analysis during Normal Operation	. 50
Table 20.2.10:	Thermal-Hydraulics Performance during a PLOFC (9.0 MPa)	. 52
Table 20.2.11:	Thermal-Hydraulics Performance during a DLOFC	. 54
Table 20.2.12:	Volume versus Temperature Analysis during DLOFC	. 55
Table 20.2.13:	Overview of Maximum Temperatures Achieved during a DLOFC	. 56

LIST OF FIGURES

Figure 20.2.1:	The AVR in Jülich	. 22
Figure 20.2.2:	The THTR-300 Reactor in Hamm-Uentrop	. 23
Figure 20.2.3:	Schematic of the HTR-MODUL Design Layout	. 25
Figure 20.2.4:	TRISO Coated Fuel Particle	. 28
Figure 20.2.5:	HTR Pebble Fuel Layout	. 29
Figure 20.2.6:	PBMR-DPP Design	. 32
Figure 20.2.7:	Description of the PBMR-DPP Internals	. 33
Figure 20.2.8:	Side Reflector Regions of the PBMR-DPP	. 34
Figure 20.2.9:	Layout of the FCR	. 35
Figure 20.2.10:	Axial Power Profile in the PBMR-DPP Fuel Channel #1	. 36
Figure 20.2.11:	PBMR Fuel Design	. 37

ACRONYMS

20.2 Prototype Power Level Study	6 of 65 January 26, 2007
RCCS	Reactor Cavity Cooling System
	(of) high power (of the) channel (type)")
RBMK reactor	Reaktor Bolshoy Moshchnosti Kanalniy (Russian for "reactor
R&D	Research and Development
PLOFC	Pressurized Loss of Forced Cooling
РНР	Process Heat Plant
PCU	Power Conversion Unit
PBMR	Pebble Bed Modular Reactor
OLTI	Outer Low Temperature Isotropic Layer Thickness
NILE	1 Nile = 1% Δk_{eff}
NGNP	Next Generation Nuclear Plant
MWd/tHM	Megawatt days per ton heavy metal
MEDUL	MEhrfachDUrchLauf (German for multi-pass)
MAGNOX	Magnesium Non-Oxidising Reactor
LWR	Light Water Reactor
LEU	Low Enriched Uranium
K _{eff}	Effective multiplication factor
ILTI	Inner Low Temperature Isotropic Layer Thickness
HTR-MODUL	High-temperature Reactor – Modul (by Interatom/Siemens)
HTR	High Temperature Reactor
H/D	Height/Diameter
FCR	Fixed Central Reflector
DPP	Demonstration Power Plant
DLOFC	Depressurized Loss of Forced Cooling
CB	Core Barrel
3-D	Three dimensional
2-D	Two dimensional
BIRGIT	VSOP preprocessor
	Experimental Reactor)
AVR	Arbeitsgemeinschaft Versuchsreaktor (German for Jointly-operated
ASME	American Society of Mechanical Engineers

RCS	Reactivity Control System
RIT	Reactor Inlet Temperature
ROT	Reactor Outlet Temperature
RPV	Reactor Pressure Vessel
RSS	Reserve Shutdown System
THERMIX	A Computer Code for the Instationary Two-Dimensional Simulation of
	Thermal-Hydraulic Transients, e.g. in the Primary Circuit of Gas-Cooled
	Nuclear Reactors
THTR	Thorium High-temperature Reactor
TINTE	Time dependent Neutronics and Temperatures code
TRISO	Triple Coated Isotropic Particle
VSOP-A	Very Superior Old Programs – Augmented

TABLE OF CONTENTS

LIST	OF TABLE	ES	4		
LIST	IST OF FIGURES				
ACRO	ACRONYMS				
20.2	PROTOTY	YPE POWER LEVEL 1	10		
SUMN	IARY ANI	O CONCLUSIONS 1	10		
	Conclusion	n 1	13		
INTR	ODUCTIO	N 1	15		
	Backgrour Scope of th	nd1 ne Evaluation	15 17		
20.2.1	PEBBLE I	BED REACTOR DESIGN REQUIREMENTS AND SELECTIONS 2	20		
	20.2.1.1 20.2.1.2	Technology Basis	20 30		
20.2.2	PBMR-DP	PP DESIGN APPROACH AND SELECTIONS 3	31		
	20.2.2.1 20.2.2.2	PBMR-DPP Reactor 3 PBMR-DPP Fuel 3	31 37		
20.2.3	APPROA	CH TO NGNP POWER LEVEL 3	39		
	20.2.3.1 20.2.3.2 20.2.3.3	Overview of Design Approach	;9 ;9 ;9		
20.2.4	SIMULAT	TION TOOLS AND INPUT DATA 4	13		
	20.2.4.1 20.2.4.2 20.2.4.3	VSOP-A Description	13 14 15		
20.2.5	DISCRIM	INATING CRITERIA 4	16		
20.2.6	EVALUA	FION, RESULTS AND COMPARISON 4	17		
	20.2.6.1 20.2.6. 20.2.6.2 20.2.6. 20.2.6.3 20.2.6.	Normal Operation 4 1.1 Evaluation of Normal Operation Performance 5 Investment Protection 5 2.1 Evaluation of Performance during a PLOFC (Investment Protection) 5 Safety Performance (DLOFC) 5 3.1 Evaluation of Performance during a DLOFC (Safety Consideration) 5	17 51 53 53 56		
20.2.7	SUMMAR	Y AND RECOMMENDATION5	57		
REFE	RENCES		<u>59</u>		

BIBLIOGRAPHY	60
DEFINITIONS	61
REQUIREMENTS	62
LIST OF ASSUMPTIONS	63
TECHNOLOGY DEVELOPMENT	64
APPENDICES	65
APPENDIX 20.2.1 PRESENTATION TO BEA, "20.2 POWER LEVEL SPECIAL STUDY," DECEMBER 6, 2006	65

20.2 PROTOTYPE POWER LEVEL

SUMMARY AND CONCLUSIONS

The NGNP Project vision and mission is to assist in the launch of commercial deployment of a worthy hydrogen and electricity production facility using high temperature gas reactors. The NGNP scope of work states that the optimal size and design temperature for the reactor type shall be determined for a "commercial scale prototype reactor" for electrical power generation, optimal hydrogen production efficiencies and other industry applications of high temperature process heat. To achieve this mission, the Project must demonstrate key licensing, performance, economic and industrial infrastructure development objectives using a sound technology reference as base.

Given the advanced state of the PBMR in South Africa in terms of design, technology, licensing, project and infrastructure development, the strong recommendation of this power level study for a pebble bed-based NGNP is to build upon the PBMR 400 MW_{th} core design as the most appropriate baseline for the NGNP design. The PBMR project in South Africa will demonstrate an advanced Brayton cycle for all electric applications. The PBMR-based NGNP will demonstrate the Process Heat Plant (PHP) design referenced on the PBMR core design, but with a 950 °C reactor outlet temperature (ROT) targeted to support hydrogen production applications. Hence, the objective of this special study is to establish the appropriate power level for a commercial-scale PBMR-PHP for the NGNP in terms of whether it should be larger or smaller than the reference 400 MW_{th}.

The major design parameter difference between the proposed NGNP and PBMR demonstration plant is the difference between the reactor inlet temperature (RIT) and the reactor outlet temperature (ROT), i.e., 350 °C/950 °C for NGNP versus 500 °C/900 °C for the PBMR DPP. The full range of energy of the reactor is utilized by process heat applications on the top end and by power generation applications on the lower end respectively. It is important to note that in the approach to determine the NGNP power level the German fuel envelope of burnup-fluence-temperature and the limitation of having the maximum fuel temperature lower than 1250 °C during normal operation are still assumed. The aim is to perform no or limited R&D and design development for the NGNP to minimize impact on schedule.

In this special study eight different power level options were evaluated using the VSOP-A suite of codes to optimize the reactor power level via a parametric investigation following the variation of the RIT/ROT. The VSOP-A codes system provides a coupled neutronics and thermal hydraulic analysis and has been employed to perform the conceptual design of the PBMR-DPP, as well as the HTR-10 plant operated in China. During this phase of the preconceptual considerations only 2-D models of the various design scenarios were developed to provide an indication of the effect of the RIT/ROT variation under consideration.

Most of the critical parameters required to make design decisions are derived from the neutronics, such as neutron leakage, ensuring a stable core due to the xenon characteristics, burnup versus enrichment, maximum power in the fuel, etc. Closely coupled to the neutronics are the thermal-hydraulic parameters, such as the maximum and average fuel temperatures during normal operation and DLOFC conditions. Included in the analysis are the maximum and average RPV and CB temperatures achieved, especially during a DLOFC event. Also reported are the volumes of fuel to be expected at different temperatures.

During the conceptual design phase a number of interfaces are to be considered within the reactor in more detail for the selected power level. These would include the fixed central reflector with RSS borings, cooling design and housing, the annular fuel region, inner side reflector region with RCS borings, cooling design and housing, the outer side reflector region with cooling borings, CB, gaps, RPV, external air gap, RCCS, etc. These interfaces have all been addressed in the PBMR-DPP design and are considered in the preconceptual calculations performed for this special study. For purposes of this investigation a comparison among results of the eight cases considered is provided based on the DPP reference case.

The assumed reactivity shutdown margins are effectively based on the calculated capabilities and requirements of the PBMR-DPP. Temperature coefficients of reactivity and typical neutronics parameters are also assessed to provide the means of comparison between the selected cases investigated. During the conceptual phase the shutdown margins should be calculated specific for the selected power level. The insertion depth of the RCS during normal operation will depend upon a number of parameters, based on the normal operating conditions and load-following conditions to be decided between the client and the design team at the time.

The different options were evaluated according to the discriminating criteria shown in the table below to determine the most suitable option. Readiness, Performance during off design conditions and Capital Cost carried the most weight in the evaluation.

Criteria		Relative weight
Readiness	Technology enabling R&D (including fuel)	High
	Design development and schedule	High
Performance	Normal operation	Medium
	Investment protection (PLOFC)	Medium
	Safety consideration (DLOFC)	High
Cost	ost Capital cost (reactor, etc.)	
	Operating cost (including fuel cycle costs)	Medium

The following options under consideration in this study are firstly based directly on the PBMR geometry with no changes:

- DPP Case: 400 MW_{th}; RIT/ROT = 500/900 °C; \dot{m} = 179 kg/s;
- Case 1: 400 MW_{th}; RIT/ROT = 350/950 °C; \dot{m} = 119 kg/s;
- Case 2: 450 MW_{th}; RIT/ROT = 350/950 °C; \dot{m} = 134 kg/s;
- Case 3: 450 MW_{th}; RIT/ROT = 500/950 °C; \dot{m} = 179 kg/s;
- Case 4: 500 MW_{th}; RIT/ROT = $450/950 \circ C$; $\dot{m} = 179 \text{ kg/s}$;
- Case 5: 500 MW_{th}; RIT/ROT = $350/950 \circ C$; $\dot{m} = 149 \text{ kg/s}$;
- Case 8: 600 MW_{th}; RIT/ROT = $350/950 \circ C$; $\dot{m} = 179 \text{ kg/s}$.

Two cases were investigated with a single change in geometry, i.e., where the diameter of the fixed central reflector (FCR) is increased from 2.0 m to 2.4 m to lower the maximum fuel temperature during a DLOFC event:

- Case 6: 500 MW_{th}; RIT/ROT = 350/950 °C; FCR = 2.4 m;
- Case 7: 600 MW_{th}; RIT/ROT = 350/950 °C; FCR = 2.4 m.

Differentiation is provided in terms of normal operation, investment protection (PLOFC analysis), and safety consideration (DLOFC analysis). The results of the eight design cases analyzed were listed in terms of these three categories.

During normal operation all the cases were within the acceptable burnup limit while Case 7 exceeded the energy per fuel sphere limitation. Cases 1, 2 and 5 had a bigger margin for the maximum fuel temperature limitation than the other cases while Case 8 exceeded the maximum fuel temperature limitation. Case 7 has a smaller flow path area due to the increased fixed centre column and subsequently the pressure drop across the reactor for this case was higher which would result in a larger helium circulator.

For the investment protection (PLOFC) analyses all the cases except Case 8 were within the required set limitations.

The DLOFC analyses showed that during such an event the maximum fuel temperature for Cases 1 and 2 are below 1600 °C while Cases 5 and 7 have some of the core volume (less than 10 percent) at temperatures above 1600 °C and Case 8 had maximum fuel temperatures in excess of 1800 °C.

20.2 Prototype Power Level Study

Conclusion

Based on the analyzed cases, Case 5 with a power level of 500 MW_{th} with RIT/ROT of 350/950 °C is proposed for the conceptual design of the NGNP. The required R&D anticipated is limited to the qualification of the fuel performance for DLOFC operation up to 1700 °C by the time of plant construction. Further it is suggested to keep the geometry similar to the PBMR-DPP after careful consideration of the following motivating factors:

- The PBMR-DPP reactor can be immediately used as the basis for NGNP design within the operational envelope of the PBMR- DPP.
- The NGNP schedule will be met minimal R&D required.
- No or minimal design development required.
- A 25 percent higher power output is achievable for the NGNP reactor, without increasing the capital cost for the reactor and auxiliary systems and building from the base PBMR design.

In conclusion, a 500 MW_{th} reactor with a core inlet temperature of 350 °C and a core outlet temperature of 950 °C utilizing the PBMR-DPP geometry is recommended for the NGNP design and the follow-on commercial application.

While not addressed in the technical aspects of the power size selection summarized above, which is based on the reference PMBR-DPP design, the short-comings of achieving this mission with a small-scale (approximately 25-50 MW_{th}) NGNP test reactor are addressed below.

Achieving the performance demonstration objectives of the NGNP is critical for commercial acceptance and requires a commercial-scale or scaleable reactor. Whereas fuel performance can be effectively demonstrated in capsule irradiation and post-irradiation tests with controlled temperature and environmental conditions, an integrated annular core performance demonstration requires a commercial-scale reactor. Anything less than full-scale makes little sense for the NGNP, especially if the basic full-scale design and technology development programs exist to support the NGNP for pebble bed reactors.

Additionally, the proposed Licensing Strategy of the PBMR-based NGNP seeks to apply Part 52 rules to demonstrate the one-step licensing process. This strategy builds upon the PBMR-DPP reactor design, licensing and deployment experience. There is also high value added from PMBR efforts for early design certification of follow-on commercial projects. A small-scale NGNP test reactor project would do little to advance these objectives. For example, licensing a small-scale test reactor that does not demonstrate the annular core and does not confirm the basic neutronics and thermal hydraulics design codes for the commercial design which is based on an annular core is not of value. Alternatively, demonstrating a reduced-scale PBMR with an annular core is a step backwards since a full scale licensing of the technology is possible. Economic objectives for NGNP include minimizing the front-end development costs and risks as well as the product costs, particularly for follow-on commercial plants. For the PBMR, a small-scale NGNP test reactor would forego the benefits of building on the PBMR-DPP development investment in exchange for expected lower capital costs of the plant. Most important, the one-of-a-kind design development costs for a small-scale NGNP test reactor would have limited transfer value to any commercial design. Higher net costs are expected with building a small-scale NGNP test reactor when considered in the context of industry adoption of the technology. Unit capital, component and O&M costs for such a NGNP will all increase dramatically, compared to a full size NGNP, and the offsets to the first-of-a-kind costs for the commercial plant will be minimal. A small scale reactor will also not be able to demonstrate hydrogen production components and reliability sufficiently for commercial acceptance, and will not allow adequate testing of critical systems, structures and components.

Broad industry and government efforts are underway to form a utility and end-user-based NGNP Alliance as the private partner in a public/private partnership with DOE for deploying a commercial-scale NGNP. Such efforts are incompatible with a small-scale NGNP test reactor. With regard to industrial infrastructure development objectives, a small-scale NGNP test reactor would be a resource distraction. Thus, a small-scale NGNP test reactor has little value for advancing the overall objectives of the NGNP.

INTRODUCTION

Background

Results of an investigation are provided in this document of the recommended power level for the NGNP plant with a pebble bed high-temperature reactor. The decision to use a pebble bed reactor came from a special study performed as part of the NGNP preconceptual investigations to establish the best choice of reactor for near term deployment (Special Study 20.1).

The NGNP Project vision and mission is to launch commercial deployment of a worthy HTGR product(s). "The optimal size and design temperature for the reactor type shall be determined for a "commercial scale prototype reactor" for electrical power generation, optimal hydrogen production efficiencies and other industry applications of high temperature process heat." 1.

A Public/Private partnership has stated: "The NGNP Project will result in a full scale prototype that demonstrates the commercialization potential of the HTGR." 2.

To achieve this mission, the Project must demonstrate key licensing, performance, economic and industrial infrastructure development objectives using a mature technology reference as the base. The Westinghouse team has selected the PBMR-DPP 400 MW_{th} design as the reference for this special study in order to capitalize on as much as possible of the PBMR-DPP first-of-a-kind development experience. The short-comings of achieving this mission with a small-scale NGNP test reactor (approximately 25-50 MW_{th}) are addressed below.

The proposed Licensing Strategy of the PBMR-based NGNP seeks to apply Part 52 rules to demonstrate the one-step licensing process. This strategy builds upon the PBMR-DPP reactor design, licensing and deployment experience, plus it seeks the value for demonstrating such in support of early design certification for follow-on commercial projects. A small-scale NGNP test reactor would do little to advance these objectives. For example, licensing a small-scale test reactor that does not demonstrate the annular core and does not confirm the basic neutronics and thermal hydraulics design codes for the commercial design which is based on an annular core is not of value. Alternatively, demonstrating a reduced-scale PBMR with an annular core is a step backwards for the PBMR concept because of the predecessor PBMR-DPP experience.

Likewise, achieving the performance demonstration objectives of the NGNP is critical for commercial acceptance and requires a commercial-scale or scaleable reactor. Whereas fuel performance can be effectively demonstrated in capsule irradiation and post-irradiation tests with controlled temperature and environmental conditions, an integrated annular core performance demonstration requires a commercial-scale reactor.

Economic objectives include minimizing the front-end development costs and risks as well as the product costs for the NGNP and particularly for the follow-on commercial plants. For the PBMR, a small-scale NGNP test reactor would forego the benefits of building on the PBMR-

20.2	Prototyn	Power	I ovol	Study
20.2	1 rowyp	e I Uwer	Levei	Sinny

DPP development investment in exchange for the expected lower capital costs of the plant. Worse yet, the one-of-a-kind design development costs for a small-scale NGNP test reactor would have limited transfer value to any commercial design. Higher net costs are expected with building a small-scale NGNP test reactor when considered in the context of industry adoption of the technology. Unit capital, component and O&M costs for such a small scale NGNP test reactor will all increase dramatically and the offsets to the first-of-a-kind costs for the commercial plant will be minimal. Furthermore, four small reactors of block and pebble fuel types have been built in the past. The foundation of basic performance, safety and operational issues derived from small reactors is well proven. The issue is the application of these technologies in a new way that will directly demonstrate commercial scale capability of both the reactor and the coupled process heat applications.

With regard to industrial infrastructure development objectives, a small-scale NGNP test reactor would be a resource distraction. Infrastructure development within the utility and end-user sectors is being advanced by PBMR-specific commercial-based project development studies in concert with the NGNP Project. In addition, broad industry and government efforts are underway to form a utility and end-user-based NGNP Alliance as the private partner in a public/private partnership with DOE for deploying a commercial-scale NGNP. Such efforts are incompatible with a small-scale NGNP test reactor.

A small-scale (25-50 MW_{th}) NGNP test reactor has little value for advancing the objectives of the NGNP, particularly for the PBMR-based NGNP. Therefore the Westinghouse team recommends a power level of 500 MW_{th} , as selected in this study.

The major difference between the proposed NGNP and PBMR-DPP exists in the differences between the reactor inlet temperature (RIT) and the reactor outlet temperature (ROT) (i.e., 350 °C/950 °C versus 500 °C/900 °C). In addition, the reactor providing process heat will be operating at a fixed pressure as compared to the PBMR-DPP which operates at variable pressure.

The reactor design is characterized by passive safety, cost competitiveness, and by readiness for deployment. The passive safety utilizes the inherent characteristics of the HTGR fuel, coolant, and moderator by configuring the core geometry and selecting the power density to maintain radionuclide release within the fuel and core.

A set of discriminating criteria is defined to guide the selection of the plant size and geometry to be investigated in more detail. The criteria for the power level selection are grouped into performance during normal plant operation, investment protection of the plant, and overall safety of the facility.

In order to facilitate the process of decision making a description is provided of the PBMR-DPP, together with its calculated characteristics. This serves the purpose of providing a basis for comparison with other alternative power levels and configurations. The alternatives are grouped into those requiring no additional R&D, minimum incremental R&D, and modest additional R&D to that underway for the DPP. The latter group also could require additional design development.

Scope of the Evaluation

Firstly a description of Pebble Bed Modular Reactor (PBMR) overall design requirements and the technological basis and characteristics of the design are provided. Next a description is provided of the PBMR-DPP design approach that includes the reactor and the fuel of the PBMR-DPP.

Following this the approach to the NGNP power level is described including the different cases under consideration. This is followed by an overview of the simulation tools and models used to perform the design calculations.

A set of discriminating criteria, with weighting factors, is then defined in order to assist in the selection of the NGNP power level. Following this the results for the different cases under consideration are presented and a selection is made of the NGNP power level.

Based on the outcome of the investigations it became apparent that a functional classification could be performed in terms of varying degrees of research and development (R&D) required for NGNP:

- No R&D required Here it is assumed that the PBMR-DPP is adequately proven by planned tests. The PBMR-DPP reactor is assumed as is. The NGNP PCU will have to be adapted for operation at constant pressure with an intermediate heat exchanger, while some characteristic adjustments are anticipated to optimize the power operation.
- Minimal level of R&D Re-evaluation of existing data, such as the fuel experimental data might be necessary. Should the test envelope of individual components in the equation be stretched, such as the maximum fuel temperature achieved, or the maximum time achievable at specified temperatures, additional calculations might be required to support or validate the attained conditions.
- Modest R&D Minor deviations from the PBMR-DPP geometry, such as the thickness of the fixed central reflector column are foreseen. Due to the anticipated impact on interfacing systems, such as the discharge chutes, careful consideration should be exercised when opting for such changes.

During this preliminary phase the investigation into the power level for the NGNP power plant is performed for the power conversion unit (PCU) mass flow conditions at 97 percent of the mass flow required for the selected power rating with a ROT of 950 °C and a RIT of 350 °C. An optimized pressure for the PBMR-DPP design has been selected as 9.0 MPa. For purposes of providing a decision matrix the equilibrium cycle calculations have been performed for the PBMR-DPP geometry:

• DPP Case: 400 MW_{th}; RIT/ROT = 500/900 °C; \dot{m} = 179 kg/s;

20.2	Prototyne	Power	Level	Study
20.2	1 rowypc	10//01	Luru	Sinny

The following three cases assume a PCU with helium mass flow of 179 kg/s and fixed ROT of 950 $^{\circ}$ C:

- Case 3: 450 MW_{th}; RIT/ROT = 500/950 °C; \dot{m} = 179 kg/s;
- Case 4: 500 MW_{th}; RIT/ROT = 450/950 °C; \dot{m} = 179 kg/s;
- Case 8: 600 MW_{th}; RIT/ROT = 350/950 °C; \dot{m} = 179 kg/s.

The following three cases assume a fixed RIT/ROT of 350/950 °C:

- Case 1: 400 MW_{th}; RIT/ROT = 350/950 °C; \dot{m} = 119 kg/s;
- Case 2: 450 MW_{th}; RIT/ROT = 350/950 °C; \dot{m} = 134 kg/s;
- Case 5: 500 MW_{th}; RIT/ROT = 350/950 °C; $\dot{m} = 149 \text{ kg/s}$.

Two cases were investigated with a single change in geometry, i.e. where the diameter of the fixed central reflector (FCR) is increased from 2.0 m to 2.4 m:

- Case 6: 500 MW_{th}; RIT/ROT = 350/950 °C; FCR = 2.4 m;
- Case 7: 600 MW_{th}; RIT/ROT = 350/950 °C; FCR = 2.4 m.

The reactivity control and shutdown characteristics in terms of requirements and capability will be somewhat different for the various designs but will only be considered in more detail as the power level and reactor design selection become fixed.

Furthermore, characteristics of the procedure for loading to first criticality, starting up the reactor and run-in will be topics of basic or even detailed design and will not be further discussed in this document. Experience suggests, however, that an equilibrium design will be the prerequisite for a first core layout.

The most important parameters of the coupled neutronics and thermal-hydraulics characteristics were evaluated of the selected spectrum of reactor designs. Originally the cases were selected based on the following criteria:

- Maintaining a helium mass flow similar to the PBMR-DPP to ensure minimal change to the PCU.
- A RIT/ROT of 350/950°C was assumed to provide a suitable range for the process heat applications and hydrogen production.

• Assume a small change in the fixed central reflector diameter, but with accompanying reduction of the fuel annulus from 0.85 m to 0.65 m. This is easily achievable in a pebble bed reactor with its associated benefits and penalties to be considered.

20.2.1 PEBBLE BED REACTOR DESIGN REQUIREMENTS AND SELECTIONS

As part of the design of a Pebble Bed Reactor a number of design requirements are important to ensure safe operation and controllability during normal and off normal conditions. Off-normal operating conditions imply the uninhibited release of decay heat. Under these conditions the maximum fuel temperature should not achieve temperatures that would lead to fuel damage.

For normal operation these design requirements include:

- Operation within the German LEU fuel test envelope.
- Operation to ensure that the maximum fuel temperature is lower than 1250 °C 6.
- Maintain inlet temperature to avoid Wigner energy buildup.
- Limit velocity through graphite orifices in the reactor core structures to less than 100 m/s.
- Ensure that the Core Barrel (CB) and Reactor Pressure Vessel (RPV) material temperature constraints are met.
- Utilize Fixed Central Reflector (FCR) to provide RSS insertion location.
- Provide control and shutdown in side reflector.
- Utilize steel RPV for passive decay heat removal.

During off normal operation the reactor is designed to achieve passive heat removal during Pressurized and Depressurized Loss of Forced Cooling Events (PLOFC and DLOFC) and to ensure that during these off normal operating conditions that the reactor metallic components such as the RPV and CB are maintained within acceptable temperatures. A primary design consideration is the fuel temperature and the aim is to limit the fuel temperatures to acceptable values.

20.2.1.1 Technology Basis

Gas cooled, graphite moderated reactor plants have been developed and constructed during the past 65 years leading to initial commercial deployment of 18 Magnox Plants with a total of 37 reactor units in the UK, France, Japan, Italy and Spain and 8 Advanced Gas Cooled Reactor Plants with a total of 15 reactor units in the UK.

Three developmental High Temperature Gas Reactor (HTGR) plants were constructed and operated in the initial round of deployments during the 1960s. These HTGR plants all used ceramic coated fuel particles with graphite as moderator and helium cooling. These reactors are listed in the table below.

20.2 Prototype Power Level Study

January 26, 2007

Reactor	Country	Power Level	Core type	Core outlet temp [°C]	Date Critical
Dragon Reactor Experiment	UK/OECD	20 MW _{th}	Prismatic	750	1965
Peach Bottom No.1	U.S.A	115 MW _{th}	Prismatic	725	1966
AVR	Germany	46 MW _{th}	Pebble	850/950	1967

The NGNP design is to be primarily based on the PBMR-DPP technology developed over the past eight years in South Africa. This technology is, however, based on the High Temperature Reactor technology developed over a period of two to three decades in Germany, especially at the Research Centre in Jülich.

In Figure 20.2.1 a depiction is presented of a German experimental reactor, the AVR (ArbeitsgemeinschaftsVersuchsReaktor) in Jülich, that came on-line in December 1967 4, 5. Amongst others, this reactor served as a test bench for a large number of fuel variations (22 in total). During the time of its initial operation the variations in level of enrichment, burnup, heavy metal loading, etc., would lead to relative uncertainty of primary parameters, such as criticality. Motivated by the inter-related parameters of cost, thermal and nuclear loading, a flat radial temperature profile had to be achieved by diluting the fissile packing density from the central area to the outside. This would be achievable by introducing depleted fuel spheres into the centre column area.

Apart from the flat axial power profile achievable under the MEDUL (MEhrfachDUrchLauf = German for multi-pass) fuelling scheme the possibility would be offered of simple correction by adding fuel spheres in the event of sub-criticality and/or de-fuelling in the event of super-criticality, while feeding depleted fuel into the centre fuelling tube would enhance the radial temperature flattening effect.



Figure 20.2.1: The AVR in Jülich

Two demonstration HTGR plants listed in the table below featuring a pre-stressed concrete reactor vessel and a HEU-Th fuel cycle were also constructed and operated during the 1970s and 1980s.

Reactor	Country	Power Level	Core type	Core outlet temp [°C]	Date Critical
Fort St. Vrain	U.S.A.	842 MW _{th}	Prismatic	775	1976
THTR-300	Germany	750 MW _{th}	Pebble	750	1985

The German prototype reactor, the THTR-300, depicted in Figure 20.2.2, was constructed between the period 1972 to 1984. It achieved its layout power output of 300 MW_e towards the end of 1985. A unique feature deployed in the THTR had been the use of in-core control rods for neutronic control and reactor shut down. This characteristic, however, bore the uncertainty of thermal-hydraulic and neutronic behavior, associated with the phenomenon of pebble bed (675,000 fuel elements) compaction following the insertion activity of the in-core rods. Once again, the choice of MEDUL fuelling offered a welcome solution in providing a pebble bed which would be effectively rearranged in accordance with the multiple passage of fuel through the core. Furthermore, the same radial temperature flattening arguments used in the case of the AVR were employed in the safety philosophy of the THTR. The MEDUL scheme would thus be equally effective in achieving this goal.



Figure 20.2.2: The THTR-300 Reactor in Hamm-Uentrop

HTGR development in Germany and the USA throughout the 1970s was focused on large HTGR steam cycle plant designs. In the USA, there were five twin plant orders for such HTGR units, which ranged from 770 MW_e to 1160 MW_e. Licensing with the NRC had advanced to the issuance of a Limited Work Authorization for one of the contracts. However, three of the contracts were canceled by the utility due to an economic recession and the remaining two contracts were then terminated by the vendor as the outlook for commercial deployment had faded.

In the early 1980s, the Germans introduced the Modular HTGR concept as an alternative approach to optimizing HTGRs based on inherent safety characteristics of the fuel, graphite and helium plus passive design features derived from a reduced core power level such that a passive cooling system will preclude fuel damage for the limiting licensing basis events. As a result, a paradigm shift for HTGR development has evolved whereby competitiveness relies on capitalizing on the enhanced safety features to reduce the safety and regulatory demands on capital and O&M costs plus capitalize on the economies of simplicity and incremental, modular deployment and close-in siting – all which are best suited for the small-to-medium power and process heat markets.

In the 1980s, Germany, Russia and the USA developed designs of the steam cycle Modular HTGR. These all featured steel reactor vessels which were embedded or partially embedded below grade. Leading designs are noted in the table below, but none were constructed. However, the HTR-Module achieved a concept license from the German regulator.

Reactor	Country	Power Level	Core type
HTR-MODUL	Germany	200 MW _{th}	Pebble
MHTGR	USA	Initially 250 MW_{th} , upgraded to 350 MW_{th} and then to 450 MW_{th}	Prismatic
VGM	Russian	200 MW _{th}	Pebble

In Figure 20.2.3 the HTR-MODUL steam cycle conceptual design is schematically depicted. Though not constructed this concept was licensed by Siemens in 1987 7. Based on the premise that the thermal evacuation capability of the pressure vessel should exceed the decay heat production of the core in the post event condition, Lohnert and Reutler in 8 proposed a cylindrical core layout with height: diameter ratio of 3:1. In this layout it is of prime importance to achieve a relatively flat axial core power distribution. At the time of its inception the only known fuelling scheme that would guarantee such a power profile was the MEDUL fuelling regime.



Figure 20.2.3: Schematic of the HTR-MODUL Design Layout

To demonstrate HTGR safety and technology and investigate high temperature process heat applications, two small test reactors were designed and constructed in the late 1990s in Japan and China, as summarized in the table below.

Reactor	Country	Power Level	Core type	Core outlet Temp [°C]	Date Critical
HTTR	Japan	$30 \mathrm{MW}_{\mathrm{th}}$	Prismatic	950°C	1998
HTR-10	China	10 MW _{th}	Pebble	900°C	2000

During the 1990s and up to now, HTGR designs and technology development have continued to advance in the RSA, USA, Russia, France, Japan, China and elsewhere with predominate focus on commercial-scale deployment. Interests in further small-scale HTGR deployment are limited to universities and institutes seeking a mission in technology development, testing and training. Albeit of the long-term value, such interests can distract the focus of limited government resources in support of near-term, commercial-scale deployment. In addition, there are budget-driven considerations of being able to achieve commercial scale deployment objectives with a reduced scale, but scaleable, demonstration project. The PBMR position on such follows.

PBMR-DPP Technology Development Path

The initial conceptual design of the PBMR reactor was for a core power of 200 MW_{th}, which was the chosen power level for the German HTR-Modul reactor designed by the HTR GmbH consortium. The HTR-Modul had a core diameter of 3.0 m with a core height of 9.4 m, and a steam generating secondary cycle. The PBMR chose a direct-cycle gas turbine plant with higher core inlet and outlet temperatures (RIT/ROT = 500/900 °C) than the HTR-Modul (RIT/ROT = 250/700 °C) plant. The core geometry of the HTR-Modul with its adapted thermal hydraulic flow path would allow a power level of only 170 MW_{th} when coupled directly to a gas turbine power generating system as described above. After introducing an adapted core fueling strategy to achieve a 2-zone core layout the power level was increased to 190 MW_{th}. In order to increase the thermal power output of the reactor, the core volume had to be increased. Without increasing the core height and power density, it implied that the diameter of the core had to be increased.

It was also a design objective that the control elements would only be located in the reflector. To ensure sufficient reactivity coupling with the active core, an increase in the diameter of the core to 3.5 m necessitated the use of the so-called reflector noses (similar to the AVR core design). These noses were protrusions of the reflector into the active core with the control elements operating in borings close to the front part of the noses as per the German AVR design. This concept permitted an increase in power to 220 MW_{th} .

In February 1998 it was decided that an annular core geometry would be pursued. A core geometry consisting of a dynamic central reflector with a nominal diameter of 1.75 m of graphite spheres moving as part of the core was chosen. The core outer diameter was fixed at 3.5 m and the effective core height was set at 9.0 m. This design yielded a power level of 268 MW_{th}. In the 268 MW_{th} reference design, the reactor pressure vessel was approximately 6.2 m in diameter, approximately 20.5 m high. The core cavity had a diameter of 3.5 m and an effective height of 8.5 m.

From the initial cost estimates obtained from the suppliers of main components, it was clear that the capital cost of the nth plant exceeded the initial targets. A Value Engineering Investigation was initiated to determine the extent to which the power could be upgraded within the general physical envelope of the 268 MW_{th} reference design. It was found that the core

thermal power could be increased to 302 MW_{th} within the same reactor pressure vessel inside diameter by increasing the core effective height from 8.5 m to 9.04 m. The thickness of the outer reflector and thermal shield was reduced to a total thickness from 1.0 m to 0.9 m, since the optimum reflector capabilities from a neutronics design perspective would be acceptable.

Following this investigation, further in-depth nuclear source term analyses showed that the core coolant bypassing the active core through the core structures and the graphite dynamic central reflector was on the order of 48 percent. Of this value, the leakage through the dynamic central reflector amounted to 28 percent. This bypass resulted in an increase of approximately 150 °C in the maximum operating fuel temperature. Since the diffusion coefficient of the fission products silver and cesium through intact coatings surrounding the fuel kernel is strongly dependent on the temperature, this increase in operating fuel temperature resulted in an increase of such releases during normal operation by two to three orders of magnitude compared to the 268 MW_{th} reference design. Further investigations confirmed that the increased silver and cesium releases would result in contamination that would necessitate the use of remote handling equipment during maintenance operations on PCU components.

As stated before, the initial decision to implement the dynamic central reflector design was based on limited knowledge of the behavior of the graphite core structures under irradiation. At this stage, more insight into the graphite behavior were becoming available, and it was clear that the core structures design had to provide for a mid-life replacement of the outer reflector part adjacent to the active core.

An opportunity was then provided for considering a core with a fixed central reflector of a design that provides for mid-life replacement of the part adjacent to the active core. The outcome of this investigation was a core with the following characteristics:

- Core outer diameter of 3.7 m, a fixed central reflector with a diameter of 2.0 m and an effective nominal height of 11 m.
- A core thermal power of 400 MW_{th}.

An additional core physics benefit gained from the use of a solid central reflector was the possibility to include reactivity control elements in the central reflector. It was then decided to redesign the placement of these elements with the objective of matching or improving on the shutdown capability of the previous 268 MW_{th} reference design.

Hence, 400 MW_{th} is the power level for the PBMR-DPP and is the baseline case for the Process Heat Plant power level study, leading to the selected NGNP power level of 500 MW_{th} .

PBMR-DPP Technology Growth Path

The PBMR technology path has substantial potential beyond the initial PBMR-DPP capabilities to be applied in early deployments for process heat and electrical generation. The technology growth path is a direct application of the PBMR-DPP from a physical building,

support systems and equipment layout perspective, and a logical development in high-temperature materials, turbo-machinery evolution and advanced fuels within the same physical boundaries.

Beyond the near-term PBMR-PH deployment, the eventual design goal is to increase the reactor outlet temperature (ROT) to 1000 °C and beyond plus increase the reactor power level to $\sim 600 \text{ MW}_{\text{th}}$ with design development and additional R&D. To accommodate the higher reactor power level and the increased ROT, ceramic based materials will have to be investigated to be used for a number of components such as the hot duct liners of the hot pipes and the control rods.

Basic to the design development, bounded by the points mentioned above, were the development of a fuel concept with enriched uranium and the selection of a favorable coolant, such as helium.



Figure 20.2.4: TRISO Coated Fuel Particle

The main characteristic of the HTR fuel development is the many small fuel particles, each of which is surrounded by a porous buffer layer and two pyrolytic carbon layers. In Figure 20.2.5 the fuel particles embedded within a graphite matrix are seen. The latest development, the so-called TRISO coated particle (depicted in Figure 20.2.4), denotes the inclusion of a highly refractory silicon carbide layer positioned between two pyrolytically deposited carbon layers. The

layers form a strong barrier against the release of fission products from within the coated particle. During heat-up experiments performed at the Research Center, Jülich during the fuel development program throughout the sixties, seventies, and eighties, emphasis was placed on maintaining intact fuel particles up to 1600 °C. In addition limited tests were run in the range of 1600 °C to 2000 °C with generally favorable results.

After burnup of the fuel the pebble configuration provides an excellent packaging of the radio-active waste material (see Figure 20.2.5).



Figure 20.2.5: HTR Pebble Fuel Layout

20.2.1.2 Safety Characteristics

Five special features characterize the reactor neutron physics and thermal hydraulics layout of the PBMR-DPP:

- The temperature coefficient comprises the temperature-dependent resonance absorption of U-238, the moderator, and the reflector regions, which includes the fixed central reflector. This coefficient is strongly negative, despite the slight positive reactivity contribution of the reflector due to the decreased absorption cross-section of graphite with increased temperature.
- In normal operation, this effect stabilizes the chain reaction. If the fuel is heated, during normal operation or in an upset event, the enhanced neutron absorption causes the chain reaction to decay. This inherent property of control is independent of the physical operation of reactor equipment, because it is solely based on the inherent characteristics embedded in the specific reactor physics.
- The core is annular with a graphite reflector on the outside and a graphite reflector on the inside.
- The reactivity control and reserve shutdown elements used in this design are located in the side reflector and fixed central reflector regions, respectively (See Figure 20.2.9).
- In the PBMR-DPP Brayton cycle design, a limited amount of cooling water provides heat removal at pressures lower than the main operating system pressure at all times during operation. A reactivity excursion resulting from accidental water ingress into the core region is therefore limited due to the design.
- Residual heat can be removed solely by thermal conduction, thermal radiation and natural convection to a Reactor Cavity Cooling System (RCCS) outside the Reactor Pressure Vessel (RPV) in all operating and upset conditions. The fuel temperature is limited by suitable core design to remain at all times below the maximum allowable fuel temperature.

In the reactor, the central reflector comprises of graphite only. In this way the thermal flux is forced towards the side reflector, with the following two associated advantages:

- It increases the efficiency of the Reactivity Control and Shutdown System (RCSS), which is located in the side reflector.
- The maximum fuel temperature is lower in the event of a DLOFC. This is due to the fact that the decay heat travels a shorter distance from the fuel through the reflector to the outside, via passive transport mechanisms (conduction and radiation).

For reasons of safety, the fuel temperature must under all postulated events, be kept below a predefined temperature limit.

20.2 Prototype	Power Level	Study

20.2.2 PBMR-DPP DESIGN APPROACH AND SELECTIONS 20.2.2.1 PBMR-DPP Reactor

The PBRM-DPP reactor has a power level of 400 MW_{th} with a reactor inlet temperature (RIT) of 500 °C and a reactor outlet temperature (ROT) of 900 °C. The average power density of the PBMR-DPP is 4.77 MW/m³. Given the RPV size the highest power level was selected for a direct cycle gas turbine with a RIT/ROT of 500/900 °C. The maximum fuel temperature during a DLOFC would determine the maximum power level at which the reactor would operate long term.

The PBMR-DPP (as shown in Figure 20.2.6) design approach was to consider the largest available RPV at the time that could be manufactured by more than one company to reduce the risk of single supply. An inner diameter of 6.2 m for a RPV designed to operate under a pressure of 9.0 MPa would require a wall thickness of 0.18m. This specification determined the size of the construction crane to be available.

The Core Barrel has an inner diameter of 5.8m with a wall thickness of 0.05 m and is manufactured using 316 stainless steel to ensure core stability.



Figure 20.2.6: PBMR-DPP Design

Figure 20.2.7 shows a layout of the PBMR-DPP internals. The reactor internals consist of a side reflector, shown in more detail in Figure 20.2.8, that comprise an inner block of thickness 0.4m and an outer block of thickness 0.5 m. The inner blocks house 24 RCS channels and the outer blocks 36 riser channels feeding helium into the core cavity. The replacement limit of the inner reflector is equivalent to a fast neutron fluence of 2.2×10^{22} at 800 °C. The 0.90 m thickness of the side reflector (0.775 m solid thickness) is the optimal thickness with regards to neutron economy and capital cost. The reflector blocks are kept in position by the core barrel.



Figure 20.2.7: Description of the PBMR-DPP Internals

No. Component

- 1 Core support structure Engineered for support of the fixed central reflector
- 2 Expansion compensator compensate for thermal expansion of the bottom plate
- 3 Bottom reflector designed to house the hot gas chamber and slots for exiting helium
- 4 Fuel discharge cone min. angle of 23 °C to prevent pebble blockage
- 5 Core barrel sides for fixing the CB and to hold in position
- 6 Side reflector (inner and outer)
- 7 Centre reflector
- 8 Top reflector designed for helium inlet flow, shielding of the top metallic components
- 9 Core barrel top plate helps to maintain structural integrity
- 10 Main inlet plenum helium into riser channel in side reflector (due to high temperatures in direct cycle)
- 11 Main outlet plenum hot helium outlet

20.2 Prototype Power Level Study

The annular core cavity has a thickness of 0.85 m and is charged from the top reflector region through three loading points. The annular core thickness ensures that there are no azimuthal Xenon swings in the reactor and that reactivity control is possible from the side reflector. The bottom reflector region houses three discharge tubes.



Figure 20.2.8: Side Reflector Regions of the PBMR-DPP

Figure 20.2.9 shows the layout of the fixed centre column. The FCR has a diameter of 2.0 m and its design is optimized for coupled Thermal-Hydraulics and Neutronic performance as well as Safety. The FCR houses the Reactivity Shutdown System channels.



Figure 20.2.9: Layout of the FCR

The PBMR-DPP has an effective core height of 11.0 m, with the height/diameter (H/D) ratio of 2.97. Table 20.2.1 provides an overview of the PBMR-DPP reference and calculated performance data.

Table 20.2.1:	Overview of PBMR-DPP Reference and Performance Data	

Description	Units	PBMR-DPP
Design Parameters:		
Thermal power rating	MW	400
Core diameter	m	3.7
Average core height	m	11.0
Uranium content per fuel sphere	g/FS	9
Average burn-up	MWd/t U	94 800
Fuelling regime		Multiple passage (6x)
Average residence time in- core	d	954
Assumed cold by-pass flow	%	7*
Number of fuelling zones		1
Moderation ratio (avg. in core)	N _C /N _U	428
Avg. packing fraction in the pebble bed	%	61
Number of fuel spheres		451 562
Fuel spheres:		
Pebble radius	cm	3.0

20.2 Prototype Power Level Study

January 26, 2007

Description	Units	PBMR-DPP
Design Parameters:		
Thickness of fuel free zone	cm	0.5
Density of graphite in matrix / fuel free zone	g/cm ³	1.75
Enrichment of uranium (N_{U5}/N_U)	%	9.6
Coated particles:		
Particle diameter	μm	500
CP Density	g/cm ³	10.4
Coating material		C / C / SiC / C
Layer thickness	μm	95 / 40 / 35 / 40
Layer densities	g/cm ³	1.05 / 1.90 / 3.18 / 1.90

Note: *The cold by-pass flow is comprised of 3 percent core barrel annulus leakage of the main inlet flow and 4 percent of the main flow directly leaking from the inlet to the outlet chamber.

The six-fold recycling of each fuel sphere through the core results in a variation in average burn-up from top to bottom of the core of approximately 15,833 MWd/t U, and therefore maintains the maximum power density to within design limits. The power is also limited in the upper region of the core by the 24 control rods that are partially inserted into the side reflector during full-load operation. The power density distribution is provided as a power profile in a typical position as modeled in VSOP-A. This profile is expressed as the power produced in a layer divided by the average power produced in the core [see Figure 20.2.10].



Figure 20.2.10: Axial Power Profile in the PBMR-DPP Fuel Channel #1

20.2 Prototype Power Level Study
20.2.2.2 PBMR-DPP Fuel

The spherical PBMR fuel element is cold pressed from matrix graphite, which is a mixture of natural graphite, electrographite, and a phenolic resin that acts as binder. It consists of an inner region that contains fuel in the form of spherical coated particles embedded in the matrix graphite. A shell of matrix graphite that does not contain any fuel surrounds the inner region.

A coated particle consists of a spherical uranium dioxide kernel surrounded by four concentric coating layers. The first layer surrounding the kernel is a porous pyrocarbon layer, known as the buffer layer. An inner high-density pyrocarbon layer, a silicon carbide layer, and an outer high-density pyrocarbon layer follow this layer. The layers are deposited sequentially by dissociation of gaseous chemical compounds in a continuous process in a fluidized bed.

Figure 20.2.11 shows the design of the PBMR fuel sphere. Nominal characteristics for a PBMR fuel sphere are shown in Table 20.2.2.



FUEL ELEMENT DESIGN FOR PBMR

Figure 20.2.11: PBMR Fuel Design

Characteristic	Unit	Nominal Value
Fuel Sphere:		
Geometry	-	Spherical
Fuel sphere diameter	mm	60
Fuel region diameter	mm	50
Fuel-free region thickness	mm	5
Heavy metal loading	g/FS	9
Uranium enrichment	% U-235	9.6 (equilibrium core)
Coated Particle:		
Kernel diameter	μm	500
Buffer layer thickness	μm	95
Inner Low Temperature Isotropic (ILTI) layer thickness	μm	40
SiC layer thickness	μm	35
Outer Low Temperature Isotropic (OLTI) layer thickness	μm	40

Table 20.2.2: PBMR-DPP Fuel Data

20.2.3 APPROACH TO NGNP POWER LEVEL

20.2.3.1 Overview of Design Approach

An early decision taken is to employ the knowledge and understanding gained from the PBMR-DPP reactor and fuel design as far as possible. Due to the fact that for purposes of the process heat application the RIT/ROT temperature regime will be changed from 500/900 °C to 350/950 °C the opportunity is created to employ the full energy range. This implies using the top end of the energy range for process heat [about 750 – 950 °C], whilst the lower end can be used for generating power/electricity [about 350 - 750 °C].

Regarding the use of pebble fuel it was decided to assume the German LEU fuel test envelope during normal operation. This implies that during normal operation the design should be within the fluence-temperature dependent burn-up envelope and that the maximum fuel temperature should be maintained below1250 °C.

Any deviations from the PBMR-DPP reactor or fuel design would result in additional R&D or design development. In order to address the R&D and design development the requirements were classified according to the following criteria: No R&D or design development, Minimal R&D and design development and Modest R&D and design development.

For the reactor power output the discriminating decision is to use the largest reactor power without any additional R&D or design development beyond the PBMR-DPP design. This implies that the current PBMR-DPP reactor geometry is used as is with varying RIT/ROT while maintaining the maximum fuel temperature below 1600 °C during DLOFC conditions.

For the cases with Minimal R&D and design development (i.e., some fuel qualification), the PBMR–DPP geometry was adopted as is and the maximum fuel temperature during a DLOFC event was kept below 1700 °C for a limited time during the DLOFC event. This would result in some fuel qualification for temperatures below 1700 °C.

For the cases with Modest R&D and design development the maximum fuel temperatures were maintained below 1700 °C for limited times during DLOFC and the outer reactor diameters were maintained while increasing the FCR thickness from 2.0 to 2.4m to lower the maximum fuel temperatures during DLOFC conditions. This change in FCR diameter will impact the design for the fuel chutes and possibly other reactor components.

20.2.3.2 Design Selections That Influence Core Power

The core power level is directly proportional to the product of the mass flow rate, specific heat capacity of the working medium, and the rise in temperature over the core. Of prime consideration in the design of the reactor are the maximum and average temperatures achievable by the fuel as well as the metallic components. Since the reactor structural components are of ceramic materials much higher temperatures are tolerable than for the metallic components.

The design selection parameters influencing the core power level are classified as follows:

During normal operation the following parameters are of importance:

- Mass flow rate This parameter determines the amount of heat that will be transported from the heat source. In a pebble bed reactor the pressure drop over the core will determine the blower power that will in turn be supplied from the grid.
- Core temperature rise The mass flow rate and temperature rise or heat-up over the core are directly proportional to each other, since the specific heat capacity of helium almost remains constant over the specific temperature regime. If the heat-up over the core becomes smaller, for example, the mass flow rate will increase for the same power level.
- Maximum and average fuel temperatures As the mass flow rate changes over the core the maximum and average fuel temperature in the core will change accordingly. A certain minimum mass flow rate needs to be maintained to ensure that the correct fuel temperatures can be derived in the pebble bed core, since fuel temperatures are only induced.

During a PLOFC event, natural circulation will be induced due to the pressure within the reactor. In a direct cycle the pressure will reduce to a level of equalization, but in the case of the NGNP the pressure is anticipated to remain constant as it is foreseen that the NGNP will be an indirect coupled plant. In this event the following parameters are of importance:

- Metallic reactor internals time-at-temperature The core barrel, RPV, and control rod cladding are the metallic components that need to be carefully considered from a design perspective. According to the ASME rules certain limits are applicable for specific stresses. These rules need to be observed, in particular during off-normal operational conditions due to thermal or mechanical loads. Other rules are also applicable for special designs, such as the hot pipes exiting the reactor.
- Reactor vessel time-at-temperature The RPV is designed according to ASME III rules as a usual reactor pressure vessel. During normal operation the temperatures are maintained within limits known by experience as a function of the fast fluence.

During a DLOFC event the pressure is reduced to ambient conditions. In the design of the reactor the decay heat is considered to be released without the credit of a decay heat removal system. Here the balance between the heat removal capacity of the reactor internals, RPV, and the reactivity core cooling system (RCCS) is calculated. The design of the reactor is performed to minimize the loss of heat during normal operation but to maximize the loss of heat during a DLOFC in order to protect the integrity of the fuel. In the complex series of calculations the following parameters are considered:

• Maximum fuel time-at-temperature which is influenced by

- Effective outer core diameter determined by:
 - Vessel diameter, shipping weight, and supplier infrastructure.
- Emissivities of the graphite and metallic components influencing the heat radiation.
- Effective core height determines:
 - Core pressure drop.
 - Axial neutronic stability.
 - Center reflector structural design.
- Annular active core thickness.
 - Control rod effectiveness.
- Thermal conductivity of the fuel and reflector graphite as a function of fast fluence and temperature.
- \circ Power density.
- Normal operation average fuel temperatures.
- Metallic reactor internals time-at-temperature Similarly to the PLOFC case the ASME rules need to be observed, but for DLOFC pressure and temperature conditions applied.
- Reactor vessel time-at-temperature The ASME rules apply for temperatures achieved at ambient pressure.

20.2.3.3 Evaluation Scope

Table 20.2.3 provides a listing of the power level cases under consideration for this study according to the above mentioned classification of:

- No R&D;
- Minimal R&D, and
- Modest R&D.

The mass flow rates shown in the table are based on 93 percent of the total mass flow in the system which makes provision for leak flows through the core structures that bypass the actual pebble bed core.

Configuration
Level
Power
Cases -
Table 20.2.3:

				No R&D		Minim	ul R&D	N	Modest R&L	
Parameter (limit)	Units	PBMR- DPP	Case 1	Case 2	Case 3	Case 4	Case 5	Case 6	Case 7	Case 8
Power level	MW _{th}	400	400	450	450	500	500	500	600	600
FCR	ш	2.0	2.0	2.0	2.0	2.0	2.0	2.4	2.4	2.0
RIT/ROT	°C	500/900	350/950	350/950	500/950	450/950	350/950	350/950	350/950	350/950
Mass flow	kg/s	179	119	134	179	179	149	149	179	179

20.2 Prototype Power Level Study

January 26, 2007

42 of 65

20.2.4 SIMULATION TOOLS AND INPUT DATA 20.2.4.1 VSOP-A Description

VSOP-A is a computer code system for the comprehensive numerical simulation of the physical processes of thermal reactors 1. It implies setting up the reactor and its fuel elements, processing of the relevant cross-sections, evaluating the neutron spectrum, and performing the neutron diffusion calculation in two or three dimensions, while fuel burnup, fuel shuffling, reactor control, thermal hydraulics and fuel cycle costs are continuously performed as per input definition. The thermal hydraulics part (steady state and time-dependent) is restricted to HTRs and in two spatial dimensions. The code can simulate all phases of reactor operation from the initial towards the equilibrium phases.

In VSOP-A the mass, momentum and energy are conserved and the balance of the gradient of pressure, the hydrostatic force of gravity, and the frictional force are calculated per unit volume. Thermal and effective conductivities are calculated as functions of temperature and fluence. Radiation is accounted for via emissivity of graphite, CB and RPV.

VSOP-A enables the designer/analyst to simulate and analyze the reactor life from the initial core loading, start-up, run-in, and towards the equilibrium core conditions. Repeated calculation of the different physics and coupled thermal-hydraulic features ensures consistency in their feedback during the proceeding burn-up, the simulation of the fuel shuffling, and variations in the core power rating. Transients can be simulated in a quasi-static nuclear approximation by repeated criticality evaluation. Characteristics of the life history of the fuel elements are used to calculate the decay power distribution.

An evaluation of fuel cycle costs over the reactor life is done using the present worth method. Reprocessing and closure of the fuel cycle can be simulated by consistent control of the fuel inventory, while including the isotopic decay during periods of intermediate storage.

The status of the reactor at the end of each calculation can be saved and used as input to new investigations, whilst calculated reactor data may be used subsequently for the purpose of joint evaluations, i.e. with third party codes beyond the capability of VSOP-A.

Even though VSOP-A has been used to analyze all operating thermal reactors to date it has been applied most widely in the area of graphite moderated, high temperature reactors, with both pebble and prismatic fuel types. For these reactor types extensive test data exists.

The burn-up calculations in VSOP-A include the essential nuclides for both the U-Pu and the Th-U fuel cycles. Validation studies for the AVR, THTR, and the Fort St. Vrain reactors have been performed for the thorium cycle, while studies on the HTR-MODUL, LWR, RBMK, and MAGNOX reactors describe the burn-up characteristics of the uranium cycle. The VSOP-A system of codes has proven to be a suitable tool for analyzing these operating reactors, albeit for different fuel cycles.

20.2 Prototype Power Level Study

The VSOP system of codes has been subjected to validation throughout an extended period of decades 12. Validation has been done against critical experiments, such as:

- The CESAR-II experiment at CEN Cadarache, France for cold, equilibrium neutronics;
- The KAHTER critical experiment at FZJ, Jülich, Germany for cold, equilibrium neutronics;
- The PROTEUS critical experiment at PSI, Villingen, Switzerland for cold, equilibrium neutronics;
- The IAEA CRP-1 for small pebble bed facilities for cold, equilibrium neutronics;
- The IAEA CRP-1 for small pebble prismatic block-type facilities for cold and hot, equilibrium neutronics and temperature coefficients;
- The IAEA CRP-5 initial core calculations of the Japanese HTTR prismatic block-type reactor for cold, equilibrium neutronics;
- The IAEA CRP-5 initial core calculations of the Chinese HTR-10 pebble bed reactor for cold, equilibrium neutronics and hot transient analysis.

The VSOP system of codes has also been validated in Germany in a licensing process for:

• The 200 MW_{th} Siemens MODUL pebble bed reactor for neutronics, coupled thermalhydraulics, and burn-up.

Furthermore, the VSOP system of codes has been compared in code-to-code validation against the SIEMENS ZIRKUS system of codes. The TÜV in Hannover, Germany has also used the VSOP system of codes to check the validity of the ZIRKUS system of codes.

The VSOP system of codes is also accepted by SIEMENS as one of the code systems to calculate the LWRs in Germany.

20.2.4.2 Steady State Comparison between VSOP-A and TINTE

In Table 20.2.4 results are tabulated between the TINTE code used to simulate transient operations and the VSOP-A code used for the quasi steady-state operation of PBMR-DPP. Values correspond mostly within 5 percent of each other, which is excellent except for a larger variation for the maximum RPV temperature.

Whereas VSOP-A is the system of codes used to perform the coupled neutronics and thermal-hydraulics design of pebble bed reactors, TINTE is an independent code which uses the isotopic distribution and the calculated fluences of VSOP to calculate time and spatially dependent transients using the transferred data as the initial condition. The comparison of calculated fuel temperatures between VSOP and TINTE provides a level of confidence in the results produced.

		TINTE	VSOP-A
T _{max} Fuel	°C	1083	1073
T _{avg} Fuel	°C	869	830
ROT	°C	897	927
T _{max} CB	°C	397	414
T _{max} RPV	°C	271	310
ΔP core	kPa	209	218

Table 20.2.4: VSOP-A and Tinte Steady-State Results

20.2.4.3 DLOFC Data Comparison between VSOP-A and TINTE

Due to the complexities involved in the design of a pebble bed reactor it is important to build a level of confidence in the results produced by the system of design codes. During the times that the VSOP system of codes was developed at the Research Centre, Jülich it became necessary to develop a code to perform short term transients specifically for pebble bed reactors. In the approach followed by VSOP it is important to consider the decay and build up of isotopes (burnup), while these are of no consequence in a transient calculation. The difference in approach between the VSOP and TINTE solutions warranted two, different numerical approaches.

Even though VSOP-A is mainly used for the design of the PBMR-DPP neutronics and the decision within PBMR was taken to deploy the TINTE results for purposes of the SAR of the PBMR-DPP, VSOP-A can equally well predict the DLOFC and PLOFC temperatures of pebble bed reactors, since the THERMIX thermal-hydraulics code is integrated in the quasi-steady state codes system. The transients stretch over a prolonged period and can thus be predicted with a large level of confidence (see Table 20.2.5).

		TINTE	VSOP-A
T _{max} Fuel	°C	1567 (46h)	1499 (45h)
T _{max} CB	°C	588 (56h)	579 (48h)
T _{max} RPV	°C	430 (59h)	419 (56h)

Table 20.2.5:	VSOP-A and	Tinte DL	OFC Results
---------------	-------------------	-----------------	--------------------

20.2.5 DISCRIMINATING CRITERIA

A specific requirement of the preliminary design of the NGNP has been the possible deployment in the near term. This implies that the design development of plant components, fuel enhancement or re-evaluation of existing data, and the schedule for necessary R&D should be basic to the immediate deployment of the NGNP. Furthermore, the reactor has to adhere to all the safety considerations of GEN IV reactors, in particular that of the PBMR-DPP reactor. In addition the overall cost must be competitive with other supply side options. Particular consideration should however, be given to the enhanced safety offered by this type of nuclear plant, its deployment wherever the need exists, i.e. by omitting large overland transmission considerations, and finally the short construction period offered, thus allowing for deployment whenever the need for it arose.

Table 20.2.6 provides a listing of the criteria for selecting a suitable power level for the NGNP reactor. Every parameter has been weighted according to the perceived level of importance it has on the decision making process.

Criteria		Relative weight
Readiness	Technology enabling R&D (including fuel)	High
	Design development and schedule	High
Performance	Normal operation	Medium
	Investment protection (PLOFC)	Medium
	Safety consideration (DLOFC)	High
Cost	Capital cost (reactor, etc.)	High
	Operating cost (including fuel cycle costs)	Medium

Table 20.2.6: Discriminating Criteria

A high relative weight is given in the table of discriminating criteria to distinguish the level of importance awarded to the ability to immediately deploy the technology. In the design safety considerations and cost are of paramount importance, yet the operating cost is deemed to be only of medium importance.

20.2.6 EVALUATION, RESULTS AND COMPARISON

In this section the results of the VSOP-A coupled thermal hydraulic and neutronic simulations are presented for the Normal operation, Investment protection (PLOFC) and Safety (DLOFC) cases under investigation.

20.2.6.1 Normal Operation

A listing is provided in Table 20.2.7 to Table 20.2.9 of the most important calculated design parameters of the eight cases during normal operation. In Table 20.2.7 the neutronics parameters are provided of the various cases. Table 20.2.8 contains the calculated thermal-hydraulic parameters, while a temperature versus volume analysis is performed in Table 20.2.9 of the fuel during normal operation. For purposes of the design calculations a series of iterations are performed between the neutronics and thermal-hydraulics until convergence is reached. Convergence is firstly achieved of the neutronic parameters for an estimated spectral temperature distribution. Thereafter a set of thermal-hydraulics data are iteratively calculated until convergence is achieved of the coupled neutronics and thermal-hydraulics parameters. Based on this set of input data the comparative calculations were performed.

NGNP-20-RPT-002

Parameters
Performance
Neutronics
Table 20.2.7 :

				No R&D		Minima	ul R&D		Modest R&D	
Parameter (limit)	Units	PBMR- DPP	Case 1	Case 2	Case 3	Case 4	Case 5	Case 6	Case 7	Case 8
Power level	MW _{th}	400	400	450	450	500	500	500	600	600
FCR	ш	2.0	2.0	2.0	2.0	2.0	2.0	2.4	2.4	2.0
k_{eff}		1.0001	1.0001	1.0001	1.0000	1.0000	1.0001	1.0001	1.0000	1.0000
Burnup (<100,000)	MWd/t_{HM}	95,723	94,949	94,508	94,708	94,254	94,079	82,895	82,101	93,462
Q _{max} /FS (<4.5)	kW	2.80	2.94	3.29	3.13	3.51	3.63	3.93	4.66	4.30
Power Peaking	Q _{max} /Q _{avg}	3.17	3.32	3.30	3.15	3.17	3.28	2.91	2.87	3.24
Fuel residence time	q	964	956	846	848	759	758	548	452	628
Heat-up over reactor (from inlet plenum to outlet plenum)	°C	500→927	354 → 1044	353 →1041	500→1004	451→1023	353→1038	353→1012	353→1018	353→1039

48 of 65

January 26, 2007

NGNP-20-RPT-002

Parameters
Performance
Thermal-hydraulics
Table 20.2.8:

				No R&D		Minim:	al R&D	N	[odest R&]	D
Parameter (limit)	Units	PBMR- DPP	Case 1	Case 2	Case 3	Case 4	Case 5	Case 6	Case 7	Case 8
Power level	MW _{th}	400	400	450	450	500	500	500	600	600
FCR	ш	2.0	2.0	2.0	2.0	2.0	2.0	2.4	2.4	2.0
T_{avg} fuel (spectrum)	О°	829	830	834	872	865	840	837	857	853
T_{max} fuel (<1250 °C)	Ъ°	1071	1126	1145	1145	1170	1168	1050	1209	1219
$T_{max} CB (<\!\!816 \ ^\circ C)$	Ъ°	414	297	<i>2</i> 97	414	374	297	297	297	296
T _{max} RPV (<371 °C)	Ъ°	324	238	238	324	967	240	240	240	240
ΔP over core	kPa	228	104	130	237	232	158	231	326	225
ΔP over the reactor	kPa	332	152	191	344	339	235	342	483	334
Circulator power	MW_{th}	I	2,627	3,730	11,144	10,291	5,091	7,410	12,576	8,692

January 26, 2007

49 of 65

				No R&D		Minima	ıl R&D	M	lodest R&	D
Parameter (limit)	Units	PBMR- DPP	Case 1	Case 2	Case 3	Case 4	Case 5	Case 6	Case 7	Case 8
Power level	$\mathrm{MW}_{\mathrm{th}}$	400	400	450	450	500	500	500	600	600
FCR	ш	2.0	2.0	2.0	2.0	2.0	2.0	2.4	2.4	2.0
T<900 °C	0%	72.79	56.56	58.61	55.45	56.56	58.61	61.75	59.09	58.61
900 °C <t <1000="" td="" °c<=""><td>0⁄0</td><td>27.21</td><td>33.36</td><td>34.26</td><td>39.93</td><td>37.63</td><td>32.29</td><td>32.76</td><td>32.25</td><td>32.21</td></t>	0⁄0	27.21	33.36	34.26	39.93	37.63	32.29	32.76	32.25	32.21
1000 °C <t <1100="" td="" °c<=""><td>0%</td><td>0.0</td><td>10.08</td><td>9.18</td><td>4.62</td><td>5.81</td><td>9.10</td><td>5.49</td><td>8.66</td><td>9.18</td></t>	0%	0.0	10.08	9.18	4.62	5.81	9.10	5.49	8.66	9.18
T>1100 °C	0%	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

20.2 Prototype Power Level Study

January 26, 2007

50 of 65

20.2.6.1.1 Evaluation of Normal Operation Performance

Apart from the obvious advantages offered by opting for an existing design the normal operational performance of the selected designs are measured against the following neutronics and thermal hydraulics parameters: maximum power produced per pebble, maximum burnup achieved by the fuel, maximum burnup achieved, maximum fuel temperature achieved, maximum temperatures achieved in the metallic components, such as the CB, RPV, and housing of the control rods. Other parameters to consider are the so-called temperature swing at the outlet due to the heat-up difference in the bottom reflector graphite, pressure drop over the core due to the associated impact on the blower size, etc.

For purposes of this special study the comparison between tabled parameters provides a good measure of effectiveness.

In Table 20.2.7 it is observed that all the cases presented for normal operation are observed to be within acceptable burnup limits. Except for Cases 6 and 7 a burnup of around $95,000 \text{ MWd/t}_{HM}$ is observed. The reason for the lower burnup in Cases 6 and 7 is due to the lower fissile content in the smaller cores of these cases due to the increased fixed centre column.

In Case 7 the power produced per fuel sphere of 4.66 kW/pebble exceeded the limit of 4.5 kW/pebble. Even though the rest of all the cases produced a higher power per fuel sphere than the PBMR-DPP the maximum levels are within acceptable limits.

Table 20.2.8 shows that Case 8 features the maximum fuel temperature that is close to the limitation of 1250 °C. Case 6 displays the lowest peak fuel temperature during normal operation but has, like Case 7, a very large ΔP over the reactor and thus requires a corresponding higher circulator power.

In Table 20.2.9 the temperature *versus* volume analysis shows that all cases apart from the PBMR-DPP design feature a considerable percentage of fuel at temperatures exceeding 1000 °C. No considerable amount of fuel exceeds 1100 °C during normal operation though.

At a higher power output than the DPP of 500 MW_{th} , Cases 5 and 6 display the largest margin for the various parameters for the range of considerations. Due to the fact that the geometry would be similar to the PBMR-DPP, Case 5 would be the preferred option based on normal operating parameters.

20.2.6.2 Investment Protection

In order to evaluate the investment protection margins for the various cases Table 20.2.10 depicts a comparison of the thermal-hydraulics performance of the various options during a PLOFC event. This evaluation is performed for a case different than the PBMR-DPP direct cycle in that the pressure is assumed to remain constant at 9.0 MPa. For purposes of this investigation a similar run has been compiled for the PBMR-DPP case, i.e. assuming that a PLOFC occurred at 9.0 MPa.

NGNP-20-RPT-002

				No R&D		Minim	al R&D	M	lodest R&	D
Parameter (limit)	Units	PBMR- DPP	Case 1	Case 2	Case 3	Case 4	Case 5	Case 6	Case 7	Case 8
Power level	MW _{th}	400	400	450	450	500	500	500	600	600
FCR	ш	2.0	2.0	2.0	2.0	2.0	2.0	2.4	2.4	2.0
T_{avg} fuel	J.	1009	1001	1031	1072	1093	1070	1039	1133	1162
T _{max} fuel (at time [h]) (<1600/1700)	Э.	1320 (27h)	1315 (27h)	1388 (30h)	1418 (27h)	1479 (30h)	1460 (30h)	1284 (30h)	1408 (36h)	1608 (33h)
T _{max} CB (<816)	Ъ°	482	518	545	553	570	565	552	591	592
T _{max} RPV (at time [h]) (>371, <427 for 3,000 hrs; >427, < 538 for 1000 hrs)	Э.	373 (48h)	370 (48h)	385 (56h)	393 (48h)	405 (56h)	401 (56h)	397 (48h)	428 (56h)	434 (56h)
							-			

 Table 20.2.10:
 Thermal-Hydraulics Performance during a PLOFC (9.0 MPa)

20.2 Prototype Power Level Study

52 of 65

January 26, 2007

20.2.6.2.1 Evaluation of Performance during a PLOFC (Investment Protection)

All cases are well within the limits for the PLOFC with the exception of the Case 8 peak fuel temperature.

20.2.6.3 Safety Performance (DLOFC)

In order to evaluate the inherent safety position of the various cases Table 20.2.11 depicts a comparison of the thermal-hydraulics performance of the DLOFC event. The reactor is assumed to operate at about 24 years full power. This would yield the most conservative conditions in terms of the thermal conductivities, i.e. where the fuel would be thermally taxed to its fullest. Subsequently, a sequence is run after the onset of the DLOFC event whereby the reactor is assumed to depressurize immediately down to ambient pressure, i.e. no heat loss is assumed with the exiting helium and the CB and RPV starts to lose heat via radiation only.

Since the DLOFC is assumed to be a Beyond Design Event the calculations are assumed to be best estimate. These results of the DLOFC analyses are listed in Table 20.2.11 and Table 20.2.12.

Following the DLOFC event an analysis is also performed of the volume of fuel expected at the elevated temperature levels. These results are listed in Table 20.2.12.

NGNP-20-RPT-002

a DLOFC	
during	
Performance	
[ydraulics	
Thermal-H	
Table 20.2.11:	

				No R&D		Minim	al R&D	2	Aodest R&	0
Parameter (limit)	Units	PBMR- DPP	Case 1	Case 2	Case 3	Case 4	Case 5	Case 6	Case 7	Case 8
Power level	MW_{th}	400	400	450	450	500	500	500	600	600
FCR	Σ	2.0	2.0	2.0	2.0	2.0	2.0	2.4	2.4	2.0
Tavg fuel	°C	1126	1111	1169	1201	1249	1232	1147	1253	1354
T _{max} fuel (at time [h]) (<1600/1700)	°C	1499 (45h)	1494 (45h)	1580 (45h)	1602 (42h)	1679 (45h)	1668 (48h)	1497 (45h)	1641 (45h)	1835 (45h)
T _{max} CB (<816)	°C	579 (48h)	571 (49h)	602 (63h)	609 (55h)	630 (62h)	625 (62h)	612 (56h)	653 (59h)	671 (62h)
T _{max} RPV (at time [h]) (>371, <427 for 3,000 hrs; >427, < 538 for 1000 hrs)	°.	419 (56h)	414 (64h)	435 (64h)	442 (56h)	459 (64h)	455 (64h)	443 (56h)	477 (64h)	492 (64h)

20.2 Prototype Power Level Study

54 of 65

January 26, 2007

NGNP-20-RPT-002

				No R&D		Minim	al R&D	N	10dest R&	D
Parameter (limit)	Units	PBMR- DPP	Case 1	Case 2	Case 3	Case 4	Case 5	Case 6	Case 7	Case 8
Power level	MW _{th}	400	400	450	450	500	500	500	600	600
FCR	ш	2.0	2.0	2.0	2.0	2.0	2.0	2.4	2.4	2.0
1200°C <t<1300°c< td=""><td>%</td><td>14.80</td><td>13.21</td><td>11.13</td><td>10.86</td><td>11.10</td><td>9.03</td><td>14.43</td><td>11.81</td><td>9.31</td></t<1300°c<>	%	14.80	13.21	11.13	10.86	11.10	9.03	14.43	11.81	9.31
1300°C <t<1400°c< td=""><td>%</td><td>14.98</td><td>15.19</td><td>14.37</td><td>14.03</td><td>13.53</td><td>10.30</td><td>19.27</td><td>14.22</td><td>10.01</td></t<1400°c<>	%	14.98	15.19	14.37	14.03	13.53	10.30	19.27	14.22	10.01
1400°C <t<1500°c< td=""><td>%</td><td>13.92</td><td>12.08</td><td>13.64</td><td>14.09</td><td>13.60</td><td>13.62</td><td>14.70</td><td>14.60</td><td>9.47</td></t<1500°c<>	%	13.92	12.08	13.64	14.09	13.60	13.62	14.70	14.60	9.47
1500°C <t<1600°c< td=""><td>%</td><td>0.0</td><td>0.0</td><td>10.21</td><td>13.96</td><td>10.15</td><td>13.70</td><td>0.0</td><td>17.25</td><td>12.48</td></t<1600°c<>	%	0.0	0.0	10.21	13.96	10.15	13.70	0.0	17.25	12.48
1600°C <t<1700°c< td=""><td>%</td><td>0.0</td><td>0.0</td><td>0.0</td><td>0.0</td><td>0.0</td><td>9.17</td><td>0.0</td><td>5.0</td><td>11.45</td></t<1700°c<>	%	0.0	0.0	0.0	0.0	0.0	9.17	0.0	5.0	11.45
1700°C <t<1800°c< td=""><td>%</td><td>0.0</td><td>0.0</td><td>0.0</td><td>0.0</td><td>0.0</td><td>0.0</td><td>0.0</td><td>0.0</td><td>13.04</td></t<1800°c<>	%	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	13.04
T>1800°C	%	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	3.14

 Table 20.2.12:
 Volume versus Temperature Analysis during DLOFC

20.2 Prototype Power Level Study

January 26, 2007

55 of 65

20.2.6.3.1 Evaluation of Performance during a DLOFC (Safety Consideration)

Case #	T < 1600 °C	1600 °C < T < 1800 °C	T > 1800 °C
1	~		
2	~		
3		~	
4		~	
5		✓	
6	~		
7		✓	
8			✓

 Table 20.2.13:
 Overview of Maximum Temperatures Achieved during a DLOFC

Cases 1, 2 & 6 yield maximum fuel temperatures during a DLOFC event lower than the set limit of 1600 °C. Even though Cases 3, 4, 5, & 7 have temperatures above 1600 °C, in Case 5 only 9.17 percent exceeds 1600 °C, while Case 7 only exceeds the 1600 °C limit by 5 percent. Case 8 displays the worst overall results with temperatures exceeding 1800 °C.

20.2.7 SUMMARY AND RECOMMENDATION

Based on the discriminating criteria noted in Table 20.2.6 a proposal for the power level could be derived. Eight design variations of the PBMR-DPP have been calculated to provide normal operating parameters, a PLOFC calculation to represent the design decisions for protecting the investment, and a DLOFC calculation of each case representing the safety aspects to be considered in the design. The following list of calculated results provides a summary relative to the list of discriminating criteria:

No R&D and design development required beyond PBMR-DPP:

Case 2: 450 MW_{th}; Geometry similar to the PBMR-DPP.

- Lower mass flow than PBMR-DPP lower ΔP over reactor smaller components.
- 12.5 percent increase in power level from PBMR-DPP.
- Immediately deployable.

The elevated power level at 450 MW_{th} from 400 MW_{th} is simply due to the choice of RIT/ROT of 350/950 °C. The fuel temperature envelope remains unchallenged and the metallic components remain well within the observed code margins.

Minimal R&D required beyond PBMR-DPP:

Case 5: 500 MW_{th}; Geometry similar to the DPP.

- 25 percent increase in power level from PBMR-DPP.
- Minimal R&D for fuel qualification to 1700 °C.
- Re-evaluation of existing fuel performance data.

In this case a re-evaluation of the existing experimental fuel data is anticipated for the qualification of fuel to 1700 °C. It is foreseen that a slightly modified strategy might be possible with respect to the interpretation of the fuel failure fraction based on more detailed modeling of the fuel failure mechanisms.

Modest R&D and design development required:

Case 6: 500 MW_{th}; FCR diameter 2.4 m.

- FCR discharge chute design needs to be re-evaluated.
- Higher ΔP over reactor.

This case assumes an increase in the diameter of the fixed center reflector to 2.4 m from 2.0 m. The consideration of this design was due to the fact that the fuel temperatures in this case will remain within currently acceptable margins. Modest R&D is foreseen in terms of the impact

of the increased diameter on the discharge fuel chutes. A higher Δp over the core will also have to be accounted for in the economic evaluation.

Case 7: 600 MW_{th}; FCR diameter 2.4 m

- Q_{max} /Pebble = 4.66 kW exceeds THTR and PBMR-DPP 4.5 kW/pebble limit.
- FCR discharge chute design needs to be reevaluated.
- Minimal R&D for fuel qualification to 1800 °C.
- Higher ΔP over reactor.

Case 7 represents an overlap of minimal and modest R&D requirements. It assumes that the PBMR-DPP provides proof of some margin in the current design assumptions of 4.5 kW/pebble and the availability of better fuel qualification data. Due to an increase of the diameter of the fixed center reflector and the elevated power level the limits as discussed above will be marginal.

Therefore, based on the set of discriminating criteria as listed in Table 20.2.6 for the NGNP reactor, Case 5: 500 MW_{th} with geometry similar to the PBMR-DPP is recommended. This is based on the following criteria:

- The PBMR-DPP reactor can be immediately used as the basis for NGNP design within the operational envelope of the PBMR- DPP.
- NGNP schedule will be met minimal R&D required.
- No or minimal design development required.
- 25 percent higher power output is achievable while retaining the PBMR-DPP capital cost for the reactor and auxiliary systems and building.

REFERENCES

- 1. Statement of Work, Preconceptual Engineering Services for the Next Generation Nuclear Plant with Hydrogen Production, Project No. 23843, Idaho National Laboratory, July 2006.
- 2. A Public/Private Partnership to Develop the Next Generation Nuclear Plant Commercial Demonstration, NGNP Public/Private Partnership Working Group, October 2006.
- 3. VSOP-A: Augmented Computer Code System for Reactor Physics and Fuel Cycle Simulation NTC_060301/A (March 2006).
- 4. E Ziermann and G Ivens, Abschlussbericht über den Leistungsbetrieb des AVR-Versuchskernkraftwerkes JÜL-3448, FZJ Report, October 1997.
- 5. AVR Experimental High-Temperature Reactor: 21 Years of Successful Operation for a Future Energy Technology Association of German Engineers, VDI-Society for Energy Technologies (Publ.), VDI-Verlag GmbH, June 1990.
- 6. Safety Analysis Report of the THTR Prototype 300 MWe Band I Technical Report, April 1968.
- 7. Siemens INTERATOM Hochtemperaturreaktor-Modul-Kraftwerksanlage Kurzbeschreibung Nov. 1988.
- 8. H Reutler and G H Lohnert, Advantages of Going Modular in HTRs, Nucl. Eng. Des. 78 (1984) 129.
- 9. Auslegung der Reaktorkerne von gasgekühlten Hochtemperaturreaktoren, Wärmeübertragung im Kugelhaufen KTA-Rule 3102.2, Version 6/83.
- 10. K Robold, Wärmetransport im Inneren und in der Randzone von Kugelschüttungen, Kernforschungsanlage Jülich GmbH, JÜL-1796 (August 1982).
- 11. A Banerjea, K Hammeke, N Hüpping, H E Kipke and A Stoehr, Thermodynamische Stoffwerte von HELIUM im Bereich von 20 bis 1500 °C und 1 bis 100 bar Jül-1562, December 1978.
- 12. E Mulder, Evaluation of Reactor Physics Experiments and VSOP, MTNC-0013, Rev. 1, August 2006.

BIBLIOGRAPHY

None.

DEFINITIONS

None.

REQUIREMENTS

None.

LIST OF ASSUMPTIONS

- 1. In VSOP-A no non-local heat production is considered; i.e. all heat is considered to be deposited at the point of fission in the core.
- 2. During a DLOFC calculation the core is assumed to immediately depressurize to 100 kPa.
- 3. The fluence- and temperature-dependent thermal conductivities are calculated according to end-of-life irradiated reflector graphite properties.
- For the effective thermal-conductivity within the pebble bed the models by Zehner-Schlünder 9 are employed for temperatures up to 1400 °C and beyond that the model by Robold 10.
- 5. Thermo-dynamic values employed for helium are derived from the equations provided in 11.
- 6. For the equilibrium calculation of all the cases the RCS was considered to be inserted into the side reflector to a depth of about 2.25 m measured from the bottom of the top reflector.
- 7. For both PLOFC and DLOFC only best estimate calculations are performed.

TECHNOLOGY DEVELOPMENT

 The only additional technology development required for the PBMR PHP reactor beyond that required and underway for the DPP is a design data need that the range of fuel performance data under conditions of DLOFC be extended. This is required to statistically supplement prior German testing in the range of 1600 °C to 2000 °C.

APPENDICES

APPENDIX 20.2.1 PRESENTATION TO BEA, "20.2 POWER LEVEL SPECIAL STUDY," DECEMBER 6, 2006

Appendix 20.2.1 provides the slides presented on this special study at the December 2006 monthly meeting at the Shaw Group offices in Stoughton, MA.

APPENDIX 20.2.1: PRESENTATION TO BEA, "20.2 POWER LEVEL SPECIAL STUDY," DECEMBER 6, 2006

December 6, 2006

20.2 Power Level Special Study

- **Select Reactor Power Level For NGNP Plant** •
- Select Hydrogen Power Level For NGNP Plant Covered In 20.7 •

→ PBMR design requirements and selections

- PBMR-DPP design approach and selections
- Approach to NGNP power level
- Simulation tools and input data
- Discriminating criteria
- Evaluation results & comparison
- Summary and recommendation

 Normal Operation Operate within the German LEU fuel test envelope Fuel T_{max} < 1250 °C during normal operation Fuel T_{max} < 1250 °C during normal operation Maintain inlet temperature to avoid Wigner energy buildup Limit velocity through graphite orifices < 100 m/s Meet Core Barrel (CB) and Reactor Pressure Vessel (RPV) material temperature constraints Utilize Fixed Central Reflector (FCR) to provide RSS insertion location Provide control and shutdown in side reflector Utilize steel RPV for passive decay heat removal Utilize Barsive heat removal during Pressurized and Depressurized Loss of Forced Cooling Events (PLOFC and DLOFC) Maintain acceptable metallic reactor temperatures Maintain acceptable RPV temperatures Limit fuel temperatures to acceptable values 	 Normal Operation Operate within the German LEU fuel test envelope Fuel T_{max} < 1250 °C during normal operation Fuel T_{max} < 1250 °C during normal operation Maintain inlet temperature to avoid Wigner energy buildup Limit velocity through graphite orifices < 100 m/s Meet Core Barrel (CB) and Reactor Pressure Vessel (RPV) material temperature constraints Utilize Fixed Central Reflector (FCR) to provide RSS insertion location Provide control and shutdown in side reflector Utilize steel RPV for passive decay heat removal Utilize steel RPV for passive decay heat removal Milize according Pressurized and Depressurized Losi of Forced Cooling Events (PLOFC and DLOFC) Maintain acceptable metallic reactor temperatures Limit fuel temperatures to acceptable values 		Design Requirements and Selections
 Operate within the German LEU fuel test envelope Fuel T_{max} < 1250 °C during normal operation Maintain inlet temperature to avoid Wigner energy buildup Limit velocity through graphite orifices < 100 m/s Limit velocity through graphite orifices < 100 m/s Weet Core Barrel (CB) and Reactor Pressure Vessel (RPV) material temperature constraints Utilize Fixed Central Reflector (FCR) to provide RSS insertion location Provide control and shutdown in side reflector Utilize steel RPV for passive decay heat removal Utilize steel RPV for passive decay heat removal Mormal Operation Provide passive heat removal during Pressurized and Depressurized Loss of Forced Cooling Events (PLOFC and DLOFC) Maintain acceptable metallic reactor temperatures Limit fuel temperatures to acceptable values Limit fuel temperatures to acceptable values 	 Operate within the German LEU fuel test envelope Fuel T_{max} < 1250 °C during normal operation Maintain inlet temperature to avoid Wigner energy buildup Limit velocity through graphite orifices < 100 m/s Limit velocity through graphite orifices < 100 m/s Weet Core Barrel (CB) and Reactor Pressure Vessel (RPV) material temperature constraints Utilize Fixed Central Reflector (FCR) to provide RSS insertion location Provide control and shutdown in side reflector Utilize steel RPV for passive decay heat removal Utilize steel RPV for passive decay heat removal Outilize steel RPV for passive decay heat removal Utilize steel RPV for passive decay heat removal<th>•</th><th>Normal Operation</th>	•	Normal Operation
 Fuel T_{max} < 1250 °C during normal operation Maintain inlet temperature to avoid Wigner energy buildup Limit velocity through graphite orifices < 100 m/s Limit velocity through graphite orifices < 100 m/s Meet Core Barrel (CB) and Reactor Pressure Vessel (RPV) material temperature constraints Utilize Fixed Central Reflector (FCR) to provide RSS insertion location Provide control and shutdown in side reflector Utilize steel RPV for passive decay heat removal Utilize steel RPV for passive decay heat removal Off Normal Operation Provide passive heat removal during Pressurized and Depressurized LOFC and DLOFC) Maintain acceptable metallic reactor temperatures Maintain acceptable RPV temperatures Limit fuel temperatures to acceptable values 	 Fuel T_{max} < 1250 °C during normal operation Maintain inlet temperature to avoid Wigner energy buildup Limit velocity through graphite orifices < 100 m/s Limit velocity through graphite orifices < 100 m/s Meet Core Barrel (CB) and Reactor Pressure Vessel (RPV) material temperature constraints Utilize Fixed Central Reflector (FCR) to provide RSS insertion location temperature constraints Utilize steel RPV for passive decay heat removal Utilize steel RPV for passive decay heat removal Off Normal Operation Provide passive heat removal during Pressurized and Depressurized Losi of Forced Cooling Events (PLOFC and DLOFC) Maintain acceptable metallic reactor temperatures Limit fuel temperatures to acceptable values 		Operate within the German LEU fuel test envelope
 Maintain inlet temperature to avoid Wigner energy buildup Limit velocity through graphite orifices < 100 m/s Limit velocity through graphite orifices < 100 m/s Meet Core Barrel (CB) and Reactor Pressure Vessel (RPV) material temperature constraints Utilize Fixed Central Reflector (FCR) to provide RSS insertion location Provide control and shutdown in side reflector Provide control and shutdown in side reflector Utilize steel RPV for passive decay heat removal Utilize steel RPV for passive decay heat removal Off Normal Operation Provide passive heat removal during Pressurized and Depressurized Loss of Forced Cooling Events (PLOFC and DLOFC) Maintain acceptable metallic reactor temperatures Maintain acceptable RPV temperatures Limit fuel temperatures to acceptable values 	 Maintain inlet temperature to avoid Wigner energy buildup Limit velocity through graphite orifices < 100 m/s Imit velocity through graphite orifices < 100 m/s Meet Core Barrel (CB) and Reactor Pressure Vessel (RPV) material temperature constraints Utilize Fixed Central Reflector (FCR) to provide RSS insertion location Provide control and shutdown in side reflector Provide control and shutdown in side reflector Utilize steel RPV for passive decay heat removal Utilize steel RPV for passive decay heat removal Off Normal Operation Provide passive heat removal during Pressurized and Depressurized Losi of Forced Cooling Events (PLOFC and DLOFC) Maintain acceptable metallic reactor temperatures Maint fuel temperatures to acceptable values 		Fuel T _{max} < 1250 °C during normal operation
 Limit velocity through graphite orifices < 100 m/s Meet Core Barrel (CB) and Reactor Pressure Vessel (RPV) material temperature constraints Utilize Fixed Central Reflector (FCR) to provide RSS insertion location Provide control and shutdown in side reflector Provide control and shutdown in side reflector Utilize steel RPV for passive decay heat removal Utilize steel RPV for passive decay heat removal Of Normal Operation Provide passive heat removal during Pressurized and Depressurized Loss of Forced Cooling Events (PLOFC and DLOFC) Maintain acceptable metallic reactor temperatures Limit fuel temperatures to acceptable values 	 Limit velocity through graphite orifices < 100 m/s Meet Core Barrel (CB) and Reactor Pressure Vessel (RPV) material temperature constraints Utilize Fixed Central Reflector (FCR) to provide RSS insertion location Provide control and shutdown in side reflector Provide control and shutdown in side reflector Utilize steel RPV for passive decay heat removal Utilize steel RPV for passive decay heat removal Off Normal Operation Provide passive heat removal during Pressurized and Depressurized Losi of Forced Cooling Events (PLOFC and DLOFC) Maintain acceptable metallic reactor temperatures Limit fuel temperatures to acceptable values 		Maintain inlet temperature to avoid Wigner energy buildup
 Meet Core Barrel (CB) and Reactor Pressure Vessel (RPV) material temperature constraints Utilize Fixed Central Reflector (FCR) to provide RSS insertion location Provide control and shutdown in side reflector Utilize steel RPV for passive decay heat removal Utilize steel RPV for passive decay heat removal Off Normal Operation Provide passive heat removal during Pressurized and Depressurized Loss of Forced Cooling Events (PLOFC and DLOFC) Maintain acceptable metallic reactor temperatures Limit fuel temperatures to acceptable values 	 Meet Core Barrel (CB) and Reactor Pressure Vessel (RPV) material temperature constraints Utilize Fixed Central Reflector (FCR) to provide RSS insertion location Provide control and shutdown in side reflector Provide control and shutdown in side reflector Utilize steel RPV for passive decay heat removal Utilize steel RPV for passive decay heat removal Of Normal Operation Provide passive heat removal during Pressurized and Depressurized Lost of Forced Cooling Events (PLOFC and DLOFC) Maintain acceptable metallic reactor temperatures Limit fuel temperatures to acceptable values 		Limit velocity through graphite orifices < 100 m/s
 Utilize Fixed Central Reflector (FCR) to provide RSS insertion location Provide control and shutdown in side reflector Utilize steel RPV for passive decay heat removal Utilize steel RPV for passive decay heat removal Def Normal Operation Provide passive heat removal during Pressurized and Depressurized Loss of Forced Cooling Events (PLOFC and DLOFC) Maintain acceptable metallic reactor temperatures Maintain acceptable RPV temperatures Limit fuel temperatures to acceptable values 	 Utilize Fixed Central Reflector (FCR) to provide RSS insertion location Provide control and shutdown in side reflector Provide control and shutdown in side reflector Utilize steel RPV for passive decay heat removal Utilize steel RPV for passive decay heat removal Definition and Structor and Drown and Depressurized Loss of Forced Cooling Events (PLOFC and DLOFC) Maintain acceptable metallic reactor temperatures Maintain acceptable RPV temperatures Limit fuel temperatures to acceptable values 		Meet Core Barrel (CB) and Reactor Pressure Vessel (RPV) material temperature constraints
 Provide control and shutdown in side reflector Utilize steel RPV for passive decay heat removal Dft Normal Operation Provide passive heat removal during Pressurized and Depressurized Loss of Forced Cooling Events (PLOFC and DLOFC) Maintain acceptable metallic reactor temperatures Maintain acceptable RPV temperatures Limit fuel temperatures to acceptable values 	 Provide control and shutdown in side reflector Utilize steel RPV for passive decay heat removal Off Normal Operation Provide passive heat removal during Pressurized and Depressurized Loss of Forced Cooling Events (PLOFC and DLOFC) Maintain acceptable metallic reactor temperatures Maintain acceptable RPV temperatures Limit fuel temperatures to acceptable values 		Utilize Fixed Central Reflector (FCR) to provide RSS insertion location
 Utilize steel RPV for passive decay heat removal Off Normal Operation Provide passive heat removal during Pressurized and Depressurized Loss of Forced Cooling Events (PLOFC and DLOFC) Maintain acceptable metallic reactor temperatures Maintain acceptable RPV temperatures Limit fuel temperatures to acceptable values 	 Utilize steel RPV for passive decay heat removal Off Normal Operation Provide passive heat removal during Pressurized and Depressurized Loss of Forced Cooling Events (PLOFC and DLOFC) Maintain acceptable metallic reactor temperatures Maintain acceptable RPV temperatures Limit fuel temperatures to acceptable values 		Provide control and shutdown in side reflector
 Off Normal Operation Provide passive heat removal during Pressurized and Depressurized Loss of Forced Cooling Events (PLOFC and DLOFC) Maintain acceptable metallic reactor temperatures Maintain acceptable RPV temperatures Limit fuel temperatures to acceptable values 	 Off Normal Operation Provide passive heat removal during Pressurized and Depressurized Los of Forced Cooling Events (PLOFC and DLOFC) Maintain acceptable metallic reactor temperatures Maintain acceptable RPV temperatures Limit fuel temperatures to acceptable values 		Utilize steel RPV for passive decay heat removal
 Provide passive heat removal during Pressurized and Depressurized Loss of Forced Cooling Events (PLOFC and DLOFC) Maintain acceptable metallic reactor temperatures Maintain acceptable RPV temperatures Limit fuel temperatures to acceptable values 	 Provide passive heat removal during Pressurized and Depressurized Loss of Forced Cooling Events (PLOFC and DLOFC) Maintain acceptable metallic reactor temperatures Maintain acceptable RPV temperatures Limit fuel temperatures to acceptable values 	٠	Off Normal Operation
 Maintain acceptable metallic reactor temperatures Maintain acceptable RPV temperatures Limit fuel temperatures to acceptable values 	 Maintain acceptable metallic reactor temperatures Maintain acceptable RPV temperatures Limit fuel temperatures to acceptable values 		Provide passive heat removal during Pressurized and Depressurized Loss of Forced Cooling Events (PLOFC and DLOFC)
 Maintain acceptable RPV temperatures Limit fuel temperatures to acceptable values 	 Maintain acceptable RPV temperatures Limit fuel temperatures to acceptable values 		 Maintain acceptable metallic reactor temperatures
 Limit fuel temperatures to acceptable values 	 Limit fuel temperatures to acceptable values 		 Maintain acceptable RPV temperatures
			 Limit fuel temperatures to acceptable values

Reactor Power Level Presentation Outline

PBMR design requirements and selections •

→ PBMR-DPP design approach and selections

- Approach to NGNP power level
- Simulation tools and input data
- Discriminating criteria
- Evaluation results & comparison
- Summary and recommendation

	PBMR-DPP Reactor Design
•	Reactor Power Level = 400MWt
•	Reactor Inlet Temperature (RIT) = 500 °C
•	Reactor Outlet Temperature (ROT) = 900 °C
•	Average core power density 4.77 MW/m ³
•	Reactor Pressure Vessel (RPV)
	Inner diameter of 6.2m (wall thickness 0.18m)
	Largest RPV readily available
	 Within current manufacturing limitations
	 Within road transportation limitations
	 With multiple suppliers available
•	Core barrel (CB)
	Inner diameter of 5.8m (wall thickness 0.06m)
	316 stainless steel vessel to maintain core stability
 Side Reflector Side reflector consists of two blocks 	

Side reflector consists of two blocks	
 Inner block 0.40m housing RCS; 	
 Outer block 0.50m thick housing helium riser channels 	
Replacement limit of inner reflector = fast neutron fluence of 2.2 x 10 ²² at 800 °C	
0.90m thickness (0.775m solid thickness) optimal w.r.t. neutron economy and capital cost	
RCS located in side reflector	
Annular Fuel Region	
Annular core layout – thickness of fuel zone 0.85m	
 No azimuthal Xenon swings 	
 Reactivity control possible from side reflector 	

-
2
0
Ö
2
0
1
S
U
2
5
ž
č.
~
4
Ц
T
2
\mathbf{m}

Fixed Centre Column (FCR) = 2.0 m

- Optimized design for coupled Thermal-Hydraulics and Neutronic performance as well as Safety
- Sufficient for reactivity control from side reflectors
- RSS located in central reflector

Effective core height <11.0 m

- No axial Xenon swings
- Acceptable pressure drop
- Structural integrity of central column

PBMR-DPP Reactor Layout



റ

PBMR-DPP Reactor Internals

σ \		2								11		J	
			3-3-8-8-8-8		<u>S S S S</u>	0 0 0	808	53		5-5-5-5			
	Component	Core support structure – Engineered for support of the fixed central reflector	Expansion compensator – compensate for thermal expansion of the bottom plate	Bottom reflector – designed to house the hot gas chamber and slots for exiting helium	Fuel discharge cone – min. angle of 23 °C to prevent pebble blockage	Core barrel sides – for fixing the CB and to hold in position	Side reflector (inner and outer)	Centre reflector	Top reflector – designed for helium inlet flow, shielding of the top metallic components	Core barrel top plate help maintain structural integrity	Main inlet plenum – helium into riser channel in side reflector (due to high temps in direct cycle)	Main outlet plenum – hot helium outlet	
	No	~	2	с	4	л	9	7	ω	о	10	11	



PBMR-DPP Reactor Side Reflectors



PBMR-DPP Reactor Fixed Centre Reflector

PBMR-DPP Fuel

Fuel design based on irradiation tests performed for HTR-MODUL operation

Nominal Value		Spherical	60	50	5	6	35 9.6 (equilibrium core)		500	95	40	35	40
Unit		-	шш	шш	шш	g/FS	% U-23		шń	แมฑ่	แป	แมฑ่	แม
Characteristic	Fuel Sphere:	Geometry	Fuel sphere diameter	Fuel region diameter	Fuel-free region thickness	Heavy metal loading	Uranium enrichment	Coated Particle:	Kernel diameter	Buffer layer thickness	Inner Low Temperature Isotropic (ILTI) layer thickness	SiC layer thickness	Outer Low Temperature Isotropic (OLTI) thickness



13

Reactor Power Level Presentation Outline

- PBMR design requirements and selections
- PBMR-DPP design approach and selections
- Approach to NGNP power level
- Simulation tools and input data
- Discriminating criteria
- Evaluation results & comparison
- Summary and recommendation

Approach to NGNP Power Level
 Employ knowledge and understanding gained from the PBMR-DPP core design as far as possible
 The normal operation power level can be increased by changing parameters i.e. RIT and ROT
 Lower RIT (350 °C) and higher ROT (950 °C) implies
Use of full range of energy
Top end for process and lower end for power generation

	Design Selections that Influence Core Power
•	During normal operation:
	 Mass flow rate Core temperature rise
	Maximum and average fuel temperatures
•	During PLOFC:
	 Interation reactor internals uniterative active active active sector vessel time-at-temperature
•	During DLOFC:
	 Maximum fuel time-at-temperature which is influenced by Effective outer core diameter
	Vessel diameter, shipping weight, and supplier infrastructure Effective core height
	 Core pressure drop (pebble) Axial neutronic stability (prismatic)
	 Fuel nanumity (prismanc) Center reflector structural design (pebble) Annular active core thickness
	Control rod effectiveness (pebble) Power density

Reactor vessel time-at-temperature А

Metallic reactor internals time-at-temperature Normal operation average fuel temperatures

Д

	Approach to NGNP Power Level
•	 Assume the German LEU fuel test envelope During normal operation stay within the burnup-fluence-temperature envelope Maintain fuel T_{max} <1250 °C during normal operation
•	 Largest reactor power without any additional R&D or design development beyond DPP Current PBMR-DPP reactor geometry with varying RIT/ROT Maintain fuel T_{max} <1600 °C during DLOFC
•	 Largest reactor power with minimal R&D PBMR-DPP, i.e. PBMR-DPP geometry adopted as is Maintain fuel T_{max} <1700 °C for limited time during DLOFC
•	 Largest reactor power with modest R&D and design development Maintain fuel T_{max} <1700 °C for limited time during DLOFC Outer reactor diameters maintained
	 Increase FCR thickness from 2.0 to 2.4m Design impact for fuel chutes etc.

Comparatively assess the important coupled neutronics and thermal-hydraulics parameters for a spectrum of cases:
No R&D and design development required beyond DPP
 Ref. PBMR-DPP: 400 MWt; RIT/ROT=500/900 °C; MF=179.5 kg/s
 Case 1: 400 MWt; RIT/ROT=350/950 °C; FCR=2.0 m ;MF=119.0 kg/s
 Case 2: 450 MWt; RIT/ROT=350/950 °C; FCR=2.0 m; MF=134.0 kg/s
Minimal R&D required
 Case 5: 500 MWt; RIT/ROT=350/950 °C; FCR=2.0 m; MF=149.0 kg/s
Modest R&D and design development required
 Case 7: 600 MWt; RIT/ROT=350/950 °C; FCR=2.4 m; MF=179.0 kg/s
 Case 8: 600 MWt; RIT/ROT=350/950 °C; FCR=2.0m; MF=179.0 kg/s

Reactor Power Level Presentation Outline

- PBMR design requirements and selections
- PBMR-DPP design approach and selections
- Approach to NGNP power level

Simulation tools and input data

- Discriminating criteria
- Evaluation results & comparison
- Summary and recommendation

			VSOP-A
•	Analytical code system for the numeri physics of thermal reactors and espec hydraulics of pebble bed HTRs.	cal	simulation of the y the coupled thermal-
	Neutronic Uses	The	rmal Hydraulic Uses
	Processing of cross-sections,	A	2D Spatial Dimensions
	Sets up the reactor and fuel element,	A	Conservation of Mass, Momentum and
	Evaluate repeated neutron spectra,		Energy
	Calculate neutron diffusion in 2- or 3-D,	A	Steady-State and Quasi Steady-State
	Fuel burnup,	A	The balance of the gradient of the
	Fuel shuffling,		pressure, the right ostatic force of the gravity, and the frictional force are
	Reactor control,		calculated per unit volume.
	Fuel cycle costs.	A	Thermal and effective conductivities are calculated as function of temperature and fluence.
		A	Radiation is accounted for via emissivity of graphite, CB and RPV

DPP Steady-State Comparison of TINTE and VSOP-A

		TINTE	VSOP-A
T _{max} Fuel	ပ္	1083	1073
T _{avg} Fuel	ပ္စ	869	830
ROT	ပ	897	927
T _{max} CB	ပိ	397	414
T _{max} RPV	ပိ	271	310
∆P core	Bar	2.09	2.18

DPP DLOFC Comparison of TINTE and VSOP-A

		TINTE	A-90SV
T _{max} Fuel	သိ	1567 (46h)	1499 (45h)
T _{max} CB	ပိ	588 (56h)	579 (48h)
T _{max} RPV	၁့	430 (59h)	419 (56h)

Reactor Power Level Presentation Outline

- PBMR design requirements and selections
- PBMR-DPP design approach and selections
- Approach to NGNP power level
- Simulation tools and input data

➔ Discriminating criteria

- Evaluation results & comparison
- Summary and recommendation

Discriminating Criteria	Criteria Relative Weight	ness	chnology enabling R&D (including fuel) High I schedule	sign development and schedule High	mance	rmal Operating conditions Medium	estment protection (PLOFC) Medium	ety consideration (DLOFC) High		oital specific cost (Reactor, etc.) High	erating cost (including Fuel Cycle cost) Medium
	Crit	Readiness	Technolog and sched	🗡 Design dev	Performanc	Vormal Op	✓ Investment	🗡 Safety con	Cost	🖌 Capital spe	Operating

Reactor Power Level Presentation Outline

- PBMR design requirements and selections
- PBMR-DPP design approach and selections
- Approach to NGNP power level
- Simulation tools and input data
- Discriminating criteria
- Evaluation results & comparison
- Summary and recommendation

Power Level Configuration Cases

			No R&D		Minimal R&D	Modest	t R&D
	Units	DPP	Case 1	Case 2	Case 5	Case 7	Case 8
Power Level	MW _{th}	400	400	450	500	600	600
FCR	ε	2.0	2.0	2.0	2.0	2.4	2.0
RIT/	ပ္စ	500/	350/	350/	350/	350/	350/
ROT		006	950	950	950	950	950
Mass flow	Kg/s	179.5	119.0	134.0	149.0	179.0	179.0

Normal Operation: Neutronics Performance

			No R&D		Minimal R&D	Mode	st R&D
Parameter (Limit)	Units	DPP	Case 1	Case 2	Case 5	Case 7	Case 8
Power	MW _{th}	400	400	450	500	600	600
FCR	ε	2.0	2.0	2.0	2.0	2.4	2.0
K _{eff}		1.0001	1.0001	1.0001	1.0001	1.0000	1.0000
Burnup (<100,000)	MWd/t _{HM}	95,723	94,949	94,508	94,078	82,101	93,461
Q _{max} /FS (<4.5)	kW	2.80	2.94	3.29	3.63	4.66	4.30
Power peaking	$\mathbf{Q}_{\max}/\mathbf{Q}_{avg}$	2.27	2.39	2.38	2.37	2.17	2.37
Fuel in-core time	EFPD	964	956	846	758	452	628
Heat-up over the reactor	၁့	500 → 957	350 → 994	350 → 990	350 → 995	350 → 996	350 → 997

Normal Operation : T-H Performance

			No R&D		Minimal R&D	Mode	st R&D
Parameter (Limit)	Units	DPP	Case 1	Case 2	Case 5	Case 7	Case 8
Power	MW _{th}	400	400	450	500	600	600
FCR	٤	2.0	2.0	2.0	2.0	2.4	2.0
T _{avg} Fuel	ပ	830	827	829	833	844	833
T _{max} Fuel (<1250)	ာ	1073	1130	1149	1148	1173	1226
T _{max} CB (<816)	၁့	414	297	296	297	296	299
T _{max} RPV (<371)	၁့	310	231	231	231	225	225
∆P reactor	Bar	3.32	1.52	1.91	2.35	4.83	3.34
Circulator power	MW_{th}	•	2.63	3.73	5.09	12.58	8.69

Normal Operation: Volume / Temperature Analysis

			No R&D		Minimal R&D	Mode	st R&D
Parameter	Units	DPP	Case 1	Case 2	Case 5	Case 7	Case 8
Power	MW _{th}	400	400	450	500	600	600
FCR	ε	2.0	2.0	2.0	2.0	2.4	2.0
℃ 006>	%	46.42	38.30	39.11	56.03	55.32	58.61
>900 °C <1000 °C	%	26.37	15.56	34.13	34.12	35.14	32.21
>1000 °C <1100 °C	%	27.21	10.83	9.86	9.86	9.55	9.18
>1100 °C	%	0~	0~	0~	0~	0~	0~

	Normal Operation Evaluation
•	All the presented energy are writhin the accordable human limit
)	All the presented cases are within the acceptable putting mitting
•	Case 7 is exceeding the energy per fuel sphere limit
٠	Cases 1, 2 & 5 have a bigger margin for T_{max} fuel than Case 6 & 7
•	Case 8 is close to the T_{max} fuel limitation of 1250 °C
•	Case 7 has a very large ΔP over the reactor and higher a circulator power
•	Given its higher power of 500MWt, Case 5 has the most margin for the various parameters for the range of considerations

Investment Protection: T-H Performance

PLOFC			No R&D		Minimal R&D	Modes	t R&D
Parameter (Limit)	Units	DPP	Case 1	Case 2	Case 5	Case 7	Case 8
Power	MW _{th}	400	400	450	500	600	600
FCR	ε	2.0	2.0	2.0	2.0	2.4	2.0
T _{avg} Fuel	ပွ	1009	1001	1031	1070	1133	1160
T _{max} Fuel	ပိ	1319	1315	1388	1460	1408	1608
(duration) (<1600/1700)	(hr)	(27h)	(27h)	(30h)	(30h)	(36h)	(33h)
T _{max} CB (<816)	ပွ	495	518	537	565	591	605
T _{max} RPV (duration)	°C (hr)	293 (96h)	387 (9h)	384 (9h)	401 (56h)	428 (56h)	433 (120h)
(>371, <427 for 3000hrs; >427, <538 for							31
TUUUUTS							I

Investment Protection Evaluation during PLOFC	

Protection PLOFC with the exception of the Case 8 peak fuel temperature All cases are well within the limits for the Investment

Safety: DLOFC Performance

DLOFC			No R&D		Minimal R&D	Modes	t R&D
Parameter (Limit)	Units	DPP	Case 1	Case 2	Case 5	Case 7	Case 8
Power	MW _{th}	400	400	450	500	600	600
FCR	ε	2.0	2.0	2.0	2.0	2.4	2.0
T _{avg} Fuel	ပ္	1126	1111	1168	1232	1253	1354
T _{max} Fuel	ວ。	1499	1494	1580	1668	1641	1835
(duration) (<1600/1700)		(45h)	(45h)	(45h)	(48h)	(45h)	(45h)
T _{max} CB (duration) (<816)	ပ္	579 (48h)	570 (48h)	594 (48h)	618 (48h)	650 (48h)	664 (48h)
T _{max} RPV (>371, <427 for 3000hr; >427,<538 for 1000hr)	ပိ	419 (56h)	414 (64h)	435 (64h)	455 (64h)	477 (64h)	492 (64h)

DLOFC: Volume / Temperature Analysis

DLOFC			No R&D		Minimal R&D	Mode	st R&D
Parameter	Units	DPP	Case 1	Case 2	Case 5	Case 7	Case 8
Power	MW _{th}	400	400	450	500	600	600
FCR	٤	2.0	2.0	2.0	2.0	2.4	2.0
>1200 °C <1300 °C	%	14.84	13.28	11.04	0.89	12.62	10.10
>1300 °C <1400 °C	%	14.82	15.16	13.53	10.40	14.45	10.89
>1400 °C <1500 °C	%	13.86	11.11	14.65	11.90	14.67	8.67
>1500 °C <1600 °C	%	0.0	0.0	9.18	14.70	16.39	11.59
>1600 °C <1700 °C	%	0.0	0.0	0.0	7.15	3.01	13.38
>1700 °C	%	0.0	0.0	0.0	0.0	0.0	12.14

Evaluation of Safety during DLOFC

- Cases 1 and 2 have T_{max} fuel temperatures below 1600 °C
- Cases 5, and 7 have $T_{\rm max}$ fuel temperatures above 1600 °C; it is however less than 10% of the core volume
- Case 8 has T_{max} fuel temperatures above 1800 °C

Outline
esentation
evel Pre
Power L
Reactor

- PBMR design requirements and selections
- PBMR-DPP design approach and selections
- Approach to NGNP power level
- Simulation tools and input data
- Discriminating criteria
- Evaluation results & comparison
- Summary and recommendation

Discrim	inating Criteria
<u>Criteria</u>	<u>Relative Weight</u>
Readiness	
Technology enabling R&D (including fuel) and schedule	High
Design development and schedule	High
Performance	
Normal Operating conditions	Medium
Investment protection (PLOFC)	Medium
Safety consideration (DLOFC)	High
Cost	
Capital specific cost (Reactor, etc.)	High
Operating cost (including Fuel Cycle cost)	Medium

Summary of the Best Cases
No R&D and design development required beyond DPP
 Case 2: 450 MWt; FCR diameter 2.0 m same as DPP Immediately deployable
 Lower mass flow – lower △P over reactor – smaller components 12.5% increase in power level from PBMR-DPP
Minimal R&D required
 Case 5: 500 MWt; FCR diameter 2.0 m same as DPP Minimal R&D for fuel qualification to 1700 °C 25% Increase in Power level from PBMR-DPP @ same canital cost
Modest R&D and design development required
 Case 7: 600 MWt; FCR diameter 2.4 m Q_{max}/Pebble = 4.66 kW - exceeds THTR and DPP 4.5 kWt/pebble limit FCR discharge chute design needs to be reevaluated Minimal R&D for fuel qualification to 1700 °C Higher △P over reactor

Recommendation
 Case 5: 500 MWt; FCR diameter 2.0 m is the option that
Uses DPP reactor as basis - within operation envelope of DPP
Meets NGNP schedule - minimal R&D required
No design development required
More power with the DPP capital cost of reactor and associated systems and building